APEX
ENVIRONMENTAL CONSULTING

April 7, 2021

Mr. Jesse Cavazos
Tigard Tualatin School District
6960 SW Sandburg
Tigard, Oregon 97223

LEAD IN WATER TESTING AT FOWLER MIDDLE SCHOOL IN TIGARD OREGON

Dear Mr. Cavazos:

At your request Apex Environmental collected samples for lead in water analysis at Fowler MS located at 10865 SW Walnut Street Tigard, Oregon. Samples were collected from possible drinking water and water used for food preparation in locations identified by the school district and located in newly remodeled areas. In accordance with EPA 3Ts Drinking Water School Tool Kit Guidelines and Oregon Health Authority Reducing Lead in Drinking School Drinking Water Guidelines of 2017.

The water in the system was flushed by School District personnel and allowed to remain in the system for a minimum of 18 hours prior to testing. Apex collected one first draw sample and a follow-up sample after the water flushed for a period of 30 seconds. Each of the samples were sent to Alexin Laboratories in Tigard, Oregon for Analysis. Alexin is accredited by the Oregon Environmental Laboratory for the analysis of drinking water under the U.S. EPA Safe Drinking Water Act as Laboratory #OR100013. Follow-up flushed samples were only analyzed if the results of the initial draw sample showed greater than 15 parts per billion lead content. All of the initial water samples collected at Fowler MS were below this threshold and therefore no follow up samples were analyzed as directed by the district. Corrective action would not be required based upon this criteria.

Attached are the lab results and chain of custody for samples collected at Fowler MS. If you have any questions or need anything further, please feel free to call me.

Sincerely,

Tulla R. Stocker

Tulla R. Stocker
Principal

PO Box 1445
p 503.682.9737
Wilsonville, OR 97070
www.apexenviro.com
f 503.682.0525

Alexin Analytical LABORATORIES, INC.
Professional Laboratory Services
13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 04/05/2021
Received: 03/18/2021
Sampled By: TS
Work Order: 1077006

CLIENT
Apex Environmental
Attn: Tulla Stocker
PO Box 1445
Wilsonville OR, 97070
Phone: (503) 682-9737

Project: TTSD Water
Project # : N/A
Sample Type :

Sampling Location: Fowler MS

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
1077006-01	**Sample Name:** FMS-01A Health Room RR 0-7 Sink **Sampled:** 3/16/21 2:58						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/19/21 16:00
1077006-03	**Sample Name:** FMS-02A Main Office Work Room Sink **Sampled:** 3/16/21 2:58						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/19/21 16:00
1077006-05	**Sample Name:** FMS-03A Science CR29-T. Desk sink **Sampled:** 3/16/21 2:58						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/19/21 16:00
1077006-07	**Sample Name:** FMS-04A Science CR29 SE **Sampled:** 3/16/21 2:59						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	1	ppb	2	15 ppb	03/19/21 16:00 J
1077006-09	**Sample Name:** FMS-05A Science CR29 SE **Sampled:** 3/16/21 2:59						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	1	ppb	2	15 ppb	03/19/21 16:00 J
1077006-11	**Sample Name:** FMS-06A Science CR29 N **Sampled:** 3/16/21 3:00						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	2	ppb	2	15 ppb	03/19/21 16:00 J
1077006-13	**Sample Name:** FMS-07A Science CR29 N **Sampled:** 3/16/21 3:00						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	1	ppb	2	15 ppb	03/19/21 16:00 J
1077006-15	**Sample Name:** FMS-08A Science CR29 SW **Sampled:** 3/16/21 3:00						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/19/21 16:00
1077006-17	**Sample Name:** FMS-09A Science CR29 SW **Sampled:** 3/16/21 3:00						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	1	ppb	2	15 ppb	03/19/21 16:00 J
1077006-19	**Sample Name:** FMS-10A Science CR28 T. Sink **Sampled:** 3/16/21 3:00						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/19/21 16:00

This report shall not be reproduced, except in full, without the written approval of the laboratory.

Alexin Analytical LABORATORIES, INC.
Professional Laboratory Services
13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 04/05/2021
Received: 03/18/2021
Sampled By: TS
Work Order: 1077006

CLIENT
Apex Environmental
Attn: Tulla Stocker
PO Box 1445
Wilsonville OR, 97070
Phone: (503) 682-9737

Project: TTSD Water
Project # : N/A
Sample Type :

Sampling Location: Fowler MS

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
1077006-21	**Sample Name:** FMS-11A Science CR28 SW **Sampled:** 3/16/21 3:00						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/19/21 16:00
1077006-23	**Sample Name:** FMS-12A Science CR28 SW **Sampled:** 3/16/21 3:03						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/19/21 16:00
1077006-25	**Sample Name:** FMS-13A Science CR28 West **Sampled:** 3/16/21 3:03						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	1	ppb	2	15 ppb	03/19/21 16:00 J
1077006-27	**Sample Name:** FMS-14A Science CR28 West **Sampled:** 3/16/21 3:03						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	2	ppb	2	15 ppb	03/29/21 15:51 J
1077006-29	**Sample Name:** FMS-15A Science CR28 N **Sampled:** 3/16/21 3:05						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	2	ppb	2	15 ppb	03/29/21 15:51
1077006-31	**Sample Name:** FMS-16A Science CR28 N **Sampled:** 3/16/21 3:05						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	3	ppb	2	15 ppb	03/29/21 15:51
1077006-33	**Sample Name:** FMS-17A Science CR24 T. Sink **Sampled:** 3/16/21 3:06						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	2	ppb	2	15 ppb	03/29/21 15:51
1077006-35	**Sample Name:** FMS-18A Science CR24 West **Sampled:** 3/16/21 3:06						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	1	ppb	2	15 ppb	03/29/21 15:51 J
1077006-37	**Sample Name:** FMS-19A Science CR24 West **Sampled:** 3/16/21 3:07						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/29/21 15:51
1077006-39	**Sample Name:** FMS-20A Science CR24 S. **Sampled:** 3/16/21 3:08						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	2	ppb	2	15 ppb	03/29/21 15:51

This report shall not be reproduced, except in full, without the written approval of the laboratory.

Alexin Analytical LABORATORIES, INC.
Professional Laboratory Services
13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 04/05/2021
Received: 03/18/2021
Sampled By: TS
Work Order: 1077006

CLIENT
Apex Environmental
Attn: Tulla Stocker
PO Box 1445
Wilsonville OR, 97070
Phone: (503) 682-9737

Project: TTSD Water
Project # : N/A
Sample Type :

Sampling Location: Fowler MS

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
1077006-41	**Sample Name:** FMS-21A Science CR24 S. **Sampled:** 3/16/21 3:10						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	2	ppb	2	15 ppb	03/29/21 15:51
1077006-43	**Sample Name:** FMS-22A Science CR24 S. **Sampled:** 3/16/21 3:10						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	2	ppb	2	15 ppb	03/29/21 15:51 J
1077006-45	**Sample Name:** FMS-23A Science CR25 **Sampled:** 3/16/21 3:11						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/29/21 15:51
1077006-47	**Sample Name:** FMS-24A Science CR26 T. Sink **Sampled:** 3/16/21 3:11						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/29/21 15:51
1077006-49	**Sample Name:** FMS-25A Science CR26 N **Sampled:** 3/16/21 3:12						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	2	ppb	2	15 ppb	03/29/21 15:51
1077006-51	**Sample Name:** FMS-26A Science CR26 N **Sampled:** 3/16/21 3:15						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	2	ppb	2	15 ppb	03/29/21 15:51 J
1077006-53	**Sample Name:** FMS-27A Science CR26 W **Sampled:** 3/16/21 3:15						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	4	ppb	2	15 ppb	03/29/21 15:51
1077006-55	**Sample Name:** FMS-28A Science CR26 W **Sampled:** 3/16/21 3:15						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	3	ppb	2	15 ppb	03/29/21 15:51
1077006-57	**Sample Name:** FMS-29A Science CR26 S **Sampled:** 3/16/21 3:18						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	1	ppb	2	15 ppb	03/29/21 15:51 J
1077006-59	**Sample Name:** FMS-30A Science CR26 S **Sampled:** 3/16/21 3:19						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	2	ppb	2	15 ppb	03/29/21 15:51

This report shall not be reproduced, except in full, without the written approval of the laboratory.

Alexin Analytical LABORATORIES, INC.
Professional Laboratory Services
13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 04/05/2021
Received: 03/18/2021
Sampled By: TS
Work Order: 1077006

CLIENT
Apex Environmental
Attn: Tulla Stocker
PO Box 1445
Wilsonville OR, 97070
Phone: (503) 682-9737

Project: TTSD Water
Project # : N/A
Sample Type :

Sampling Location: Fowler MS

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
1077006-61	**Sample Name:** FMS-31A Science Wing Bubbler **Sampled:** 3/16/21 3:20						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/29/21 15:51
1077006-63	**Sample Name:** FMS-32A Science Wing Water B Refill **Sampled:** 3/16/21 3:20						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/29/21 15:51
1077006-65	**Sample Name:** FMS-33A Classroom 27 T Sink **Sampled:** 3/16/21 3:25						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	2	ppb	2	15 ppb	03/29/21 15:51
1077006-67	**Sample Name:** FMS-34A Classroom 27 N **Sampled:** 3/16/21 3:30						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	5	ppb	2	15 ppb	03/29/21 15:51
1077006-69	**Sample Name:** FMS-35A Classroom 27 N **Sampled:** 3/16/21 3:30						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	4	ppb	2	15 ppb	03/31/21 16:16
1077006-71	**Sample Name:** FMS-36A Classroom 27 E **Sampled:** 3/16/21 3:40						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	1	ppb	2	15 ppb	03/29/21 15:51 J
1077006-73	**Sample Name:** FMS-37A Classroom 27 E **Sampled:** 3/16/21 3:40						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	4	ppb	2	15 ppb	03/29/21 15:51
1077006-75	**Sample Name:** FMS-38A Classroom 27 S **Sampled:** 3/16/21 3:42						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	2	ppb	2	15 ppb	03/29/21 15:51
1077006-77	**Sample Name:** FMS-39A Classroom 27 S **Sampled:** 3/16/21 3:42						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/29/21 15:51
1077006-79	**Sample Name:** FMS-40A Classroom 30 T. Sink **Sampled:** 3/16/21 3:45						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	4	ppb	2	15 ppb	03/29/21 15:51

This report shall not be reproduced, except in full, without the written approval of the laboratory.

Alexin Analytical LABORATORIES, INC.
Professional Laboratory Services
13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 04/05/2021
Received: 03/18/2021
Sampled By: TS
Work Order: 1077006

CLIENT
Apex Environmental
Attn: Tulla Stocker
PO Box 1445
Wilsonville OR, 97070
Phone: (503) 682-9737

Project: TTSD Water
Project # : N/A
Sample Type :

Sampling Location: Fowler MS

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
1077006-81	**Sample Name:** FMS-41A Classroom 30 S **Sampled:** 3/16/21 3:47						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	1	ppb	2	15 ppb	03/29/21 15:51 J
1077006-83	**Sample Name:** FMS-42A Classroom 30 S **Sampled:** 3/16/21 3:47						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	1	ppb	2	15 ppb	03/29/21 15:51 J
1077006-85	**Sample Name:** FMS-43A Classroom 30 W **Sampled:** 3/16/21 3:47						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	3	ppb	2	15 ppb	03/29/21 15:51
1077006-87	**Sample Name:** FMS-44A Classroom 30 W **Sampled:** 3/16/21 3:50						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/29/21 15:51
1077006-89	**Sample Name:** FMS-45A Classroom 30 N **Sampled:** 3/16/21 3:50						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/29/21 15:51
1077006-91	**Sample Name:** FMS-46A Classroom 30 N **Sampled:** 3/16/21 3:50						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	1	ppb	2	15 ppb	03/29/21 15:51 J
1077006-93	**Sample Name:** FMS-47A Kiln Room 38A Sink **Sampled:** 3/16/21 3:51						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	5	ppb	2	15 ppb	03/29/21 15:51
1077006-95	**Sample Name:** FMS-48A Room 420 Makers Space **Sampled:** 3/16/21 3:51						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	3	ppb	2	15 ppb	03/29/21 15:51

J The reported value is greater than the Method Detection Limit of 0.001 mg/L or 1 ppb but less than the Reporting Limit.

ND = None detected at the MRL **MRL** = Minimum Reporting Limit **MCL** = Maximum Contamination Limit

†All procedures for this analysis are in accordance with NELAP standards.

* The EPA MCL for Lead in Public Drinking Water Systems is 15 ppb; this is a maximum contamination level for lead in samples, this is not an acceptance level for health based exposure.

This report shall not be reproduced, except in full, without the written approval of the laboratory.

Alexin Analytical LABORATORIES, INC.
Professional Laboratory Services
13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 04/05/2021
Received: 03/18/2021
Sampled By: TS
Work Order: 1077006

CLIENT
Apex Environmental
Attn: Tulla Stocker
PO Box 1445
Wilsonville OR, 97070
Phone: (503) 682-9737

Project: TTSD Water
Project # : N/A
Sample Type :

Sampling Location: Fowler MS

Lab Number

Approved by: _____
Adriana Gonzalez-Gray
Laboratory Director

This report shall not be reproduced, except in full, without the written approval of the laboratory.

Alexin Analytical LABORATORIES INC. Professional Laboratory Services

Chain of Custody Record

52 47

Laboratory Job Number: 1077006-01-10

Page 1 of 10

13035 SW Pacific Hwy Tigard, OR 97223 ph: 503.639.9311 fax: 503.684.1588 email:mail@alexinlabs.com

Client Contact Information	Results Reporting Information	Invoicing Information
Company/Client Name: Apex Environmental	Project Manager: Tulla Stocker	Accounts Payable Contact: Tulla Stocker
Address: PO Box 1445	Mailing Address:	Mailing Address:
City/State/Zip: Wilsonville OR 97070	City/State/Zip: Same	City/State/Zip: Same
phone: 503 789-4185	phone:	phone:
fax or email: Tulla.Stocker@apexenviro.com	fax or email:	fax or email:

SAMPLING INFORMATION

Sampling Location: Fowler MS	P.O. #:	PWSID #:	
Sampled By: JS	Project Name: TTSD Water	Project #:	Permit #:

Send results to OR State Health Division? (Please circle) Yes (No)

Analyze A and hold B for further Direction

Lab ID (Lab use only)	Sample Identification (Please enter a unique ID per line for each separate sample)	Date Collected	Time Collected (Begin-End if comp.)	Sample Matrix*	# of cont. rec'd	Lead	SEE ATTACHED	Sample Specific Notes/Field Data (for each WW sample, specify Grab / Composite; for each DW sample, specify Raw / Treated, Source / Distribution, Single / Combined WHERE APPLICABLE)
-01	FMS-01A	3/16/21	water 1358			X		Health Room RR 0-7 SINK
-02	-01B							" "
-03	-02A							Main Office Work Room SINK
-04	-02B							" "
-05	-03A							Science CR29 - T. Desk SINK
-06	-03B		1359					" "
-07	-04A							Science CR29 SE
-08	-04B							" "
-09	-05A							" " SD
-10	-05B							" "

Relinquished By (print): Tulla Stocker	Company: Apex	Date/Time: 3-16-21	Signature:	Received By:	Company:	Date/Time:	Signature:
Relinquished By (print):	Company:	Date/Time:	Signature:	Received By:	Company:	Date/Time:	Signature:

The most current revision of SOP-10-003 was used when these samples were collected ☐

Received by Laboratory Log-In Staff: Ale 3/18/21 11:45am

Temp. on receipt: ___ °C On ice? Y (N)

Containers Intact? (Y) N ID: TRM-10-___

* Drinking water (DW), effluent (EFF), ground water (GW), influent (INF), non-aqueous liquid (NAL), paint chips, raw water (RW), sludge, soil, solid, source water (SOURCE), spring, stormwater (SW), surface water, wastewater (WW), well water (WELL)

** Analyses for SOC, Radionuclide, Radon, and Asbestos are subcontracted out to other accredited laboratories.

Alexin Analytical LABORATORIES, INC. Professional Laboratory Services

Chain of Custody Record

Laboratory Job Number: 1077006-11-20

Page 2 of 10

13035 SW Pacific Hwy Tigard, OR 97223 ph: 503.639.9311 fax: 503.684.1588 email:mail@alexinlabs.com

Client Contact Information	Results Reporting Information	Invoicing Information
Company/Client Name: Apex Environmental	Project Manager: Tulla Stocker	Accounts Payable Contact: Tulla Stocker
Address: PO Box 1445	Mailing Address:	Mailing Address:
City/State/Zip: Wilsonville OR 97070	City/State/Zip: Same	City/State/Zip: Same
phone: 503 789-4185	phone:	phone:
fax or email: Tulla.Stocker@apexenviro.com	fax or email:	fax or email:

SAMPLING INFORMATION

Sampling Location: Fowler MS	P.O. #:	PWSID #:	
Sampled By: TS	Project Name: TTS Water	Project #:	Permit #:

Send results to OR State Health Division? (Please circle) Yes No

See page 1

Analysis Requested**

Lab ID (Lab use only)	Sample Identification (Please enter a unique ID per line for each separate sample)	Date Collected	Time Collected (Begin-End if comp.)	Sample Matrix*	# of cont. rec'd	Lead	SEE ATTACHED	Sample Specific Notes/Field Data (for each WW sample, specify Grab / Composite; for each DW sample, specify Raw / Treated, Source / Distribution, Single / Combined WHERE APPLICABLE)
-01	FMS-06A	3/16/21	1130	water		X		Source 09 N
-02	-06B							" "
-13	-07A							" "
-14	-07B							" "
-15	-08A							" " SW
-16	-08B							" " SW
-17	-09A							" " "
-18	-09B							" " "
-19	-10A		300					" " 28 T. Sink
-20	-10B							" " "

Relinquished By (print): Tulla Stocker	Company: Apex	Date/Time: 3/16/21	Signature:	Received By:	Company:	Date/Time:	Signature:
Relinquished By (print):	Company:	Date/Time:	Signature:	Received By:	Company:	Date/Time:	Signature:

The most current revision of SOP-10-003 was used when these samples were collected ☐

Received by Laboratory Log-In Staff: ale 3/18/21 Date/Time: 11:45 am Temp. on receipt: ____ °C On ice? Y (N) Containers Intact? (Y) N ID: TRM-10-____

* Drinking water (DW), effluent (EFF), ground water (GW), influent (INF), non-aqueous liquid (NAL), paint chips, raw water (RW), sludge, soil, solid, source water (SOURCE), spring, stormwater (SW), surface water, wastewater (WW), well water (WELL)

** Analyses for SOC, Radionuclide, Radon, and Asbestos are subcontracted out to other accredited laboratories.

COC-90-006rev0.1

Alexin Analytical LABORATORIES INC. Professional Laboratory Services

Chain of Custody Record

Laboratory Job Number: 1077006-21-30

13035 SW Pacific Hwy Tigard, OR 97223 ph: 503.639.9311 fax: 503.684.1588 email:mail@alexinlabs.com

Client Contact Information	Results Reporting Information	Invoicing Information
Company/Client Name: Apex Environmental	Project Manager: Tulla Stocker	Accounts Payable Contact: Tulla Stocker
Address: PO Box 1445	Mailing Address:	Mailing Address:
City/State/Zip: Wilsonville OR 97070	City/State/Zip: Same	City/State/Zip: Same
phone: 503 789-4185	phone:	phone:
fax or email: Tulla.Stocker@apexenviro.com	fax or email:	fax or email:

SAMPLING INFORMATION

Sampling Location: Foulen MS	P.O. #:		PWSID #:
Sampled By: JS	Project Name: TTSDwater	Project #:	Permit #:

Send results to OR State Health Division? (Please circle) Yes (No)

See page 1

Lab ID (Lab use only)	Sample Identification (Please enter a unique ID per line for each separate sample)	Date Collected	Time Collected (Begin-End if comp.)	Sample Matrix*	# of cont. rec'd	Analysis Requested** Lead	SEE ATTACHED	Sample Specific Notes/Field Data (for each WW sample, specify Grab / Composite; for each DW sample, specify Raw / Treated, Source / Distribution, Single / Combined WHERE APPLICABLE)
-21	FMS-11A	3-16-21	1	Water		X		Sacre CR28 SW
-22	-11B							" CR28 "
-23	-12A		303					" " "
-24	-12B							" " "
-25	-13A							" " West
-26	-13B		1					" " "
-27	-14A							" " "
-28	-14B		1					" " "
-29	-15A		305					" " "
-30	-15B		1					" " NW

Relinquished By (print): Tulla Stocker	Company: Apex	Date/Time: 3-16-21	Signature:	Received By:	Company:	Date/Time:	Signature:
Relinquished By (print):	Company:	Date/Time:	Signature:	Received By:	Company:	Date/Time:	Signature:

The most current revision of SOP-10-003 was used when these samples were collected ☐

Received by Laboratory Log-In Staff: Date/Time: 3/18/21 11:45am Temp. on receipt: ___ °C Containers Intact? (Y) N On ice? Y (N) ID: TRM-10-___

* Drinking water (DW), effluent (EFF), ground water (GW), influent (INF), non-aqueous liquid (NAL), paint chips, raw water (RW), sludge, soil, solid, source water (SOURCE), spring, stormwater (SW), surface water, wastewater (WW), well water (WELL)

** Analyses for SOC, Radionuclide, Radon, and Asbestos are subcontracted out to other accredited laboratories.

Alexin Analytical LABORATORIES, INC.
Professional Laboratory Services

Chain of Custody Record

Laboratory Job Number: 1077006-31-40

Page 4 of 10

13035 SW Pacific Hwy Tigard, OR 97223 ph: 503.639.9311 fax: 503.684.1588 email:mail@alexinlabs.com

Client Contact Information	Results Reporting Information	Invoicing Information
Company/Client Name: Apex Environmental	Project Manager: Tulla Stocker	Accounts Payable Contact: Tulla Stocker
Address: PO Box 1445	Mailing Address:	Mailing Address:
City/State/Zip: Wilsonville OR 97070	City/State/Zip: Same	City/State/Zip: Same
phone: 503 789-4185	phone:	phone:
fax or email: Tulla.Stocker@apexenviro.com	fax or email:	fax or email:

SAMPLING INFORMATION

Sampling Location: Fowler MS	P.O. #:	PWSID #:	
Sampled By: [illegible]	Project Name: TTSDWater	Project #:	Permit #:

Send results to OR State Health Division? (Please circle) Yes (No)

See page 1

Lab ID (Lab use only)	Sample Identification (Please enter a unique ID per line for each separate sample)	Date Collected	Time Collected (Begin-End if comp.)	Sample Matrix*	# of cont. rec'd	Analysis Requested** Lead	SEE ATTACHED	Sample Specific Notes/Field Data (for each WW sample, specify Grab / Composite; for each DW sample, specify Raw / Treated, Source / Distribution, Single / Combined WHERE APPLICABLE)
-31	FMS - 16A	3-16-21	1	Water		X		Science CR28 N
-32	- 16B		306					" " N
-33	17A							" " 24 T.Sink
-34	17B		1					" " "
-35	18A							West
-36	18B		307					"
-37	19A							"
-38	19B		1					"
-39	20A		308					S.
-40	20B							S.

Relinquished By (print)	Company	Date/Time	Signature	Received By	Company	Date/Time	Signature
Tulla Stocker	Apex	3-16-21	[signature]				
Relinquished By (print)	Company	Date/Time	Signature	Received By	Company	Date/Time	Signature

The most current revision of SOP-10-003 was used when these samples were collected ☐

Received by Laboratory Log-In Staff: [signature] 3/18/21 11:4 Sam Date/Time:

Temp. on receipt: — °C On ice? Y (N)

Containers Intact? (Y) N ID: TRM-10-

* Drinking water (DW), effluent (EFF), ground water (GW), influent (INF), non-aqueous liquid (NAL), paint chips, raw water (RW), sludge, soil, solid, source water (SOURCE), spring, stormwater (SW), surface water, wastewater (WW), well water (WELL)

** Analyses for SOC, Radionuclide, Radon, and Asbestos are subcontracted out to other accredited laboratories.

Alexin Analytical LABORATORIES, INC. Professional Laboratory Services

Chain of Custody Record

Laboratory Job Number: 1077006-41-50

Page 5 of 10

13035 SW Pacific Hwy Tigard, OR 97223 ph: 503.639.9311 fax: 503.684.1588 email:mail@alexinlabs.com

Client Contact Information	Results Reporting Information	Invoicing Information
Company/Client Name: Apex Environmental	Project Manager: Tulla Stocker	Accounts Payable Contact: Tulla Stocker
Address: PO Box 1445	Mailing Address:	Mailing Address:
City/State/Zip: Wilsonville OR 97070	City/State/Zip: Same	City/State/Zip: Same
phone: 503 789-4185	phone:	phone:
fax or email: Tulla.Stocker@apexenviro.com	fax or email:	fax or email:

SAMPLING INFORMATION

Sampling Location: Fowler MS	P.O. #:	PWSID #:	
Sampled By: SB	Project Name: TTS Water	Project #:	Permit #:

Send results to OR State Health Division? (Please circle) Yes (No)

See page 1

Lab ID (Lab use only)	Sample Identification (Please enter a unique ID per line for each separate sample)	Date Collected	Time Collected (Begin-End if comp.)	Sample Matrix*	# of cont. rec'd	Analysis Requested** Lead	SEE ATTACHED	Sample Specific Notes/Field Data (for each WW sample, specify Grab / Composite; for each DW sample, specify Raw / Treated, Source / Distribution, Single / Combined WHERE APPLICABLE)
-41	FMS-21A	3/4/21	310	water	1	1		Sconce CR 24 S
-42	21B							" " S
-43	22A		1					" " S
-44	22B							" " S
-45	23A		311					CR 25
-46	23B		1					"
-47	24A							Sconce CR 26 Tank
-48	24B		312					" " "
-49	25A							N
-50	25B		1					N

Relinquished By (print):	Company:	Date/Time:	Signature:	Received By:	Company:	Date/Time:	Signature:
Tulla Stock	Apex	3/4/21					
Relinquished By (print):	Company:	Date/Time:	Signature:	Received By:	Company:	Date/Time:	Signature:

The most current revision of SOP-10-003 was used when these samples were collected ☐

Received by Laboratory Log-In Staff: All 3/18/21 Date/Time: 11:45am Temp. on receipt: — °C On ice? Y (N) Containers Intact? (Y) N ID: TRM-10-

* Drinking water (DW), effluent (EFF), ground water (GW), influent (INF), non-aqueous liquid (NAL), paint chips, raw water (RW), sludge, soil, solid, source water (SOURCE), spring, stormwater (SW), surface water, wastewater (WW), well water (WELL)

** Analyses for SOC, Radionuclide, Radon, and Asbestos are subcontracted out to other accredited laboratories.

Alexin Analytical LABORATORIES, INC.
Professional Laboratory Services

Chain of Custody Record

Laboratory Job Number: 1077006-51-60

Page 6 of 10

13035 SW Pacific Hwy Tigard, OR 97223 ph: 503.639.9311 fax: 503.684.1588 email:mail@alexinlabs.com

Client Contact Information		Results Reporting Information		Invoicing Information	
Company/Client Name:	Apex Environmental	Project Manager:	Tulla Stocker	Accounts Payable Contact:	Tulla Stocker
Address:	PO Box 1445	Mailing Address:		Mailing Address:	
City/State/Zip:	Wilsonville OR 97070	City/State/Zip:	Same	City/State/Zip:	Same
phone:	503 789-4185	phone:		phone:	
fax or email:	Tulla.Stocker@apexenviro.com	fax or email:		fax or email:	

SAMPLING INFORMATION

Sampling Location:	Fowler MS	P.O. #:	PWSID #:
Sampled By:	TS	Project Name: TTS Water	Project #: Permit #:

Send results to OR State Health Division? (Please circle) Yes (No)

See page 1

Lab ID (Lab use only)	Sample Identification (Please enter a unique ID per line for each separate sample)	Date Collected	Time Collected (Begin-End if comp.)	Sample Matrix*	# of cont. rec'd	Analysis Requested** Lead	SEE ATTACHED	Sample Specific Notes/Field Data (for each WW sample, specify Grab / Composite; for each DW sample, specify Raw / Treated, Source / Distribution, Single / Combined WHERE APPLICABLE)
-51	FMS-26A	3/16/21	315	WW	~~5~~	X		Science 26 - N
-52	26B							27 - N
-53	27A							W
-54	27B							W
-55	28A							W
-56	28B		318					W
-57	29A							S
-58	29B							S
-59	30A		319					S
-60	30B	↓						S

Relinquished By (print):	Company:	Date/Time:	Signature:	Received By:	Company:	Date/Time:	Signature:
Tulla Stocker	Apex	3-16-21					
Relinquished By (print):	Company:	Date/Time:	Signature:	Received By:	Company:	Date/Time:	Signature:

The most current revision of SOP-10-003 was used when these samples were collected ☐

Received by Laboratory Log-In Staff: [illegible] 3/18/21 11:45 am Temp. on receipt: — °C On ice? Y (N)

Containers Intact? (Y) N ID: TRM-10-

* Drinking water (DW), effluent (EFF), ground water (GW), influent (INF), non-aqueous liquid (NAL), paint chips, raw water (RW), sludge, soil, solid, source water (SOURCE), spring, stormwater (SW), surface water, wastewater (WW), well water (WELL)

** Analyses for SOC, Radionuclide, Radon, and Asbestos are subcontracted out to other accredited laboratories.

Alexin Analytical LABORATORIES, INC.
Professional Laboratory Services

Chain of Custody Record

Laboratory Job Number: 1077006-61-70

Page 1 of 10

13035 SW Pacific Hwy Tigard, OR 97223 ph: 503.639.9311 fax: 503.684.1588 email:mail@alexinlabs.com

Client Contact Information	Results Reporting Information	Invoicing Information
Company/Client Name: Apex Environmental	Project Manager: Tulla Stocker	Accounts Payable Contact: Tulla Stocker
Address: PO Box 1445	Mailing Address:	Mailing Address:
City/State/Zip: Wilsonville OR 97070	City/State/Zip: Same	City/State/Zip: Same
phone: 503 789-4185	phone:	phone:
fax or email: Tulla.Stocker@apexenviro.com	fax or email:	fax or email:

SAMPLING INFORMATION

Sampling Location: Fowler MS	P.O. #:	PWSID #:	
Sampled By: JD	Project Name: TTSDWater	Project #:	Permit #:

Send results to OR State Health Division? (Please circle) Yes (No)

See page 1

Lab ID (Lab use only)	Sample Identification (Please enter a unique ID per line for each separate sample)	Date Collected	(Begin-End if comp.) Time Collected	Sample Matrix*	# of cont. rec'd	Lead	SEE ATTACHED	Sample Specific Notes/Field Data (for each WW sample, specify Grab / Composite; for each DW sample, specify Raw / Treated, Source / Distribution, Single / Combined WHERE APPLICABLE)
-61	FMS- 31A	3/16/21	320	drink		X		Science Wing Bubbler
-62	31B							" "
-63	32A							" " Water Refill
-64	32B		325					N "
-65	33A							classroom 27 T Sink
-66	33B							N "
-67	34A		330					N
-68	34B							
-69	35A							
-70	35B							

Relinquished By (print): Tulla Stocker	Company: Apex	Date/Time: 3/16/21	Signature:	
Relinquished By (print):	Company:	Date/Time:	Signature:	
Received By:	Company:	Date/Time:	Signature:	
Received By:	Company:	Date/Time:	Signature:	

The most current revision of SOP-10-003 was used when these samples were collected ☐

Received by Laboratory Log-In Staff: [illegible] 3/18/21 11:45am Date/Time:

Temp. on receipt: ____ °C Containers Intact? (Y) N On ice? Y (N) ID: TRM-10-____

* Drinking water (DW), effluent (EFF), ground water (GW), influent (INF), non-aqueous liquid (NAL), paint chips, raw water (RW), sludge, soil, solid, source water (SOURCE), spring, stormwater (SW), surface water, wastewater (WW), well water (WELL)

** Analyses for SOC, Radionuclide, Radon, and Asbestos are subcontracted out to other accredited laboratories.

Alexin Analytical LABORATORIES, INC.
Professional Laboratory Services

Chain of Custody Record

Laboratory Job Number: 1077006-71-80

Page 8 of 10

13035 SW Pacific Hwy Tigard, OR 97223 ph: 503.639.9311 fax: 503.684.1588 email:mail@alexinlabs.com

Client Contact Information	Results Reporting Information	Invoicing Information
Company/Client Name: Apex Environmental	Project Manager: Tulla Stocker	Accounts Payable Contact: Tulla Stocker
Address: PO Box 1445	Mailing Address:	Mailing Address:
City/State/Zip: Wilsonville OR 97070	City/State/Zip: Same	City/State/Zip: Same
phone: 503 789-4185	phone:	phone:
fax or email: Tulla.Stocker@apexenviro.com	fax or email:	fax or email:

SAMPLING INFORMATION

Sampling Location: Fowlers MS	P.O. #:		PWSID #:
Sampled By: TS	Project Name: TTS Water	Project #:	Permit #:

Send results to OR State Health Division? (Please circle) Yes (No)

See page 1

Lab ID (Lab use only)	Sample Identification (Please enter a unique ID per line for each separate sample)	Date Collected	(Begin-End if comp.) Time Collected	Sample Matrix*	# of cont. rec'd	Analysis Requested**	SEE ATTACHED	Sample Specific Notes/Field Data (for each WW sample, specify Grab / Composite; for each DW sample, specify Raw / Treated, Source / Distribution, Single / Combined WHERE APPLICABLE)
-71	FMS-36A	3-16-21	340	Water		X		Classroom 27 E
-72	36B							"
-73	37A							"
-74	37B							"
-75	38A		342					S
-76	38B							"
-77	39A							"
-78	39B							"
-79	40A		345					Classroom 30 T. Sink
-80	40B		"					"

Relinquished By (print): Tulla Stocker	Company: Apex	Date/Time: 3-16-21	Signature: TS	Received By:	Company:	Date/Time:	Signature:
Relinquished By (print):	Company:	Date/Time:	Signature:	Received By:	Company:	Date/Time:	Signature:

The most current revision of SOP-10-003 was used when these samples were collected ☐

Received by Laboratory Log-In Staff: dll 3/18/21 11:45am Date/Time: Temp. on receipt: ___ °C Containers Intact? (Y) N On ice? Y (N) ID: TRM-10-___

* Drinking water (DW), effluent (EFF), ground water (GW), influent (INF), non-aqueous liquid (NAL), paint chips, raw water (RW), sludge, soil, solid, source water (SOURCE), spring, stormwater (SW), surface water, wastewater (WW), well water (WELL)

** Analyses for SOC, Radionuclide, Radon, and Asbestos are subcontracted out to other accredited laboratories.

COC-90-006rev0.1

Alexin Analytical LABORATORIES INC. Professional Laboratory Services

Chain of Custody Record

Laboratory Job Number: 1077006-81-90

Page 9 of 10

13035 SW Pacific Hwy Tigard, OR 97223 ph: 503.639.9311 fax: 503.684.1588 email:mail@alexinlabs.com

Client Contact Information	Results Reporting Information	Invoicing Information
Company/Client Name: Apex Environmental	Project Manager: Tulla Stocker	Accounts Payable Contact: Tulla Stocker
Address: PO Box 1445	Mailing Address:	Mailing Address:
City/State/Zip: Wilsonville OR 97070	City/State/Zip: Same	City/State/Zip: Same
phone: 503 789-4185	phone:	phone:
fax or email: Tulla.Stocker@apexenviro.com	fax or email:	fax or email:

SAMPLING INFORMATION

Sampling Location: Fowler MS	P.O. #:		PWSID #:
Sampled By: TS	Project Name: TTS Water	Project #:	Permit #:

Send results to OR State Health Division? (Please circle) Yes (No)

See page 1

Lab ID (Lab use only)	Sample Identification (Please enter a unique ID per line for each separate sample)	Date Collected	Time Collected (Begin-End if comp.)	Sample Matrix*	# of cont. rec'd	Analysis Requested**	SEE ATTACHED	Sample Specific Notes/Field Data (for each WW sample, specify Grab / Composite; for each DW sample, specify Raw / Treated, Source / Distribution, Single / Combined WHERE APPLICABLE)
-81	Fmos- 41A	3-16-21	347			X		Classroom 30 S
-82	41B							S
-83	42A							S
-84	42B							S
-85	43A							W
-86	43B		350					W
-87	44A							W
-88	44B							W
-89	45A							N
-90	45B							N

Relinquished By (print): Tulla Stocker	Company: Apex	Date/Time: 3-16-21	Signature:	Received By:	Company:	Date/Time:	Signature:
Relinquished By (print):	Company:	Date/Time:	Signature:	Received By:	Company:	Date/Time:	Signature:

The most current revision of SOP-10-003 was used when these samples were collected ☐

Received by Laboratory Log-In Staff: Date/Time: Temp. on receipt: ___ °C On ice? Y (N)

Containers Intact? (Y) N ID: TRM-10-___

* Drinking water (DW), effluent (EFF), ground water (GW), influent (INF), non-aqueous liquid (NAL), paint chips, raw water (RW), sludge, soil, solid, source water (SOURCE), spring, stormwater (SW), surface water, wastewater (WW), well water (WELL)

** Analyses for SOC, Radionuclide, Radon, and Asbestos are subcontracted out to other accredited laboratories.

Alexin Analytical LABORATORIES, INC. Professional Laboratory Services

Chain of Custody Record

Laboratory Job Number: 1077006-91-96

13035 SW Pacific Hwy Tigard, OR 97223 ph: 503.639.9311 fax: 503.684.1588 email:mail@alexinlabs.com

Client Contact Information	Results Reporting Information	Invoicing Information
Company/Client Name: Apex Environmental	Project Manager: Tulla Stocker	Accounts Payable Contact: Tulla Stocker
Address: PO Box 1445	Mailing Address:	Mailing Address:
City/State/Zip: Wilsonville OR 97070	City/State/Zip: Same	City/State/Zip: Same
phone: 503 789-4185	phone:	phone:
fax or email: Tulla.Stocker@apexenviro.com	fax or email:	fax or email:

SAMPLING INFORMATION

Sampling Location: Fowler MS	P.O. #:		PWSID #:
Sampled By:	Project Name: TTSDWater	Project #:	Permit #:

Send results to OR State Health Division? (Please circle) Yes (No)

See page 1

Lab ID (Lab use only)	Sample Identification (Please enter a unique ID per line for each separate sample)	Date Collected	Time Collected (Begin-End if comp.)	Sample Matrix*	# of cont. rec'd	Analysis Requested**: Lead	SEE ATTACHED	Sample Specific Notes/Field Data (for each WW sample, specify Grab / Composite; for each DW sample, specify Raw / Treated, Source / Distribution, Single / Combined WHERE APPLICABLE)
-91	FMS-46A	3-16-21	350	water		Y		Classroom 30 W
-92	46B	"	"	"		"		" "
-93	47A	"	351	"		"		Kiln Room 38A SINK
-94	47B	"	"	"		"		" "
-95	48A	"	"	"		"		Ram 420 Makerspace
-96	48B	"	"	"		"		" "

Relinquished By (print): Tulla Stocker	Company: Apex	Date/Time: 3-16-21	Signature:	Received By:	Company:	Date/Time:	Signature:
Relinquished By (print):	Company:	Date/Time:	Signature:	Received By:	Company:	Date/Time:	Signature:

The most current revision of SOP-10-003 was used when these samples were collected ☐

Received by Laboratory Log-In Staff: AO 3/18/21 Date/Time: 11:45am

Temp. on receipt: — °C On ice? Y (N)

Containers Intact? (Y) N ID: TRM-10-

* Drinking water (DW), effluent (EFF), ground water (GW), influent (INF), non-aqueous liquid (NAL), paint chips, raw water (RW), sludge, soil, solid, source water (SOURCE), spring, stormwater (SW), surface water, wastewater (WW), well water (WELL)

** Analyses for SOC, Radionuclide, Radon, and Asbestos are subcontracted out to other accredited laboratories.