Alexin Analytical LABORATORIES, INC.
Professional Laboratory Services
13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 03/19/2021
Received: 03/04/2021
Sampled By: Tulla Stocker
Work Order: Multiple Work Orders

CLIENT
Apex Environmental
Attn: Tulla Stocker
PO Box 1445
Wilsonville OR, 97070
Phone: (503) 682-9737

Project: Templeton
Project # : N/A
Sample Type :

Sampling Location: Templeton Elementary School

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
1063020-01	**Sample Name:** TES-01A B129 Bubble **Sampled:** 3/4/21 3:08						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/05/21 15:37
1063020-03	**Sample Name:** TES-02A B129 faucet **Sampled:** 3/4/21 3:12						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/05/21 15:37
1063020-05	**Sample Name:** TES-03A B130 Bubbler **Sampled:** 3/4/21 3:18						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/05/21 15:37
1063020-07	**Sample Name:** TES-04A B130 faucet **Sampled:** 3/4/21 3:17						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/05/21 15:37
1063020-09	**Sample Name:** TES-05A B131 Bubbler **Sampled:** 3/4/21 3:15						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/05/21 15:37
1063020-11	**Sample Name:** TES-06A B131 faucet **Sampled:** 3/4/21 3:14						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/05/21 15:37
1063020-13	**Sample Name:** TES-07A B129 Bubbler **Sampled:** 3/4/21 3:15						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/05/21 15:37
1063020-15	**Sample Name:** TES-08A B129 faucet **Sampled:** 3/4/21 3:16						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/05/21 15:37
1063020-17	**Sample Name:** TES-09A B128 Bubbler **Sampled:** 3/4/21 3:15						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/05/21 15:37
1063020-19	**Sample Name:** TES-10A B128 faucet **Sampled:** 3/4/21 3:14						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/05/21 15:37

This report shall not be reproduced, except in full, without the written approval of the laboratory.

Alexin Analytical LABORATORIES, INC.
Professional Laboratory Services
13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 03/19/2021
Received: 03/04/2021
Sampled By: Tulla Stocker
Work Order: Multiple Work Orders

CLIENT
Apex Environmental
Attn: Tulla Stocker
PO Box 1445
Wilsonville OR, 97070
Phone: (503) 682-9737

Project: Templeton
Project # : N/A
Sample Type :

Sampling Location: Templeton Elementary School

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
1063020-21	**Sample Name:** TES-11A outside RR B126 & 125 faucets **Sampled:** 3/4/21 3:14						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/05/21 15:37
1063020-23	**Sample Name:** TES-12A outside RR B126 & 125 faucets **Sampled:** 3/4/21 3:15						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/05/21 15:37
1063020-25	**Sample Name:** TES-13A B118 shopsink **Sampled:** 3/4/21 3:16						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/05/21 15:37
1063020-27	**Sample Name:** TES-14A B118 center faucet **Sampled:** 3/4/21 3:16						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/05/21 15:37
1063020-29	**Sample Name:** TES-15A B118 Bubbler **Sampled:** 3/4/21 3:16						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/05/21 15:37
1063020-31	**Sample Name:** TES-16A B118 faucet w Bubbler **Sampled:** 3/4/21 3:17						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/05/21 15:37
1063020-33	**Sample Name:** TES-17A B111 Bubbler **Sampled:** 3/4/21 3:18						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	3	ppb	2	15 ppb	03/05/21 15:37
1063020-35	**Sample Name:** TES-18A B111 Faucet **Sampled:** 3/4/21 3:18						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/05/21 15:37
1063020-37	**Sample Name:** TES-19A B110 Bubbler **Sampled:** 3/4/21 3:19						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/05/21 15:37
1063020-39	**Sample Name:** TES-20A B110 Faucet **Sampled:** 3/4/21 3:19						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/05/21 15:37

This report shall not be reproduced, except in full, without the written approval of the laboratory.

Alexin Analytical LABORATORIES, INC.
Professional Laboratory Services
13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 03/19/2021
Received: 03/04/2021
Sampled By: Tulla Stocker
Work Order: Multiple Work Orders

CLIENT
Apex Environmental
Attn: Tulla Stocker
PO Box 1445
Wilsonville OR, 97070
Phone: (503) 682-9737

Project: Templeton
Project # : N/A
Sample Type :

Sampling Location: Templeton Elementary School

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
1063020-41	**Sample Name:** TES-21A B106 Sink **Sampled:** 3/4/21 3:20						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/05/21 15:37
1063020-43	**Sample Name:** TES-22A B115 Bubbler **Sampled:** 3/4/21 3:21						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/05/21 15:37
1063020-45	**Sample Name:** TES-23A B115 Faucet **Sampled:** 3/4/21 3:21						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/05/21 15:37
1063020-47	**Sample Name:** TES-24A B116 Bubbler **Sampled:** 3/4/21 3:22						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/05/21 15:37
1063020-49	**Sample Name:** TES-25A B116 Faucet **Sampled:** 3/4/21 3:22						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/05/21 15:37
1063020-51	**Sample Name:** TES-26A RR114-113 Sink **Sampled:** 3/4/21 3:23						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/05/21 15:37
1063020-53	**Sample Name:** TES-27A RR114-113 Sink **Sampled:** 3/4/21 3:24						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/05/21 15:37
1063020-55	**Sample Name:** TES-28A A137 & 138 RR **Sampled:** 3/4/21 3:26						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/05/21 15:37
1063020-57	**Sample Name:** TES-29A A137 & 138 RR **Sampled:** 3/4/21 3:27						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/05/21 15:37
1063020-59	**Sample Name:** TES-30A A130 Faucet **Sampled:** 3/4/21 3:27						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/05/21 15:37

This report shall not be reproduced, except in full, without the written approval of the laboratory.

Alexin Analytical LABORATORIES, INC.
Professional Laboratory Services
13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 03/19/2021
Received: 03/04/2021
Sampled By: Tulla Stocker
Work Order: Multiple Work Orders

CLIENT
Apex Environmental
Attn: Tulla Stocker
PO Box 1445
Wilsonville OR, 97070
Phone: (503) 682-9737

Project: Templeton
Project # : N/A
Sample Type :

Sampling Location: Templeton Elementary School

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
1063020-61	**Sample Name:** TES-31A A132 Faucet **Sampled:** 3/4/21 3:28						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/05/21 15:37
1063020-63	**Sample Name:** TES-32A A133 Bubble **Sampled:** 3/4/21 3:28						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	3	ppb	2	15 ppb	03/05/21 15:37
1063020-65	**Sample Name:** TES-33A A133 Faucet **Sampled:** 3/4/21 3:30						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	2	ppb	2	15 ppb	03/05/21 15:37
1063020-67	**Sample Name:** TES-34A A134 Bubbler **Sampled:** 3/4/21 3:30						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	2	ppb	2	15 ppb	03/05/21 15:37
1063020-69	**Sample Name:** TES-35A A134 Faucet **Sampled:** 3/4/21 3:32						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	2	ppb	2	15 ppb	03/05/21 15:37
1063020-71	**Sample Name:** TES-36A Room A135 Bubbler **Sampled:** 3/4/21 3:28						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	3	ppb	2	15 ppb	03/05/21 15:37
1063020-73	**Sample Name:** TES-37A Room A135 Faucet **Sampled:** 3/4/21 3:28						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/05/21 15:37
1063020-75	**Sample Name:** TES-38A 236-237 RR Sink **Sampled:** 3/4/21 3:28						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/05/21 15:37
1063020-77	**Sample Name:** TES-39A 236-237 RR Sink **Sampled:** 3/4/21 3:26						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/05/21 15:37
1063020-79	**Sample Name:** TES-40A Room A235 Bubbler **Sampled:** 3/4/21 3:26						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/05/21 15:37

This report shall not be reproduced, except in full, without the written approval of the laboratory.

Alexin Analytical LABORATORIES, INC.
Professional Laboratory Services
13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 03/19/2021
Received: 03/04/2021
Sampled By: Tulla Stocker
Work Order: Multiple Work Orders

CLIENT
Apex Environmental
Attn: Tulla Stocker
PO Box 1445
Wilsonville OR, 97070
Phone: (503) 682-9737

Project: Templeton
Project # : N/A
Sample Type :

Sampling Location: Templeton Elementary School

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
1063021-01	**Sample Name:** TES-41A Room A235 Faucet **Sampled:** 3/4/21 3:27						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/05/21 15:37
1063021-03	**Sample Name:** TES-42A Room A24 Bubbler **Sampled:** 3/4/21 3:27						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/05/21 15:37
1063021-05	**Sample Name:** TES-43A Room A24 Faucet **Sampled:** 3/4/21 3:29						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/05/21 15:37
1063021-07	**Sample Name:** TES-44A Room A233 Bubbler **Sampled:** 3/4/21 3:31						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/05/21 15:37
1063021-09	**Sample Name:** TES-45A Room A233 Faucet **Sampled:** 3/4/21 3:31						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/05/21 15:37
1063021-11	**Sample Name:** TES-46A Room A232 Bubbler **Sampled:** 3/4/21 3:32						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/05/21 15:37
1063021-13	**Sample Name:** TES-47A Room A232 Faucet **Sampled:** 3/4/21 3:32						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/05/21 15:37
1063021-15	**Sample Name:** TES-48A Room A231 Bubbler **Sampled:** 3/4/21 3:27						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/05/21 15:37
1063021-17	**Sample Name:** TES-49A Room A231 Faucet **Sampled:** 3/4/21 3:32						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/05/21 15:37
1063021-19	**Sample Name:** TES-50A B209 Bubbler **Sampled:** 3/4/21 3:32						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/05/21 15:37

This report shall not be reproduced, except in full, without the written approval of the laboratory.

Alexin Analytical LABORATORIES, INC.
Professional Laboratory Services
13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 03/19/2021
Received: 03/04/2021
Sampled By: Tulla Stocker
Work Order: Multiple Work Orders

CLIENT
Apex Environmental
Attn: Tulla Stocker
PO Box 1445
Wilsonville OR, 97070
Phone: (503) 682-9737

Project: Templeton
Project # : N/A
Sample Type :

Sampling Location: Templeton Elementary School

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
1063021-21	**Sample Name:** TES-51A Room 209 Faucet **Sampled:** 3/4/21 3:10						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/05/21 15:37
1063021-23	**Sample Name:** TES-52A Room 210 Bubbler **Sampled:** 3/4/21 3:10						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/05/21 15:37
1063021-25	**Sample Name:** TES-53A Room 210 Faucet **Sampled:** 3/4/21 3:10						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/05/21 15:37
1063021-27	**Sample Name:** TES-54A Room 211 Bubbler **Sampled:** 3/4/21 3:10						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	7	ppb	2	15 ppb	03/05/21 15:37
1063021-29	**Sample Name:** TES-55A Room 211 Faucet **Sampled:** 3/4/21 3:10						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/05/21 15:37
1063021-31	**Sample Name:** TES-56A RR 213-214 Faucet **Sampled:** 3/4/21 3:20						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/05/21 15:37
1063021-33	**Sample Name:** TES-57A RR 213-214 Faucet **Sampled:** 3/4/21 3:20						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/05/21 15:37
1063021-35	**Sample Name:** TES-58A Room 215 Bubbler **Sampled:** 3/4/21 3:20						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/05/21 15:37
1063021-37	**Sample Name:** TES-59A Room 215 Faucet **Sampled:** 3/4/21 3:20						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/05/21 15:37
1063021-39	**Sample Name:** TES-60A Room 216 Bubbler **Sampled:** 3/4/21 3:20						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/05/21 15:37

This report shall not be reproduced, except in full, without the written approval of the laboratory.

Alexin Analytical LABORATORIES, INC.
Professional Laboratory Services
13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 03/19/2021
Received: 03/04/2021
Sampled By: Tulla Stocker
Work Order: Multiple Work Orders

CLIENT
Apex Environmental
Attn: Tulla Stocker
PO Box 1445
Wilsonville OR, 97070
Phone: (503) 682-9737

Project: Templeton
Project # : N/A
Sample Type :

Sampling Location: Templeton Elementary School

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
1063021-41	**Sample Name:** TES-62A Hallway Bubbler (2) **Sampled:** 3/4/21 3:35						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/05/21 15:37
1063021-43	**Sample Name:** TES-63A Hallway Bubbler (2) **Sampled:** 3/4/21 3:35						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/05/21 15:37
1063021-45	**Sample Name:** TES-64A B218 Staff Faucet **Sampled:** 3/4/21 3:35						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/05/21 15:37
1063021-47	**Sample Name:** TES-65A RR225-226 Faucet **Sampled:** 3/4/21 3:35						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/05/21 15:37
1063021-49	**Sample Name:** TES-66A RR225-226 Faucet **Sampled:** 3/4/21 3:35						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	4	ppb	2	15 ppb	03/08/21 14:06
1063021-51	**Sample Name:** TES-67A B227 Bubbler **Sampled:** 3/4/21 3:40						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/05/21 15:37
1063021-53	**Sample Name:** TES-68A B227 Faucet **Sampled:** 3/4/21 3:40						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/05/21 15:37
1063021-55	**Sample Name:** TES-69A B228 Bubbler **Sampled:** 3/4/21 3:40						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/05/21 15:37
1063021-57	**Sample Name:** TES-70A B228 Faucet **Sampled:** 3/4/21 3:40						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/05/21 15:37
1063021-59	**Sample Name:** TES-71A B229 Bubbler **Sampled:** 3/4/21 3:40						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/05/21 15:37

This report shall not be reproduced, except in full, without the written approval of the laboratory.

Alexin Analytical LABORATORIES, INC.
Professional Laboratory Services
13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 03/19/2021
Received: 03/04/2021
Sampled By: Tulla Stocker
Work Order: Multiple Work Orders

CLIENT
Apex Environmental
Attn: Tulla Stocker
PO Box 1445
Wilsonville OR, 97070
Phone: (503) 682-9737

Project: Templeton
Project # : N/A
Sample Type :

Sampling Location: Templeton Elementary School

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
1063021-61	**Sample Name:** TES-72A Room 229 Faucet **Sampled:** 3/4/21 3:50						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/08/21 14:06
1063021-63	**Sample Name:** TES-73A Room 230 Bubbler **Sampled:** 3/4/21 3:50						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/08/21 14:06
1063021-65	**Sample Name:** TES-74A Room 230 Faucet **Sampled:** 3/4/21 3:50						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/08/21 14:06
1063021-67	**Sample Name:** TES-75A Room 231 Bubbler **Sampled:** 3/4/21 3:50						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/08/21 14:06
1063021-69	**Sample Name:** TES-76A Room 231 Faucet **Sampled:** 3/4/21 3:50						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/08/21 14:06
1063021-71	**Sample Name:** TES-77A A102 Health R Faucet **Sampled:** 3/4/21 4:00						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/08/21 14:06
1063021-73	**Sample Name:** TES-78A A102 Health RR Faucet **Sampled:** 3/4/21 4:00						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/08/21 14:06
1063021-75	**Sample Name:** TES-79A A110 Sink Faucet **Sampled:** 3/4/21 4:00						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/08/21 14:06
1063021-77	**Sample Name:** TES-80A A109 Sink Faucet **Sampled:** 3/4/21 4:00						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/08/21 14:06
1063021-79	**Sample Name:** TES-81A A119 Sink Faucet **Sampled:** 3/4/21 4:00						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/08/21 14:06

This report shall not be reproduced, except in full, without the written approval of the laboratory.

Alexin Analytical LABORATORIES, INC.
Professional Laboratory Services
13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 03/19/2021
Received: 03/04/2021
Sampled By: Tulla Stocker
Work Order: Multiple Work Orders

CLIENT
Apex Environmental
Attn: Tulla Stocker
PO Box 1445
Wilsonville OR, 97070
Phone: (503) 682-9737

Project: Templeton
Project # : N/A
Sample Type :

Sampling Location: Templeton Elementary School

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
1063021-81	**Sample Name:** TES-61A Room 216 Faucet **Sampled:** 3/4/21 0:00						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/08/21 14:06
1063028-01	**Sample Name:** TES-87A Kitchen sink faucet NE **Sampled:** 3/4/21 4:05						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	3	ppb	2	15 ppb	03/08/21 14:06
1063028-03	**Sample Name:** TES-88A Kitchen sink faucet center **Sampled:** 3/4/21 4:05						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/08/21 14:06
1063028-05	**Sample Name:** TES-89A Kitchen sink faucet North **Sampled:** 3/4/21 4:05						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/08/21 14:06
1063028-07	**Sample Name:** TES-90A Kitchen sink faucet East **Sampled:** 3/4/21 4:05						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/08/21 14:06
1063028-09	**Sample Name:** TES-91A Kitchen RR 106 **Sampled:** 3/4/21 4:05						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/08/21 14:06
1063028-11	**Sample Name:** TES-82A RR 111 sink faucet **Sampled:** 3/4/21 4:20						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/08/21 14:06
1063028-13	**Sample Name:** TES-83A RR 112 sink faucet **Sampled:** 3/4/21 4:20						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/08/21 14:06
1063028-15	**Sample Name:** TES-84A A108-D in Cafeteria Fountain Bubble 1 **Sampled:** 3/4/21 4:20						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/08/21 14:06
1063028-17	**Sample Name:** TES-85A A108-D in Cafeteria Fountain Bubbler 2 **Sampled:** 3/4/21 4:20						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/08/21 14:06

This report shall not be reproduced, except in full, without the written approval of the laboratory.

Alexin Analytical LABORATORIES, INC.
Professional Laboratory Services
13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 03/19/2021
Received: 03/04/2021
Sampled By: Tulla Stocker
Work Order: Multiple Work Orders

CLIENT
Apex Environmental
Attn: Tulla Stocker
PO Box 1445
Wilsonville OR, 97070
Phone: (503) 682-9737

Project: Templeton
Project # : N/A
Sample Type :

Sampling Location: Templeton Elementary School

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
1063028-19	**Sample Name:** TES-86A A108-D in Cafeteria Sink Faucet **Sampled:** 3/4/21 4:20						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/08/21 14:06
1063028-21	**Sample Name:** TES-92A Kitchen DW 108 **Sampled:** 3/4/21 4:32						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/08/21 14:06
1063028-23	**Sample Name:** TES-93A Kitchen DW 108 **Sampled:** 3/4/21 4:32						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/08/21 14:06
1063028-25	**Sample Name:** TES-94A Kitchen DW 108 **Sampled:** 3/4/21 4:32						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/08/21 14:06
1063028-27	**Sample Name:** TES-95A RR 113 Sink (R to Left) **Sampled:** 3/4/21 4:32						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/08/21 14:06
1063028-29	**Sample Name:** TES-96A RR 113 Sink (R to Left) **Sampled:** 3/4/21 4:32						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/08/21 14:06
1063028-31	**Sample Name:** TES-97A RR 113 Sink **Sampled:** 3/4/21 4:54						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/08/21 14:06
1063028-33	**Sample Name:** TES-98A RRC 114 Sink Faucet (R to L) **Sampled:** 3/4/21 4:57						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/08/21 14:06
1063028-35	**Sample Name:** TES-99A RRC 114 Sink Faucet (R to L) **Sampled:** 3/4/21 5:06						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/08/21 14:06
1063028-37	**Sample Name:** TES-100A RRC 114 Sink Faucet (R to L) **Sampled:** 3/4/21 5:10						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/08/21 14:06

This report shall not be reproduced, except in full, without the written approval of the laboratory.

Alexin Analytical LABORATORIES, INC.
Professional Laboratory Services
13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 03/19/2021
Received: 03/04/2021
Sampled By: Tulla Stocker
Work Order: Multiple Work Orders

CLIENT
Apex Environmental
Attn: Tulla Stocker
PO Box 1445
Wilsonville OR, 97070
Phone: (503) 682-9737

Project: Templeton
Project # : N/A
Sample Type :

Sampling Location: Templeton Elementary School

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
1063028-39	**Sample Name:** TES-101A D107 Girls RR Gym Faucet **Sampled:** 3/4/21 5:16						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	2	ppb	2	15 ppb	03/08/21 14:06
1063028-41	**Sample Name:** TES-102A Girls RR D107 Sink Faucet **Sampled:** 3/4/21 5:20						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/08/21 14:06
1063028-43	**Sample Name:** TES-103A Girls RR D107 Sink Faucet **Sampled:** 3/4/21 5:25						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	2	ppb	2	15 ppb	03/08/21 14:06
1063028-45	**Sample Name:** TES-104A Girls RR D107 Sink Faucet **Sampled:** 3/4/21 5:25						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/08/21 14:06
1063028-47	**Sample Name:** TES-105A Girls RR D107 Sink Faucet **Sampled:** 3/4/21 5:26						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	3	ppb	2	15 ppb	03/08/21 14:06
1063028-49	**Sample Name:** TES-106A Boy RR 106 Sink Faucet **Sampled:** 3/4/21 5:30						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	2	ppb	2	15 ppb	03/08/21 14:06
1063028-51	**Sample Name:** TES-107A D102B RR Sink **Sampled:** 3/4/21 5:36						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	**19**	ppb	2	15 ppb	03/11/21 16:05 **MCLE**

MCLE This analyte exceeds the MCL limit.

ND = None detected at the MRL **MRL** = Minimum Reporting Limit **MCL** = Maximum Contamination Limit

†All procedures for this analysis are in accordance with NELAP standards.

***** The EPA MCL for Lead in Public Drinking Water Systems is 15 ppb; this is a maximum contamination level for lead in samples, this is not an acceptance level for health based exposure.

Approved by: _____
Adriana Gonzalez-Gray
Laboratory Director

This report shall not be reproduced, except in full, without the written approval of the laboratory.