APEX
ENVIRONMENTAL CONSULTING

March 29, 2021

Mr. Jesse Cavazos
Tigard Tualatin School District
6960 SW Sandburg
Tigard, Oregon 97223

LEAD IN WATER TESTING AT TIGARD HIGH SCHOOL IN TIGARD OREGON

Dear Mr. Cavazos:

At your request Apex Environmental collected samples for lead in water analysis at Tigard HS located at 9000 SW Durham Rd. in Tigard, Oregon. Samples were collected from possible drinking water and water used for food preparation in locations identified by the school district and located in newly remodeled areas. In accordance with EPA 3Ts Drinking Water School Tool Kit Guidelines and Oregon Health Authority Reducing Lead in Drinking School Drinking Water Guidelines of 2017.

The water in the system was flushed by School District personnel and allowed to remain in the system for a minimum of 18 hours prior to testing. Apex collected one first draw sample and a follow-up sample after the water flushed for a period of 30 seconds. Each of the samples were sent to Alexin Laboratories in Tigard, Oregon for Analysis. Alexin is accredited by the Oregon Environmental Laboratory for the analysis of drinking water under the U.S. EPA Safe Drinking Water Act as Laboratory #OR100013. Follow-up flushed samples were only analyzed if the results of the initial draw sample showed greater than 15 parts per billion lead content. All of the initial water samples collected at Tigard H.S. were below this threshold and therefore no follow up samples were analyzed as directed by the district. Corrective action would not be required based upon this criteria.

Attached are the lab results for samples collected at Tigard H. S. If you have any questions or need anything further, please feel free to call me.

Sincerely,

Tulla R. Stocker

Tulla R. Stocker
Principal

PO Box 1445
p 503.682.9737
Wilsonville, OR 97070
www.apexenviro.com
f 503.682.0525

Alexin Analytical LABORATORIES, INC.
Professional Laboratory Services
13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 03/26/2021
Received: 03/09/2021
Sampled By: TS
Work Order: Multiple Work Orders

CLIENT
Apex Environmental
Attn: Tulla Stocker
PO Box 1445
Wilsonville OR, 97070
Phone: (503) 682-9737

Project: TTSD Water
Project # : N/A
Sample Type :

Sampling Location: Tigard HS

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
1068015-01	**Sample Name:** THS-01A Girls RR-U2 N213 North (Right to Left) **Sampled:** 3/8/21 3:18						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	2	ppb	2	15 ppb	03/11/21 16:05 J
1068015-03	**Sample Name:** THS-02A Girls RR-U2 N213 North (Right to Left) **Sampled:** 3/8/21 3:18						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	3	ppb	2	15 ppb	03/11/21 16:05
1068015-05	**Sample Name:** THS-03A Girls RR-U2 N213 North (Right to Left) **Sampled:** 3/8/21 3:18						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	2	ppb	2	15 ppb	03/11/21 16:05 J
1068015-07	**Sample Name:** THS-04A Drinking F. outside N213 G. RR **Sampled:** 3/8/21 3:21						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/11/21 16:05
1068015-09	**Sample Name:** THS-05A Drinking F. outside N213 G. RR **Sampled:** 3/8/21 3:21						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/11/21 16:05
1068015-11	**Sample Name:** THS-06A BRR N21 UL North **Sampled:** 3/8/21 3:22						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/11/21 16:05
1068015-13	**Sample Name:** THS-07A BRR N21 UL North **Sampled:** 3/8/21 3:22						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/11/21 16:05
1068015-15	**Sample Name:** THS-08A BRR N21 UL North **Sampled:** 3/8/21 3:22						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/11/21 16:05
1068015-17	**Sample Name:** THS-09A Staff RR N Main Level **Sampled:** 3/8/21 3:28						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/11/21 16:05
1068015-19	**Sample Name:** THS-10A N107 D Teaching Kitchen **Sampled:** 3/8/21 3:28						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/11/21 16:05

This report shall not be reproduced, except in full, without the written approval of the laboratory.

Alexin Analytical LABORATORIES, INC.
Professional Laboratory Services
13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 03/26/2021
Received: 03/09/2021
Sampled By: TS
Work Order: Multiple Work Orders

CLIENT
Apex Environmental
Attn: Tulla Stocker
PO Box 1445
Wilsonville OR, 97070
Phone: (503) 682-9737

Project: TTSD Water
Project # : N/A
Sample Type :

Sampling Location: Tigard HS

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
1068015-21	**Sample Name:** THS-11A Main Level N112 Girls RR **Sampled:** 3/8/21 3:32						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	1	ppb	2	15 ppb	03/11/21 16:05 J
1068015-23	**Sample Name:** THS-12A Main Level N112 Girls RR **Sampled:** 3/8/21 3:32						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/11/21 16:05
1068015-25	**Sample Name:** THS-13A Main Level N111 Boys RR **Sampled:** 3/8/21 3:32						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/11/21 16:05
1068015-27	**Sample Name:** THS-14A Main Level N111 Boys RR **Sampled:** 3/8/21 3:33						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	1	ppb	2	15 ppb	03/11/21 16:05 J
1068015-29	**Sample Name:** THS-15A DR Fountain outside N111 **Sampled:** 3/8/21 3:35						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/11/21 16:05
1068015-31	**Sample Name:** THS-16A DR Fountain outside N111 **Sampled:** 3/8/21 3:36						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/11/21 16:05
1068015-33	**Sample Name:** THS-17A Staff RR across from N111 (R to Left) **Sampled:** 3/8/21 3:36						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/11/21 16:05
1068015-35	**Sample Name:** THS-18A Staff RR across from N111 (R to Left) **Sampled:** 3/8/21 3:36						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/11/21 16:05
1068015-37	**Sample Name:** THS-19A Staff RR across from N111 (R to Left) **Sampled:** 3/8/21 3:36						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	1	ppb	2	15 ppb	03/11/21 16:05 J
1068015-39	**Sample Name:** THS-20A Staff RR across from N111 (R to Left) **Sampled:** 3/8/21 3:36						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/11/21 16:05

This report shall not be reproduced, except in full, without the written approval of the laboratory.

Alexin Analytical LABORATORIES, INC.
Professional Laboratory Services
13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 03/26/2021
Received: 03/09/2021
Sampled By: TS
Work Order: Multiple Work Orders

CLIENT
Apex Environmental
Attn: Tulla Stocker
PO Box 1445
Wilsonville OR, 97070
Phone: (503) 682-9737

Project: TTSD Water
Project # : N/A
Sample Type :

Sampling Location: Tigard HS

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
1068015-41	**Sample Name:** THS-21A A108 - Mail room/ Break R **Sampled:** 3/8/21 3:42						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/11/21 16:05
1068015-43	**Sample Name:** THS-22A Main Level Kitchen - Frontside **Sampled:** 3/8/21 3:42						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/11/21 16:05
1068015-45	**Sample Name:** THS-23A Main Level Kitchen - Frontside **Sampled:** 3/8/21 3:42						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/11/21 16:05
1068015-47	**Sample Name:** THS-24A Main Level Kitchen - Backside L-R **Sampled:** 3/8/21 3:51						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/11/21 16:05
1068015-49	**Sample Name:** THS-25A Main Level Kitchen - Backside L-R **Sampled:** 3/8/21 3:51						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/11/21 16:05
1068015-51	**Sample Name:** THS-26A Main Kitchen - Backside **Sampled:** 3/8/21 3:20						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/11/21 16:05
1068015-53	**Sample Name:** THS-27A Main Kitchen - Backside **Sampled:** 3/8/21 3:20						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/11/21 16:05
1068015-55	**Sample Name:** THS-28A Main Kitchen - Dish area (Hose First) **Sampled:** 3/8/21 3:53						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/11/21 16:05
1068015-57	**Sample Name:** THS-29A Main Kitchen - Two Sinks L-R **Sampled:** 3/8/21 3:54						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/11/21 16:05
1068015-59	**Sample Name:** THS-30A Main Kitchen - Two Sinks L-R **Sampled:** 3/8/21 3:55						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/11/21 16:05

This report shall not be reproduced, except in full, without the written approval of the laboratory.

Alexin Analytical LABORATORIES, INC.
Professional Laboratory Services
13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 03/26/2021
Received: 03/09/2021
Sampled By: TS
Work Order: Multiple Work Orders

CLIENT
Apex Environmental
Attn: Tulla Stocker
PO Box 1445
Wilsonville OR, 97070
Phone: (503) 682-9737

Project: TTSD Water
Project # : N/A
Sample Type :

Sampling Location: Tigard HS

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
1068015-61	**Sample Name:** THS-31A Kitchen - Small Sink **Sampled:** 3/8/21 3:56						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/11/21 16:05
1068015-63	**Sample Name:** THS-32A Kitchen - RR **Sampled:** 3/8/21 3:57						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/11/21 16:05
1068015-65	**Sample Name:** THS-33A Commons Bubbler W105 **Sampled:** 3/8/21 3:59						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/11/21 16:05
1068015-67	**Sample Name:** THS-34A Commons Bubbler W105 **Sampled:** 3/8/21 3:59						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/11/21 16:05
1068015-69	**Sample Name:** THS-35A Counselor E101 **Sampled:** 3/8/21 4:00						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	7	ppb	2	15 ppb	03/11/21 16:05
1068015-71	**Sample Name:** THS-36A E120 D Waiting Room RR **Sampled:** 3/8/21 4:05						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/11/21 16:05
1068015-73	**Sample Name:** THS-37A Student Store E113A **Sampled:** 3/8/21 4:08						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	5	ppb	2	15 ppb	03/11/21 16:05
1068015-75	**Sample Name:** THS-38A Student Store E113A **Sampled:** 3/8/21 4:10						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	3	ppb	2	15 ppb	03/11/21 16:05
1068015-77	**Sample Name:** THS-39A Bus Class E113 **Sampled:** 3/8/21 4:11						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	2	ppb	2	15 ppb	03/11/21 16:05 J
1068015-79	**Sample Name:** THS-40A Bus Class E114 **Sampled:** 3/8/21 4:11						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	6	ppb	2	15 ppb	03/11/21 16:05

This report shall not be reproduced, except in full, without the written approval of the laboratory.

Alexin Analytical LABORATORIES, INC.
Professional Laboratory Services
13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 03/26/2021
Received: 03/09/2021
Sampled By: TS
Work Order: Multiple Work Orders

CLIENT
Apex Environmental
Attn: Tulla Stocker
PO Box 1445
Wilsonville OR, 97070
Phone: (503) 682-9737

Project: TTSD Water
Project # : N/A
Sample Type :

Sampling Location: Tigard HS

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
1068016-01	**Sample Name:** THS-41A Bus Class 115 **Sampled:** 3/8/21 4:14						**Matrix:** Water
†*Lead*	1030	EPA 200.9	3	ppb	2	15 ppb	03/11/21 16:05
1068016-03	**Sample Name:** THS-42A E118 T. Lounge **Sampled:** 3/8/21 4:16						**Matrix:** Water
†*Lead*	1030	EPA 200.9	2	ppb	2	15 ppb	03/11/21 16:05
1068016-05	**Sample Name:** THS-43A W103 Boy RR- (R-L) **Sampled:** 3/8/21 4:22						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/11/21 16:05
1068016-07	**Sample Name:** THS-44A W103 Boy RR- (R-L) **Sampled:** 3/8/21 4:22						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/11/21 16:05
1068016-09	**Sample Name:** THS-45A W103 Boy RR- (R-L) **Sampled:** 3/8/21 4:22						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/11/21 16:05
1068016-11	**Sample Name:** THS-46A Boy RR-W103 **Sampled:** 3/8/21 4:27						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/11/21 16:05
1068016-13	**Sample Name:** THS-47A Girls RR-W104 **Sampled:** 3/8/21 4:27						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/11/21 16:05
1068016-15	**Sample Name:** THS-48A Girls RR-W104 **Sampled:** 3/8/21 4:27						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/11/21 16:05
1068016-17	**Sample Name:** THS-49A Girls RR-W104 **Sampled:** 3/8/21 4:27						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/11/21 16:05
1068016-19	**Sample Name:** THS-50A Girls RR-W104 **Sampled:** 3/8/21 4:27						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/11/21 16:05

This report shall not be reproduced, except in full, without the written approval of the laboratory.

Alexin Analytical LABORATORIES, INC.
Professional Laboratory Services
13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 03/26/2021
Received: 03/09/2021
Sampled By: TS
Work Order: Multiple Work Orders

CLIENT
Apex Environmental
Attn: Tulla Stocker
PO Box 1445
Wilsonville OR, 97070
Phone: (503) 682-9737

Project: TTSD Water
Project # : N/A
Sample Type :

Sampling Location: Tigard HS

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
1068016-21	**Sample Name:** THS-51A Concession W110 **Sampled:** 3/8/21 4:34						**Matrix:** Water
†*Lead*	1030	EPA 200.9	2	ppb	2	15 ppb	03/11/21 16:05
1068016-23	**Sample Name:** THS-52A Concession W110 **Sampled:** 3/8/21 4:34						**Matrix:** Water
†*Lead*	1030	EPA 200.9	1	ppb	2	15 ppb	03/11/21 16:05 J
1068016-25	**Sample Name:** THS-53A Handicapp RR near Girls W116 **Sampled:** 3/8/21 4:34						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/11/21 16:05
1068016-27	**Sample Name:** THS-54A Girls RR W116 **Sampled:** 3/8/21 4:33						**Matrix:** Water
†*Lead*	1030	EPA 200.9	1	ppb	2	15 ppb	03/11/21 16:05 J
1068016-29	**Sample Name:** THS-55A Girls RR W116 **Sampled:** 3/8/21 4:33						**Matrix:** Water
†*Lead*	1030	EPA 200.9	2	ppb	2	15 ppb	03/11/21 16:05 J
1068016-31	**Sample Name:** THS-56A Girls RR W116 **Sampled:** 3/8/21 4:34						**Matrix:** Water
†*Lead*	1030	EPA 200.9	1	ppb	2	15 ppb	03/11/21 16:05 J
1068016-33	**Sample Name:** THS-57A Girls RR W116 **Sampled:** 3/8/21 4:34						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/11/21 16:05
1068016-35	**Sample Name:** THS-58A Boy RR W115 **Sampled:** 3/8/21 4:36						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/11/21 16:05
1068016-37	**Sample Name:** THS-59A Boy RR W115 **Sampled:** 3/8/21 4:36						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/11/21 16:05
1068016-39	**Sample Name:** THS-60A Boy RR W115 **Sampled:** 3/8/21 4:39						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/11/21 16:05

This report shall not be reproduced, except in full, without the written approval of the laboratory.

Alexin Analytical LABORATORIES, INC.
Professional Laboratory Services
13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 03/26/2021
Received: 03/09/2021
Sampled By: TS
Work Order: Multiple Work Orders

CLIENT
Apex Environmental
Attn: Tulla Stocker
PO Box 1445
Wilsonville OR, 97070
Phone: (503) 682-9737

Project: TTSD Water
Project # : N/A
Sample Type :

Sampling Location: Tigard HS

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
1068016-41	**Sample Name:** THS-61A Boy RR W116 **Sampled:** 3/8/21 4:40						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/11/21 16:05
1068016-43	**Sample Name:** THS-62A Weight Room W117 Bubblers **Sampled:** 3/8/21 4:42						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/11/21 16:05
1068016-45	**Sample Name:** THS-63A Weight Room W117 Bubblers **Sampled:** 3/8/21 4:42						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/11/21 16:05
1068016-47	**Sample Name:** THS-64A Office W111A Sink **Sampled:** 3/8/21 4:46						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/11/21 16:05
1068016-49	**Sample Name:** THS-65A Office W112 **Sampled:** 3/8/21 4:46						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/11/21 16:05
1068016-51	**Sample Name:** THS-66A W113- Office Sink **Sampled:** 3/8/21 4:48						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/11/21 16:05
1068016-53	**Sample Name:** THS-67A Upper Level Handicap Sink W203 **Sampled:** 3/8/21 4:48						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/11/21 16:05
1068016-55	**Sample Name:** THS-68A Boys RR W204 **Sampled:** 3/8/21 4:53						**Matrix:** Water
†*Lead*	1030	EPA 200.9	1	ppb	2	15 ppb	03/11/21 16:05 J
1068016-57	**Sample Name:** THS-69A Boys RR W204 **Sampled:** 3/8/21 4:53						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/11/21 16:05
1068016-59	**Sample Name:** THS-70A Boys RR W204 **Sampled:** 3/8/21 4:57						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/11/21 16:05

This report shall not be reproduced, except in full, without the written approval of the laboratory.

Alexin Analytical LABORATORIES, INC.
Professional Laboratory Services
13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 03/26/2021
Received: 03/09/2021
Sampled By: TS
Work Order: Multiple Work Orders

CLIENT
Apex Environmental
Attn: Tulla Stocker
PO Box 1445
Wilsonville OR, 97070
Phone: (503) 682-9737

Project: TTSD Water
Project # : N/A
Sample Type :

Sampling Location: Tigard HS

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
1068016-61	**Sample Name:** THS-71A W203 Girls RR **Sampled:** 3/8/21 4:58						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/11/21 16:05
1068016-63	**Sample Name:** THS-72A W203 Girls RR **Sampled:** 3/8/21 4:59						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/11/21 16:05
1068016-65	**Sample Name:** THS-73A W203 Girls RR **Sampled:** 3/8/21 5:00						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/11/21 16:05
1068016-67	**Sample Name:** THS-74A Bubbler (L) Near W203 **Sampled:** 3/8/21 5:03						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/11/21 16:05
1068016-69	**Sample Name:** THS-75A Bubbler (R) Near W203 **Sampled:** 3/8/21 5:04						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/12/21 13:44
1068016-71	**Sample Name:** THS-76A S201 Painting Class Sink **Sampled:** 3/8/21 5:06						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/12/21 13:44
1068016-73	**Sample Name:** THS-77A S201 Painting Class Sink **Sampled:** 3/8/21 5:07						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/12/21 13:44
1068016-75	**Sample Name:** THS-78A S201 Painting Class Sink **Sampled:** 3/8/21 5:07						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/12/21 13:44
1068016-77	**Sample Name:** THS-79A S201 Painting Class Sink **Sampled:** 3/8/21 5:08						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/12/21 13:44
1068016-79	**Sample Name:** THS-80A S201 Painting Class Sink **Sampled:** 3/8/21 5:10						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/12/21 13:44

This report shall not be reproduced, except in full, without the written approval of the laboratory.

Alexin Analytical LABORATORIES, INC.
Professional Laboratory Services
13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 03/26/2021
Received: 03/09/2021
Sampled By: TS
Work Order: Multiple Work Orders

CLIENT
Apex Environmental
Attn: Tulla Stocker
PO Box 1445
Wilsonville OR, 97070
Phone: (503) 682-9737

Project: TTSD Water
Project # : N/A
Sample Type :

Sampling Location: Tigard HS

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
1068018-01	**Sample Name:** THS-81A S201 Painting 28 C. sink **Sampled:** 3/8/21 5:10						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	1	ppb	2	15 ppb	03/12/21 13:44 J
1068018-03	**Sample Name:** THS-82A S202 - Drawing Sink (R - L) **Sampled:** 3/8/21 5:10						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/12/21 13:44
1068018-05	**Sample Name:** THS-83A S202 - Drawing Sink (R - L) **Sampled:** 3/8/21 5:10						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/12/21 13:44
1068018-07	**Sample Name:** THS-84A S202 - Drawing Sink (R - L) **Sampled:** 3/8/21 5:10						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/12/21 13:44
1068018-09	**Sample Name:** THS-85A S005 Maker Place Sink **Sampled:** 3/8/21 5:10						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/12/21 13:44
1068018-11	**Sample Name:** THS-87A S005 Maker Place Sink (R-L) **Sampled:** 3/8/21 5:22						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/12/21 13:44
1068018-13	**Sample Name:** THS-88A S005 Maker Place Sink (R-L) **Sampled:** 3/8/21 5:22						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/12/21 13:44
1068018-15	**Sample Name:** THS-89A S002 Auto shop sink (R-L) **Sampled:** 3/8/21 5:22						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/12/21 13:44
1068018-17	**Sample Name:** THS-90A S002 Auto shop sink (R-L) **Sampled:** 3/8/21 5:22						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/12/21 13:44
1068018-19	**Sample Name:** THS-91A S002 sinks ceramics (R-L) **Sampled:** 3/8/21 5:32						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/12/21 13:44

This report shall not be reproduced, except in full, without the written approval of the laboratory.

Alexin Analytical LABORATORIES, INC.
Professional Laboratory Services
13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 03/26/2021
Received: 03/09/2021
Sampled By: TS
Work Order: Multiple Work Orders

CLIENT
Apex Environmental
Attn: Tulla Stocker
PO Box 1445
Wilsonville OR, 97070
Phone: (503) 682-9737

Project: TTSD Water
Project # : N/A
Sample Type :

Sampling Location: Tigard HS

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
1068018-21	**Sample Name:** THS-92A S002 sinks ceramics **Sampled:** 3/8/21 5:35						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/12/21 13:44
1068018-23	**Sample Name:** THS-93A S002 sinks ceramics **Sampled:** 3/8/21 5:35						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	2	ppb	2	15 ppb	03/12/21 13:44 J
1068018-25	**Sample Name:** THS-94A S002 sinks ceramics **Sampled:** 3/8/21 5:35						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/12/21 13:44
1068018-27	**Sample Name:** THS-95A S002 sinks ceramics **Sampled:** 3/8/21 5:35						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/12/21 13:44
1068018-29	**Sample Name:** THS-96A S002 sinks ceramics **Sampled:** 3/8/21 5:35						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	2	ppb	2	15 ppb	03/12/21 13:44 J
1068018-31	**Sample Name:** THS-97A W011 - Sink training sink R-L **Sampled:** 3/8/21 5:37						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/12/21 13:44
1068018-33	**Sample Name:** THS-98A W011 - Hose **Sampled:** 3/8/21 5:37						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	12	ppb	2	15 ppb	03/12/21 13:44
1068018-35	**Sample Name:** THS-99A W007 - Boys Locker room sink **Sampled:** 3/8/21 5:40						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	1	ppb	2	15 ppb	03/12/21 13:44 J
1068018-37	**Sample Name:** THS-100A W007 - Boys Locker room sink **Sampled:** 3/8/21 5:40						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	1	ppb	2	15 ppb	03/12/21 13:44 J
1068018-39	**Sample Name:** THS-101A W007 - Boys Locker room sink **Sampled:** 3/8/21 5:40						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	2	ppb	2	15 ppb	03/12/21 13:44 J

This report shall not be reproduced, except in full, without the written approval of the laboratory.

Alexin Analytical LABORATORIES, INC.
Professional Laboratory Services
13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 03/26/2021
Received: 03/09/2021
Sampled By: TS
Work Order: Multiple Work Orders

CLIENT
Apex Environmental
Attn: Tulla Stocker
PO Box 1445
Wilsonville OR, 97070
Phone: (503) 682-9737

Project: TTSD Water
Project # : N/A
Sample Type :

Sampling Location: Tigard HS

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
1068018-41	**Sample Name:** THS-102A Boys Locker Room W007 sink **Sampled:** 3/8/21 5:45						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/12/21 13:44
1068018-43	**Sample Name:** THS-103A Boys Locker Room W007 sink **Sampled:** 3/8/21 5:45						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	2	ppb	2	15 ppb	03/12/21 13:44 J
1068018-45	**Sample Name:** THS-104A Boys Locker Room W007 A Teachers RR **Sampled:** 3/8/21 5:48						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/12/21 13:44
1068018-47	**Sample Name:** THS-105A Girls RR W013 **Sampled:** 3/8/21 5:50						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/12/21 13:44
1068018-49	**Sample Name:** THS-106A Girls RR W013 **Sampled:** 3/8/21 5:50						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/12/21 13:44
1068018-51	**Sample Name:** THS-107A Girls RR Sink W013 **Sampled:** 3/8/21 5:53						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/12/21 13:44
1068018-53	**Sample Name:** THS-108A Outside W013 Bubbler **Sampled:** 3/8/21 5:55						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/12/21 13:44
1068018-55	**Sample Name:** THS-109A Outside W013 Bubbler **Sampled:** 3/8/21 5:55						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/12/21 13:44
1068018-57	**Sample Name:** THS-110A Boys RR Sink W014 **Sampled:** 3/8/21 5:59						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/12/21 13:44
1068018-59	**Sample Name:** THS-111A Boys RR Sink W014 **Sampled:** 3/8/21 5:59						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/12/21 13:44

This report shall not be reproduced, except in full, without the written approval of the laboratory.

Alexin Analytical LABORATORIES, INC.
Professional Laboratory Services
13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 03/26/2021
Received: 03/09/2021
Sampled By: TS
Work Order: Multiple Work Orders

CLIENT
Apex Environmental
Attn: Tulla Stocker
PO Box 1445
Wilsonville OR, 97070
Phone: (503) 682-9737

Project: TTSD Water
Project # : N/A
Sample Type :

Sampling Location: Tigard HS

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
1068018-61	**Sample Name:** THS-112A Boys RR Sink W014 **Sampled:** 3/8/21 6:00						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/12/21 13:44
1068018-63	**Sample Name:** THS-113A Girls LR Sink - W004 **Sampled:** 3/8/21 6:03						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/12/21 13:44
1068018-65	**Sample Name:** THS-114A Girls LR Sink - W004 **Sampled:** 3/8/21 6:03						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	1	ppb	2	15 ppb	03/12/21 13:44 J
1068018-67	**Sample Name:** THS-115A Girls LR Sink - W004 **Sampled:** 3/8/21 6:03						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	2	ppb	2	15 ppb	03/12/21 13:44 J
1068018-69	**Sample Name:** THS-116A Girls LR Sink - W004 **Sampled:** 3/8/21 6:03						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	4	ppb	2	15 ppb	03/12/21 13:44
1068018-71	**Sample Name:** THS-117A Girls LR Sink **Sampled:** 3/8/21 6:08						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	2	ppb	2	15 ppb	03/12/21 13:44
1068018-73	**Sample Name:** THS-118A Girls LR - Office W004A **Sampled:** 3/8/21 6:08						**Matrix:** Drinking Water
†*Lead*	1030	EPA 200.9	ND	ppb	2	15 ppb	03/12/21 13:44

J The reported value is greater than the Method Detection Limit of 0.001 mg/L or 1 ppb but less than the Reporting Limit.

ND = None detected at the MRL **MRL** = Minimum Reporting Limit **MCL** = Maximum Contamination Limit

†All procedures for this analysis are in accordance with NELAP standards.

* The EPA MCL for Lead in Public Drinking Water Systems is 15 ppb; this is a maximum contamination level for lead in samples, this is not an acceptance level for health based exposure.

Approved by: _____
Adriana Gonzalez-Gray
Laboratory Director

This report shall not be reproduced, except in full, without the written approval of the laboratory.