



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 07/20/2020
Received: 06/26/2020
Sampled By: Jose Godinez
Work Order: 0178003

C **Apex Environmental**
L Attn: Tulla Stocker
I PO Box 1445
E Wilsonville OR, 97070
N Phone: (503) 682-9737
T

Project:
Project # : N/A
Sample Type :

Sampling Location: Templeton

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
0178003-06	Sample Name: Temw - 03B Sampled: 6/26/20 7:25		Matrix: Drinking Water				
†Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	07/15/20 14:21
0178003-10	Sample Name: Temw - 05B Sampled: 6/26/20 7:34		Matrix: Drinking Water				
†Lead	1030	EPA 200.9	3	ppb	2	20 ppb	07/15/20 14:21
0178003-12	Sample Name: Temw - 06B Sampled: 6/26/20 7:37		Matrix: Drinking Water				
†Lead	1030	EPA 200.9	4	ppb	2	20 ppb	07/15/20 14:21
0178003-16	Sample Name: Temw - 08B Sampled: 6/26/20 7:43		Matrix: Drinking Water				
†Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	07/15/20 14:21

ND = None detected at the MRL **MRL** = Minimum Reporting Limit **MCL** = Maximum Contamination Limit
†All procedures for this analysis are in accordance with NELAP standards.

* The EPA MCL for Lead in Public Drinking Water Systems is 15 ppb. For school, daycare, or non-residential building testing the EPA recommends outlets be taken out of service if the lead level exceeds 20 ppb; this is a maximum contamination level for lead in samples based on a 250 mL first-draw sample, exceedences require remediation or further sampling. This is not an acceptance level for health based exposure.

Approved by: 
Adriana Gonzalez-Gray
Laboratory Director