



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 07/06/2020
Received: 06/26/2020
Sampled By: Jose Godinez
Work Order: 0178003

C **Apex Environmental**
L Attn: Tulla Stocker
I PO Box 1445
E Wilsonville OR, 97070
N Phone: (503) 682-9737
T

Project:
Project # : N/A
Sample Type :

Sampling Location: Templeton

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
0178003-01	Sample Name: Temw - 01A Sampled: 6/26/20 7:18		Matrix: Drinking Water				
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	06/29/20 15:14
0178003-03	Sample Name: Temw - 02A Sampled: 6/26/20 7:21		Matrix: Drinking Water				
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	06/29/20 15:14
0178003-05	Sample Name: Temw - 03A Sampled: 6/26/20 7:25		Matrix: Drinking Water				
+Lead	1030	EPA 200.9	12	ppb	2	20 ppb	06/29/20 15:14
0178003-07	Sample Name: Temw - 04A Sampled: 6/26/20 7:30		Matrix: Drinking Water				
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	06/29/20 15:14
0178003-09	Sample Name: Temw - 05A Sampled: 6/26/20 7:34		Matrix: Drinking Water				
+Lead	1030	EPA 200.9	17	ppb	2	20 ppb	06/29/20 15:14
0178003-11	Sample Name: Temw - 06A Sampled: 6/26/20 7:37		Matrix: Drinking Water				
+Lead	1030	EPA 200.9	18	ppb	2	20 ppb	06/29/20 15:14
0178003-13	Sample Name: Temw - 07A Sampled: 6/26/20 7:41		Matrix: Drinking Water				
+Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	06/29/20 15:14
0178003-15	Sample Name: Temw - 08A Sampled: 6/26/20 7:43		Matrix: Drinking Water				
+Lead	1030	EPA 200.9	13	ppb	2	20 ppb	06/29/20 15:14
0178003-17	Sample Name: Temw - 09A Sampled: 6/26/20 7:49		Matrix: Drinking Water				
+Lead	1030	EPA 200.9	2	ppb	2	20 ppb	06/29/20 15:14
0178003-19	Sample Name: Temw - 10A Sampled: 6/26/20 7:54		Matrix: Drinking Water				
+Lead	1030	EPA 200.9	2	ppb	2	20 ppb	06/29/20 15:14



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 07/06/2020
Received: 06/26/2020
Sampled By: Jose Godinez
Work Order: 0178003

C **Apex Environmental**
L Attn: Tulla Stocker
I PO Box 1445
E Wilsonville OR, 97070
N Phone: (503) 682-9737
T

Project:
Project # : N/A
Sample Type :

Sampling Location: Templeton

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
0178003-21	Sample Name: Temw - 11A Sampled: 6/26/20 7:56		Matrix: Drinking Water				
†Lead	1030	EPA 200.9	7	ppb	2	20 ppb	06/29/20 15:14
0178003-23	Sample Name: Temw - 12A Sampled: 6/26/20 7:57		Matrix: Drinking Water				
†Lead	1030	EPA 200.9	5	ppb	2	20 ppb	06/29/20 15:14
0178003-25	Sample Name: Temw - 13A Sampled: 6/26/20 8:04		Matrix: Drinking Water				
†Lead	1030	EPA 200.9	6	ppb	2	20 ppb	06/29/20 15:14
0178003-27	Sample Name: Temw - 14A Sampled: 6/26/20 8:20		Matrix: Drinking Water				
†Lead	1030	EPA 200.9	10	ppb	2	20 ppb	06/29/20 15:14

ND = None detected at the MRL **MRL** = Minimum Reporting Limit **MCL** = Maximum Contamination Limit

†All procedures for this analysis are in accordance with NELAP standards.

* The EPA MCL for Lead in Public Drinking Water Systems is 15 ppb. For school, daycare, or non-residential building testing the EPA recommends outlets be taken out of service if the lead level exceeds 20 ppb; this is a maximum contamination level for lead in samples based on a 250 mL first-draw sample, exceedences require remediation or further sampling. This is not an acceptance level for health based exposure.

Approved by: _____

Adriana Gonzalez-Gray
Laboratory Director