Templeton Elementary School
Results of February 20-22, 2013
Water Quality Testing

The specific results are listed below in tables and in accordance to the date when the samples were collected. The results are shown in parts per billion ("ppb").

For this set of data, "ND" means no detection, which are results that are less than 2 ppb.

The gray highlighted number is the sole sample that exceeds the Environmental Protection Agency's recommended level of 20 ppb.

February 20, 2013 Samples		
Location	No-Flush	Flushed
G1	8	2
G4	5	2
G Boys' Left Sink	3	ND
G Girls' Left Sink	6	ND
F7	5	2
F10	4	ND
F Girls' Center Sink	6	3
F Boys' Center Sink	5	3
Kitchen N Sink	ND	ND
Restroom by A7	ND	ND
K2	5	ND
D19	7	6
D22	5	ND
E13	9	6
E16	ND	ND
E Boys' Left	4	ND
D Boys' Center	2	ND
D Girls' Center	5	ND
E Girls' Center	4	ND

February 21, 2013 Samples		
Location	No-Flush	Flushed
G5	4	ND

February 21, 2013 Samples		
Location	No-Flush	Flushed
G2	3	2
F8	2	2
F12	2	ND
D20	3	3
D24	2	2
E17	11	2
E14	5	2
Staff Room Sink	9	ND
Staff Restroom by A7	2	2
Girls' Restroom by Gym Door	2	ND
Boys' Restroom by Gym Door	ND	ND
Fountain by Gym/Main Office	ND	ND
Comp	ND	ND

February 22, 2013 Samples		
Location	No-Flush	Flushed
G3	ND	ND
G6	5	ND
F9	4	ND
F11	5	ND
D21	ND	ND
D23	6	ND
E15	5	ND
E18	5	ND
K1	3	ND
Music	ND	ND
Gym Rt Fountain	6	24