Woodward Elementary School
Water Quality Testing

The specific results are listed below in tables and in accordance to the date when the samples were collected. The results are shown in parts per billion ("ppb").

For this set of data, "ND" means no detection, which are results that are less than 2 ppb.

The gray highlighted numbers are samples that exceed the Environmental Protection Agency's recommended level of 20 ppb.

Results of February 26, 2013 Testing

Location	No-Flush	Flushed
Room 2 (Drinking Fountain turned off)	72	25
Room 5	37	8
Room 8	13	4
Room 11	7	ND
Room 16	4	ND
Room 17	5	2
Room 22	3	ND
Gym	ND	ND
Kitchen	2	ND

Results of April 18, 2013 Testing

Location	No-Flush	Flushed
Room 1 (See May 21 re-test)	8	170
Room 3	95	16
Room 4	75	8
Room 6	16	14
Room 7	4	2
Room 8	3	ND

Results of April 18, 2013 Testing		
Location	No-Flush	Flushed
Room 9	2	ND
Room 10	ND	ND
Room 11	2	ND
Room 12	ND	ND
Room 16	3	2
Room 17	2	2
Room 18	ND	ND
Room 19	ND	ND
Room 20	ND	ND
Room 21	ND	ND
Room 22	ND	ND
Room 23	ND	ND
Room 24	ND	ND
Room 25	3	3
Room 30	13	6
Room 31	9	3
Cafeteria	ND	3
Gym	ND	ND
First Aid/Health	14	4
Kitchen	6	ND
Staff Lounge	5	ND

Results of May 21, 2013 Testing		
Location	No-Flush	Flushed
Room 1	90	17