

School Name: Stonebridge Elementary (SB)

Date: 5/4/2023

Floor	Room Number	Location	Sample ID	Type S = Sink WC = Water Cooler BF = Bottle Filler SP = Sprayer	Lead Result (ppb)	Copper Result (ppb)
First	-	Kitchen	1-SB-Kit-SP	SP	0.67	313
First	-	Kitchen	2-SB-Kit-S	S	1.44	210
First	-	Kitchen	3-SB-Kit-S	S	5.46	62
First	-	Kitchen	4-SB-Kit-S	S	3.12	329
First	-	Cafeteria	5-SB-Café-WC	WC	<0.5	27.4
First	-	Cafeteria	6-SB-Café-BF	BF	<0.5	39.2
First	-	Dish Rm	7-SB-Dish-S	S	3.94	193
First	-	Dish Rm	8-SB-Dish-SP	SP	27	502
First	-	Hallway	9-SB-Hall Gym-WC	WC	<0.5	30.6
First	-	Hallway	10-SB-Hall Gym-BF	BF	<0.5	32.2
First	A124	Classroom	11-SB-A124-S	S	10.3	232
First	A119	Classroom	12-SB-A119-S	S	20.3	59.8
First	A112	Classroom	13-SB-A112-S L	S	1.87	339
First	A112	Classroom	14-SB-A112-S R	S	2.31	324
First	A113	Classroom	15-SB-A113-S L	S	2.73	514
First	A113	Classroom	16-SB-A113-S R	S	2.16	485
First	A114	Classroom	17-SB-A114-S L	S	1.02	366
First	A114	Classroom	18-SB-A114-S R	S	1.05	225
First	B126	Classroom	19-SB-B126-S	S	2.96	155
First	B127	Classroom	20-SB-B127-S	S	1.93	273
First	B128	Classroom	21-SB-B128-S	S	2.86	130
First	B129	Classroom	22-SB-B129-S	S	1.58	115
First	B101	Classroom	23-SB-B101-S	S	1.8	122
First	B102	Classroom	24-SB-B102-S	S	3.22	135
First	B103	Classroom	25-SB-B103-S	S	1.91	78.2
First	B104	Classroom	26-SB-B104-S	S	20.9	162
First	B105	Classroom	27-SB-B105-S	S	1.92	137
First	B106	Classroom	28-SB-B106-S	S	1.63	113
First	B107	Classroom	29-SB-B107-S	S	1.98	71.8
First	B108	Classroom	30-SB-B108-S	S	2.02	134
First	B110	Classroom	31-SB-B110-S	S	2.44	215
First	B111	Classroom	32-SB-B111-S	S	0.98	241
First	B112	Classroom	33-SB-B112-S	S	1.05	131
First	B145	Classroom	34-SB-B145-S	S	2.61	1410
First	B113	Classroom	35-SB-B113-S	S	1.55	114
First	B118	Classroom	36-SB-B118-S	S	1.29	1090
First	B119	Classroom	37-SB-B119-S	S	0.65	380
First	B120	Classroom	38-SB-B120-S	S	0.79	970
First	B121	Classroom	39-SB-B121-S	S	1.23	959
First	B135	Classroom	40-SB-B135-S	S	1.46	802
First	B136	Classroom	41-SB-B136-S	S	2.24	778
First	B137	Classroom	42-SB-B137-S	S	2.08	711
First	B138	Classroom	43-SB-B138-S	S	1.96	1060
First	-	Teacher Lounge	44-SB-Teacher Lounge-S	S	5.45	155
First	-	Nurse	45-SB-Nurse-S	S	4.75	268
First	-	Nurse RR	46-SB-Nurse RR-S	S	8.1	235
First	A119	Restroom	47-SB-A119 RR-S	S	10.7	297

Stonebridge Elementary

Copper in Drinking Water

Project #23072

