Greenwood Lake UFSD Lead Testing of School Drinking Water, 2021

All Schools in New York State are required to test their drinking water for lead every 5 years. On March 24, 2021. The Greenwood Lake UFSD authorized Orange Ulster BOCES to collect water samples from all applicable water taps as defined by the New York State Department of Health. The samples were sent to an independent certified laboratory for analysis. On Monday May 3, 2021 we received our test results. The spreadsheet below shows all test location and their test results. The allowable threshold is 15 ppb (parts per billion).

Test conducted by EnviroTest Laboratories Inc. ID# ELAP # 10142 using EPA Method 200.7/200.8

Lab Sample ID			School	Sample Location	Result
420	193912	1	Greenwood Lake Elementary School	Kitchen Pot Sink	7.57
420	193912	2	Greenwood Lake Elementary School	5 Classroom Sink	ND<1.00
420	193912	3	Greenwood Lake Elementary School	6 Classroom Sink	1.61
420	193912	4	Greenwood Lake Elementary School	7 Classroom Sink	1.80
420	193912	5	Greenwood Lake Elementary School	8 Classroom Sink	1.21
420	193912	6	Greenwood Lake Elementary School	9 Classroom Sink	2.26
420	193912	7	Greenwood Lake Elementary School	10 Classroom Sink	1.84
420	193912	8	Greenwood Lake Elementary School	Faculty Room Sink 2	1.83
420	193912	9	Greenwood Lake Elementary School	OT Classroom Sink	5.61
420	193912	10	Greenwood Lake Elementary School	Art Room Left Classroom Sink	2.33
420	193912	11	Greenwood Lake Elementary School	Art Room Right Classroom Sink	1.53
420	193912	12	Greenwood Lake Elementary School	Kitchen Dishwasher Sink	2.97
420	193912	13	Greenwood Lake Elementary School	Bathroom Faucet Outside Art Room	ND<1.00
420	193912	14	Greenwood Lake Elementary School	Bathroom Faucet Outside Library	ND<1.00
420	193912	15	Greenwood Lake Elementary School	Bathroom Faucet by Classroom 13	ND<1.00
420	193912	16	Greenwood Lake Elementary School	Kitchen Prep Sink	8.53
420	193912	17	Greenwood Lake Elementary School	Faculty Room Sink 1	1.72
420	193912	18	Greenwood Lake Elementary School	Main Office Copy Room Sink	1.50
420	193912	19	Greenwood Lake Elementary School	Nurse Sink	2.62
420	193912	20	Greenwood Lake Elementary School	2 Classroom Sink	ND<1.00
420	193912	21	Greenwood Lake Elementary School	3 Classroom Sink	1.43
420	193912	22	Greenwood Lake Elementary School	4 Classroom Sink	1.05
420	193913	1	Greenwood Lake Middle School	Kitchen Sink 1	ND<1.00
420	193913	2	Greenwood Lake Middle School	219 Classroom Sink	7.80
420	193913	3	Greenwood Lake Middle School	222 Classroom Sink	ND<1.00
420	193913	4	Greenwood Lake Middle School	223 Classroom Sink	ND<1.00
420	193913	5	Greenwood Lake Middle School	Nurse Well Room Sink	ND<1.00
420	193913	6	Greenwood Lake Middle School	Main Office Sink	ND<1.00
420	193913	7	Greenwood Lake Middle School	Nurse Sink	ND<1.00
420	193913	8	Greenwood Lake Middle School	Business Office Sink	ND<1.00
420	193913	9	Greenwood Lake Middle School	200 Classroom Sink	1.63
420	193913	10	Greenwood Lake Middle School	202 Classroom Sink	1.73
420	193913	11	Greenwood Lake Middle School	204 Classroom Sink	1.89
420	193913	12	Greenwood Lake Middle School	Kitchen Sink 2	ND<1.00
420	193913	13	Greenwood Lake Middle School	205 Classroom Sink	1.56
420	193913	14	Greenwood Lake Middle School	206 Classroom Sink	2.01
420	193913	15	Greenwood Lake Middle School	207 Classroom Sink	ND<1.00
420	193913	16	Greenwood Lake Middle School	209 Classroom Sink	ND<1.00
420	193913	17	Greenwood Lake Middle School	210 Classroom Sink	1.49
420	193913	18	Greenwood Lake Middle School	212 Classroom Sink	2.19
420	193913	19	Greenwood Lake Middle School	Kitchen Left Hand Washing Sink	30.1
420	193913	20	Greenwood Lake Middle School	Kitchen Pot Sink	1.40
420	193913	21	Greenwood Lake Middle School	124 Classroom Sink	ND<1.00
420	193913	22	Greenwood Lake Middle School	125 Classroom Sink	1.44
420	193913	23	Greenwood Lake Middle School	126 Classroom Sink	ND<1.00
420	193913	24	Greenwood Lake Middle School	127 Classroom Sink	ND<1.00
420	193913	25	Greenwood Lake Middle School	218 Classroom Sink	ND<1.00