

Barnes

LOCATION_ID	SAMPLE_ID	LOCATION	DATE	LEAD RESULT (ppb)
Barnes/27121.009	22430200-01NS22A	Health	5/25/2022	1.38
Barnes/27121.009	22430200-02CF22A	C102	5/25/2022	1.36
Barnes/27121.009	22430200-03DW22A	C102	5/25/2022	2.27
Barnes/27121.009	22430200-04CF22A	C104	5/25/2022	3.1
Barnes/27121.009	22430200-05DW22A	C104	5/25/2022	1.58
Barnes/27121.009	22430200-06CF22A	C106	5/25/2022	2.58
Barnes/27121.009	22430200-07DW22A	C106	5/25/2022	1.89
Barnes/27121.009	22430200-08DW22A	C hall, left fountain	5/25/2022	ND
Barnes/27121.009	22430200-09DW22A	C hall, right fountain	5/25/2022	ND
Barnes/27121.009	22430200-10CF22A	C108	5/25/2022	1.95
Barnes/27121.009	22430200-11DW22A	C108	5/25/2022	1.97
Barnes/27121.009	22430200-12CF22A	C115	5/25/2022	1.07
Barnes/27121.009	22430200-13DW22A	C115	5/25/2022	0.958
Barnes/27121.009	22430200-14CF22A	C113	5/25/2022	2.37
Barnes/27121.009	22430200-15DW22A	C113	5/25/2022	1.24
Barnes/27121.009	22430200-16CF22A	C111	5/25/2022	1.76
Barnes/27121.009	22430200-17DW22A	C111	5/25/2022	3.1
Barnes/27121.009	22430200-18CF22A	C109	5/25/2022	1.05
Barnes/27121.009	22430200-19DW22A	C109	5/25/2022	1.54
Barnes/27121.009	22430200-20CF22A	C107	5/25/2022	1.54
Barnes/27121.009	22430200-21DW22A	C107	5/25/2022	1.76
Barnes/27121.009	22430200-22CF22A	C105	5/25/2022	1.56
Barnes/27121.009	22430200-23CF22A	C103	5/25/2022	2.07
Barnes/27121.009	22430200-24DW22A	C103	5/25/2022	1.71
Barnes/27121.009	22430200-25CF22A	C101	5/25/2022	1.63
Barnes/27121.009	22430200-26DW22A	C101	5/25/2022	3.78
Barnes/27121.009	22430200-27CF22A	B108	5/25/2022	4.46
Barnes/27121.009	22430200-28DW22A	B108	5/25/2022	2.37
Barnes/27121.009	22430200-29CF22A	B106	5/25/2022	5.17
Barnes/27121.009	22430200-30DW22A	B106	5/25/2022	2.82
Barnes/27121.009	22430200-31CF22A	B104	5/25/2022	3.58
Barnes/27121.009	22430200-32DW22A	B104	5/25/2022	1.12
Barnes/27121.009	22430200-33CF22A	B102	5/25/2022	6.92
Barnes/27121.009	22430200-34DW22A	B102	5/25/2022	3.18
Barnes/27121.009	22430200-35CF22A	B100	5/25/2022	1.82
Barnes/27121.009	22430200-36DW22A	B100	5/25/2022	2.94
Barnes/27121.009	22430200-37KF22A	Café	5/25/2022	1.02
Barnes/27121.009	22430200-38KF22A	Kitchen	5/25/2022	0.89
Barnes/27121.009	22430200-39KF22A	Kitchen	5/25/2022	0.716
Barnes/27121.009	22430200-40CF22A	A005	5/25/2022	2.87
Barnes/27121.009	22430200-41DW22A	A005	5/25/2022	2.43
Barnes/27121.009	22430200-42CF22A	A011	5/25/2022	3.1

Barnes/27121.009	22430200-43DW22A	A011		5/25/2022	5.07
Barnes/27121.009	22430200-44CF22A	A010		5/25/2022	6.57
Barnes/27121.009	22430200-45CF22A	Low A hall		5/25/2022	0.936
Barnes/27121.009	22430200-46DW22A	Low A hall		5/25/2022	0.49
Barnes/27121.009	22430200-47CF22A	A106		5/25/2022	5.24
Barnes/27121.009	22430200-48DW22A	A106		5/25/2022	1.44
Barnes/27121.009	22430200-49CF22A	A108		5/25/2022	5.42
Barnes/27121.009	22430200-50DW22A	A108		5/25/2022	3.63
Barnes/27121.009	22430200-51CF22A	A110		5/25/2022	5.67
Barnes/27121.009	22430200-52DW22A	A110		5/25/2022	5.95
Barnes/27121.009	22430200-53CF22A	A111		5/25/2022	5.35
Barnes/27121.009	22430200-54DW22A	A111		5/25/2022	4.66
Barnes/27121.009	22430200-55CF22A	A109		5/25/2022	3.55
Barnes/27121.009	22430200-56DW22A	A109		5/25/2022	2.13
Barnes/27121.009	22430200-57CF22A	A107	<i>(restricted access)</i>	5/25/2022	167
Barnes/27121.009	22430200 57CF22B	A107	<i>(restricted access)</i>	8/4/2022	140
Barnes/27121.009	22430200 57CF22C	A107	<i>(flush sample/handwashing only)</i>	10/26/2022	3.05
Barnes/27121.009	22430200-057CF23A	A107	<i>(post-mitigation testing)</i>	8/8/2023	14.7
Barnes/27121.009	22430200-057CF23B	A107	<i>(flush sample)</i>	8/8/2023	4.19
Barnes/27121.009	22430200-58DW22A	A107	<i>(restricted access)</i>	5/25/2022	34.3
Barnes/27121.009	22430200 58DW22B	A107	<i>(restricted/removed from service)</i>	8/4/2022	52.2
Barnes/27121.009	22430200-59CF22A	A105		5/25/2022	6.53
Barnes/27121.009	22430200-60DW22A	A105		5/25/2022	1.75
Barnes/27121.009	22430200-61DW22A	West A hall, left fountain		5/25/2022	2.79
Barnes/27121.009	22430200-62DW22A	West A hall, right fountain		5/25/2022	0.789
Barnes/27121.009	22430200-63CF22A	A103		5/25/2022	3.27
Barnes/27121.009	22430200-64DW22A	A103		5/25/2022	6.25
Barnes/27121.009	22430200-65CF22A	A101		5/25/2022	1.62
Barnes/27121.009	22430200-66DW22A	A101		5/25/2022	0.72
Barnes/27121.009	22430200-67CF22A	Staff A		5/25/2022	0.954
Barnes/27121.009	22430200-68DW22A	Gym, west fountain		5/25/2022	0.554
Barnes/27121.009	22430200-69DW22A	Gym, east fountain		5/25/2022	6.37
Barnes/27121.009	22430200-70CF22A	A100		5/25/2022	2.21
Barnes/27121.009	22430200-71DW22A	A100		5/25/2022	1.27
Barnes/27121.009	22430200-72CF22A	A102		5/25/2022	5.19
Barnes/27121.009	22430200-73DW22A	A102		5/25/2022	1.53
Barnes/27121.009	22430200-74DW22A	C105		6/9/2022	39.7
Barnes/27121.009	22430200 74DW22B	C105	<i>(post-mitigation retest)</i>	8/4/2022	7.12
Barnes/27121.009	22430200-75CF22A	Office A1	<i>(restricted access)</i>	6/9/2022	20.1
Barnes/27121.009	22430200 75CF22B	Office A1	<i>(restricted access)</i>	8/4/2022	78.0
Barnes/27121.009	22430200 75CF22B	Office A1	<i>(flush sample/handwashing only)</i>	10/26/2022	1.98
Barnes/27121.009	22430200-075SF23A	Office A1	<i>(handwashing only)</i>	8/8/2023	16.2
Barnes/27121.009	22430200-075SF23B	Office A1	<i>(flush sample/handwashing only)</i>	8/8/2023	2.09