

Beaver Acres

LOCATION	SAMPLE ID	DATE	LEAD RESULT (ppb)
Kitchen North Prep Sink	22430300-001KF23A	6/8/2023	0.342
Kitchen South Prep Sink	22430300-002KF23A	6/8/2023	6.95
Cafeteria	22430300-003CF23A	6/8/2023	4.64
Cafeteria	22430300-004DW23A	6/8/2023	2.91
Staff Lounge	22430300-005SF23A	6/8/2023	1.85
Front Office Hallway	22430300-006DW23A	6/8/2023	ND
C100	22430300-007CF23A	6/8/2023	0.262
C100	22430300-008DW23A	6/8/2023	4.17
C102	22430300-009CF23A	6/8/2023	2.57
C102	22430300-010DW23A	6/8/2023	1.3
C104	22430300-011CF23A	6/8/2023	0.256
C104	22430300-012DW23A	6/8/2023	3.75
C106	22430300-013CF23A	6/8/2023	1.44
C106	22430300-014DW23A	6/8/2023	3.05
C108	22430300-015CF23A	6/8/2023	1.15
C108	22430300-016DW23A	6/8/2023	3.24
Nurses Office	22430300-017NS23A	6/8/2023	0.749
B100	22430300-018CF23A	6/8/2023	0.417
B100	22430300-019DW23A	6/8/2023	1.38
B102	22430300-020CF23A	6/8/2023	1.45
B102	22430300-021DW23A	6/8/2023	1.95
B104	22430300-022CF23A	6/8/2023	2.01
B104	22430300-023DW23A	6/8/2023	2.47
B106	22430300-024CF23A	6/8/2023	0.998
B106	22430300-025DW23A	6/8/2023	0.995
B108	22430300-026CF23A	6/8/2023	0.582
B108	22430300-027DW23A	6/8/2023	0.287
B110	22430300-028CF23A	6/8/2023	1.77
B110	22430300-029DW23A	6/8/2023	2.56
B112	22430300-030CF23A	6/8/2023	1.03
B112	22430300-031DW23A	6/8/2023	0.861
B114	22430300-032CF23A	6/8/2023	0.306
B114	22430300-033DW23A	6/8/2023	1.65
B116	22430300-034CF23A	6/8/2023	0.671
B116	22430300-035DW23A	6/8/2023	0.339
B Hall	22430300-036DW23A	6/8/2023	0.219
B120	22430300-037CF23A	6/8/2023	3.08
B120	22430300-038DW23A	6/8/2023	3.81
B122	22430300-039CF23A	6/8/2023	1.3
B122	22430300-040DW23A	6/8/2023	3.15
B124	22430300-041CF23A	6/8/2023	11
B124	22430300-042DW23A	6/8/2023	5.04
B126	22430300-043CF23A	6/8/2023	3.13
B126	22430300-044DW23A	6/8/2023	3.94

B128	22430300-045CF23A		6/8/2023	0.452
B128	22430300-046DW23A		6/8/2023	5.52
B130	22430300-047CF23A		6/8/2023	0.888
B130	22430300-048DW23A		6/8/2023	0.341
A116	22430300-049SF23A		6/8/2023	4.08
A117	22430300-050CF23A		6/8/2023	0.704
A117	22430300-051DW23A	<i>(restricted access)</i>	6/8/2023	<b>69.8</b>
A117	22430300-51DW23B	<i>(post-mitigation)</i>	8/8/2023	1.74
A117	22430300-51DW23C	<i>(post-mitigation flush)</i>	8/8/2023	0.425
A115	22430300-052CF23A		6/8/2023	1.12
A115	22430300-053DW23A		6/8/2023	5.11
A113	22430300-054CF23A		6/8/2023	2.2
A113	22430300-055DW23A		6/8/2023	6.1
A111	22430300-056CF23A		6/8/2023	1.11
A111	22430300-057DW23A	<i>(restricted access)</i>	6/8/2023	<b>18.8</b>
A111	22430300-57DW23B	<i>(post-mitigation)</i>	8/8/2023	1.62
A111	22430300-57DW23C	<i>(post-mitigation flush)</i>	8/8/2023	ND
A114	22430300-058CF23A		6/8/2023	2.31
A114	22430300-059DW23A		6/8/2023	6.48
A112	22430300-060CF23A		6/8/2023	1.91
A112	22430300-061DW23A		6/8/2023	2.5
"A" Hall North Wall Left	22430300-062DW23A		6/8/2023	0.237
"A" Hall North Wall	22430300-063DW23A		6/8/2023	0.773
A110	22430300-064CF23A		6/8/2023	0.584
A110	22430300-065DW23A		6/8/2023	3.33
A108	22430300-066CF23A		6/8/2023	0.332
A108	22430300-067DW23A		6/8/2023	1.12
A106	22430300-068CF23A		6/8/2023	2.58
A106	22430300-069DW23A		6/8/2023	1.81
"A" Hall South Wall Left	22430300-070DW23A		6/8/2023	ND
"A" Hall South Wall Right	22430300-071DW23A		6/8/2023	ND
A104	22430300-072CF23A		6/8/2023	0.904
A104	22430300-073DW23A		6/8/2023	0.901
M304	22430300-074CF23A		6/8/2023	0.463
M304	22430300-075DW23A		6/8/2023	0.986
M306	22430300-076CF23A		6/8/2023	1.04
M306	22430300-077DW23A		6/8/2023	0.566
M308	22430300-078CF23A		6/8/2023	2.2
M308	22430300-079DW23A		6/8/2023	0.306
M310	22430300-080CF23A		6/8/2023	0.444
M312	22430300-082DW23A		6/8/2023	0.528
M312	22430300-083CF23A		6/8/2023	0.462
M314	22430300-084DW23A		6/8/2023	0.386
M314	22430300-085CF23A		6/8/2023	0.937
"M" Hall	22430300-086DW23A		6/8/2023	0.438
Gym	22430300-087DW23A		6/8/2023	ND
Music	22430300-088CF23A		6/8/2023	0.544

Music	22430300-089DW23A	6/8/2023	1.09
IT Therapy	22430300-090DW23A	6/8/2023	1.39
IT Therapy	22430300-091CF23A	6/8/2023	0.528
M310	22430300-081DW23A	6/16/2023	0.689