

Erroll Hassell

Fixture Number	Sample Number	Building	Location / Room No.	Fixture Type	Results (ppb)
001	22401161-001SF21A	Main	Health Room	Health Room Sink	3.11
002	22431161-002SF21A	Main	Staff Kitchen	Sink Faucet	0.513
003	22431161-003KF21A	Main	Kitchen	Prep Sink	2.62
004	22431161-004KF21A	Main	Kitchen	Steam Kettle	1.34
005	22431161-005CF21A	Main	B-114	Classroom Faucet	10.9
006	22431161-006DW21A	Main	B-114	Drinking Fountain	7.13
007	22431161-007CF21A	Main	B-112	Classroom Faucet	8.49
008	22431161-008DW21A	Main	B-112	Drinking Fountain	3.62
009	22431161-009CF21A	Main	B-110	Classroom Faucet	2.89
010	22431161-010DW21A	Main	B-110	Drinking Fountain	3.34
011	22431161-011CF21A	Main	B-104	Classroom Faucet	3.59
012	22431161-012DW21A	Main	B-104	Drinking Fountain	1.02
013	22431161-013CF21A	Main	B-102	Classroom Faucet	15.9
013	22431161-013CF21B	Main	B-102	Classroom Faucet (post mitigation)	2.32
014	22431161-014DW21A	Main	B-102	Drinking Fountain	4.71
015	22431161-015CF21A	Main	B-100	Classroom Faucet	19.9
015	22431161-015CF21B	Main	B-100	Classroom Faucet (post mitigation)	5.62
016	22431161-016DW21A	Main	B-100	Drinking Fountain	5.72
017	22431161-017SF21A	Main	Workroom B	Staffroom Sink Faucet	5.02
018	22431161-018DW21A	Main	Workroom B	Drinking Fountain	1.89
019	22431161-019CF21A	Main	M-106	Classroom Faucet	16.1
020	22431161-020DW21A	Main	M-106	Drinking Fountain	4.34
021	22431161-021CF21A	Main	M-104 (out of service)	Classroom Faucet	16.7
021	22431161-021CF21B	Main	M-104 (out of service)	Classroom Faucet - Follow Up	19.5
	22430800-03CF22A	Main	M-104 (out of service)	Classroom Faucet - Follow Up	325
	22433300-003CF23A	Main	M-104 (out of service)	Classroom Faucet - Follow Up	25.6
	22433300-003CF23B	Main	M-104 (out of service, flush sample)	Classroom Faucet - Flush	0.4
	22430900-003CF23C	Main	M-104 (post-mitigation)	Classroom Faucet (post-mitigation)	12.3
	22430900-003CF23D	Main	M-104 (post-mitigation flush sample)	Classroom Faucet	0.701
022	22431161-022DW21A	Main	M-104 (out of service)	Drinking Fountain	6.1
	22430800-02DW22A	Main	M-104 (out of service)	Drinking Fountain - Follow Up	70.6
	22430800-02DW22C	Main	M-104 (out of service)	Drinking Fountain - Follow Up	140
	22433300-002DW23A	Main	M-104 (out of service)	Drinking Fountain - Follow Up	26.4
	22433300-002DW23B	Main	M-104 (out of service/removed permanently)	Drinking Fountain - Follow Up	37.6
023	22431161-023CF21A	Main	M-102	Classroom Faucet	2.44
024	22431161-024DW21A	Main	M-102	Drinking Fountain	1.98
025	22431161-025CF21A	Main	M-100	Classroom Faucet	25.2
025	22431161-025CF21B	Main	M-100 (post-mitigation)	Classroom Faucet (post mitigation)	3.03
026	22431161-026DW21A	Main	M-100	Drinking Fountain	29.7
026	22431161-026DW21B	Main	M-100	Drinking Fountain (post mitigation)	2.39
027	22431161-027DW21A	Main	Hall	Drinking Fountain	0.652
028	22431161-028DW21A	Main	Gym	Drinking Fountain	2.84
029	22431161-029WC21A	Main	Staff Breakroom	Water Cooler on Fridge	1.55
030	22431161-030CF21A	Main	A-100	Classroom Faucet	7.53
031	22431161-031DW21A	Main	A-100	Drinking Fountain	5.11
032	22431161-032CF21A	Main	A-102	Classroom Faucet	12
033	22431161-033DW21A	Main	A-102	Drinking Fountain	4.8
034	22431161-034CF21A	Main	A-104	Classroom Faucet	12.5
035	22431161-035DW21A	Main	A-104	Drinking Fountain	3.28
036	22431161-036CF21A	Main	A-106	Classroom Faucet	1.17
037	22431161-037DW21A	Main	A-106	Drinking Fountain	3.02
038	22431161-038CF21A	Main	A-108	Classroom Faucet	9.78

039	22431161-039DW21A	Main	A-108	Drinking Fountain	4.53
040	22431161-040CF21A	Main	A-110	Classroom Faucet	1.92
041	22431161-041DW21A	Main	A-110	Drinking Fountain	1.71
042	22431161-042CF21A	Main	A-112	Classroom Faucet	11.1
043	22431161-043CF21A	Main	A-114	Classroom Faucet	6.8
044	22431161-044DW21A	Main	A-114	Drinking Fountain	3.45
045	22431161-045CF21A	Main	A-116	Classroom Faucet	1.31
046	22431161-046DW21A	Main	A-116	Drinking Fountain	0.451
047	22431161-047CF21A	Main	A-118	Classroom Faucet	10.5
048	22431161-048DW21A	Main	A-118	Drinking Fountain	2.21
049	22431161-049CF21A	Main	A-120	Classroom Faucet	8.38
050	22431161-050DW21A	Main	A-120	Drinking Fountain	1.26
051	22431161-051CF21A	Main	A-122	Classroom Faucet	8.09
052	22431161-052DW21A	Main	A-122	Drinking Fountain	7.49
053	22431161-053CF21A	Main	A-124	Classroom Faucet	6.11
054	22431161-054DW21A	Main	A-124	Drinking Fountain	3.38
055	22431161-055KF21A	Main	Kitchen	Dish Room Prep Sink	ND
056	22431161-056CF21A	Main	A-126	Classroom Faucet	0.344
-	22430900-004DW23A	Main	Modular Hallway	Drinking Fountain	1.61
-	22430900-004DW23B	Main	Modular Hallway (<i>flush sample</i>)	Drinking Fountain	0.74