

FINAL REPORT

SOLID BLEND TECHNOLOGIES

DOUG DOLDER
10 GRANITE DR.
DAYTON, OH 45415 USA
Phone No:

Customer No: 11849_01
Q Labs Order: 0712166
Report Date: July 16, 2023
Purchase Order: Oakwood Smith 34698

<u>Test</u>	<u>Methodology</u>
Legionella	Centers for Disease Control (01/2005)
Client Sample ID:	Kitchen Sprayer sink CDC Hot, 107, 7.96, 0.04, 9:20am
Q Labs Sample ID:	0712166-1001
Date Received:	7/7/2023
Parameter	Sample Result Specification Comment
CDC Legionella Result	None Detected /250 mL
Client Sample ID:	Kitchen Sink #2 CDC Hot, 121, 7.78, 0.00, 9:24am
Q Labs Sample ID:	0712166-1002
Date Received:	7/7/2023
Parameter	Sample Result Specification Comment
CDC Legionella Result	None Detected /250 mL
Client Sample ID:	Rm 206 Sink CDC Hot, 118, 7.79, 0.03, 9:27am
Q Labs Sample ID:	0712166-1003
Date Received:	7/7/2023
Parameter	Sample Result Specification Comment
CDC Legionella Result	None Detected /250 mL
Client Sample ID:	Rm 212 Sink CDC Hot, 112, 7.81, 0.07, 9:30am
Q Labs Sample ID:	0712166-1004
Date Received:	7/7/2023
Parameter	Sample Result Specification Comment
CDC Legionella Result	None Detected /250 mL
Client Sample ID:	GRR by Rm 209 sink #1 CDC Hot, 108, 7.89, 0.06, 9:36am
Q Labs Sample ID:	0712166-1005
Date Received:	7/7/2023
Parameter	Sample Result Specification Comment
CDC Legionella Result	None Detected /250 mL
Client Sample ID:	Rm 300 sink CDC Hot, 111, 7.84, 0.04, 9:42am
Q Labs Sample ID:	0712166-1006
Date Received:	7/7/2023
Parameter	Sample Result Specification Comment
CDC Legionella Result	None Detected /250 mL
Client Sample ID:	Preschool RR Sink #2 Mix, 97.3, 7.79, 0.01, 9:47am
Q Labs Sample ID:	0712166-1007
Date Received:	7/7/2023
Parameter	Sample Result Specification Comment
CDC Legionella Result	None Detected /250 mL
Client Sample ID:	Rm 103 RR2 Sink CDC Hot, 123, 7.80, 0.00, 9:53am
Q Labs Sample ID:	0712166-1008
Date Received:	7/7/2023
Parameter	Sample Result Specification Comment
CDC Legionella Result	None Detected /250 mL



Client Sample ID:	Storage by 301 Sink CDC Hot, 102, 7.82, 0.08, 9:59am		
Q Labs Sample ID:	0712166-1009	Date Received:	7/7/2023
Parameter		Sample Result	Specification Comment
CDC Legionella Result		None Detected /250 mL	
Client Sample ID:	Rm 318 Sink CDC Hot, 96.8, 8.00, 0.02, 10:03am		
Q Labs Sample ID:	0712166-1010	Date Received:	7/7/2023
Parameter		Sample Result	Specification Comment
CDC Legionella Result		None Detected /250 mL	
Client Sample ID:	GRR by gym sink #1 CDC Hot, 81.3, 7.91, 0.03, 10:07am		
Q Labs Sample ID:	0712166-1011	Date Received:	7/7/2023
Parameter		Sample Result	Specification Comment
CDC Legionella Result		None Detected /250 mL	
Client Sample ID:	BRR by gym sink #1 CDC Hot, 87.2, 7.95, 0.00, 10:12am		
Q Labs Sample ID:	0712166-1012	Date Received:	7/7/2023
Parameter		Sample Result	Specification Comment
CDC Legionella Result		None Detected /250 mL	

Results Electronically Approved By:

Judy Bosley

QA Microbiologist

7/16/2023 7:51:13 PM

The results on this report relate only to the sample(s) submitted for testing at Q Laboratories. These results were obtained from sample(s) submitted in good condition unless otherwise noted above. This report should not be reproduced except in full, without the approval of the laboratory.



Q Laboratories

Legionella Sample Submission Form

1930 Radcliff Dr. Cincinnati, OH 45204
Phone: (513) 471-1300 • Fax: (513) 471-5600
• www.QLABORATORIES.com

• Email: office@qlaboratories.com

Customer Information

Company Name: Solid Blend Technologies, Inc.
Report Results To: Doug Dolder
Street Address: 10 Grante Dr
City, State, Zip: Dayton, OH 45415
Phone #: 937-264-8453

Please list option(s) for receiving results ONLY (electronic documents will be in Adobe Acrobat (PDF) format).
Email to: info@solidblendtechnologies.com ddolder@solidblendtechnologies.com;
cmiller@solidblendtechnologies.com

Date Submitted: 7/16/23
Billing Contact (if different):
Billing Email:
Street Address:
City, State, Zip:
Phone #:
Project Identifier: Oakwood Smith 34698
☒ Routine Monitoring ☐ Case Investigation

Sample # Location ID	Sample ID	Temp (°F)	pH	Free Cl (ppm)	Time Collected	Sample Type				Legionella Analysis				In the event of a PCR/qPCR positive perform Cultural Isolation	
						Swab	Non-Potable 100 mL	Potable 250 mL	Potable 1 L	CDC	PCR	qPCR	Yes	No	
1A	Kitchen Sprayer sink catch	101	7.94	0.04	9:20 am/pm	☐	☐	☒	☐	☒	☐	☐	☐	☐	
2A	Kitchen Sink #2 catch	121	7.78	0.00	9:24 am/pm	☐	☐	☒	☐	☒	☐	☐	☐	☐	
3A	Rm 206 Sink catch	118	7.79	0.03	9:27 am/pm	☐	☐	☒	☐	☒	☐	☐	☐	☐	
4A	Rm 212 Sink catch	112	7.81	0.07	9:30 am/pm	☐	☐	☒	☐	☒	☐	☐	☐	☐	
5A	GRR by Rm 209 sink #1 catch	108	7.89	0.06	9:36 am/pm	☐	☐	☒	☐	☒	☐	☐	☐	☐	
6A	Rm 300 Sink catch	111	7.84	0.04	9:42 am/pm	☐	☐	☒	☐	☒	☐	☐	☐	☐	
7A	Freshwater Sink #2 mix	97.3	7.79	0.01	9:47 am/pm	☐	☐	☒	☐	☒	☐	☐	☐	☐	
8A	Rm 103 RRR Sink catch	123	7.80	0.00	9:53 am/pm	☐	☐	☒	☐	☒	☐	☐	☐	☐	
9A	Storage by 301 Sink catch	102	7.82	0.08	9:59 am/pm	☐	☐	☒	☐	☒	☐	☐	☐	☐	
10A	Rm 318 Sink catch	96.8	8.00	0.02	10:03 am/pm	☐	☐	☒	☐	☒	☐	☐	☐	☐	
11A	GRR by gym Sink #1 catch	81.3	7.91	0.03	10:07 am/pm	☐	☐	☒	☐	☒	☐	☐	☐	☐	
12A	BRR by gym Sink #1 catch	87.2	7.95	0.00	10:12 am/pm	☐	☐	☒	☐	☒	☐	☐	☐	☐	
Special Instructions:															

Page 3 of 3

Completed and signed sample submission form indicates agreement with Q Laboratories terms and conditions and authorizes Q Laboratories to perform the requested tests.

Authorizing Signature:

[Signature]