

FINAL REPORT

SOLID BLEND TECHNOLOGIES

DOUG DOLDER
10 GRANITE DR.
DAYTON, OH 45415 USA
Phone No:

Customer No: 11849_01
Q Labs Order: 0713026
Report Date: July 20, 2023
Purchase Order: Oakwood Harman 34699

Test	Methodology		
Legionella	Centers for Disease Control (01/2005)		
Client Sample ID:	L1 Rm 46 Sink CDC HOT, 103, 7.87, 0.04, 10:05am		
Q Labs Sample ID:	0713026-1001	Date Received:	7/12/2023
Parameter	Sample Result	Specification	Comment
CDC Legionella Result	None Detected /250 mL		
Client Sample ID:	L1 Rm 52 Sink CDC HOT, 72.4, 7.79, 0.11, 10:04am		
Q Labs Sample ID:	0713026-1002	Date Received:	7/12/2023
Parameter	Sample Result	Specification	Comment
CDC Legionella Result	None Detected /250 mL		
Client Sample ID:	L1 Music Rm 32 Sink CDC HOT, 76.7, 7.81, 0.03, 10:18am		
Q Labs Sample ID:	0713026-1003	Date Received:	7/12/2023
Parameter	Sample Result	Specification	Comment
CDC Legionella Result	None Detected /250 mL		
Client Sample ID:	L1 GRR by Stair E Sink #2 mixed, 97.8, 7.91, 0.15, 10:23am		
Q Labs Sample ID:	0713026-1004	Date Received:	7/12/2023
Parameter	Sample Result	Specification	Comment
CDC Legionella Result	None Detected /250 mL		
Client Sample ID:	L1 Rm 36 Sink CDC HOT, 87.4, 7.92, 0.05, 10:26am		
Q Labs Sample ID:	0713026-1005	Date Received:	7/12/2023
Parameter	Sample Result	Specification	Comment
CDC Legionella Result	None Detected /250 mL		
Client Sample ID:	L1 Kitchen Sink #1 food prep sink CDC HOT, 93.2, 7.80, 0.00, 10:29am		
Q Labs Sample ID:	0713026-1006	Date Received:	7/12/2023
Parameter	Sample Result	Specification	Comment
CDC Legionella Result	None Detected /250 mL		
Client Sample ID:	L1 Kitchen sink #4 CDC HOT, 97.2, 7.71, 0.00, 10:33am		
Q Labs Sample ID:	0713026-1007	Date Received:	7/12/2023
Parameter	Sample Result	Specification	Comment
CDC Legionella Result	Positive /250 mL		Legionella pneumophila
L. pneumophila SG 1 Result	Positive		
Legionella Concentration (per mL)	23 CFU/mL		
Legionella Concentration (per 250 mL)	5800 CFU/250 mL		
Client Sample ID:	L2 Rm 1 RR Sink CDC HOT, 71.2, 7.99, 0.00, 10:38am		
Q Labs Sample ID:	0713026-1008	Date Received:	7/12/2023
Parameter	Sample Result	Specification	Comment
CDC Legionella Result	None Detected /250 mL		



Client Sample ID:	L2 Rm 7 Sink CDC HOT, 109, 7.67, 0.03, 10:42am		
Q Labs Sample ID:	0713026-1009	Date Received:	7/12/2023
Parameter		Sample Result	Specification Comment
CDC Legionella Result		None Detected /250 mL	
Client Sample ID:	L2 Rm 11 Sink CDC HOT, 107, 7.69, 0.07, 10:45am		
Q Labs Sample ID:	0713026-1010	Date Received:	7/12/2023
Parameter		Sample Result	Specification Comment
CDC Legionella Result		None Detected /250 mL	
Client Sample ID:	L2 Rm 16 Sink CDC HOT, 126, 7.52, 0.00, 10:48am		
Q Labs Sample ID:	0713026-1011	Date Received:	7/12/2023
Parameter		Sample Result	Specification Comment
CDC Legionella Result		None Detected /250 mL	
Client Sample ID:	L2 Rm 19 Sink CDC HOT, 129, 7.50, 0.00, 10:51am		
Q Labs Sample ID:	0713026-1012	Date Received:	7/12/2023
Parameter		Sample Result	Specification Comment
CDC Legionella Result		None Detected /250 mL	

Results Electronically Approved By:

Amanda Clarkston

QA Microbiologist

7/20/2023 10:11:33 AM

The results on this report relate only to the sample(s) submitted for testing at Q Laboratories. These results were obtained from sample(s) submitted in good condition unless otherwise noted above. This report should not be reproduced except in full, without the approval of the laboratory.



Q Laboratories Legionella Sample Submission Form

1930 Radcliff Dr. Cincinnati, OH 45204
Phone: (513) 471-1300 • Fax: (513) 471-5600
• www.QLABORATORIES.com
• Email: office@qlaboratories.com

Customer Information				Date Submitted: 7/11/23
Company Name: Solid Blend Technologies, Inc.				Billing Contact (if different):
Report Results To: Doug Dolder				Billing Email:
Street Address: 10 Granite Dr				Street Address:
City, State, Zip: Dayton, OH 45415				City, State, Zip:
Phone #: 937-264-8453				Phone #:
Please List option(s) for receiving results ONLY (electronic documents will be in Adobe Acrobat (PDF) format).				Project Identifier: Oakwood Hurman 34699
Email to: info@solidblendtechnologies.com ddolder@solidblendtechnologies.com;				☒ Routine Monitoring ☐ Case Investigation
cmiller@solidblendtechnologies.com				

Sample # Location ID	Sample ID	Temp (°F)	pH	Free Cl (ppm)	Time Collected	Sample Type				Legionella Analysis			In the event of a PCR/qPCR positive perform Cultural Isolation	
						Swab	Non-Potable 100 mL	Potable 250 mL	Potable 1 L	CDC	PCR	qPCR	Yes	No
1C	L1 Rm 46 Sink cdc hot	103	7.87	0.04	10:05 am/pm	☐	☐	☒	☐	☒	☐	☐	☐	☐
2C	L1 Rm 57 Sink cdc hot	72.4	7.79	0.11	10:14 am/pm	☐	☐	☒	☐	☒	☐	☐	☐	☐
3C	L1 Music Rm Sink cdc hot	76.1	7.81	0.03	10:18 am/pm	☐	☐	☒	☐	☒	☐	☐	☐	☐
4C	L1 GALL by Stair E Sink 2 mixed	97.8	7.91	0.15	10:23 am/pm	☐	☐	☒	☐	☒	☐	☐	☐	☐
5C	L1 Rm 34 Sink cdc hot	87.4	7.92	0.05	10:26 am/pm	☐	☐	☒	☐	☒	☐	☐	☐	☐
6C	L1 Kitchen Sink #1 Food prep sink cdc hot	93.2	7.80	0.00	10:29 am/pm	☐	☐	☒	☐	☒	☐	☐	☐	☐
7C	L1 Kitchen Sink #4 cdc hot	97.2	7.71	0.00	10:33 am/pm	☐	☐	☒	☐	☒	☐	☐	☐	☐
8C	L2 Rm 1 R2 Sink cdc hot	71.2	7.99	0.00	10:38 am/pm	☐	☐	☒	☐	☒	☐	☐	☐	☐
9C	L2 Rm 7 Sink cdc hot	109	7.67	0.03	10:42 am/pm	☐	☐	☒	☐	☒	☐	☐	☐	☐
10C	L2 Rm 11 Sink cdc hot	107	7.69	0.01	10:45 am/pm	☐	☐	☒	☐	☒	☐	☐	☐	☐
11C	L2 Rm 16 Sink cdc hot	126	7.52	0.00	10:48 am/pm	☐	☐	☒	☐	☒	☐	☐	☐	☐
12C	L2 Rm 19 Sink cdc hot	129	7.50	0.00	10:51 am/pm	☐	☐	☒	☐	☒	☐	☐	☐	☐
Special Instructions:														

Special Instructions:

Completed and signed sample submission form indicates agreement with Q Laboratories terms and conditions and authorizes Q Laboratories to perform the requested tests.

Authorizing Signature: