

ANALYTICAL REPORT

Job Number: 420-195975-1

SDG Number: Seymour Smith ILC

Job Description: Pine Plains CSD

For:

Pine Plains CSD
2829 Church Street
Pine Plains, NY 12567

Attention: Richard McKibben



Mary Hernandez

Customer Service Manager

reports@envirotestlaboratories.com

07/01/2021

NYSDOH ELAP does not certify for all parameters. EnviroTest Laboratories does hold certification for all analytes where certification is offered by ELAP unless otherwise specified in the Certification Information section of this report. Pursuant to NELAP, this report may not be reproduced, except in full, without written approval of the laboratory. EnviroTest Laboratories LLC certifies that the analytical results contained herein apply only to the samples tested as received by our laboratory. All questions regarding this report should be directed to the EnviroTest Customer Service Representative. All services performed by EnviroTest Laboratories LLC are subject to our Terms and Conditions available at Envirotestlabs/terms.com. As of 12/23/19, EnviroTest Laboratories LLC acquired substantially all of the lab and testing assets of EnviroTest Laboratories Inc, including its name.

EnviroTest Laboratories, LLC. Certifications and Approvals: NYSDOH 10142, NJDEP NY015, CTDOPH PH-0554

Envirotest Laboratories

315 Fullerton Avenue, Newburgh, NY 12550

Tel (845) 562-0890 Fax (845) 562-0841 www.envirotestlaboratories.com

METHOD SUMMARY

Client: Pine Plains CSD

Job Number: 420-195975-1
SDG Number: Seymour Smith ILC

Description	Lab Location	Method	Preparation Method
Matrix: Water			
ICPMS Metals by 200.8	EnvTest	EPA 200.8 Rev.5.4	
200 Series Drinking Water Prep Determination Step	EnvTest		EPA 200.7/200.8

Lab References:

EnvTest = EnviroTest

Method References:

EPA = US Environmental Protection Agency

METHOD / ANALYST SUMMARY

Client: Pine Plains CSD

Job Number: 420-195975-1
SDG Number: Seymour Smith ILC

Method	Analyst	Analyst ID
EPA 200.8 Rev.5.4	Luis, Carlos	CL

SAMPLE SUMMARY

Client: Pine Plains CSD

Job Number: 420-195975-1
SDG Number: Seymour Smith ILC

Lab Sample ID	Client Sample ID	Client Matrix	Date/Time Sampled	Date/Time Received
420-195975-1	315 Fountain	Drinking Water	04/24/2021 0742	04/26/2021 1600
420-195975-2	3 Boys Room A	Drinking Water	04/24/2021 0744	04/26/2021 1600
420-195975-3	3 Boys Room B	Drinking Water	04/24/2021 0745	04/26/2021 1600
420-195975-4	321	Drinking Water	04/24/2021 0747	04/26/2021 1600
420-195975-5	305	Drinking Water	04/24/2021 0750	04/26/2021 1600
420-195975-6	Student HQ	Drinking Water	04/24/2021 0752	04/26/2021 1600
420-195975-7	308	Drinking Water	04/24/2021 0755	04/26/2021 1600
420-195975-8	3 Girls Rm A	Drinking Water	04/24/2021 0759	04/26/2021 1600
420-195975-9	3 Girls Rm B	Drinking Water	04/24/2021 0800	04/26/2021 1600
420-195975-10	Fountain @307	Drinking Water	04/24/2021 0802	04/26/2021 1600
420-195975-11	Fountain @201	Drinking Water	04/24/2021 0815	04/26/2021 1600
420-195975-12	2 Girls Rm A	Drinking Water	04/24/2021 0817	04/26/2021 1600
420-195975-13	2 Girls Rm B	Drinking Water	04/24/2021 0818	04/26/2021 1600
420-195975-14	210	Drinking Water	04/24/2021 0823	04/26/2021 1600
420-195975-15	205A	Drinking Water	04/24/2021 0825	04/26/2021 1600
420-195975-16	205B	Drinking Water	04/24/2021 0827	04/26/2021 1600
420-195975-17	205C	Drinking Water	04/24/2021 0828	04/26/2021 1600
420-195975-18	2 Boys Rm A	Drinking Water	04/24/2021 0837	04/26/2021 1600
420-195975-19	2 Boys Rm B	Drinking Water	04/24/2021 0839	04/26/2021 1600
420-195975-20	Fountain @ 215	Drinking Water	04/24/2021 0841	04/26/2021 1600
420-195975-21	226 Classroom	Drinking Water	04/24/2021 0844	04/26/2021 1600
420-195975-22	226 Bathroom	Drinking Water	04/24/2021 0846	04/26/2021 1600
420-195975-23	125 Classroom	Drinking Water	04/24/2021 0852	04/26/2021 1600
420-195975-24	125 Bathroom A	Drinking Water	04/24/2021 0854	04/26/2021 1600
420-195975-25	125 Bathroom B	Drinking Water	04/24/2021 0856	04/26/2021 1600
420-195975-26	125 Fountain	Drinking Water	04/24/2021 0858	04/26/2021 1600
420-195975-27	126 Classroom	Drinking Water	04/24/2021 0903	04/26/2021 1600
420-195975-28	126 Fountain	Drinking Water	04/24/2021 0904	04/26/2021 1600
420-195975-29	126 Bathroom	Drinking Water	04/24/2021 0911	04/26/2021 1600
420-195975-30	120 Fountain	Drinking Water	04/24/2021 0915	04/26/2021 1600
420-195975-31	120 Bathroom	Drinking Water	04/24/2021 0917	04/26/2021 1600
420-195975-32	Boys Fountain	Drinking Water	04/24/2021 0919	04/26/2021 1600
420-195975-33	1 Boys Rm A	Drinking Water	04/24/2021 0924	04/26/2021 1600
420-195975-34	1 Boys Rm B	Drinking Water	04/24/2021 0926	04/26/2021 1600
420-195975-35	III	Drinking Water	04/24/2021 0929	04/26/2021 1600
420-195975-36	Clinic Bathroom	Drinking Water	04/24/2021 0933	04/26/2021 1600
420-195975-37	Clinic Sink	Drinking Water	04/24/2021 0935	04/26/2021 1600
420-195975-38	116	Drinking Water	04/24/2021 0938	04/26/2021 1600
420-195975-39	107	Drinking Water	04/24/2021 0941	04/26/2021 1600
420-195975-40	1 Girls Fountain	Drinking Water	04/24/2021 0945	04/26/2021 1600
420-195975-41	1 Girls BR A	Drinking Water	04/24/2021 0947	04/26/2021 1600
420-195975-42	1 Girls BR B	Drinking Water	04/24/2021 0948	04/26/2021 1600
420-195975-43	Cafeteria Fountain	Drinking Water	04/24/2021 0951	04/26/2021 1600
420-195975-44	Island Sink	Drinking Water	04/24/2021 0953	04/26/2021 1600
420-195975-45	Kitchen Sink A	Drinking Water	04/24/2021 0956	04/26/2021 1600
420-195975-46	Kitchen Sink B	Drinking Water	04/24/2021 0958	04/26/2021 1600

SAMPLE SUMMARY

Client: Pine Plains CSD

Job Number: 420-195975-1
SDG Number: Seymour Smith ILC

Lab Sample ID	Client Sample ID	Client Matrix	Date/Time Sampled	Date/Time Received
420-195975-47	Auditorium BR Girls	Drinking Water	04/24/2021 1002	04/26/2021 1600
420-195975-48	109	Drinking Water	04/24/2021 1005	04/26/2021 1600
420-195975-49	109 Bathroom	Drinking Water	04/24/2021 1006	04/26/2021 1600
420-195975-50	Gym Fountain A	Drinking Water	04/24/2021 1010	04/26/2021 1600
420-195975-51	Gym Fountain B	Drinking Water	04/24/2021 1017	04/26/2021 1600
420-195975-52	114	Drinking Water	04/24/2021 1020	04/26/2021 1600
420-195975-53	Auditorium BR Mens	Drinking Water	04/24/2021 1022	04/26/2021 1600
420-195975-54	119	Drinking Water	04/24/2021 1024	04/26/2021 1600

Richard McKibben
Pine Plains CSD
2829 Church Street
Pine Plains, NY 12567

Job Number: 420-195975-1
Sdg Number: Seymour Smith ILC

Client Sample ID: 315 Fountain
Lab Sample ID: 420-195975-1

Date Sampled: 04/24/2021 0742
Date Received: 04/26/2021 1600
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/29/2021 1328	
Prep Method: 200.7/200.8			Date Prepared:	06/28/2021 0900	
Lead	<1.0	ug/L	1.0	1.0	1.0

Richard McKibben
Pine Plains CSD
2829 Church Street
Pine Plains, NY 12567

Job Number: 420-195975-1
Sdg Number: Seymour Smith ILC

Client Sample ID: 3 Boys Room A
Lab Sample ID: 420-195975-2

Date Sampled: 04/24/2021 0744
Date Received: 04/26/2021 1600
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/29/2021 1335	
Prep Method: 200.7/200.8			Date Prepared:	06/28/2021 0900	
Lead	4.1	ug/L	1.0	1.0	1.0

Richard McKibben
Pine Plains CSD
2829 Church Street
Pine Plains, NY 12567

Job Number: 420-195975-1
Sdg Number: Seymour Smith ILC

Client Sample ID: 3 Boys Room B
Lab Sample ID: 420-195975-3

Date Sampled: 04/24/2021 0745
Date Received: 04/26/2021 1600
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/29/2021 1343	
Prep Method: 200.7/200.8			Date Prepared:	06/28/2021 0900	
Lead	6.0	ug/L	1.0	1.0	1.0

Richard McKibben
Pine Plains CSD
2829 Church Street
Pine Plains, NY 12567

Job Number: 420-195975-1
Sdg Number: Seymour Smith ILC

Client Sample ID: 321
Lab Sample ID: 420-195975-4

Date Sampled: 04/24/2021 0747
Date Received: 04/26/2021 1600
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/29/2021 1346	
Prep Method: 200.7/200.8			Date Prepared:	06/28/2021 0900	
Lead	17 g	ug/L	1.0	1.0	1.0

Richard McKibben
Pine Plains CSD
2829 Church Street
Pine Plains, NY 12567

Job Number: 420-195975-1
Sdg Number: Seymour Smith ILC

Client Sample ID: 305
Lab Sample ID: 420-195975-5

Date Sampled: 04/24/2021 0750
Date Received: 04/26/2021 1600
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/29/2021 1348	
Prep Method: 200.7/200.8			Date Prepared:	06/28/2021 0900	
Lead	11	ug/L	1.0	1.0	1.0

Richard McKibben
Pine Plains CSD
2829 Church Street
Pine Plains, NY 12567

Job Number: 420-195975-1
Sdg Number: Seymour Smith ILC

Client Sample ID: Student HQ
Lab Sample ID: 420-195975-6

Date Sampled: 04/24/2021 0752
Date Received: 04/26/2021 1600
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/29/2021 1350	
Prep Method: 200.7/200.8			Date Prepared:	06/28/2021 0900	
Lead	18 g	ug/L	1.0	1.0	1.0

Richard McKibben
Pine Plains CSD
2829 Church Street
Pine Plains, NY 12567

Job Number: 420-195975-1
Sdg Number: Seymour Smith ILC

Client Sample ID: 308
Lab Sample ID: 420-195975-7

Date Sampled: 04/24/2021 0755
Date Received: 04/26/2021 1600
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/29/2021 1352	
Prep Method: 200.7/200.8			Date Prepared:	06/28/2021 0900	
Lead	9.4	ug/L	1.0	1.0	1.0

Richard McKibben
Pine Plains CSD
2829 Church Street
Pine Plains, NY 12567

Job Number: 420-195975-1
Sdg Number: Seymour Smith ILC

Client Sample ID: 3 Girls Rm A
Lab Sample ID: 420-195975-8

Date Sampled: 04/24/2021 0759
Date Received: 04/26/2021 1600
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/29/2021 1354	
Prep Method: 200.7/200.8			Date Prepared:	06/28/2021 0900	
Lead	6.5	ug/L	1.0	1.0	1.0

Richard McKibben
Pine Plains CSD
2829 Church Street
Pine Plains, NY 12567

Job Number: 420-195975-1
Sdg Number: Seymour Smith ILC

Client Sample ID: 3 Girls Rm B
Lab Sample ID: 420-195975-9

Date Sampled: 04/24/2021 0800
Date Received: 04/26/2021 1600
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/29/2021 1401	
Prep Method: 200.7/200.8			Date Prepared:	06/28/2021 0900	
Lead	9.4	ug/L	1.0	1.0	1.0

Richard McKibben
Pine Plains CSD
2829 Church Street
Pine Plains, NY 12567

Job Number: 420-195975-1
Sdg Number: Seymour Smith ILC

Client Sample ID: Fountain @307
Lab Sample ID: 420-195975-10

Date Sampled: 04/24/2021 0802
Date Received: 04/26/2021 1600
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/29/2021 1403	
Prep Method: 200.7/200.8			Date Prepared:	06/28/2021 0900	
Lead	3.0	ug/L	1.0	1.0	1.0

Richard McKibben
Pine Plains CSD
2829 Church Street
Pine Plains, NY 12567

Job Number: 420-195975-1
Sdg Number: Seymour Smith ILC

Client Sample ID: Fountain @201
Lab Sample ID: 420-195975-11

Date Sampled: 04/24/2021 0815
Date Received: 04/26/2021 1600
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4				Date Analyzed:	06/29/2021 1405	
Prep Method: 200.7/200.8				Date Prepared:	06/28/2021 0900	
Lead	140	g	ug/L	1.0	1.0	1.0

Richard McKibben
Pine Plains CSD
2829 Church Street
Pine Plains, NY 12567

Job Number: 420-195975-1
Sdg Number: Seymour Smith ILC

Client Sample ID: 2 Girls Rm A
Lab Sample ID: 420-195975-12

Date Sampled: 04/24/2021 0817
Date Received: 04/26/2021 1600
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/29/2021 1407	
Prep Method: 200.7/200.8			Date Prepared:	06/28/2021 0900	
Lead	6.5	ug/L	1.0	1.0	1.0

Richard McKibben
Pine Plains CSD
2829 Church Street
Pine Plains, NY 12567

Job Number: 420-195975-1
Sdg Number: Seymour Smith ILC

Client Sample ID: 2 Girls Rm B
Lab Sample ID: 420-195975-13

Date Sampled: 04/24/2021 0818
Date Received: 04/26/2021 1600
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/29/2021 1412	
Prep Method: 200.7/200.8			Date Prepared:	06/28/2021 0900	
Lead	7.0	ug/L	1.0	1.0	1.0

Richard McKibben
Pine Plains CSD
2829 Church Street
Pine Plains, NY 12567

Job Number: 420-195975-1
Sdg Number: Seymour Smith ILC

Client Sample ID: 210
Lab Sample ID: 420-195975-14

Date Sampled: 04/24/2021 0823
Date Received: 04/26/2021 1600
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/29/2021 1414	
Prep Method: 200.7/200.8			Date Prepared:	06/28/2021 0900	
Lead	5.4	ug/L	1.0	1.0	1.0

Richard McKibben
Pine Plains CSD
2829 Church Street
Pine Plains, NY 12567

Job Number: 420-195975-1
Sdg Number: Seymour Smith ILC

Client Sample ID: 205A
Lab Sample ID: 420-195975-15

Date Sampled: 04/24/2021 0825
Date Received: 04/26/2021 1600
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/29/2021 1416	
Prep Method: 200.7/200.8			Date Prepared:	06/28/2021 0900	
Lead	1.9	ug/L	1.0	1.0	1.0

Richard McKibben
Pine Plains CSD
2829 Church Street
Pine Plains, NY 12567

Job Number: 420-195975-1
Sdg Number: Seymour Smith ILC

Client Sample ID: 205B
Lab Sample ID: 420-195975-16

Date Sampled: 04/24/2021 0827
Date Received: 04/26/2021 1600
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/29/2021 1418	
Prep Method: 200.7/200.8			Date Prepared:	06/28/2021 0900	
Lead	2.2	ug/L	1.0	1.0	1.0

Richard McKibben
Pine Plains CSD
2829 Church Street
Pine Plains, NY 12567

Job Number: 420-195975-1
Sdg Number: Seymour Smith ILC

Client Sample ID: 205C
Lab Sample ID: 420-195975-17

Date Sampled: 04/24/2021 0828
Date Received: 04/26/2021 1600
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/29/2021 1420	
Prep Method: 200.7/200.8			Date Prepared:	06/28/2021 0900	
Lead	1.8	ug/L	1.0	1.0	1.0

Richard McKibben
Pine Plains CSD
2829 Church Street
Pine Plains, NY 12567

Job Number: 420-195975-1
Sdg Number: Seymour Smith ILC

Client Sample ID: 2 Boys Rm A
Lab Sample ID: 420-195975-18

Date Sampled: 04/24/2021 0837
Date Received: 04/26/2021 1600
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/29/2021 1427	
Prep Method: 200.7/200.8			Date Prepared:	06/28/2021 0900	
Lead	4.4	ug/L	1.0	1.0	1.0

Richard McKibben
Pine Plains CSD
2829 Church Street
Pine Plains, NY 12567

Job Number: 420-195975-1
Sdg Number: Seymour Smith ILC

Client Sample ID: 2 Boys Rm B
Lab Sample ID: 420-195975-19

Date Sampled: 04/24/2021 0839
Date Received: 04/26/2021 1600
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/29/2021 1429	
Prep Method: 200.7/200.8			Date Prepared:	06/28/2021 0900	
Lead	4.9	ug/L	1.0	1.0	1.0

Richard McKibben
Pine Plains CSD
2829 Church Street
Pine Plains, NY 12567

Job Number: 420-195975-1
Sdg Number: Seymour Smith ILC

Client Sample ID: Fountain @ 215
Lab Sample ID: 420-195975-20

Date Sampled: 04/24/2021 0841
Date Received: 04/26/2021 1600
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/29/2021 1431	
Prep Method: 200.7/200.8			Date Prepared:	06/28/2021 0900	
Lead	<1.0	ug/L	1.0	1.0	1.0

Richard McKibben
Pine Plains CSD
2829 Church Street
Pine Plains, NY 12567

Job Number: 420-195975-1
Sdg Number: Seymour Smith ILC

Client Sample ID: 226 Classroom
Lab Sample ID: 420-195975-21

Date Sampled: 04/24/2021 0844
Date Received: 04/26/2021 1600
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/29/2021 1434	
Prep Method: 200.7/200.8			Date Prepared:	06/28/2021 0900	
Lead	11	ug/L	1.0	1.0	1.0

Richard McKibben
Pine Plains CSD
2829 Church Street
Pine Plains, NY 12567

Job Number: 420-195975-1
Sdg Number: Seymour Smith ILC

Client Sample ID: 226 Bathroom
Lab Sample ID: 420-195975-22

Date Sampled: 04/24/2021 0846
Date Received: 04/26/2021 1600
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/29/2021 1436	
Prep Method: 200.7/200.8			Date Prepared:	06/28/2021 0900	
Lead	21 g	ug/L	1.0	1.0	1.0

Richard McKibben
Pine Plains CSD
2829 Church Street
Pine Plains, NY 12567

Job Number: 420-195975-1
Sdg Number: Seymour Smith ILC

Client Sample ID: 125 Classroom
Lab Sample ID: 420-195975-23

Date Sampled: 04/24/2021 0852
Date Received: 04/26/2021 1600
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/29/2021 1444	
Prep Method: 200.7/200.8			Date Prepared:	06/28/2021 0900	
Lead	8.4	ug/L	1.0	1.0	1.0

Richard McKibben
Pine Plains CSD
2829 Church Street
Pine Plains, NY 12567

Job Number: 420-195975-1
Sdg Number: Seymour Smith ILC

Client Sample ID: 125 Bathroom A
Lab Sample ID: 420-195975-24

Date Sampled: 04/24/2021 0854
Date Received: 04/26/2021 1600
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/29/2021 1447	
Prep Method: 200.7/200.8			Date Prepared:	06/28/2021 0900	
Lead	13	ug/L	1.0	1.0	1.0

Richard McKibben
Pine Plains CSD
2829 Church Street
Pine Plains, NY 12567

Job Number: 420-195975-1
Sdg Number: Seymour Smith ILC

Client Sample ID: 125 Bathroom B
Lab Sample ID: 420-195975-25

Date Sampled: 04/24/2021 0856
Date Received: 04/26/2021 1600
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/29/2021 1453	
Prep Method: 200.7/200.8			Date Prepared:	06/28/2021 0900	
Lead	8.9	ug/L	1.0	1.0	1.0

Richard McKibben
Pine Plains CSD
2829 Church Street
Pine Plains, NY 12567

Job Number: 420-195975-1
Sdg Number: Seymour Smith ILC

Client Sample ID: 125 Fountain
Lab Sample ID: 420-195975-26

Date Sampled: 04/24/2021 0858
Date Received: 04/26/2021 1600
Client Matrix: Drinking Water

Analyte	Result/Qualifier		Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/29/2021	1455	
Prep Method: 200.7/200.8			Date Prepared:	06/28/2021	0900	
Lead	20	g	ug/L	1.0	1.0	1.0

Richard McKibben
Pine Plains CSD
2829 Church Street
Pine Plains, NY 12567

Job Number: 420-195975-1
Sdg Number: Seymour Smith ILC

Client Sample ID: 126 Classroom
Lab Sample ID: 420-195975-27

Date Sampled: 04/24/2021 0903
Date Received: 04/26/2021 1600
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/29/2021 1458	
Prep Method: 200.7/200.8			Date Prepared:	06/28/2021 0900	
Lead	12	ug/L	1.0	1.0	1.0

Richard McKibben
Pine Plains CSD
2829 Church Street
Pine Plains, NY 12567

Job Number: 420-195975-1
Sdg Number: Seymour Smith ILC

Client Sample ID: 126 Fountain
Lab Sample ID: 420-195975-28

Date Sampled: 04/24/2021 0904
Date Received: 04/26/2021 1600
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/30/2021 1139	
Prep Method: 200.7/200.8			Date Prepared:	06/28/2021 1752	
Lead	2300 g	ug/L	1.0	1.0	1.0

Richard McKibben
Pine Plains CSD
2829 Church Street
Pine Plains, NY 12567

Job Number: 420-195975-1
Sdg Number: Seymour Smith ILC

Client Sample ID: 126 Bathroom
Lab Sample ID: 420-195975-29

Date Sampled: 04/24/2021 0911
Date Received: 04/26/2021 1600
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/29/2021 1500	
Prep Method: 200.7/200.8			Date Prepared:	06/28/2021 0900	
Lead	7.6	ug/L	1.0	1.0	1.0

Richard McKibben
Pine Plains CSD
2829 Church Street
Pine Plains, NY 12567

Job Number: 420-195975-1
Sdg Number: Seymour Smith ILC

Client Sample ID: 120 Fountain
Lab Sample ID: 420-195975-30

Date Sampled: 04/24/2021 0915
Date Received: 04/26/2021 1600
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/30/2021 1159	
Prep Method: 200.7/200.8			Date Prepared:	06/28/2021 1752	
Lead	42 g	ug/L	1.0	1.0	1.0

Richard McKibben
Pine Plains CSD
2829 Church Street
Pine Plains, NY 12567

Job Number: 420-195975-1
Sdg Number: Seymour Smith ILC

Client Sample ID: 120 Bathroom
Lab Sample ID: 420-195975-31

Date Sampled: 04/24/2021 0917
Date Received: 04/26/2021 1600
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/29/2021 1502	
Prep Method: 200.7/200.8			Date Prepared:	06/28/2021 0900	
Lead	12	ug/L	1.0	1.0	1.0

Richard McKibben
Pine Plains CSD
2829 Church Street
Pine Plains, NY 12567

Job Number: 420-195975-1
Sdg Number: Seymour Smith ILC

Client Sample ID: Boys Fountain
Lab Sample ID: 420-195975-32

Date Sampled: 04/24/2021 0919
Date Received: 04/26/2021 1600
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/29/2021 1504	
Prep Method: 200.7/200.8			Date Prepared:	06/28/2021 0900	
Lead	<1.0	ug/L	1.0	1.0	1.0

Richard McKibben
Pine Plains CSD
2829 Church Street
Pine Plains, NY 12567

Job Number: 420-195975-1
Sdg Number: Seymour Smith ILC

Client Sample ID: 1 Boys Rm A
Lab Sample ID: 420-195975-33

Date Sampled: 04/24/2021 0924
Date Received: 04/26/2021 1600
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/29/2021 1506	
Prep Method: 200.7/200.8			Date Prepared:	06/28/2021 0900	
Lead	11	ug/L	1.0	1.0	1.0

Richard McKibben
Pine Plains CSD
2829 Church Street
Pine Plains, NY 12567

Job Number: 420-195975-1
Sdg Number: Seymour Smith ILC

Client Sample ID: 1 Boys Rm B
Lab Sample ID: 420-195975-34

Date Sampled: 04/24/2021 0926
Date Received: 04/26/2021 1600
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/29/2021 1508	
Prep Method: 200.7/200.8			Date Prepared:	06/28/2021 0900	
Lead	4.8	ug/L	1.0	1.0	1.0

Richard McKibben
Pine Plains CSD
2829 Church Street
Pine Plains, NY 12567

Job Number: 420-195975-1
Sdg Number: Seymour Smith ILC

Client Sample ID: III
Lab Sample ID: 420-195975-35

Date Sampled: 04/24/2021 0929
Date Received: 04/26/2021 1600
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/29/2021 1513	
Prep Method: 200.7/200.8			Date Prepared:	06/28/2021 0900	
Lead	12	ug/L	1.0	1.0	1.0

Richard McKibben
Pine Plains CSD
2829 Church Street
Pine Plains, NY 12567

Job Number: 420-195975-1
Sdg Number: Seymour Smith ILC

Client Sample ID: Clinic Bathroom
Lab Sample ID: 420-195975-36

Date Sampled: 04/24/2021 0933
Date Received: 04/26/2021 1600
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/29/2021 1519	
Prep Method: 200.7/200.8			Date Prepared:	06/28/2021 0900	
Lead	14	ug/L	1.0	1.0	1.0

Richard McKibben
Pine Plains CSD
2829 Church Street
Pine Plains, NY 12567

Job Number: 420-195975-1
Sdg Number: Seymour Smith ILC

Client Sample ID: Clinic Sink
Lab Sample ID: 420-195975-37

Date Sampled: 04/24/2021 0935
Date Received: 04/26/2021 1600
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/29/2021 1521	
Prep Method: 200.7/200.8			Date Prepared:	06/28/2021 0900	
Lead	16 g	ug/L	1.0	1.0	1.0

Richard McKibben
Pine Plains CSD
2829 Church Street
Pine Plains, NY 12567

Job Number: 420-195975-1
Sdg Number: Seymour Smith ILC

Client Sample ID: 116
Lab Sample ID: 420-195975-38

Date Sampled: 04/24/2021 0938
Date Received: 04/26/2021 1600
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/29/2021 1524	
Prep Method: 200.7/200.8			Date Prepared:	06/28/2021 0900	
Lead	15 g	ug/L	1.0	1.0	1.0

Richard McKibben
Pine Plains CSD
2829 Church Street
Pine Plains, NY 12567

Job Number: 420-195975-1
Sdg Number: Seymour Smith ILC

Client Sample ID: 107
Lab Sample ID: 420-195975-39

Date Sampled: 04/24/2021 0941
Date Received: 04/26/2021 1600
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/29/2021 1526	
Prep Method: 200.7/200.8			Date Prepared:	06/28/2021 0900	
Lead	23 g	ug/L	1.0	1.0	1.0

Richard McKibben
Pine Plains CSD
2829 Church Street
Pine Plains, NY 12567

Job Number: 420-195975-1
Sdg Number: Seymour Smith ILC

Client Sample ID: 1 Girls Fountain
Lab Sample ID: 420-195975-40

Date Sampled: 04/24/2021 0945
Date Received: 04/26/2021 1600
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/29/2021 1528	
Prep Method: 200.7/200.8			Date Prepared:	06/28/2021 0900	
Lead	26 g	ug/L	1.0	1.0	1.0

Richard McKibben
Pine Plains CSD
2829 Church Street
Pine Plains, NY 12567

Job Number: 420-195975-1
Sdg Number: Seymour Smith ILC

Client Sample ID: 1 Girls BR A
Lab Sample ID: 420-195975-41

Date Sampled: 04/24/2021 0947
Date Received: 04/26/2021 1600
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/29/2021 1530	
Prep Method: 200.7/200.8			Date Prepared:	06/28/2021 0900	
Lead	8.9	ug/L	1.0	1.0	1.0

Richard McKibben
Pine Plains CSD
2829 Church Street
Pine Plains, NY 12567

Job Number: 420-195975-1
Sdg Number: Seymour Smith ILC

Client Sample ID: 1 Girls BR B
Lab Sample ID: 420-195975-42

Date Sampled: 04/24/2021 0948
Date Received: 04/26/2021 1600
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/29/2021 1532	
Prep Method: 200.7/200.8			Date Prepared:	06/28/2021 0900	
Lead	11	ug/L	1.0	1.0	1.0

Richard McKibben
Pine Plains CSD
2829 Church Street
Pine Plains, NY 12567

Job Number: 420-195975-1
Sdg Number: Seymour Smith ILC

Client Sample ID: Cafeteria Fountain
Lab Sample ID: 420-195975-43

Date Sampled: 04/24/2021 0951
Date Received: 04/26/2021 1600
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/29/2021 1535	
Prep Method: 200.7/200.8			Date Prepared:	06/28/2021 0900	
Lead	<1.0	ug/L	1.0	1.0	1.0

Richard McKibben
Pine Plains CSD
2829 Church Street
Pine Plains, NY 12567

Job Number: 420-195975-1
Sdg Number: Seymour Smith ILC

Client Sample ID: Island Sink
Lab Sample ID: 420-195975-44

Date Sampled: 04/24/2021 0953
Date Received: 04/26/2021 1600
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/29/2021 1537	
Prep Method: 200.7/200.8			Date Prepared:	06/28/2021 0900	
Lead	29 g	ug/L	1.0	1.0	1.0

Richard McKibben
Pine Plains CSD
2829 Church Street
Pine Plains, NY 12567

Job Number: 420-195975-1
Sdg Number: Seymour Smith ILC

Client Sample ID: Kitchen Sink A
Lab Sample ID: 420-195975-45

Date Sampled: 04/24/2021 0956
Date Received: 04/26/2021 1600
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/29/2021 1550	
Prep Method: 200.7/200.8			Date Prepared:	06/28/2021 0900	
Lead	11	ug/L	1.0	1.0	1.0

Richard McKibben
Pine Plains CSD
2829 Church Street
Pine Plains, NY 12567

Job Number: 420-195975-1
Sdg Number: Seymour Smith ILC

Client Sample ID: Kitchen Sink B
Lab Sample ID: 420-195975-46

Date Sampled: 04/24/2021 0958
Date Received: 04/26/2021 1600
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/29/2021 1552	
Prep Method: 200.7/200.8			Date Prepared:	06/28/2021 0900	
Lead	19 g	ug/L	1.0	1.0	1.0

Richard McKibben
Pine Plains CSD
2829 Church Street
Pine Plains, NY 12567

Job Number: 420-195975-1
Sdg Number: Seymour Smith ILC

Client Sample ID: Auditorium BR Girls
Lab Sample ID: 420-195975-47

Date Sampled: 04/24/2021 1002
Date Received: 04/26/2021 1600
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/29/2021 1554	
Prep Method: 200.7/200.8			Date Prepared:	06/28/2021 0900	
Lead	10	ug/L	1.0	1.0	1.0

Richard McKibben
Pine Plains CSD
2829 Church Street
Pine Plains, NY 12567

Job Number: 420-195975-1
Sdg Number: Seymour Smith ILC

Client Sample ID: 109
Lab Sample ID: 420-195975-48

Date Sampled: 04/24/2021 1005
Date Received: 04/26/2021 1600
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/30/2021 1202	
Prep Method: 200.7/200.8			Date Prepared:	06/28/2021 1752	
Lead	20 g	ug/L	1.0	1.0	1.0

Richard McKibben
Pine Plains CSD
2829 Church Street
Pine Plains, NY 12567

Job Number: 420-195975-1
Sdg Number: Seymour Smith ILC

Client Sample ID: 109 Bathroom
Lab Sample ID: 420-195975-49

Date Sampled: 04/24/2021 1006
Date Received: 04/26/2021 1600
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/29/2021 1556	
Prep Method: 200.7/200.8			Date Prepared:	06/28/2021 0900	
Lead	7.9	ug/L	1.0	1.0	1.0

Richard McKibben
Pine Plains CSD
2829 Church Street
Pine Plains, NY 12567

Job Number: 420-195975-1
Sdg Number: Seymour Smith ILC

Client Sample ID: Gym Fountain A
Lab Sample ID: 420-195975-50

Date Sampled: 04/24/2021 1010
Date Received: 04/26/2021 1600
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/29/2021 1559	
Prep Method: 200.7/200.8			Date Prepared:	06/28/2021 0900	
Lead	2.6	ug/L	1.0	1.0	1.0

Richard McKibben
Pine Plains CSD
2829 Church Street
Pine Plains, NY 12567

Job Number: 420-195975-1
Sdg Number: Seymour Smith ILC

Client Sample ID: Gym Fountain B
Lab Sample ID: 420-195975-51

Date Sampled: 04/24/2021 1017
Date Received: 04/26/2021 1600
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4					
Prep Method: 200.7/200.8					
Lead	11	ug/L	1.0	1.0	1.0

Richard McKibben
Pine Plains CSD
2829 Church Street
Pine Plains, NY 12567

Job Number: 420-195975-1
Sdg Number: Seymour Smith ILC

Client Sample ID: 114
Lab Sample ID: 420-195975-52

Date Sampled: 04/24/2021 1020
Date Received: 04/26/2021 1600
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/29/2021 1603	
Prep Method: 200.7/200.8			Date Prepared:	06/28/2021 0900	
Lead	5.2	ug/L	1.0	1.0	1.0

Richard McKibben
Pine Plains CSD
2829 Church Street
Pine Plains, NY 12567

Job Number: 420-195975-1
Sdg Number: Seymour Smith ILC

Client Sample ID: Auditorium BR Mens
Lab Sample ID: 420-195975-53

Date Sampled: 04/24/2021 1022
Date Received: 04/26/2021 1600
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/29/2021 1605	
Prep Method: 200.7/200.8			Date Prepared:	06/28/2021 0900	
Lead	5.4	ug/L	1.0	1.0	1.0

Richard McKibben
Pine Plains CSD
2829 Church Street
Pine Plains, NY 12567

Job Number: 420-195975-1
Sdg Number: Seymour Smith ILC

Client Sample ID: 119
Lab Sample ID: 420-195975-54

Date Sampled: 04/24/2021 1024
Date Received: 04/26/2021 1600
Client Matrix: Drinking Water

Analyte	Result/Qualifier	Unit	RL	RL	Dilution
Method: 200.8 Rev.5.4			Date Analyzed:	06/29/2021 1612	
Prep Method: 200.7/200.8			Date Prepared:	06/28/2021 0900	
Lead	5.0	ug/L	1.0	1.0	1.0

DATA REPORTING QUALIFIERS

Client: Pine Plains CSD

Job Number:
Sdg Number: Seymour Smith ILC

Lab Section	Qualifier	Description
Metals	g	Result fails applicable NYS drinking water standards

Certification Information

Client: Pine Plains CSD

Job Number:

Sdg Number: Seymour Smith ILC

The following analytes are Not Part of the ELAP scope of accreditation

Sulfur, Tungsten, Bicarbonate Alkalinity, 7 Day BOD 5210C, 28 Day BOD, Soluble BOD, Carbon Dioxide, Carbonate Alkalinity, CBOD Soluble, Chlorine, Cyanide (WAD), Ferrous Iron, Ferric Iron, Total Nitrogen, Total Organic Nitrogen, Dissolved Oxygen, pH, Solids (Fixed), Solids (Percent), Solids (Percent Moisture), Solids (Percent Volatile), Solids (Volatile Suspended), Temperature, TKN (Soluble), COD (Soluble), Total Inorganic Carbon, 2-Aminopyridine, 3-Picoline, 1-Methyl-2-pyrrilidinone, Aziridine, Dimethyl sulfoxide, 1-Chlorohexane, 1,2,4,5-Tetramethylbenzene, 4-Ethyl toluene, p-Diethylbenzene, Iron Bacteria, Salmonella, Sulfur Reducing Bacteria, & UOD (Ultimate Oxygen Demand).

The following analytes are Not Part of ELAP Potable Water scope of accreditation

Ammonia (SM 4500NH₃G), Biochemical Oxygen Demand (SM 5210B), Chemical Oxygen Demand (EPA 410.4), Dissolved Oxygen (SM 4500 O C), TKN (351.2), Phosphorus (365.3), Nitrate-Nitrite (353.2), Settable Solids (SM 2540F), Total Suspended Solids (SM 2540 C), m-Xylene & p-Xylene (502.2, 524), o-Xylene (502.2, 524), Sulfide (SM4500SD), Acenaphthene (525.2), Acenaphthylene (525.2), Fluoranthene (525.2), Fluorene (525.2), Phenanthrene (525.2), Anthracene (525.2), Pyrene (525.2), Benzo[a]anthracene (525.2), Benzo[b]fluoranthene (525.2), Benzo[g,h,i]perylene (525.2), Benzo[k]fluoranthene (525.2), Indeno[1,2,3-cd]pyrene (525.2), & Dibenz(a,h)anthracene (525.2). Pyridine

The following analytes are Not Part of ELAP Solid and Hazardous Waste scope of accreditation

Ammonia (SM 4500NH₃G), TKN (351.2), Phosphorus (365.3), 1,2-Dichloro-1,1,2-trifluoroethane (8260), & Chlorodifluoromethane (8260).

The following analytes are Not Part of ELAP Non Potable Water scope of accreditation

Dissolved Organic Carbon (5310C), Mecoprop (8151A), MCPA (8151A).

Definitions and Glossary

Client: Pine Plains CSD

Job Number:

Sdg Number: Seymour Smith ILC

Abbreviation	These commonly used abbreviations may or may not be present in this report.
%R	Percent Recovery
DL, RA, RE	Indicates a Dilution, Reanalysis or Reextraction.
EPA	United States Environmental Protection Agency
MDL	Method Detection Limit - an estimate of the minimum amount of a substance that an analytical process can reliably detect. A MDL is analyte- and matrix-specific and may be laboratory-dependent.
ND	Not detected at the reporting limit (or MDL if shown).
QC	Quality Control
RL	Reporting Limit - the minimum levels, concentrations, or quantities of a target variable (e.g., target analyte) that can be reported with a specified degree of confidence.
RPD	Relative Percent Difference - a measure of the relative difference between two points

**EnviroTest
Laboratories** [illegible]

EnviroTest Laboratories, LLC

315 Fullerton Avenue
Newburgh, NY 12550
Phone (845) 562-0890 Fax (845) 562-0841

Chain of Custody Record

EnviroTest
Laboratories

Client Information Client Contact: Richard McKibben Company: Pine Plains Central School District Address: 2829 Church Street City: Pine Plains State, Zip: NY, 12567 Phone: (518) 398-7181 x1344 Email: r.mckibben@ppcsd.org Project Name: Lead in Water 2020-2021 Site: Seymour Smith ILC		Sampler: Mike McCarthy Phone: (845) 706-8855 Lab PM: E-Mail: r.mckibben@ppcsd.org Deliverable Type: Level I, Level II, NYS ASP Cat B EDD (Specify):		JOB #: 195975 Page: 2 of 5 Preservation Codes: A - HCL B - NaOH C - Nitric Acid D - H2SO4 E - MeOH F - NH4CL G - Ascorbic Acid H - Ice J - DI Water K - Sodium Thiosulfate L - EDA M - Sodium Sulfite N - None O - MCAA P - Other (specify)	
Due Date Requested: Standard turn around TAT Requested (days): PO #: PWS #:		Analysis Requested			
Additional Contacts:		Total Number of containers:			
Sample Identification Client ID (Lab ID)		Sample Date		Sample Time (C=Comp, G=grab)	
Matrix (DW= drinking water, W=water, S=solid, O=waste/oil)		Field Filtered Sample (Yes or No)		Perform MS/MSD (Yes or No)	
Preservation Code:		Chlorine Present (Yes or No)		Lead in Water	
Special Instructions/Note:		Upon Receipt Preservation verified: Y / N			
Sample 012 2 Girl's Rm A Sample 013 2 Girl's Rm B Sample 014 210 Sample 015 205A Sample 016 205B Sample 017 205C Sample 018 Sample 019 2 Boy's Rm A Sample 020 2 Boy's Rm B Sample 021 Fountain @ 215 Sample 022 226 Classroom		4/24/21 4/24/21 4/24/21 4/24/21 4/24/21 4/24/21 4/24/21 4/24/21 4/24/21 4/24/21 4/24/21 4/24/21 4/24/21 4/24/21		8:18 8:18 8:23 8:25 8:27 8:28 8:37 8:39 8:41 8:44	
Container Code: P=Plastic, A=Amber, V=Vial, G=Glass, B=Bacteria, C=Cube, O=Other, T=Terracore, D=BOD Bottle Size Code: 1=Liter, 2=250 mL, 3=125 mL, 4=40 mL, 5=Gallon, 6=Half Gallon, 7=Other		P 2		Container Type Container Size	
Preservation Added Upon Receipt:		Date:		Time:	
Relinquished by: Brian Walsh Relinquished by: MS Relinquished by: [Signature]		Date/Time: 04/26/2021 10:57 Date/Time: 4/29/21 15:15 Date/Time: 4-26-21 1600		Company: [Signature] Company: ETL Company: [Signature]	
Relinquished by: [Signature]		Date/Time: 4/26/21 10:50 Date/Time: 4-26-21 1515 Date/Time: 4/26/21 1600		Company: ETL Company: ETL Company: ETL	
ICE Present: Yes ☒ No ☐		Custody Seal No.:		Custody Seal Intact: Yes ☒ No ☐	
Cooler Temperature(s) °C/°F: 0.7C		Date: 07/01/2021		Page 04 of 08	

EnviroTest Laboratories, LLC

315 Fullerton Avenue
Newburgh, NY 12550
Phone (845) 562-0890 Fax (845) 562-0841

Chain of Custody Record

EnviroTest
Laboratories

Client Information Client Contact: Richard McKibben Company: Pine Plains Central School District		Sampler: Mike McCarthy Phone: (845) 706-8855		Lab PM: E-Mail: r.mckibben@ppcsd.org		Deliverable Type: Level I, Level II, NYS ASP Cat B EDD (Specify):		JOB #: 195975			
Address: 2829 Church Street City: Pine Plains State, Zip: NY, 12567 Phone: (518) 398-7181 x1344 Email: r.mckibben@ppcsd.org		Due Date Requested: Standard turn around TAT Requested (days): PO #: PWS #:		Analysis Requested						Page: Page 3 of 5 Preservation Codes: A - HCL L- EDA B - NaOH M - Sodium Sulfite C - Nitric Acid N - None E - H2SO4 O - MCAA F - MeOH P - Other (specify) G - NH4CL H - Ascorbic Acid I - Ice J - DI Water K - Sodium Thiosulfate Other:	
Project Name: Lead in Water 2020-2021 Site: Seymour Smith ILC		Project #: Additional Contacts:		Field Filtered Sample (Yes or No) Perform MS/MSD (Yes or No) Chlorine Present (Yes or No) Lead in Water		Total Number of Containers		Upon Receipt Preservation verified: Y / N			
Sample Identification Client ID (Lab ID)		Sample Date	Sample Time	Sample Type (C=comp, G=grab)	Matrix (DW=drinking water, W=water, S=solid, O=waste/oil)	Preservation Code:		Special Instructions/Note:			
Sample 023 226 Bathroom		4/24/21	8:46	G	DW			All Samples have D-Nitric Acid added for preservation.			
Sample 024 125 Classroom		4/24/21	8:52	G	DW						
Sample 025 125 Bathroom A		4/24/21	8:54	G	DW						
Sample 026 125 Bathroom B		4/24/21	8:56	G	DW						
Sample 027 125 Fountain		4/24/21	8:58	G	DW						
Sample 028 126 Classroom		4/24/21	9:03	G	DW						
Sample 029 126 Fountain		4/24/21	9:04	G	DW						
Sample 030 126 Bathroom		4/24/21	9:11	G	DW						
Sample 031 120 Fountain		4/24/21	9:15	G	DW						
Sample 032 120 Bathroom		4/24/21	9:17	G	DW						
Sample 033 Boy's Fountain		4/24/21	9:19	G	DW						
Container Code: P=Plastic, A=Amber, V=Vial, G=Glass, B=Bacteria, C=Cube, O=Other, T=Terracore, D=BOD Bottle Size Code: 1=Liter, 2=250 mL, 3=125 mL, 4=40 mL, 5=Gallon, 6=Half Gallon, 7=Other						P 2		Container Type Container Size			
Preservation Added Upon Receipt:		Date:		Time:		Sample # (s):					
Relinquished by: Brian Walsh		Date/Time: 4/24/2021 10:57		Company:		Received by: Bk		Date/Time: 4/26/21 10:50		Company: ETL	
Relinquished by: MS		Date/Time: 4/29/21 15:15		Company: ETL		Received by: [Signature]		Date/Time: 4-28-21 1515		Company: ETL	
Relinquished by: [Signature]		Date/Time: 4/29/21 1600		Company: ETL		Received by: [Signature]		Date/Time: 4/29/21 1600		Company: ETL	
ICE Present: Yes		Custody Seal No.:		Custody Seal No.:		Color Temperature (°C) or IR GUN #:		0.1C		07/01/2021	

EnviroTest Laboratories, LLC

315 Fullerton Avenue
Newburgh, NY 12550
Phone (845) 562-0890 Fax (845) 562-0841

Chain of Custody Record

EnviroTest
Laboratories

Client Information		Sampler: Mike McCarthy		Lab PM:		Deliverable Type: Level I, Level II, NYS ASP Cat B EDD (Specify):		JOB #: 195975	
Client Contact: Richard McKibben Company: Pine Plains Central School District		Phone: (845) 706-8855		E-Mail: r.mckibben@ppcsd.org				Page: Page 4 of 5	
Address: 2829 Church Street City: Pine Plains State, Zip: NY, 12567 Phone: (518) 398-7181 x1344 Email: r.mckibben@ppcsd.org		Due Date Requested: Standard turn around TAT Requested (days): PO #: PWS #:				Analysis Requested		Preservation Codes: A - HCL B - NaOH C - Nitric Acid D - H2SO4 E - MeOH F - NH4CL G - Ascorbic Acid H - DI Water J - Sodium Thiosulfate K - Other: Upon Receipt Preservation verified: Y / N	
Project Name: Lead in Water 2020-2021 Site: Seymour Smith ILC		Additional Contacts:						Total Number of containers	
Sample Identification Client ID (Lab ID)		Sample Date	Sample Time	Sample Type (C=Comp, G=grab)	Matrix (DW=drinking water, W=water, S=solid, O=waste/oil)	Field Filtered Sample (Yes or No)	Perform MS/MSD (Yes or No)	Chlorine Present (Yes or No)	Lead in Water
Sample 034 1 Boy's Rm A		4/24/21	9:24	G	DW				
Sample 035 1 Boy's Rm B		4/24/21	9:26	G	DW				
Sample 036 111		4/24/21	9:29	G	DW				
Sample 037 Clinic Bathroom		4/24/21	9:33	G	DW				
Sample 038 Clinic Sink		4/24/21	9:35	G	DW				
Sample 039 116		4/24/21	9:38	G	DW				
Sample 040 107		4/24/21	9:41	G	DW				
Sample 041 1 Girl's Fountain		4/24/21	9:45	G	DW				
Sample 042 1 Girl's BR A		4/24/21	9:47	G	DW				
Sample 043 1 Girl's BR B		4/24/21	9:48	G	DW				
Sample 044 Cafeteria Fountain		4/24/21	9:51	G	DW				
Container Code: P=Plastic, A=Amber, V=Vial, G=Glass, B=Bacteria, C=Cube, O=Other, T=Terracore, D=BOD Bottle								P	
Size Code: 1=Liter, 2=250 mL, 3=125 mL, 4=40 mL, 5=Gallon, 6=Half Gallon, 7=Other								2	
Preservation Added Upon Receipt:		Date:	Time:	Sample # (s):					
Relinquished by: Brian Walsh		Date/Time: 4/26/2021 10:57	Company: ETC	Received by: Bm		Date/Time: 4/26/21 1050	Company: ETC		
Relinquished by: MS		Date/Time: 4/29/21 15:15	Company: ETC	Received by: MHA		Date/Time: 4-29-21 1515	Company: ETC		
Relinquished by: MHO		Date/Time: 4-29-21 1600	Company: ETC	Received by: V-A		Date/Time: 4/29/21 1600	Company: ETC		
ICF Present: Yes Δ No		Custody Seal No.		Custody Seal No.		Temperature(s) C/F IR SUN #		0.1C	
								07/01/2021	

**EnviroTest
Laboratories**

[illegible]

LOGIN SAMPLE RECEIPT CHECK LIST

Client: Pine Plains CSD

Job Number: 420-195975-1
SDG Number: Seymour Smith ILC

Login Number: 195975

Question	T/F/NA	Comment
Samples were collected by ETL employee as per SOP-SAM-1	NA	
The cooler's custody seal, if present, is intact.	NA	
The cooler or samples do not appear to have been compromised or tampered with.	True	
Samples were received on ice.	True	
Cooler Temperature is recorded.	True	0.1 C
Cooler Temp. is within method specified range.(0-6 C PW, 0-8 C NPW, or BAC <10 C	True	
If false, was sample received on ice within 6 hours of collection.	NA	
Based on above criteria cooler temperature is acceptable.	True	
COC is present.	True	
COC is filled out in ink and legible.	True	
COC is filled out with all pertinent information.	True	
There are no discrepancies between the sample IDs on the containers and the COC.	True	
Samples are received within Holding Time.	True	
Sample containers have legible labels.	True	
Containers are not broken or leaking.	True	
Sample collection date/times are provided.	True	
Appropriate sample containers are used.	True	
Sample bottles are completely filled.	True	
There is sufficient vol. for all requested analyses, incl. any requested MS/MSDs	True	
VOA sample vials do not have headspace or bubble is <6mm (1/4") in diameter.	NA	
If necessary, staff have been informed of any short hold time or quick TAT needs	True	
Multiphasic samples are not present.	True	
Samples do not require splitting or compositing.	True	