

Lead in Water Testing Results  
South Washington County Schools  
Red Rock Elementary

On December 28th, 2022 Red Rock Elementary School's drinking water was tested for concentration of lead.

**All water sources tested less than our current action level of 20 parts-per-billion.**

**No action was taken at this time.**

<b>LOCATION</b>	<b>SOURCE</b>	<b>RESULTS (in ug/L)</b>
Nurse's Office	SINK	.59
Staff Lounge	SINK	8.4
Kitchen (right)	SINK	7.2
Kitchen (left)	SINK	3.4
Kitchen	SPRAYER	13.1
Hallway (gym)	FOUNTAIN	ND
Hallway (gym)	BOTTLE FILLER	ND
Gym A	FOUNTAIN	1.3
Gym B	FOUNTAIN	.25
Gym C	FOUNTAIN	.28
Hallway (NW, left)	FOUNTAIN	ND
Hallway	BOTTLE FILLER	ND
Hallway (NW, right)	FOUNTAIN	1.2
Room E101	SINK	3.0
Room E116	SINK	1.9
Hallway (outside E115)	SINK	2.8
Room E115	SINK	2.1

Room E114	SINK	2.7
Room E112	SINK	3.2
Room E119	SINK	5.4
Room E118	SINK	1.7
Room E103	SINK	2.1
Room E104	SINK	2.3
Room E111	SINK	4.6
Room E109	SINK	9.7
Room E108	SINK	1.9
Hallway (outside E108)	SINK	5.7
Room E107	SINK	3.3
Room E106	SINK	1.3
Hallway (SW)	FOUNTAIN	1.2
Room D116	SINK	3.9
Room D108	SINK	2.3
Room D103	SINK	4.3
Hallway (SE)	FOUNTAIN	9.1
Room C106	SINK	1.5
Room C107	SINK	1.8
Hallway (outside C108)	SINK	2.4
Room C108	SINK	.81
Room C109	SINK	4.1
Room C111	SINK	2.1
Room C118	SINK	1.5
Room C119	SINK	2.7

Room C104	SINK	2.2
Media Work Room	SINK	2.0
Room C103	SINK	2.2
Room C112	SINK	2.7
Room C114	SINK	1.5
Room C115	SINK	1.9
Hallway (outside C115)	SINK	2.5
Room C116	SINK	1.9
Room C101	SINK	2.3
Hallway (NE, left)	FOUNTAIN	1.7
Hallway (NE, right)	FOUNTAIN	ND
Hallway (NE)	BOTTLE FILLER	ND