

Lead in Water Testing Results
South Washington County Schools
Liberty Ridge Elementary – Site II

On December 30th, 2022 Liberty Ridge Elementary – Site II - School's drinking water was tested for concentration of lead.

All water sources tested less than our current action level of 20 parts-per-billion.

No action was taken at this time.

LOCATION	SOURCE	RESULTS (in ug/L)
Room 104	SINK	3.0
Room 105	SINK	1.2
Room 111	SINK	1.0
Room 112	SINK	.27
Room 113	SINK	4.3
Room 127 (left)	SINK	1.4
Room 127 (right)	SINK	1.9
Room 128 (left)	SINK	1.6
Room 128 (right)	SINK	.75
Hallway (outside 128)	BOTTLE FILLER	ND
Room 129 (left)	SINK	.77
Room 129 (right)	SINK	1.0
Room 131 (left)	SINK	1.7
Room 131 (right)	SINK	.7
Room 132 (left)	SINK	1.7
Room 132 (right)	SINK	.67
Cafeteria	BOTTLE FILLER	ND