

Lead in Water Testing Results
South Washington County Schools
Newport Elementary

On December 28th, 2022 Newport Elementary School's drinking water was tested for concentration of lead.

The following water sources tested less than our current action level of 20 parts-per-billion.

No action was taken at this time.

LOCATION	SOURCE	RESULTS (in ug/L)
Nurse's Office	SINK	11.7
Nurse's Office (bathroom)	SINK	5.1
Staff Lounge	SINK	5.3
Hallway (outside 103, left)	FOUNTAIN	.17
Hallway (outside 103, right)	FOUNTAIN	.19
Kitchen	SPRAYER	.88
Kitchen (left)	SINK	2.0
Kitchen (right)	SINK	11.9
Outside Gym	FOUNTAIN	.58
Hallway (outside 125)	FOUNTAIN	ND
Hallway (outside 125)	BOTTLE FILLER	ND
Hallway (outside 120)	FOUNTAIN	.27
Hallway (outside 116, left)	FOUNTAIN	10.2
Room 101	SINK	2.0
Room 103	SINK	1.4
Room 106	SINK	4.2
Room 107	SINK	5.3

Room 108	SINK	12.5
Room 109	SINK	7.5
Room 110	SINK	9.3
Room 111	SINK	5.7
Room 112	SINK	5.7
Room 113	SINK	3.7
Room 115	SINK	2.3
Room 116	SINK	3.4
Room 117	SINK	8.6
Room 122	SINK	16.2
Room 123	SINK	15.6
Room 124	SINK	7.0
Room 125	SINK	12.9
Room 126	SINK	11.3
Room 127	SINK	3.6

The following water sources tested with results of the concentration to be over 20 parts-per-billion. The fixture of this water source was replaced, and a re-test was administered.

LOCATION	SOURCE	INITIAL RESULTS (in ug/L)	FINAL RESULTS
Hallway (outside 116, right)	FOUNTAIN	12.2	ND