

Lead in Water Testing Results
South Washington County Schools
Central Park

On December 30th, 2022 Central Park's drinking water was tested for concentration of lead.

All water sources tested less than our action level of 20 parts-per-billion.

No action was taken to these sources at this time.

LOCATION	SOURCE	RESULTS (in ug/L)
Hallway (1)	FOUNTAIN	3.3
Hallway (2)	FOUNTAIN	2.3
Hallway (3)	FOUNTAIN	1.8
Owl Room (left)	SINK	10.5
Owl Room (right)	SINK	14.0
Beaver Room (left)	SINK	14.6
Beaver Room (right)	SINK	18.8
Fox Room (left)	SINK	12.2
Fox Room (right)	SINK	9.5
Bear Room (left)	SINK	17.1
Bear Room (right)	SINK	15.5