

Lead in Water Testing Results  
South Washington County Schools  
Cottage Grove Middle

On December 28th, 2022 Cottage Grove Middle School's drinking water was tested for concentration of lead.

**All water sources tested less than our current action level of 20 parts-per-billion.  
No action was taken to these sources at this time.**

<b>LOCATION</b>	<b>SOURCE</b>	<b>RESULTS (in ug/L)</b>
Office Work Room	SINK	8.8
Nurse's Office	SINK	4.8
Staff Work Room	SINK	7.6
AV Work Room	SINK	6.5
Hallway (1)	FOUNTAIN	.59
Hallway (2)	FOUNTAIN	ND
Hallway (2)	BOTTLE FILLER	ND
Hallway (3)	FOUNTAIN	ND
Hallway (3)	BOTTLE FILLER	ND
Hallway (4)	FOUNTAIN	ND
Hallway (4)	BOTTLE FILLER	ND
Hallway (5)	FOUNTAIN	ND
Hallway (5)	BOTTLE FILLER	ND
Hallway (commons)	FOUNTAIN	ND
Hallway (commons)	BOTTLE FILLER	ND
Hallway (by gym, left)	FOUNTAIN	.13
Hallway (by gym, right)	FOUNTAIN	.34
Hallway (by gym C)	FOUNTAIN	ND

Hallway (by gym C)	BOTTLE FILLER	.12
Hallway (by Choir)	FOUNTAIN	.59
Concessions	SINK	7.0
Kitchen	SINK	2.8
Kitchen	SPRAYER	3.6
Staff Dining	SINK	3.9
Room G103	SINK	1.7
Room A114	SINK	1.6
Room A116	SINK	.52
Room A141	SINK	6.6
Room B114	SINK	12.6
Room B115	SINK	4.1
Room C124	SINK	4.3
Room C125	SINK	11.0
Room H103	SINK	2.6
Room H107	SINK	.34