

Lead in Water Testing Results
South Washington County Schools
Park High School

On December 28th, 2022 Park High School's drinking water was tested for concentration of lead.

All water sources tested less than our current action level of 20 parts-per-billion.

No action was taken at this time.

LOCATION	SOURCE	RESULTS (in ug/L)
Hallway (outside 101)	FOUNTAIN	4.0
Room 101	SINK	1.0
Hallway (outside 111, left)	FOUNTAIN	2.1
Hallway (outside 111, right)	FOUNTAIN	2.2
Hallway (outside 117)	FOUNTAIN	.67
Hallway (outside 178)	FOUNTAIN	1.8
Room 178	SINK	2.2
Hallway (outside 136)	FOUNTAIN	9.5
Hallway (outside 136)	BOTTLE FILLER	.24
Hallway (outside 139)	FOUNTAIN	9.5
Kitchen	SINK	11.5
Kitchen	SPRAYER	.88
Hallway (lobby, left)	FOUNTAIN	ND
Hallway (lobby, right)	FOUNTAIN	ND
Nurse's Office	SINK	3.1
Copy Room	SINK	3.3
Room 181	BOTTLE FILLER	ND

Room 183	BOTTLE FILLER	ND
Room 183	FOUNTAIN	ND
Room 185	BOTTLE FILLER	ND
Hallway (front of gym)	FOUNTAIN	ND
Hallway (front of gym)	BOTTLE FILLER	ND
Concessions (left)	SINK	3.9
Concessions (right)	SINK	4.0
Hallway (behind gym)	FOUNTAIN	8.1
Hallway (outside 202)	FOUNTAIN	4.0
Hallway (outside 214, left)	FOUNTAIN	ND
Hallway (outside 214, right)	FOUNTAIN	ND
Hallway (outside 214)	BOTTLE FILLER	ND
Hallway (outside 223, left)	FOUNTAIN	1.9
Hallway (outside 223, right)	FOUNTAIN	4.6
Hallway (outside 238, right)	FOUNTAIN	2.3
Activities Center (1)	FOUNTAIN	1.8
Activities Center (2)	FOUNTAIN	2.9
Activities Center (3)	FOUNTAIN	1.2
Activities Center (4)	FOUNTAIN	.89