

Lead in Water Testing Results
South Washington County Schools
East Ridge High School

On December 28th, 2022 East Ridge High School's drinking water was tested for concentration of lead.

The following water sources tested less than our current action level of 20 parts-per-billion. No action was taken on these sources at this time.

LOCATION	SOURCE	RESULTS (in ug/L)
Main Office	BOTTLE FILLER	ND
Main Office WR	SINK	3.7
Nurse's Office	SINK	2.3
Nurse's Office (bathroom)	SINK	1.6
Special Ed Kitchen	SINK	1.6
Hallway (A)	FOUNTAIN	ND
Hallway (A)	BOTTLE FILLER	ND
Staff Offices (A)	SINK	8.1
Hallway (B)	FOUNTAIN	.24
Staff Offices (B)	SINK	11.4
Hallway (C, right)	FOUNTAIN	1.1
Hallway (C, left)	FOUNTAIN	1.1
Room 1028 (1)	SINK	2.2
Room 1028 (2)	SINK	2.4
Room 1028 (3)	SINK	2.8
Room 1028 (4)	SINK	2.1
Room 1028 (5)	SINK	2.4
Room 1028 (6)	SINK	3.0

Room 1028 (7)	SINK	3.6
Room 1028 (8)	SINK	4.2
Concessions (left)	SINK	12.0
Concessions (right)	SINK	17.7
Kitchen	SINK	7.1
Kitchen	SPRAYER	5.1
Hallway (gym, left)	FOUNTAIN	1.4
Hallway (gym, right)	FOUNTAIN	1.7
Cafeteria	FOUNTAIN	ND
Cafeteria	BOTTLE FILLER	ND
Room 1053 (left)	SINK	10.2
Room 1053 (right)	SINK	5.6
Room 1055	FOUNTAIN	1.8
Hallway (band, left)	FOUNTAIN	.87
Hallway (band, right)	FOUNTAIN	.94
Hallway (basement gym, left)	FOUNTAIN	.67
Hallway (basement gym, right)	FOUNTAIN	.47
Hallway (2A, left)	FOUNTAIN	.71
Hallway (2A, right)	FOUNTAIN	1.1
Staff Offices (2A)	SINK	13.8
Hallway (2B, right)	FOUNTAIN	ND
Staff Offices (2B)	SINK	11.6
Hallway (2C, left)	FOUNTAIN	.54
Hallway (2C, right)	FOUNTAIN	1.1
Staff Offices (2C)	SINK	5.8

The following water sources tested at or above 20.0 ppb. The fixture has been replaced and retested.

LOCATION	SOURCE	INITIAL RESULTS (in ug/L)	FINAL RESULTS
Room 1030	SINK	20.0	ND