

Lead in Water Testing Results
South Washington County Schools

Next Step

On December 30th, 2022 Next Step's drinking water was tested for concentration of lead.

The following water sources tested less than our action level of 20 parts-per-billion.

No action was taken to these sources at this time.

LOCATION	SOURCE	RESULTS (in ug/L)
Kitchen	SINK	.46
Commons	SINK	2.0
Staff Room	SINK	ND
Nurse Bathroom	SINK	1.7
Main Area	FOUNTAINS	ND