Lead in School Drinking Water Report

Salem Woods Elementary School

Date(s) collected: 2023-04-25
Date(s) analyzed: 2023-05-01

Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Lead Test Result (ppb)
373694	A Building (Multipurpose)	Sink - Multi-Compartment	Kitchen	Largest 3 tier sink across from dishwasher	Tap	47
373695	A Building (Multipurpose)	Sink - Multi-Compartment	Kitchen	Largest 3 tier sink	Tap	2
373690	A Building (Multipurpose)	Fountain	Through Double Doors	Right outside gymnasium	Water Fountain	1
373693	A Building (Multipurpose)	Sink	Kitchen	Left of dishwasher	Sprayer	1
373691	A Building (Multipurpose)	Sink	Kitchen	Fruit and vegetable prep sink	Sprayer	<1
373692	A Building (Multipurpose)	Sink	Kitchen	Fruit and vegetable prep sink. Pot filler to the right of spray er	Tap	<1

Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Lead Test Result (ppb)
373696	A Building (Multipurpose)	Fountain	Restroom Hallway	Next to boys and girls bathroom A-106 and A-109	Water Fountain	<1

EXPLANATION OF TESTING AND RESULTS:

Results in this report represent sampling conducted by Washington State Department of Health. Per **RCW 28A.210.410** sampling and testing protocols, samples were collected as first-draw. Depending on size of the school(s) and number of drinking water fixtures, multiple dates for collecting samples may have been necessary to meet sampling and testing protocols. Above is information related to lead sampling for your school(s). For questions regarding testing and result, please email: **leadfreekids@doh.wa.gov**