Lead in School Drinking Water Report

Maltby Elementary School

Date(s) collected: 2023-06-02
Date(s) analyzed: 2023-06-20

Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Lead Test Result (ppb)
374102	Building B	Sink - Multi-Compartment	Kitchen	Largest 3 tier sink. Back of room	Sprayer	42
374040	Building B	Sink	Music Room	Only sink	Tap	23
374033	Building C	Sink	Room C-6	Only sink	Tap	14
374035	Building C	Sink	Room C-9	Only sink	Water Fountain	9
374105	Building B	Sink - Multi-Compartment	Kitchen	3 tier sink across from dish washer	Tap	9
374131	Building A	Sink	Room A-8	Only sink	Tap	9
374039	Building C	Sink	Library	Office only sink	Tap	7
374100	Building B	Sink	Kitchen	Hand washing sink on right side counter when	Tap	6

Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Lead Test Result (ppb)
				entering kitchen		
374049	Building D	Sink	Room D-4	Only sink	Water Fountain	5
374108	Building A	Sink	Room A-1	Only sink	Tap	5
374119	Building A	Sink	Room A-4	Only sink	Tap	5
374025	Building C	Sink	Room C-11	Only sink	Tap	4
374036	Building C	Sink	Room C-8	Only sink	Tap	4
374048	Building D	Sink	Room D-4	Only sink	Tap	4
374103	Building B	Sink - Multi-Compartment	Kitchen	Largest 3 tier sink	Tap	4
374109	Building A	Sink	Room A-1	Only sink	Water Fountain	4
374123	Building A	Sink	Room A-5	Only sink	Tap	4
374020	Building C	Sink	Room C-2	Only sink	Tap	3
374024	Building C	Sink	Room C-10	Only sink	Tap	3
374041	Building B	Sink	Music Room	Only sink	Water Fountain	3
374045	Building D	Sink	Room D-2	Only sink	Water Fountain	3
374047	Building D	Sink	Room D-3	Only sink	Water Fountain	3
374110	Building A	Sink	Health Room/Nurses Room	Only sink	Tap	3
374117	Building A	Sink	Room A-3	Only sink	Tap	3
374121	Building A	Sink	Room A-4	Only sink	Water Fountain	3

Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Lead Test Result (ppb)
374021	Building C	Sink	Room C-2	Only sink	Water Fountain	2
374027	Building C	Sink	Room C-12	Only sink	Tap	2
374028	Building C	Sink	Room C-12	Only sink	Water Fountain	2
374029	Building C	Sink	Room C-4	Only sink	Tap	2
374032	Building C	Sink	Room C-5	Only sink	Water Fountain	2
374034	Building C	Sink	Room C-9	Only sink	Tap	2
374038	Building C	Sink	Room C-7	Only sink	Water Fountain	2
374043	Building D	Sink	Room D-1	Only sink	Water Fountain	2
374044	Building D	Sink	Room D-2	Only sink	Tap	2
374101	Building B	Pot Filler	Kitchen	Middle of room	Tap	2
374133	Building A	Sink	Room A-8	Only sink	Water Fountain	2
374135	Building C	Fountain - Multi-Level	Hallway	Higher fountain. Across from room C-1	Water Fountain	2
374023	Building C	Sink	Room C-3	Only sink	Water Fountain	1
374026	Building C	Sink	Room C-11	Only sink	Water Fountain	1
374030	Building C	Sink	Room C-4	Only sink	Water Fountain	1
374031	Building C	Sink	Room C-5	Only sink	Tap	1
374037	Building C	Sink	Room C-7	Only sink	Tap	1
374046	Building	Sink	Room D-3	Only sink	Tap	1

Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Lead Test Result (ppb)
	D					
374111	Building A	Sink	Health/Nurses Room	Only sink	Water Fountain	1
374125	Building A	Sink	Room A-6	Only sink	Tap	1
374127	Building A	Sink	Room A-7	Only sink	Tap	1
374139	Building C	Sink	Room C-1	Only sink	Tap	1
374022	Building C	Sink	Room C-3	Only sink	Tap	<1
374042	Building D	Sink	Room D-1	Only sink	Tap	<1
374104	Building B	Sink	Kitchen	Left of dish washer	Sprayer	<1
374106	Building B	Fountain - Multi-Level	Gymnasium	In between restrooms. Higher fountain	Water Fountain	<1
374107	Building A	Sink	Room A-2	Only sink	Tap	<1
374113	Building A	Fountain - Multi-Level	Hallway	Next to electrical closest across from restrooms. Higher fountain	Water Fountain	<1
374115	Building A	Fountain - Multi-Level	Hallway	Across from restrooms	Water Fountain	<1
374129	Building A	Sink	Room A-7	Only sink	Water Fountain	<1
374137	Building C	Fountain - Multi-Level	Hallway	Across from room C-1	Water Fountain	<1

EXPLANATION OF TESTING AND RESULTS:

Results in this report represent sampling conducted by Washington State Department of Health. Per **RCW 28A.210.410** sampling and testing protocols, samples were collected as first-draw. Depending on size of the school(s) and number of drinking water fixtures, multiple dates for collecting samples may have been necessary to meet sampling and testing protocols. Above is information related to lead sampling for your school(s). For questions regarding testing and result, please email: **leadfreekids@doh.wa.gov**