Lead in School Drinking Water Report

Chain Lake Elementary School

Date(s) collected: 2023-04-14
Date(s) analyzed: 2023-04-20

Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Lead Test Result (ppb)
373511	Administration Building	Sink	Kitchen	Across from dishwasher	Sprayer	18
373510	Administration Building	Sink	Kitchen	Across from ndishwasher	Tap	9
373514	Administration Building	Sink	Kitchen	Next to dishwasher	Sprayer	7
373526	Building 100	Sink - Multi-Compartment	Room 108	Only sink	Water Fountain	4
373512	Administration Building	Sink - Multi-Compartment	Kitchen	Across from walk in cooler	Tap	3
373515	Administration Building	Sink	Health Room/Nurses Office	Only sink	Tap	2
373518	Building 100	Sink - Multi-Compartment	Room 104	Only sink	Water Fountain	2

Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Lead Test Result (ppb)
373522	Building 100	Sink - Multi-Compartment	Room 106	Only sink	Water Fountain	2
373528	Building 200	Sink - Multi-Compartment	Room 201	Only sink	Water Fountain	2
373539	Building 200	Sink - Multi-Compartment	Room 206	Only sink	Water Fountain	2
373554	Building 300	Sink - Multi-Compartment	Room 305	Only sink	Water Fountain	2
373513	Administration Building	Sink - Multi-Compartment	Kitchen	Across from walk in cooler	Sprayer	1
373519	Building 100	Sink - Multi-Compartment	Room 105	Only sink	Tap	1
373520	Building 100	Sink - Multi-Compartment	Room 105	Only sink	Water Fountain	1
373531	Building 200	Sink - Multi-Compartment	Room 202	Only sink	Water Fountain	1
373535	Building 200	Sink - Multi-Compartment	Room 204	Only sink	Water Fountain	1
373537	Building 200	Sink - Multi-Compartment	Room 205	Only sink	Water Fountain	1
373552	Building 300	Sink - Multi-Compartment	Room 304	Only sink	Water Fountain	1
373555	Building 300	Sink - Multi-Compartment	Room 306	Only sink	Tap	1
37355	Building 300	Sink - Multi-	Room 307	Only sink	Water	1

Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Lead Test Result (ppb)
8		Compartment			Fountain	
373516	Building 100	Fountain	Hallway	In between restrooms close to room 104	Water Fountain	<1
373517	Building 100	Sink - Multi-Compartment	Room 104	Only sink	Tap	<1
373521	Building 100	Sink - Multi-Compartment	Room 106	Only sink	Tap	<1
373523	Building 100	Sink - Multi-Compartment	Room 107	Only sink	Tap	<1
373524	Building 100	Sink - Multi-Compartment	Room 107	Only sink	Water Fountain	<1
373525	Building 100	Sink - Multi-Compartment	Room 108	Only sink	Tap	<1
373527	Building 200	Sink - Multi-Compartment	Room 201	Only sink	Tap	<1
373529	Building 200	Fountain	In Between Restrooms	Across from room 201	Water Fountain	<1
373530	Building 200	Sink - Multi-Compartment	Room 202	Only sink	Tap	<1
373532	Building 200	Sink - Multi-Compartment	Room 203	Only sink	Tap	<1
373533	Building 200	Sink - Multi-Compartment	Room 203	Only sink	Water Fountain	<1
37353	Building 200	Sink - Multi-	Room 204	Only sink	Tap	<1

Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Lead Test Result (ppb)
4		Compartment				
373536	Building 200	Sink - Multi-Compartment	Room 205	Only sink	Tap	<1
373538	Building 200	Sink - Multi-Compartment	Room 206	Only sink	Tap	<1
373540	Building 200	Sink - Multi-Compartment	Room 207	Only sink	Tap	<1
373541	Building 200	Sink - Multi-Compartment	Room 207	Only sink	Water Fountain	<1
373542	Building 200	Sink - Multi-Compartment	Room 208	Only sink	Tap	<1
373543	Building 200	Sink - Multi-Compartment	Room 208	Only sink	Water Fountain	<1
373544	Building 300	Sink - Multi-Compartment	Room 301	Only sink	Tap	<1
373545	Building 300	Sink - Multi-Compartment	Room 301	Only sink	Water Fountain	<1
373546	Building 300	Fountain	In Between Restrooms	Across from room 301	Water Fountain	<1
373547	Building 300	Sink - Multi-Compartment	Room 302	Only sink	Tap	<1
373548	Building 300	Sink - Multi-Compartment	Room 302	Only sink	Water Fountain	<1
373549	Building 300	Sink - Multi-Compartmen	Room 303	Only sink	Tap	<1

Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Lead Test Result (ppb)
		t				
373550	Building 300	Sink - Multi-Compartment	Room 303	Only sink	Water Fountain	<1
373551	Building 300	Sink - Multi-Compartment	Room 304	Only sink	Tap	<1
373553	Building 300	Sink - Multi-Compartment	Room 305	Only sink	Tap	<1
373556	Building 300	Sink - Multi-Compartment	Room 306	Only sink	Water Fountain	<1
373557	Building 300	Sink - Multi-Compartment	Room 307	Only sink	Tap	<1
373559	Building 300	Sink - Multi-Compartment	Room 308	Only sink	Tap	<1
373560	Building 300	Sink - Multi-Compartment	Room 308	Only sink	Water Fountain	<1
373561	Administration Building	Fountain	In Between Restrooms	Next to main offices	Water Fountain	<1

EXPLANATION OF TESTING AND RESULTS:

Results in this report represent sampling conducted by Washington State Department of Health. Per **RCW 28A.210.410** sampling and testing protocols, samples were collected as first-draw. Depending on size of the school(s) and number of drinking water fixtures, multiple dates for collecting samples may have been necessary to meet sampling and testing protocols. Above is information related to lead sampling for your school(s). For questions regarding testing and result, please email: **leadfreekids@doh.wa.gov**