Lead in School Drinking Water Report

Hidden River Middle School - Second Visit

Date(s) collected: 2023-06-07
Date(s) analyzed: 2023-06-28

Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Lead Test Result (ppb)
374228	Main Building	Sink	Room 110	Outlets facing back of room	Tap	3
374229	Main Building	Sink	Room 110	Outlets facing back of room	Tap	3
374225	Main Building	Sink	Room 110	3 outlets facing front of room	Tap	2
374226	Main Building	Sink	Room 110	3 outlets facing front of room	Tap	2
374227	Main Building	Sink	Room 110	Outlets facing back of room	Tap	2
374220	Main Building	Sink	Room 108	Only sink	Tap	1
374222	Main Building	Sink	Room 109	Only sink	Tap	1
374221	Main Building	Sink	Room 108	Only sink	Water Fountain	<1
374223	Main Building	Sink	Room 109	Only sink	Water Fountain	<1
374224	Main Building	Sink	Room 110	6 total outlets. 3 facing front of	Tap	<1

Sample ID	Building Name	Fixture Housing Type	Fixture Location	Fixture Location Details	Fixture Type	Lead Test Result (ppb)
				room		

EXPLANATION OF TESTING AND RESULTS:

Results in this report represent sampling conducted by Washington State Department of Health. Per **RCW 28A.210.410** sampling and testing protocols, samples were collected as first-draw. Depending on size of the school(s) and number of drinking water fixtures, multiple dates for collecting samples may have been necessary to meet sampling and testing protocols. Above is information related to lead sampling for your school(s). For questions regarding testing and result, please email: **leadfreekids@doh.wa.gov**