# Lead in School Drinking Water Report

## Fryelands Elementary School

Date(s) collected: 2023-04-19
Date(s) analyzed: 2023-04-28

| Sample ID | Building Name | Fixture Housing Type | Fixture Location | Fixture Location Details | Fixture Type | Lead Test Result (ppb) |
|---|---|---|---|---|---|---|
| 373708 | Main Building | Fountain - Multi-Level | 1st Floor Hallway | Across from room 05 | Water Fountain | 7 |
| 373709 | Main Building | Sink | Room 05 | Only sink | Tap | 7 |
| 373735 | Main Building | Sink | Room 21 | Only sink | Tap | 6 |
| 373565 | Main Building | Sink - Multi-Compartment | Kitchen | Largest 3 tier sink | Tap | 5 |
| 373721 | Main Building | Sink | Room 17 | Only sink | Tap | 5 |
| 373711 | Main Building | Sink | Room 04 | Only sink | Tap | 4 |
| 373731 | Main Building | Sink | Room 22 | Only sink | Tap | 4 |
| 373579 | Main Building | Sink | Room 09 | Only sink | Tap | 3 |
| 373661 | Main Building | Sink | Room 18 | Only sink | Tap | 3 |
| 373702 | Main | Sink | Room 07 | Only sink | Tap | 3 |

| Sample ID | Building Name | Fixture Housing Type | Fixture Location | Fixture Location Details | Fixture Type | Lead Test Result (ppb) |
|---|---|---|---|---|---|---|
| | Building | | | | | |
| 373713 | Main Building | Sink | Room 03 | Only sink | Tap | 3 |
| 373719 | Main Building | Sink | Room 16 | Only sink | Tap | 3 |
| 373723 | Main Building | Sink | Room 15 | Only sink | Tap | 3 |
| 373725 | Main Building | Sink | Room 14 | Only sink | Tap | 3 |
| 373729 | Main Building | Sink | Room 13 | Only sink | Tap | 3 |
| 373738 | Main Building | Sink | Room 20 | Only sink | Water Fountain | 3 |
| 373739 | Main Building | Sink | Room 19 | Only sink | Tap | 3 |
| 373573 | Main Building | Sink | Room 11 | Only sink | Tap | 2 |
| 373575 | Main Building | Sink | Room 12 | Only sink | Tap | 2 |
| 373577 | Main Building | Sink | Room 10 | Only sink | Tap | 2 |
| 373701 | Main Building | Sink | Room 08 | Only sink | Tap | 2 |
| 373705 | Main Building | Sink | Music Room | Only sink | Water Fountain | 2 |
| 373717 | Main Building | Sink | Room 01 | Only sink | Tap | 2 |
| 373562 | Main Building | Sink - Multi-Compartment | Kitchen | Food prep sink by entrance/exit door 2 tier | Tap | 1 |
| 373563 | Main Building | Sink - Multi-Compartment | Kitchen | 2 tier sink next to entrance/exit door food prep sink | Sprayer | 1 |
| 373569 | Main Building | Sink | Health Room | Only sink | Tap | 1 |
| 373570 | Main | Sink | Health | Only sink | Water | 1 |

| Sample ID | Building Name | Fixture Housing Type | Fixture Location | Fixture Location Details | Fixture Type | Lead Test Result (ppb) |
|---|---|---|---|---|---|---|
| | Building | | Room | | Fountain | |
| 373576 | Main Building | Sink | Room 12 | Only sink | Water Fountain | 1 |
| 373704 | Main Building | Sink | Music Room | Only sink | Tap | 1 |
| 373710 | Main Building | Sink | Room 05 | Only sink | Water Fountain | 1 |
| 373716 | Main Building | Sink | Room 02 | Only sink | Water Fountain | 1 |
| 373726 | Main Building | Sink | Room 14 | Only sink | Water Fountain | 1 |
| 373727 | Main Building | Fountain - Multi-Level | 2nd Floor Hallway | Higher fountain close to room 14 | Water Fountain | 1 |
| 373728 | Main Building | Fountain - Multi-Level | 2nd Floor Hallway | Lower fountain close to room 14 | Water Fountain | 1 |
| 373730 | Main Building | Sink | Room 13 | Only sink | Water Fountain | 1 |
| 373733 | Main Building | Fountain - Multi-Level | 2nd Floor Hallway | Next to room 22 higher fountain | Water Fountain | 1 |
| 373734 | Main Building | Fountain - Multi-Level | 2nd Floor Hallway | Lower fountain next to room 22 | Water Fountain | 1 |
| 373564 | Main Building | Sink - Multi-Compartment | Kitchen | Largest 3 tier sink to the left of dish washer | Tap | <1 |
| 373566 | Main Building | Sink | Kitchen | Right of dishwasher | Sprayer | <1 |
| 373567 | Main Building | Fountain | Gymnasium | 2 fountains total one on right side | Water Fountain | <1 |
| 373568 | Main Building | Fountain | Gymnasium | Fountain on left | Water Fountain | <1 |
| 373571 | Main Building | Fountain - Multi-Level | 1st Floor Hallway | Across from classroom 08 higher fountain | Water Fountain | <1 |
| 373572 | Main Building | Fountain - Multi-Level | 1st Floor Hallway | Across from classroom 08 | Water Fountain | <1 |
| 373574 | Main Building | Sink | Room 11 | Only sink | Water Fountain | <1 |

| Sample ID | Building Name | Fixture Housing Type | Fixture Location | Fixture Location Details | Fixture Type | Lead Test Result (ppb) |
|---|---|---|---|---|---|---|
| 373578 | Main Building | Sink | Room 10 | Only sink | Water Fountain | <1 |
| 373660 | Main Building | Sink | Room 19 | Only sink | Water Fountain | <1 |
| 373662 | Main Building | Sink | Room 18 | Only sink | Water Fountain | <1 |
| 373700 | Main Building | Sink | Room 09 | Only sink | Water Fountain | <1 |
| 373703 | Main Building | Sink | Room 07 | Only sink | Water Fountain | <1 |
| 373706 | Main Building | Sink | Room 06 | Only sink | Tap | <1 |
| 373707 | Main Building | Fountain - Multi-Level | 1st Floor Hallway | Across from room 05 higher fountain | Water Fountain | <1 |
| 373712 | Main Building | Sink | Room 04 | Only sink | Water Fountain | <1 |
| 373714 | Main Building | Sink | Room 03 | Only sink | Water Fountain | <1 |
| 373715 | Main Building | Sink | Room 02 | Only sink | Tap | <1 |
| 373718 | Main Building | Sink | Room 01 | Only sink | Water Fountain | <1 |
| 373720 | Main Building | Sink | Room 16 | Only sink | Water Fountain | <1 |
| 373722 | Main Building | Sink | Room 17 | Only sink | Water Fountain | <1 |
| 373724 | Main Building | Sink | Room 15 | Only sink | Water Fountain | <1 |
| 373732 | Main Building | Sink | Room 22 | Only sink | Water Fountain | <1 |
| 373736 | Main Building | Sink | Room 21 | Only sink | Water Fountain | <1 |
| 373737 | Main Building | Sink | Room 20 | Only sink | Tap | <1 |

## EXPLANATION OF TESTING AND RESULTS:

Results in this report represent sampling conducted by Washington State Department of Health. Per **RCW 28A.210.410** sampling and testing protocols, samples were collected as first-draw. Depending on size of the school(s) and number of drinking water fixtures, multiple dates for collecting samples may have been necessary to meet sampling and testing protocols. Above is information related to lead sampling for your school(s). For questions regarding testing and result, please email: **leadfreekids@doh.wa.gov**