


Eastern Analytical Services, Inc.
Water Sample Report

RE: CPN HOH-1030-16-IH - Hasting-On-Hudson UFSD


Date Collected: 03/23/2016
Collected By: Ernest Coon
Date Received: 03/23/2016
Date Analyzed: 03/24/2016
Analyzed By: Peter P. Argyrakis
Signature: 
Analyte: Pb Water
Analytical Method EPA 200.9
NYS Lab Number: 10851

Client: RegCom
245 Albany Avenue
Thornwood, NY 10594

Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
1A 2414087	HS/MS Health Office	Water	0.003 mg/L
1B 2414088	HS/MS Health Office	Water	0.001 mg/L
2A 2414089	Coustdian's Office	Water	0.001 mg/L
2B 2414090	Coustdian's Office	Water	0.001 mg/L
3A 2414091	Teacher's Lounge	Water	0.001 mg/L
3B 2414092	Teacher's Lounge	Water	0.001 mg/L
4A 2414093	W.F. Hallway Next to Room 252	Water	0.001 mg/L
4B 2414094	W.F. Hallway Next to Room 252	Water	0.001 mg/L
5A 2414095	W.F. Hallway Next to Room 357	Water	BDL < 0.001 mg/L

Eastern Analytical Services, Inc.
Water Sample Report

RE: CPN HOH-1030-16-IH - Hasting-On-Hudson UFSD


Date Collected: 03/23/2016
Collected By: Ernest Coon
Date Received: 03/23/2016
Date Analyzed: 03/24/2016
Analyzed By: Peter P. Argyrakis
Signature: 
Analyte: Pb Water
Analytical Method EPA 200.9
NYS Lab Number: 10851

Client: RegCom
245 Albany Avenue
Thornwood, NY 10594

Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
5B 2414096	W.F. Hallway Next to Room 357	Water	BDL < 0.001 mg/L
6A 2414097	MS/HS Cafeteria	Water	0.001 mg/L
6B 2414098	MS/HS Cafeteria	Water	0.001 mg/L
7A 2414099	W.F. Hallway Next to Room 265	Water	0.001 mg/L
7B 2414100	W.F. Hallway Next to Room 265	Water	0.002 mg/L
8A 2414101	W.F. Hallway Next to Room 165	Water	BDL < 0.001 mg/L
8B 2414102	W.F. Hallway Next to Room 165	Water	BDL < 0.001 mg/L
9A 2414103	Gym Lobby W.F. Next to Custodian Closet	Water	0.001 mg/L
9B 2414104	Gym Lobby W.F. Next to Custodian Closet	Water	0.001 mg/L

Eastern Analytical Services, Inc.
Water Sample Report

RE: CPN HOH-1030-16-IH - Hasting-On-Hudson UFSD


Date Collected: 03/23/2016
Collected By: Ernest Coon
Date Received: 03/23/2016
Date Analyzed: 03/24/2016
Analyzed By: Peter P. Argyrakis
Signature: 
Analyte: Pb Water
Analytical Method EPA 200.9
NYS Lab Number: 10851

Client: RegCom
245 Albany Avenue
Thornwood, NY 10594

Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
10A 2414105	W.F. Hallway Next to Room 224	Water	0.002 mg/L
10B 2414106	W.F. Hallway Next to Room 224	Water	0.003 mg/L
11A 2414107	HS Teacher's Lounge	Water	0.002 mg/L
11B 2414108	HS Teacher's Lounge	Water	BDL < 0.001 mg/L
12A 2414109	W.F. Hallway Near Room 332	Water	0.002 mg/L
12B 2414110	W.F. Hallway Near Room 332	Water	0.006 mg/L
13A 2414111	W.F. Hallway Near Room 305	Water	BDL < 0.001 mg/L
13B 2414112	W.F. Hallway Near Room 305	Water	0.001 mg/L
14A 2414113	W.F. High School Lobby	Water	0.002 mg/L

Eastern Analytical Services, Inc.
Water Sample Report

RE: CPN HOH-1030-16-IH - Hasting-On-Hudson UFSD

Date Collected: 03/23/2016
 Collected By: Ernest Coon
 Date Received: 03/23/2016
 Date Analyzed: 03/24/2016
 Analyzed By: Peter P. Argyrakis
 Signature: 
 Analyte: Pb Water
 Analytical Method EPA 200.9
 NYS Lab Number: 10851


Client: RegCom
 245 Albany Avenue
 Thornwood, NY 10594

Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
14B 2414114	W.F. High School Lobby	Water	0.003 mg/L
15A 2414115	Kitchen Sink Near Salar Bar	Water	0.001 mg/L
15B 2414116	Kitchen Sink Near Salar Bar	Water	0.001 mg/L
16A 2414117	MS W.F. Hallway Near Music Room 109	Water	0.002 mg/L
16B 2414118	MS W.F. Hallway Near Music Room 109	Water	0.002 mg/L
17A 2414119	Hillside Elementary School Main Office Kitchen Sink	Water	0.001 mg/L
17B 2414120	Hillside Elementary School Main Office Kitchen Sink	Water	BDL < 0.001 mg/L
18A 2414121	Hillside Elementary School Teacher's Lounge	Water	0.002 mg/L
18B 2414122	Hillside Elementary School Teacher's Lounge	Water	0.001 mg/L

BDL = Below Detectable Limits
 Liability Limited to Cost of Analysis
 Results Applicable to Those Items Tested

Eastern Analytical Services, Inc.
Water Sample Report

RE: CPN HOH-1030-16-IH - Hasting-On-Hudson UFSD


Date Collected: 03/23/2016
Collected By: Ernest Coon
Date Received: 03/23/2016
Date Analyzed: 03/24/2016
Analyzed By: Peter P. Argyrakis
Signature: 
Analyte: Pb Water
Analytical Method EPA 200.9
NYS Lab Number: 10851

Client: RegCom
245 Albany Avenue
Thornwood, NY 10594

Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
19A 2414123	Hillside Elementary School Caf� Sink	Water	0.001 mg/L
19B 2414124	Hillside Elementary School Caf� Sink	Water	BDL < 0.001 mg/L
20A 2414125	Hillside Elementary School WF Hallway Near Caf� (Room 159)	Water	BDL < 0.001 mg/L
20B 2414126	Hillside Elementary School WF Hallway Near Caf� (Room 159)	Water	0.001 mg/L
21A 2414127	Hillside Elementary School CR155	Water	0.008 mg/L
21B 2414128	Hillside Elementary School CR155	Water	0.144 mg/L
22A 2414129	Hillside Elementary School CR52	Water	0.083 mg/L
22B 2414130	Hillside Elementary School CR52	Water	0.005 mg/L
23A 2414131	Hillside Elementary School W.F. Hallway Outside Main Office	Water	0.001 mg/L

Eastern Analytical Services, Inc.
Water Sample Report

RE: CPN HOH-1030-16-IH - Hasting-On-Hudson UFSD

Date Collected: 03/23/2016
 Collected By: Ernest Coon
 Date Received: 03/23/2016
 Date Analyzed: 03/24/2016
 Analyzed By: Peter P. Argyrakis
 Signature: 
 Analyte: Pb Water
 Analytical Method EPA 200.9
 NYS Lab Number: 10851


Client: RegCom
 245 Albany Avenue
 Thornwood, NY 10594

Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
23B 2414132	Hillside Elementary School W.F. Hallway Outside Main Office	Water	BDL < 0.001 mg/L
24A 2414133	Hillside Elementary School Nurses Office	Water	0.013 mg/L
24B 2414134	Hillside Elementary School Nurses Office	Water	0.001 mg/L
25A 2414135	Hillside Elementary School W.F. Hallway Next to Room 137 Near Electrical Panel	Water	0.002 mg/L
25B 2414136	Hillside Elementary School W.F. Hallway Next to Room 137 Near Electrical Panel	Water	BDL < 0.001 mg/L
26A 2414137	Hillside Elementary School CR135	Water	0.003 mg/L
26B 2414138	Hillside Elementary School CR135	Water	BDL < 0.001 mg/L
27A 2414139	Hillside Elementary School W.F. Hallway Near CR124 Near Electrical Panel	Water	0.001 mg/L
27B 2414140	Hillside Elementary School W.F. Hallway Near CR124 Near Electrical Panel	Water	BDL < 0.001 mg/L

BDL = Below Detectable Limits
 Liability Limited to Cost of Analysis
 Results Applicable to Those Items Tested

Eastern Analytical Services, Inc.
Water Sample Report

RE: CPN HOH-1030-16-IH - Hasting-On-Hudson UFSD

Date Collected: 03/23/2016
Collected By: Ernest Coon
Date Received: 03/23/2016
Date Analyzed: 03/24/2016
Analyzed By: Peter P. Argyrakis
Signature: 
Analyte: Pb Water
Analytical Method EPA 200.9
NYS Lab Number: 10851

Client: RegCom
245 Albany Avenue
Thornwood, NY 10594

Sample ID# / Lab ID#	Sample Location	Sample Notes	Concentration
28A 2414141	Hillside Elementary School CR214	Water	0.002 mg/L
28B 2414142	Hillside Elementary School CR214	Water	0.001 mg/L