

Griffin Creek Elementary									
Radon Tests - Griffin Creek Elementary School									
#	Location/Type	Placement Description	Serial #	Dated Opened	Time Opened	Date Closed	Time Closed	Radon Test Results	Remarks
1	☉ Cafeteria # 1	S.E. Corner By Bear	2916945	3/28/2022	5:59 AM	3/30/2022	6:13 AM	0.6	
2	☉ Cafeteria # 2	N.W. Corner Table	2901003	3/28/2022	5:59 AM	3/30/2022	6:13 AM	0.5	
3	Cafeteria - Duplicate	S.E. Corner By Bear	2916045	3/28/2022	5:59 AM	3/30/2022	6:13 AM	0.3	
4	Cafeteria - Blank	N.W. Corner Table	2918238	3/28/2022	5:59 AM	3/30/2022	6:13 AM	0.1	
5	Main Office	Lisa's Desk	2916027	3/28/2022	6:06 AM	3/30/2022	6:16 AM	0.1	
6	Principal's Office	Louie's Desk	2918289	3/28/2022	6:07 AM	3/30/2022	6:16 AM	0.2	
7	Health Room	Top of Fridge	2916231	3/28/2022	6:08 AM	3/30/2022	6:17 AM	0.7	
8	Staff Work Room	S. Wall Cabinet	2917647	3/28/2022	6:09 AM	3/30/2022	6:18 AM	0.5	
9	Staff Break Room	S. Wall Cabinet	2917646	3/28/2022	6:10 AM	3/30/2022	6:19 AM	0.2	
10	Small Office Next to Room 20	Bookcase	2916923	3/28/2022	6:10 AM	3/30/2022	6:20 AM	0.6	
11	Room 20	File Cabinet	2916054	3/28/2022	6:11 AM	3/30/2022	6:21 AM	0.1	
12	Room 19	Top of Cubbie	2916930	3/28/2022	6:12 AM	3/30/2022	6:21 AM	0.4	
13	Room 18	Top of Cubbie	2916955	3/28/2022	6:13 AM	3/30/2022	6:22 AM	0.2	
14	Room 17	Top of Cubbie	2917599	3/28/2022	6:14 AM	3/30/2022	6:21 AM	0.2	
15	Room 17 - Blank	Top of Cubbie	2916082	3/28/2022	6:14 AM	3/30/2022	6:24 AM	0.1	
16	Room 16	Top of Cubbie	2916929	3/28/2022	6:16 AM	3/30/2022	6:25 AM	0.2	
17	Room 15	Top of Cubbie	2917606	3/28/2022	6:16 AM	3/30/2022	6:26 AM	0.1	
18	☉ Media Center (MC) # 1	Open Shelf Bottom of Ramp	2901036	3/28/2022	6:17 AM	3/30/2022	6:27 AM	0.5	
19	☉ Media Center(MC) # 2	Top of Fireplace	2916559	3/28/2022	6:20 AM	3/30/2022	6:27 AM	0.1	
20	MC Computer Room	Shelf Above Teachers Computer	2918244	3/28/2022	6:20 AM	3/30/2022	6:29 AM	0.8	
21	Media Center Office	N.W. Corner Countertop	2917601	3/28/2022	6:21 AM	3/30/2022	6:28 AM	0.8	
22	Music Room	N.E. Corner Desk	2916574	3/28/2022	5:58 AM	3/30/2022	6:13 AM	0.2	
23	Room 9	Center of Room	2917645	3/28/2022	6:00 AM	3/30/2022	6:14 AM	0.6	
24	Room 9 - Duplicate	Center of Room	2917633	3/28/2022	6:00 AM	3/30/2022	6:14 AM	0.4	
25	Room 10	N. Wall Center	2918292	3/28/2022	6:03 AM	3/30/2022	6:16 AM	0.3	
26	Room 11	N. Wall Center	2917600	3/28/2022	6:04 AM	3/30/2022	6:16 AM	0.4	
27	Room 12	N. Wall Center	2918223	3/28/2022	6:05 AM	3/30/2022	6:18 AM	2.4	
28	Room 13	N.E. Desk	2918285	3/28/2022	6:06 AM	3/30/2022	6:20 AM	1.4	
29	Room 14	E. Wall Desk	2918236	3/28/2022	6:09 AM	3/30/2022	6:22 AM	1.8	
30	☉ Gymnasium # 1	N.W. Wall By Stage	2902650	3/28/2022	6:15 AM	3/30/2022	6:25 AM	0.1	
31	Gymnasium # 1 Blank	N.W. Wall By Stage	2916965	3/28/2022	6:15 AM	3/30/2022	6:25 AM	0.1	
32	☉ Gymnasium # 2	S.W. Wall By Stage	2918225	3/28/2022	6:17 AM	3/30/2022	6:26 AM	0.5	
33	☉ Gymnasium # 3	S. Wall By Drinking Fountain	2917628	3/28/2022	6:18 AM	3/30/2022	6:26 AM	0.5	
34	Gymnasium - Stage	E. Wall Bookcase	2916053	3/28/2022	6:23 AM	3/30/2022	6:27 AM	0.2	
35	Gymnasium - Stage-Duplicate	E. Wall Bookcase	2903012	3/28/2022	6:23 AM	3/30/2022	6:27 AM	0.1	
36	Room 21	Middle Filing Cabinet	2916023	3/28/2022	6:26 AM	3/30/2022	6:31 AM	0.1	
37	Room 22	N. Wall Filing Cabinet	2916049	3/28/2022	6:28 AM	3/30/2022	6:33 AM	0.2	
38	Room 23	N.W. Wall Filing Cabinet	2917609	3/28/2022	6:31 AM	3/30/2022	6:34 AM	0.6	
39	Room 23 - Duplicate	N.W. Wall Filing Cabinet	2918270	3/28/2022	6:31 AM	3/30/2022	6:34 AM	0.1	
40	Room 24	S. Wall	2918233	3/28/2022	6:34 AM	3/30/2022	6:35 AM	0.1	
41	Room 25	N.W. Corner	2918197	3/28/2022	6:36 AM	3/30/2022	6:36 AM	0.1	
42	Room 25 - Blank	N.W. Corner	2916915	3/28/2022	6:36 AM	3/30/2022	6:36 AM	0.2	
43	Room 1	S. Wall Table	2918201	3/28/2022	6:00 AM	3/30/2022	6:07 AM	0.2	
44	Room 2	Top of Shelf	2901029	3/28/2022	6:03 AM	3/30/2022	6:10 AM	0.1	
45	Room 2 - Duplicate	Top of Shelf	2917635	3/28/2022	6:03 AM	3/30/2022	6:10 AM	0.1	
46	Room 3	S. Wall Filing Cabinet	2917611	3/28/2022	6:05 AM	3/30/2022	6:12 AM	0.1	
47	Room 4	E. Wall Shelf	2916015	3/28/2022	6:07 AM	3/30/2022	6:13 AM	0.8	
48	Room 7	N.E. Wall Counter Top	2917616	3/28/2022	6:09 AM	3/30/2022	6:14 AM	0.7	
49	Room 5	W. Wall Top of Shelf	2917618	3/28/2022	6:11 AM	3/30/2022	6:16 AM	2.3	
50	Room 8	W. Wall Desk	2918199	3/28/2022	6:15 AM	3/30/2022	6:17 AM	0.4	
51	Room 8 - Blank	W. wall desk	2917614	3/28/2022	6:16 AM	3/30/2022	6:17 AM	0.1	
52	Room 6	W. Wall Bookshelf	2918242	3/28/2022	6:18 AM	3/30/2022	6:18 AM	1.8	
53	Room 26	E. Wall Counter	2918202	3/28/2022	6:21 AM	3/30/2022	6:21 AM	1.1	
54	Room 27	E. Wall Cubbie	2918239	3/28/2022	6:22 AM	3/30/2022	6:22 AM	0.7	
55	Room 27 - Blank	E. Wall Cubbie	2918274	3/28/2022	6:23 AM	3/30/2022	6:23 AM	0.3	

56	Room 28	E. Wall Counter	2918234	3/28/2022	6:26 AM	3/30/2022	6:26 AM	0.2	
57	Room 28 - Duplicate	E. Wall Counter	2916041	3/28/2022	6:26 AM	3/30/2022	6:26 AM	0.2	
58	Room 29	E. Wall Counter	2916042	3/28/2022	6:27 AM	3/30/2022	6:27 AM	0.9	
#	Type	Description	Serial #	Dated Opened	Time Opened	Date Closed	Time Closed	Radon Test Results	Remarks
59	Spike # 1 (Room A)		2913657	28-Mar-22	6:00 AM	30-Mar-22	6:00 AM	20.7	
60	Spike # 2 (Room B)		2918203	28-Mar-22	6:00 AM	30-Mar-22	6:00 AM	21.5	