

## Hoover Elementary School

### Lead Tests - Hoover Elementary School - Main Building - # 20480200

#	Fixture ID #	Sample ID #	Location/Type	Date Tested	Lead Test Results	Remarks
1	20480200-001NS	20480200-001NS24A	Health Room - Sink	6/23/2016	Passed with 0.00385	The drinking fountain was removed from this sink on 1 July 2016.
2	20480200-002SF	20480200-002SF24A	Staff Work Room - Sink	6/23/2016	Passed with 0.00340	None.
3	20480200-003DW	20480200-003DW24A	Room 1 - Drinking Fountain	6/23/2016	Passed with 0.00118	None.
4	20480200-004CF	20480200-004CF24A	Room 1 - Sink	4/16/2019	Passed with 0.000764	None.
5	20480200-005WB	20480200-005WB24A	Outside Health Room - In Hallway - Bottle Filler	7/16/2021	Passed with None Detected	None.
6	20480200-006DF	20480200-006DF24A	Outside Health Room - In Hallway - Drinking Fountain	7/16/2021	Passed with None Detected	None.

### Lead Tests - Hoover Elementary School - Rooms 61-62 Building - # 20480201

#	Fixture ID #	Sample ID #	Location/Type	Date Tested	Lead Test Results	Remarks
1	20480201-001DW	20480201-001DW24A	Room 61 - Drinking Fountain	6/29/2017	Passed with 0.000441	This drinking fountain has a lead filter on it for copper.
2	20480201-002CF	20480201-002CF24A	Room 61 - Sink	4/16/2019	Passed with 0.000225	None.
3	20480201-003BF	20480201-003BF24A	Room 61 - Sink (Bathroom)	4/16/2019	Passed with 0.000294	None.
4	20480201-004DW	20480201-004DW24A	Room 62 - Drinking Fountain	6/23/2016	Passed with 0.000237	This drinking fountain has a lead filter on it for copper.
5	20480201-005CF	20480201-005CF24A	Room 62 - Sink	4/16/2019	Passed with 0.000251	None.
6	20480201-006BF	20480201-006BF24A	Room 62 - Sink (Bathroom)	4/16/2019	Passed with 0.000342	None.

### Lead Tests - Hoover Elementary School - Gym/Cafeteria - # 20480202

#	Fixture ID #	Sample ID #	Location/Type	Date Tested	Lead Test Results	Remarks
1	20480202-001DW	20480202-001DW24A	Gym - Drinking Fountain (Northeast Corner - Upper)	12/6/2019	Passed with None Detected	These replaced the previous DF and spit sink during the seismic work in 2019.
2	20480202-002DW	20480202-002DW24A	Gym - Drinking Fountain (Northeast Corner - Lower)	12/6/2019	Passed with None Detected	
3	20480202-003KF	20480202-003KF24A	Kitchen - Sink	4/16/2019	Passed with 0.00319	None.
4	20480202-004KF	20480202-004KF24A	Kitchen Vegetable Prep Sink - Double Sink	6/23/2016	Passed with 0.00599	None.
5	20480202-005KF	20480202-005KF24A	Kitchen - Sink (Dishwasher)	4/16/2019	Passed with 0.00634	None.
6	20480202-006BF	20480202-006BF24A	Kitchen - Sink (Restroom)	12/6/2019	Passed with 0.00376	None.
7	20480202-007DW	20480202-007DW24A	Outside Cafeteria - Drinking Fountain (Near Boiler Room)	6/23/2016	Passed with 0.00261	None.
8	20480202-008CF	20480202-008CF24A	Room 5 - Sink	4/16/2019	Passed with 0.000977	None.
9	20480202-009CF	20480202-009CF24A	Cafeteria - Utility Sink	7/16/2021	Passed with 3.42 ppb	None.

### Lead Tests - Hoover Elementary School - Media Center - # 20480203

#	Fixture ID #	Sample ID #	Location/Type	Date Tested	Lead Test Results	Remarks
1	20480203-001SF	20480203-001SF24A	Media Center - Sink (In Server Room)	4/16/2019	Passed with 0.00231	None.

### Lead Tests - Hoover Elementary School - Ramp 5 Upper Restrooms - # 20480204

#	Fixture ID #	Sample ID #	Location/Type	Date Tested	Lead Test Results	Remarks
1	20480204-001BF	20480204-001BF24A	Boys Restroom Outside Rooms 53/54 - Sink (Left)	4/16/2019	Passed with 0.00245	None.
2	20480204-002BF	20480204-002BF24A	Boys Restroom Outside Rooms 53/54 - Sink (Right)	4/16/2019	Passed with 0.00218	None.
3	20480204-003BF	20480204-003BF24A	Unisex Restroom Outside Rooms 53/54 - Sink	4/16/2019	Passed with 0.00134	None.
4	20480204-004BF	20480204-004BF24A	Girls Restroom Outside Rooms 53/54 - Sink (Left)	4/16/2019	Passed with 0.00128	None.
5	20480204-005BF	20480204-005BF24A	Girls Restroom Outside Rooms 53/54 - Sink (Right)	4/16/2019	Passed with 0.00464	None.

### Lead Tests - Hoover Elementary School - Ramp 1 - # 20480205

#	Fixture ID #	Sample ID #	Location/Type	Date Tested	Lead Test Results	Remarks
1	20480205-001BF	20480205-001BF24A	Boys Restroom Across From The Office - Sink (Left)	4/16/2019	Passed with 0.00164	None.
2	20480205-002BF	20480205-002BF24A	Boys Restroom Across From The Office - Sink (Right)	4/16/2019	Passed with 0.000510	None.
3	20480205-003BF	20480205-003BF24A	Girls Restroom Across From The Office - Sink (Left)	4/16/2019	Passed with 0.000294	None.
4	20480205-004BF	20480205-004BF24A	Girls Restroom Across From The Office - Sink (Right)	4/16/2019	Passed with 0.000747	None.
5	20480205-005DW	20480205-005DW24A	Room 11 - Drinking Fountain	6/29/2017	Passed with 0.00751	None.
6	20480205-006CF	20480205-006CF24A	Room 11 - Sink	4/16/2019	Passed with 0.00133	None.
7	20480205-007DW	20480205-007DW24A	Room 12 - Drinking Fountain	6/23/2016	Passed with 0.00558	None.
8	20480205-008CF	20480205-008CF24A	Room 12 - Sink	4/16/2019	Passed with 0.00392	None.
9	20480205-009DW	20480205-009DW24A	Room 13 - Drinking Fountain	6/18/2018	Passed with 0.00704	None.
10	20480205-010CF	20480205-010CF24A	Room 13 - Sink	4/16/2019	Passed with 0.00960	None.
11	20480205-011DW	20480205-011DW24A	Room 14 - Drinking Fountain	3/13/2020	Passed with 0.00407	None.
12	20480205-012CF	20480205-012CF24A	Room 14 - Sink	4/16/2019	Passed with 0.00923	None.

### Lead Tests - Hoover Elementary School - Ramp 2 - # 20480206

#	Fixture ID #	Sample ID #	Location/Type	Date Tested	Lead Test Results	Remarks
1	20480206-001IM	20480206-001IM24A	Staff Break Room Refrigerator - Ice Maker/Water	2/14/2020	Passed with 0.000260	This supply line has a lead filter on it.
2	20480206-002SF	20480206-002SF24A	Staff Break Room - Sink (Main Fixture)	6/18/2018	Passed with 0.000481	None.
3	20480206-003SF	20480206-003SF24A	Staff Break Room - Sink (Insta-Hot)	6/29/2016	Passed with 0.000283	None.
4	20480206-004SF	20480206-004SF24A	Small Room Adjacent To Staff Break Room - Sink	3/13/2020	Passed with 0.00598	None.
5	20480206-005BF	20480206-005BF24A	West Side Ramp 2 Mens Restroom (Staff Only) - Sink	4/16/2019	Passed with 0.00134	None.
6	20480206-006BF	20480206-006BF24A	West Side Ramp 2 Womens Restroom (Staff Only) - Sink (Left)	4/16/2019	Passed with 0.00151	None.
7	20480206-007BF	20480206-007BF24A	West Side Ramp 2 Womens Restroom (Staff Only) - Sink (Right)	4/16/2019	Passed with 0.00122	None.
8	20480206-008DW	20480206-008DW24A	Room 21 - Drinking Fountain	6/23/2016	Passed with 0.00283	None.
9	20480206-009CF	20480206-009CF24A	Room 21 - Sink	4/16/2019	Passed with 0.00972	None.
10	20480206-010DW	20480206-010DW24A	Room 22 - Drinking Fountain	6/29/2017	Passed with 0.00229	None.
11	20480206-011CF	20480206-011CF24A	Room 22 - Sink	4/16/2019	Passed with 0.000778	None.
12	20480206-012DW	20480206-012DW24A	Room 23 - Drinking Fountain	6/23/2016	Passed with 0.00344	None.
13	20480206-013CF	20480206-013CF24A	Room 23 - Sink	4/16/2019	Passed with 0.00294	None.
14	20480206-014DW	20480206-014DW24A	Room 24 - Drinking Fountain	6/23/2016	Passed with 0.00129	None.

15	20480206-015CF	20480206-015CF24A	Room 24 - Sink	4/16/2019	Passed with 0.00135	None.
<b>Lead Tests - Hoover Elementary School - Ramp 3 - # 20480207</b>						
#	Fixture ID #	Sample ID #	Location/Type	Date Tested	Lead Test Results	Remarks
1	20480207-001BF	20480207-001BF24A	West Side Ramp 3 Boys Restroom - Sink (Left)	4/16/2019	Passed with 0.000424	None.
2	20480207-002BF	20480207-002BF24A	West Side Ramp 3 Boys Restroom - Sink (Right)	4/16/2019	Passed with 0.000780	None.
3	20480207-003BF	20480207-003BF24A	West Side Ramp 3 Girls Restroom - Sink (Left)	4/16/2019	Passed with 0.000612	None.
4	20480207-004BF	20480207-004BF24A	West Side Ramp 3 Girls Restroom - Sink (Right)	4/16/2019	Passed with 0.00124	None.
5	20480207-005DW	20480207-005DW24A	Room 31 - Drinking Fountain	3/13/2020	Passed with 0.00118	None.
6	20480207-006CF	20480207-006CF24A	Room 31 - Sink	4/16/2019	Passed with 0.00145	None.
7	20480207-007DW	20480207-007DW24A	Room 32 - Drinking Fountain	6/23/2016	Passed with 0.00172	None.
8	20480207-008CF	20480207-008CF24A	Room 32 - Sink	4/16/2019	Passed with 0.00241	None.
9	20480207-009DW	20480207-009DW24A	Room 33 - Drinking Fountain	6/23/2016	Passed with 0.00551	None.
10	20480207-010CF	20480207-010CF24A	Room 33 - Sink	4/16/2019	Passed with 0.000473	None.
11	20480207-011DW	20480207-011DW24A	Room 34 - Drinking Fountain	6/20/2018	Passed with 0.00238	None.
12	20480207-012CF	20480207-012CF24A	Room 34 - Sink	4/16/2019	Passed with 0.000392	None.
<b>Lead Tests - Hoover Elementary School - Ramp 4 - # 20480208</b>						
#	Fixture ID #	Sample ID #	Location/Type	Date Tested	Lead Test Results	Remarks
1	20480208-001DW	20480208-001DW24A	Room 41 - Drinking Fountain	6/23/2016	Passed with 0.00120	None.
2	20480208-002CF	20480208-002CF24A	Room 41 - Sink	4/16/2019	Passed with 0.00233	None.
3	20480208-003DW	20480208-003DW24A	Room 42 - Drinking Fountain	6/23/2016	Passed with 0.000436	None.
4	20480208-004CF	20480208-004CF24A	Room 42 - Sink	4/16/2019	Passed with 0.00282	None.
5	20480208-005DW	20480208-005DW24A	Room 43 - Drinking Fountain	6/23/2016	Passed with 0.000699	None.
6	20480208-006CF	20480208-006CF24A	Room 43 - Sink	4/16/2019	Passed with 0.00232	None.
7	20480208-007DW	20480208-007DW24A	Room 44 - Drinking Fountain	6/23/2016	Passed with 0.000504	None.
8	20480208-008CF	20480208-008CF24A	Room 44 - Sink	4/16/2019	Passed with 0.00197	None.
<b>Lead Tests - Hoover Elementary School - Rooms 45-48 Building - # 20480209</b>						
#	Fixture ID #	Sample ID #	Location/Type	Date Tested	Lead Test Results	Remarks
1	20480209-001DW	20480209-001DW24A	Room 45 - Drinking Fountain	6/23/2016	Passed with 0.00627	None.
2	20480209-002CF	20480209-002CF24A	Room 45 - Sink	4/16/2019	Passed with 0.00746	None.
3	20480209-003DW	20480209-003DW24A	Room 46 - Drinking Fountain	6/23/2016	Passed with 0.00316	None.
4	20480209-004CF	20480209-004CF24A	Room 46 - Sink	4/16/2019	Passed with 0.00522	None.
5	20480209-005DW	20480209-005DW24A	Room 47 - Drinking Fountain	6/23/2016	Passed with 0.00139	None.
6	20480209-006CF	20480209-006CF24A	Room 47 - Sink	4/16/2019	Passed with 0.00260	None.
7	20480209-007DW	20480209-007DW24A	Room 48 - Drinking Fountain	9/1/2016	Passed with 0.00886	None.
8	20480209-008CF	20480209-008CF24A	Room 48 - Sink	4/16/2019	Passed with 0.00439	None.
9	20480209-009BF	20480209-009BF24A	Room 48 - Sink (Restroom)	4/16/2019	Passed with 0.00118	None.
<b>Lead Tests - Hoover Elementary School - Ramp 5 - # 20480210</b>						
#	Fixture ID #	Sample ID #	Location/Type	Date Tested	Lead Test Results	Remarks
1	20480210-001DW	20480210-001DW24A	West Side of Ramp 5 - Drinking Fountain (Outdoors)	6/20/2018	Passed with 0.000255	None.
2	20480210-002BF	20480210-002BF24A	West Side of Ramp 5 Boys Restroom - Sink (Left)	4/16/2019	Passed with 0.00469	None.
3	20480210-003BF	20480210-003BF24A	West Side of Ramp 5 Boys Restroom - Sink (Right)	4/16/2019	Passed with 0.00319	None.
4	20480210-004BF	20480210-004BF24A	West Side of Ramp 5 Girls Restroom - Sink (Left)	4/16/2019	Passed with 0.00512	None.
5	20480210-005BF	20480210-005BF24A	West Side of Ramp 5 Girls Restroom - Sink (Right)	4/16/2019	Passed with 0.00479	None.
6	20480210-006DW	20480210-006DW24A	Room 51 - Drinking Fountain	6/23/2016	Passed with 0.00189	None.
7	20480210-007CF	20480210-007CF24A	Room 51 - Sink	4/16/2019	Passed with 0.00358	None.
8	20480210-008DW	20480210-008DW24A	Room 52 - Drinking Fountain	6/23/2016	Passed with 0.00252	None.
9	20480210-009CF	20480210-009CF24A	Room 52 - Sink	12/6/2019	Passed with 0.00171	None.
10	20480210-010DW	20480210-010DW24A	Room 53 - Drinking Fountain	6/23/2016	Passed with 0.00227	None.
11	20480210-011CF	20480210-011CF24A	Room 53 - Sink	4/16/2019	Passed with 0.00291	None.
12	20480210-012DW	20480210-012DW24A	Room 54 - Drinking Fountain	6/29/2017	Passed with 0.00104	This drinking fountain has a lead filter on it.
13	20480210-013CF	20480210-013CF24A	Room 54 - Sink	4/16/2019	Passed with 0.00283	None.
<b>Lead Tests - Hoover Elementary School - Rooms 55-56 Building - # 20480211</b>						
#	Fixture ID #	Sample ID #	Location/Type	Date Tested	Lead Test Results	Remarks
1	20480211-001DW	20480211-001DW24A	Room 55 - Drinking Fountain	6/23/2016	Passed with 0.000588	None.
2	20480211-002CF	20480211-002CF24A	Room 55 - Sink	4/16/2019	Passed with None Detected	None.
3	20480211-003DW	20480211-003DW24A	Room 56 - Drinking Fountain	3/13/2020	Passed with 0.000749	None.
4	20480211-004CF	20480211-004CF24A	Room 56 - Sink	4/16/2019	Passed with 0.000668	None.

\*None Detected (ND) = .005 Or Less

 = Fixture Where Water Has The Potential of Being Consumed (All of These Will Be Tested When Testing The Whole School)

\*ODE's required action level is 15 parts per billion (PPB)

\*The E.P.A.'s recommended action level for lead in schools is 0.020. Oregon's action level for schools changed to 0.015 in 2019 in accordance with OAR 333-061-0400. In 2021, ODE changed the unit of measurement for reporting to parts per billion (PPB)

\*The E.P.A. action level for copper is 1.30

\*Lead test results will be posted on the MSD/Facilities website within 5 days minus the school map for security purposes.