



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

May 02, 2019

Andy Chasteen
Medford School District
815 S Oakdale Ave
Medford, OR 97501
TEL: 541-842-3646
FAX: 541-842-1160

RE: 18-16 Hoover 2019 Lead Testing

Order No.: 19040669

Dear Andy Chasteen:

Neilson Research Corporation received 57 sample(s) on 4/16/2019 for the analyses presented in the following report.

The results relate only to the parameters tested or to the sample as received by the laboratory. This report shall not be reproduced except in full, without the written approval of Neilson Research Corporation. If you have any questions regarding these test results, please feel free to call.

Sincerely,
Neilson Research Corporation

Tamra Schmedemann
Senior Project Manager
245 S Grape St
Medford, OR 97501

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Case Narrative

WO#: 19040669
Date: 5/2/2019

CLIENT: Medford School District
Project: 18-16 Hoover 2019 Lead Testing

The analyses were performed according to the guidelines in the Neilson Research Corporation Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

Neilson Research Corporation certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 19040669
 Date Reported: 5/2/2019

Medford School District
 815 S Oakdale Ave
 Medford, OR 97501

Lab Order: 19040669
Received Date: 4/16/2019 9:11:00 AM
Reported Date: 5/2/2019 12:13:48 PM

Sample Information:

Lab ID: 19040669-01 Client Sample ID: Room 41-Sink
 Collection Date: 4/16/2019 6:04:00 AM Collected By: Roger Moulard
 Matrix: Drinking Water Sample Location: Room 41-Sink

Trace Metals by EPA 200.8 ICP-MS								Analyst: CSB
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.00233		0.000100	mg/L	1	4/29/2019	0.0150	A

Lab ID: 19040669-02 Client Sample ID: Room 42-Sink
 Collection Date: 4/16/2019 6:06:00 AM Collected By: Roger Moulard
 Matrix: Drinking Water Sample Location: Room 42-Sink

Trace Metals by EPA 200.8 ICP-MS								Analyst: CSB
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.00282		0.000100	mg/L	1	4/29/2019	0.0150	A

Lab ID: 19040669-03 Client Sample ID: Room 43-Sink
 Collection Date: 4/16/2019 6:08:00 AM Collected By: Roger Moulard
 Matrix: Drinking Water Sample Location: Room 43-Sink

Trace Metals by EPA 200.8 ICP-MS								Analyst: CSB
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.00232		0.000100	mg/L	1	4/29/2019	0.0150	A

QUALIFIERS	* Value exceeds Maximum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	MI Recovery outside control limits due to Matrix Interference
	ND Not Detected at the Reporting Limit	PL Permit Limit
	R RPD outside accepted recovery limits	

Results are out of the EPA limits

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 19040669
 Date Reported: 5/2/2019

Medford School District
 815 S Oakdale Ave
 Medford, OR 97501

Lab Order: 19040669
Received Date: 4/16/2019 9:11:00 AM
Reported Date: 5/2/2019 12:13:48 PM

Sample Information:

Lab ID: 19040669-04 Client Sample ID: Room 44-Sink
 Collection Date: 4/16/2019 6:10:00 AM Collected By: Roger Moulard
 Matrix: Drinking Water Sample Location: Room 44-Sink

Trace Metals by EPA 200.8 ICP-MS								Analyst: CSB
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.00197		0.000100	mg/L	1	4/29/2019	0.0150	A

Lab ID: 19040669-05 Client Sample ID: Room 45-Sink
 Collection Date: 4/16/2019 6:12:00 AM Collected By: Roger Moulard
 Matrix: Drinking Water Sample Location: Room 45-Sink

Trace Metals by EPA 200.8 ICP-MS								Analyst: CSB
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.00746		0.000100	mg/L	1	4/29/2019	0.0150	A

Lab ID: 19040669-06 Client Sample ID: Room 46-Sink
 Collection Date: 4/16/2019 6:13:00 AM Collected By: Roger Moulard
 Matrix: Drinking Water Sample Location: Room 46-Sink

Trace Metals by EPA 200.8 ICP-MS								Analyst: CSB
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.00522		0.000100	mg/L	1	4/29/2019	0.0150	A

QUALIFIERS	* Value exceeds Maximum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	MI Recovery outside control limits due to Matrix Interference
	ND Not Detected at the Reporting Limit	PL Permit Limit
	R RPD outside accepted recovery limits	

Results are out of the EPA limits

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 19040669
 Date Reported: 5/2/2019

Medford School District
 815 S Oakdale Ave
 Medford, OR 97501

Lab Order: 19040669
Received Date: 4/16/2019 9:11:00 AM
Reported Date: 5/2/2019 12:13:48 PM

Sample Information:

Lab ID: 19040669-07 Client Sample ID: Room 47-Sink
 Collection Date: 4/16/2019 6:16:00 AM Collected By: Roger Moulard
 Matrix: Drinking Water Sample Location: Room 47-Sink

Trace Metals by EPA 200.8 ICP-MS								Analyst: CSB
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.00260		0.000100	mg/L	1	4/29/2019	0.0150	A

Lab ID: 19040669-08 Client Sample ID: Room 48-Sink
 Collection Date: 4/16/2019 6:18:00 AM Collected By: Roger Moulard
 Matrix: Drinking Water Sample Location: Room 48-Sink

Trace Metals by EPA 200.8 ICP-MS								Analyst: CSB
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.00439		0.000100	mg/L	1	4/29/2019	0.0150	A

Lab ID: 19040669-09 Client Sample ID: Room 48-Sink (RR)
 Collection Date: 4/16/2019 6:18:00 AM Collected By: Roger Moulard
 Matrix: Drinking Water Sample Location: Room 48-Sink (RR)

Trace Metals by EPA 200.8 ICP-MS								Analyst: CSB
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.00118		0.000100	mg/L	1	4/29/2019	0.0150	A

QUALIFIERS	* Value exceeds Maximum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	MI Recovery outside control limits due to Matrix Interference
	ND Not Detected at the Reporting Limit	PL Permit Limit
	R RPD outside accepted recovery limits	

Results are out of the EPA limits

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 19040669
 Date Reported: 5/2/2019

Medford School District
 815 S Oakdale Ave
 Medford, OR 97501

Lab Order: 19040669
Received Date: 4/16/2019 9:11:00 AM
Reported Date: 5/2/2019 12:13:48 PM

Sample Information:

Lab ID: 19040669-10 Client Sample ID: W Side of Ramp 5 Boys RR-Sink (L)
 Collection Date: 4/16/2019 6:21:00 AM Collected By: Roger Moulard
 Matrix: Drinking Water Sample Location: W Side of Ramp 5 Boys RR-Sink (L)

Trace Metals by EPA 200.8 ICP-MS								Analyst: CSB
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.00469		0.000100	mg/L	1	4/29/2019	0.0150	A

Lab ID: 19040669-11 Client Sample ID: W Side of Ramp 5 Boys RR-Sink (R)
 Collection Date: 4/16/2019 6:21:00 AM Collected By: Roger Moulard
 Matrix: Drinking Water Sample Location: W Side of Ramp 5 Boys RR-Sink (R)

Trace Metals by EPA 200.8 ICP-MS								Analyst: CSB
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.00319		0.000100	mg/L	1	4/29/2019	0.0150	A


Lab ID: 19040669-12 Client Sample ID: W Side of Ramp 5 Girls RR-Sink (L)
 Collection Date: 4/16/2019 6:23:00 AM Collected By: Roger Moulard
 Matrix: Drinking Water Sample Location: W Side of Ramp 5 Girls RR-Sink (L)

Trace Metals by EPA 200.8 ICP-MS								Analyst: CSB
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.00512		0.000100	mg/L	1	4/29/2019	0.0150	A

QUALIFIERS	* Value exceeds Maximum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	MI Recovery outside control limits due to Matrix Interference
	ND Not Detected at the Reporting Limit	PL Permit Limit
	R RPD outside accepted recovery limits	

Results are out of the EPA limits

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 19040669
 Date Reported: 5/2/2019

Medford School District
 815 S Oakdale Ave
 Medford, OR 97501

Lab Order: 19040669
Received Date: 4/16/2019 9:11:00 AM
Reported Date: 5/2/2019 12:13:48 PM

Sample Information:

Lab ID: 19040669-13 Client Sample ID: W Side of Ramp 5 Girls RR-Sink (R)
 Collection Date: 4/16/2019 6:23:00 AM Collected By: Roger Moulard
 Matrix: Drinking Water Sample Location: W Side of Ramp 5 Girls RR-Sink (R)

Trace Metals by EPA 200.8 ICP-MS								Analyst:	CSB
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.00479		0.000100	mg/L	1	4/29/2019	0.0150	A	

Lab ID: 19040669-14 Client Sample ID: Room 51-Sink
 Collection Date: 4/16/2019 6:25:00 AM Collected By: Roger Moulard
 Matrix: Drinking Water Sample Location: Room 51-Sink

Trace Metals by EPA 200.8 ICP-MS								Analyst:	CSB
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.00358		0.000100	mg/L	1	4/29/2019	0.0150	A	

Lab ID: 19040669-15 Client Sample ID: Room 52-Sink
 Collection Date: 4/16/2019 6:27:00 AM Collected By: Roger Moulard
 Matrix: Drinking Water Sample Location: Room 52-Sink

Trace Metals by EPA 200.8 ICP-MS								Analyst:	CSB
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status	
Lead	0.0177	*	0.000100	mg/L	1	4/29/2019	0.0150	A	

QUALIFIERS	* Value exceeds Maximum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	MI Recovery outside control limits due to Matrix Interference
	ND Not Detected at the Reporting Limit	PL Permit Limit
	R RPD outside accepted recovery limits	

Results are out of the EPA limits

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 19040669
 Date Reported: 5/2/2019

Medford School District
 815 S Oakdale Ave
 Medford, OR 97501

Lab Order: 19040669
Received Date: 4/16/2019 9:11:00 AM
Reported Date: 5/2/2019 12:13:48 PM

Sample Information:

Lab ID: 19040669-16 Client Sample ID: Room 53-Sink
 Collection Date: 4/16/2019 6:28:00 AM Collected By: Roger Moulard
 Matrix: Drinking Water Sample Location: Room 53-Sink

Trace Metals by EPA 200.8 ICP-MS								Analyst: CSB
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.00291		0.000100	mg/L	1	4/29/2019	0.0150	A

Lab ID: 19040669-17 Client Sample ID: Room 54-Sink
 Collection Date: 4/16/2019 6:30:00 AM Collected By: Roger Moulard
 Matrix: Drinking Water Sample Location: Room 54-Sink

Trace Metals by EPA 200.8 ICP-MS								Analyst: CSB
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.00283		0.000100	mg/L	1	4/29/2019	0.0150	A

Lab ID: 19040669-18 Client Sample ID: Boys RR Outside Rms 53/54-Sink (L)
 Collection Date: 4/16/2019 6:32:00 AM Collected By: Roger Moulard
 Matrix: Drinking Water Sample Location: Boys RR Outside Rms 53/54-Sink (L)

Trace Metals by EPA 200.8 ICP-MS								Analyst: CSB
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.00245		0.000100	mg/L	1	4/29/2019	0.0150	A

QUALIFIERS	* Value exceeds Maximum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	MI Recovery outside control limits due to Matrix Interference
	ND Not Detected at the Reporting Limit	PL Permit Limit
	R RPD outside accepted recovery limits	

Results are out of the EPA limits

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 19040669
 Date Reported: 5/2/2019

Medford School District
 815 S Oakdale Ave
 Medford, OR 97501

Lab Order: 19040669
Received Date: 4/16/2019 9:11:00 AM
Reported Date: 5/2/2019 12:13:48 PM

Sample Information:

Lab ID: 19040669-19 Client Sample ID: Boys RR Outside Rms 53/54-Sink (R)
 Collection Date: 4/16/2019 6:32:00 AM Collected By: Roger Moulard
 Matrix: Drinking Water Sample Location: Boys RR Outside Rms 53/54-Sink (R)

Trace Metals by EPA 200.8 ICP-MS								Analyst: CSB
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.00218		0.000100	mg/L	1	4/29/2019	0.0150	A

Lab ID: 19040669-20 Client Sample ID: Unisex RR Outside Rms 53/54-Sink
 Collection Date: 4/16/2019 6:37:00 AM Collected By: Roger Moulard
 Matrix: Drinking Water Sample Location: Unisex RR Outside Rms 53/54-Sink

Trace Metals by EPA 200.8 ICP-MS								Analyst: CSB
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.00134		0.000100	mg/L	1	4/29/2019	0.0150	A

Lab ID: 19040669-21 Client Sample ID: Girls RR Outside Rms 53/54-Sink (L)
 Collection Date: 4/16/2019 6:34:00 AM Collected By: Roger Moulard
 Matrix: Drinking Water Sample Location: Girls RR Outside Rms 53/54-Sink (L)

Trace Metals by EPA 200.8 ICP-MS								Analyst: CSB
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.00128		0.000100	mg/L	1	4/29/2019	0.0150	A

QUALIFIERS	* Value exceeds Maximum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	MI Recovery outside control limits due to Matrix Interference
	ND Not Detected at the Reporting Limit	PL Permit Limit
	R RPD outside accepted recovery limits	

Results are out of the EPA limits

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 19040669
 Date Reported: 5/2/2019

Medford School District
 815 S Oakdale Ave
 Medford, OR 97501

Lab Order: 19040669
Received Date: 4/16/2019 9:11:00 AM
Reported Date: 5/2/2019 12:13:48 PM

Sample Information:

Lab ID: 19040669-22 Client Sample ID: Girls RR Outside Rms 53/54-Sink (R)
 Collection Date: 4/16/2019 6:34:00 AM Collected By: Roger Moulard
 Matrix: Drinking Water Sample Location: Girls RR Outside Rms 53/54-Sink (R)

Trace Metals by EPA 200.8 ICP-MS								Analyst: CSB
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.00464		0.000100	mg/L	1	4/29/2019	0.0150	A

Lab ID: 19040669-23 Client Sample ID: Room 55-Sink
 Collection Date: 4/16/2019 6:39:00 AM Collected By: Roger Moulard
 Matrix: Drinking Water Sample Location: Room 55-Sink

Trace Metals by EPA 200.8 ICP-MS								Analyst: CSB
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.000100	mg/L	1	4/29/2019	0.0150	A

Lab ID: 19040669-24 Client Sample ID: Room 56-Sink
 Collection Date: 4/16/2019 6:40:00 AM Collected By: Roger Moulard
 Matrix: Drinking Water Sample Location: Room 56-Sink

Trace Metals by EPA 200.8 ICP-MS								Analyst: CSB
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.000668		0.000100	mg/L	1	4/29/2019	0.0150	A

QUALIFIERS	* Value exceeds Maximum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	MI Recovery outside control limits due to Matrix Interference
	ND Not Detected at the Reporting Limit	PL Permit Limit
	R RPD outside accepted recovery limits	

Results are out of the EPA limits

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 19040669
 Date Reported: 5/2/2019

Medford School District
 815 S Oakdale Ave
 Medford, OR 97501

Lab Order: 19040669
Received Date: 4/16/2019 9:11:00 AM
Reported Date: 5/2/2019 12:13:48 PM

Sample Information:

Lab ID: 19040669-25 Client Sample ID: Room 61-Sink
 Collection Date: 4/16/2019 6:43:00 AM Collected By: Roger Moulard
 Matrix: Drinking Water Sample Location: Room 61-Sink

Trace Metals by EPA 200.8 ICP-MS								Analyst: CSB
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.000225		0.000100	mg/L	1	4/29/2019	0.0150	A

Lab ID: 19040669-26 Client Sample ID: Room 61-Sink (Bathroom)
 Collection Date: 4/16/2019 6:44:00 AM Collected By: Roger Moulard
 Matrix: Drinking Water Sample Location: Room 61-Sink (Bathroom)

Trace Metals by EPA 200.8 ICP-MS								Analyst: CSB
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.000294		0.000100	mg/L	1	4/29/2019	0.0150	A

Lab ID: 19040669-27 Client Sample ID: Room 62-Sink
 Collection Date: 4/16/2019 6:46:00 AM Collected By: Roger Moulard
 Matrix: Drinking Water Sample Location: Room 62-Sink

Trace Metals by EPA 200.8 ICP-MS								Analyst: CSB
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.000251		0.000100	mg/L	1	4/29/2019	0.0150	A

QUALIFIERS	* Value exceeds Maximum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	MI Recovery outside control limits due to Matrix Interference
	ND Not Detected at the Reporting Limit	PL Permit Limit
	R RPD outside accepted recovery limits	

Results are out of the EPA limits

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 19040669
 Date Reported: 5/2/2019

Medford School District
 815 S Oakdale Ave
 Medford, OR 97501

Lab Order: 19040669
Received Date: 4/16/2019 9:11:00 AM
Reported Date: 5/2/2019 12:13:48 PM

Sample Information:

Lab ID: 19040669-28 Client Sample ID: Room 62-Sink (Bathroom)
 Collection Date: 4/16/2019 6:46:00 AM Collected By: Roger Moulard
 Matrix: Drinking Water Sample Location: Room 62-Sink (Bathroom)

Trace Metals by EPA 200.8 ICP-MS								Analyst: CSB
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.000342		0.000100	mg/L	1	4/29/2019	0.0150	A

Lab ID: 19040669-29 Client Sample ID: Boys RR Across From Office-Sink (L)
 Collection Date: 4/16/2019 6:06:00 AM Collected By:
 Matrix: Drinking Water Sample Location: Boys RR Across From Office-Sink (L)

Trace Metals by EPA 200.8 ICP-MS								Analyst: CSB
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.00164		0.000100	mg/L	1	4/29/2019	0.0150	A

Lab ID: 19040669-30 Client Sample ID: Boys RR Across From Office-Sink (R)
 Collection Date: 4/16/2019 6:06:00 AM Collected By:
 Matrix: Drinking Water Sample Location: Boys RR Across From Office-Sink (R)

Trace Metals by EPA 200.8 ICP-MS								Analyst: CSB
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.000510		0.000100	mg/L	1	4/30/2019	0.0150	A

QUALIFIERS	* Value exceeds Maximum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	MI Recovery outside control limits due to Matrix Interference
	ND Not Detected at the Reporting Limit	PL Permit Limit
	R RPD outside accepted recovery limits	

Results are out of the EPA limits

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 19040669
 Date Reported: 5/2/2019

Medford School District
 815 S Oakdale Ave
 Medford, OR 97501

Lab Order: 19040669
Received Date: 4/16/2019 9:11:00 AM
Reported Date: 5/2/2019 12:13:48 PM

Sample Information:

Lab ID: 19040669-31 Client Sample ID: Girls RR Across From Office-Sink (L)
 Collection Date: 4/16/2019 6:05:00 AM Collected By:
 Matrix: Drinking Water Sample Location: Girls RR Across From Office-Sink (L)

Trace Metals by EPA 200.8 ICP-MS								Analyst: CSB
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.000294		0.000100	mg/L	1	4/29/2019	0.0150	A

Lab ID: 19040669-32 Client Sample ID: Girls RR Across From Office-Sink (R)
 Collection Date: 4/16/2019 6:05:00 AM Collected By:
 Matrix: Drinking Water Sample Location: Girls RR Across From Office-Sink (R)

Trace Metals by EPA 200.8 ICP-MS								Analyst: CSB
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.000747		0.000100	mg/L	1	4/29/2019	0.0150	A


Lab ID: 19040669-33 Client Sample ID: Kitchen-Sink
 Collection Date: 4/16/2019 6:12:00 AM Collected By:
 Matrix: Drinking Water Sample Location: Kitchen-Sink

Trace Metals by EPA 200.8 ICP-MS								Analyst: CSB
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.00319		0.000100	mg/L	1	4/30/2019	0.0150	A

QUALIFIERS	* Value exceeds Maximum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	MI Recovery outside control limits due to Matrix Interference
	ND Not Detected at the Reporting Limit	PL Permit Limit
	R RPD outside accepted recovery limits	

Results are out of the EPA limits

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 19040669
 Date Reported: 5/2/2019

Medford School District
 815 S Oakdale Ave
 Medford, OR 97501

Lab Order: 19040669
Received Date: 4/16/2019 9:11:00 AM
Reported Date: 5/2/2019 12:13:48 PM

Sample Information:

Lab ID: 19040669-34 Client Sample ID: Kitchen-Sink (Dishwasher)
 Collection Date: 4/16/2019 6:11:00 AM Collected By:
 Matrix: Drinking Water Sample Location: Kitchen-Sink (Dishwasher)

Trace Metals by EPA 200.8 ICP-MS								Analyst: CSB
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.00634		0.000100	mg/L	1	4/30/2019	0.0150	A

Lab ID: 19040669-35 Client Sample ID: Kitchen-Sink (RR)
 Collection Date: 4/16/2019 6:10:00 AM Collected By:
 Matrix: Drinking Water Sample Location: Kitchen-Sink (RR)

Trace Metals by EPA 200.8 ICP-MS								Analyst: CSB
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.0450	*	0.000100	mg/L	1	4/30/2019	0.0150	A

Lab ID: 19040669-36 Client Sample ID: Media Center-Sink (In Server Rm)
 Collection Date: 4/16/2019 6:16:00 AM Collected By:
 Matrix: Drinking Water Sample Location: Media Center-Sink (In Server Rm)

Trace Metals by EPA 200.8 ICP-MS								Analyst: CSB
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.00231		0.000100	mg/L	1	4/30/2019	0.0150	A

QUALIFIERS	* Value exceeds Maximum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	MI Recovery outside control limits due to Matrix Interference
	ND Not Detected at the Reporting Limit	PL Permit Limit
	R RPD outside accepted recovery limits	

Results are out of the EPA limits

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 19040669
 Date Reported: 5/2/2019

Medford School District
 815 S Oakdale Ave
 Medford, OR 97501

Lab Order: 19040669
Received Date: 4/16/2019 9:11:00 AM
Reported Date: 5/2/2019 12:13:48 PM

Sample Information:

Lab ID: 19040669-37 Client Sample ID: Room 1-Sink
 Collection Date: 4/16/2019 6:20:00 AM Collected By:
 Matrix: Drinking Water Sample Location: Room 1-Sink

Trace Metals by EPA 200.8 ICP-MS								Analyst: CSB
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.000764		0.000100	mg/L	1	4/30/2019	0.0150	A

Lab ID: 19040669-38 Client Sample ID: Room 5-Sink
 Collection Date: 4/16/2019 6:45:00 AM Collected By:
 Matrix: Drinking Water Sample Location: Room 5-Sink

Trace Metals by EPA 200.8 ICP-MS								Analyst: CSB
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.000977		0.000100	mg/L	1	4/30/2019	0.0150	A

Lab ID: 19040669-39 Client Sample ID: Room 11-Sink
 Collection Date: 4/16/2019 6:28:00 AM Collected By:
 Matrix: Drinking Water Sample Location: Room 11-Sink

Trace Metals by EPA 200.8 ICP-MS								Analyst: CSB
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.00133		0.000100	mg/L	1	4/30/2019	0.0150	A

QUALIFIERS	* Value exceeds Maximum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	MI Recovery outside control limits due to Matrix Interference
	ND Not Detected at the Reporting Limit	PL Permit Limit
	R RPD outside accepted recovery limits	

Results are out of the EPA limits

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 19040669
 Date Reported: 5/2/2019

Medford School District
 815 S Oakdale Ave
 Medford, OR 97501

Lab Order: 19040669
Received Date: 4/16/2019 9:11:00 AM
Reported Date: 5/2/2019 12:13:48 PM

Sample Information:

Lab ID: 19040669-40 Client Sample ID: Room 12-Sink
 Collection Date: 4/16/2019 6:32:00 AM Collected By:
 Matrix: Drinking Water Sample Location: Room 12-Sink

Trace Metals by EPA 200.8 ICP-MS								Analyst: CSB
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.00392		0.000100	mg/L	1	4/29/2019	0.0150	A

Lab ID: 19040669-41 Client Sample ID: Room 13-Sink
 Collection Date: 4/16/2019 6:34:00 AM Collected By:
 Matrix: Drinking Water Sample Location: Room 13-Sink

Trace Metals by EPA 200.8 ICP-MS								Analyst: CSB
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.00960		0.000100	mg/L	1	4/30/2019	0.0150	A

Lab ID: 19040669-42 Client Sample ID: Room 14-Sink
 Collection Date: 4/16/2019 6:36:00 AM Collected By:
 Matrix: Drinking Water Sample Location: Room 14-Sink

Trace Metals by EPA 200.8 ICP-MS								Analyst: CSB
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.00923		0.000100	mg/L	1	4/30/2019	0.0150	A

QUALIFIERS	* Value exceeds Maximum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	MI Recovery outside control limits due to Matrix Interference
	ND Not Detected at the Reporting Limit	PL Permit Limit
	R RPD outside accepted recovery limits	

Results are out of the EPA limits

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 19040669
 Date Reported: 5/2/2019

Medford School District
 815 S Oakdale Ave
 Medford, OR 97501

Lab Order: 19040669
Received Date: 4/16/2019 9:11:00 AM
Reported Date: 5/2/2019 12:13:48 PM

Sample Information:

Lab ID: 19040669-43 Client Sample ID: W Ramp 2 Mens RR (Staff Only)-Sink
 Collection Date: 4/16/2019 6:41:00 AM Collected By:
 Matrix: Drinking Water Sample Location: W Ramp 2 Mens RR (Staff Only)-Sink

Trace Metals by EPA 200.8 ICP-MS								Analyst: CSB
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.00134		0.000100	mg/L	1	4/30/2019	0.0150	A

Lab ID: 19040669-44 Client Sample ID: W Ramp 2 Womens RR (Staff Only)-Sink (L)
 Collection Date: 4/16/2019 6:42:00 AM Collected By:
 Matrix: Drinking Water Sample Location: W Ramp 2 Womens RR (Staff Only)-Sink (L)

Trace Metals by EPA 200.8 ICP-MS								Analyst: CSB
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.00151		0.000100	mg/L	1	4/30/2019	0.0150	A

Lab ID: 19040669-45 Client Sample ID: W Ramp 2 Womens RR (Staff Only)-Sink (R)
 Collection Date: 4/16/2019 6:42:00 AM Collected By:
 Matrix: Drinking Water Sample Location: W Ramp 2 Womens RR (Staff Only)-Sink (R)

Trace Metals by EPA 200.8 ICP-MS								Analyst: CSB
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.00122		0.000100	mg/L	1	4/30/2019	0.0150	A

QUALIFIERS	* Value exceeds Maximum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	MI Recovery outside control limits due to Matrix Interference
	ND Not Detected at the Reporting Limit	PL Permit Limit
	R RPD outside accepted recovery limits	

Results are out of the EPA limits

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 19040669
 Date Reported: 5/2/2019

Medford School District
 815 S Oakdale Ave
 Medford, OR 97501

Lab Order: 19040669
Received Date: 4/16/2019 9:11:00 AM
Reported Date: 5/2/2019 12:13:48 PM

Sample Information:

Lab ID: 19040669-46 Client Sample ID: Room 21-Sink
 Collection Date: 4/16/2019 6:47:00 AM Collected By:
 Matrix: Drinking Water Sample Location: Room 21-Sink

Trace Metals by EPA 200.8 ICP-MS								Analyst: CSB
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.000972		0.000100	mg/L	1	4/30/2019	0.0150	A

Lab ID: 19040669-47 Client Sample ID: Room 22-Sink
 Collection Date: 4/16/2019 6:48:00 AM Collected By:
 Matrix: Drinking Water Sample Location: Room 22-Sink

Trace Metals by EPA 200.8 ICP-MS								Analyst: CSB
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.000778		0.000100	mg/L	1	4/30/2019	0.0150	A

Lab ID: 19040669-48 Client Sample ID: Room 23-Sink
 Collection Date: 4/16/2019 6:49:00 AM Collected By:
 Matrix: Drinking Water Sample Location: Room 23-Sink

Trace Metals by EPA 200.8 ICP-MS								Analyst: CSB
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.00294		0.000100	mg/L	1	4/30/2019	0.0150	A

QUALIFIERS	* Value exceeds Maximum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	MI Recovery outside control limits due to Matrix Interference
	ND Not Detected at the Reporting Limit	PL Permit Limit
	R RPD outside accepted recovery limits	

Results are out of the EPA limits

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 19040669
 Date Reported: 5/2/2019

Medford School District
 815 S Oakdale Ave
 Medford, OR 97501

Lab Order: 19040669
Received Date: 4/16/2019 9:11:00 AM
Reported Date: 5/2/2019 12:13:48 PM

Sample Information:

Lab ID: 19040669-49 Client Sample ID: Room 24-Sink
 Collection Date: 4/16/2019 6:50:00 AM Collected By:
 Matrix: Drinking Water Sample Location: Room 24-Sink

Trace Metals by EPA 200.8 ICP-MS								Analyst: CSB
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.00135		0.000100	mg/L	1	4/30/2019	0.0150	A

Lab ID: 19040669-50 Client Sample ID: W Side Ramp 3 Boys RR-Sink (L)
 Collection Date: 4/16/2019 6:53:00 AM Collected By:
 Matrix: Drinking Water Sample Location: W Side Ramp 3 Boys RR-Sink (L)

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.000424		0.000100	mg/L	1	4/30/2019	0.0150	A

Lab ID: 19040669-51 Client Sample ID: W Side Ramp 3 Boys RR-Sink (R)
 Collection Date: 4/16/2019 6:53:00 AM Collected By:
 Matrix: Drinking Water Sample Location: W Side Ramp 3 Boys RR-Sink (R)

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.000780		0.000100	mg/L	1	4/30/2019	0.0150	A

QUALIFIERS	* Value exceeds Maximum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	MI Recovery outside control limits due to Matrix Interference
	ND Not Detected at the Reporting Limit	PL Permit Limit
	R RPD outside accepted recovery limits	

Results are out of the EPA limits

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 19040669
 Date Reported: 5/2/2019

Medford School District
 815 S Oakdale Ave
 Medford, OR 97501

Lab Order: 19040669
Received Date: 4/16/2019 9:11:00 AM
Reported Date: 5/2/2019 12:13:48 PM

Sample Information:

Lab ID: 19040669-52 Client Sample ID: W Side Ramp 3 Girls RR-Sink (L)
 Collection Date: 4/16/2019 6:56:00 AM Collected By:
 Matrix: Drinking Water Sample Location: W Side Ramp 3 Girls RR-Sink (L)

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.000612		0.000100	mg/L	1	4/30/2019	0.0150	A

Lab ID: 19040669-53 Client Sample ID: W Side Ramp 3 Girls RR-Sink (R)
 Collection Date: 4/16/2019 6:56:00 AM Collected By:
 Matrix: Drinking Water Sample Location: W Side Ramp 3 Girls RR-Sink (R)

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.00124		0.000100	mg/L	1	4/30/2019	0.0150	A

Lab ID: 19040669-54 Client Sample ID: Room 31-Sink
 Collection Date: 4/16/2019 6:58:00 AM Collected By:
 Matrix: Drinking Water Sample Location: Room 31-Sink

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.00145		0.000100	mg/L	1	4/30/2019	0.0150	A

QUALIFIERS	* Value exceeds Maximum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	MI Recovery outside control limits due to Matrix Interference
	ND Not Detected at the Reporting Limit	PL Permit Limit
	R RPD outside accepted recovery limits	

Results are out of the EPA limits

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 19040669
 Date Reported: 5/2/2019

Medford School District
 815 S Oakdale Ave
 Medford, OR 97501

Lab Order: 19040669
Received Date: 4/16/2019 9:11:00 AM
Reported Date: 5/2/2019 12:13:48 PM

Sample Information:

Lab ID: 19040669-55 Client Sample ID: Room 32-Sink
 Collection Date: 4/16/2019 6:59:00 AM Collected By:
 Matrix: Drinking Water Sample Location: Room 32-Sink

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.00241		0.000100	mg/L	1	4/30/2019	0.0150	A

Lab ID: 19040669-56 Client Sample ID: Room 33-Sink
 Collection Date: 4/16/2019 7:01:00 AM Collected By:
 Matrix: Drinking Water Sample Location: Room 33-Sink

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.000473		0.000100	mg/L	1	4/30/2019	0.0150	A


Lab ID: 19040669-57 Client Sample ID: Room 34-Sink
 Collection Date: 4/16/2019 7:02:00 AM Collected By:
 Matrix: Drinking Water Sample Location: Room 34-Sink

Trace Metals by EPA 200.8 ICP-MS								Analyst: CSB
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.000392		0.000100	mg/L	1	4/30/2019	0.0150	A

QUALIFIERS	* Value exceeds Maximum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	MI Recovery outside control limits due to Matrix Interference
	ND Not Detected at the Reporting Limit	PL Permit Limit
	R RPD outside accepted recovery limits	

Results are out of the EPA limits

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

QC SUMMARY REPORT

WO#: 19040669

02-May-19

Client: Medford School District
Project: 18-16 Hoover 2019 Lead Testing

TestCode: ICPMS_200.8_DW

Sample ID: MB-235	SampType: MBLK	TestCode: ICPMS_200.8	Units: mg/L	Prep Date: 4/18/2019	RunNo: 708						
Client ID: PBW	Batch ID: 235	TestNo: E200.8	E200.8	Analysis Date: 4/29/2019	SeqNo: 12826						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	ND	0.000100									

Sample ID: LCS-235	SampType: LCS	TestCode: ICPMS_200.8	Units: mg/L	Prep Date: 4/18/2019	RunNo: 708						
Client ID: LCSW	Batch ID: 235	TestNo: E200.8	E200.8	Analysis Date: 4/29/2019	SeqNo: 12827						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	0.106	0.000100	0.1000	0	106	85	115				


Sample ID: 19040669-20AMS	SampType: MS	TestCode: ICPMS_200.8	Units: mg/L	Prep Date: 4/18/2019	RunNo: 708						
Client ID: Unisex RR Outside	Batch ID: 235	TestNo: E200.8	E200.8	Analysis Date: 4/29/2019	SeqNo: 12838						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	0.103	0.000100	0.1000	0.001335	102	70	130				

Sample ID: 19040669-20AMSD	SampType: MSD	TestCode: ICPMS_200.8	Units: mg/L	Prep Date: 4/18/2019	RunNo: 708						
Client ID: Unisex RR Outside	Batch ID: 235	TestNo: E200.8	E200.8	Analysis Date: 4/29/2019	SeqNo: 12839						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	0.104	0.000100	0.1000	0.001335	102	70	130	0.1034	0.368	20	

Qualifiers:

* Value exceeds Maximum Contaminant Level.	B Analyte detected in the associated Method Blank	C1 Sample container temperature is out of limit as sj
E Value above quantitation range	H Holding times for preparation or analysis exceeded	MI Recovery outside control limits due to Matrix In
ND Not Detected at the Reporting Limit	PL Permit Limit	RL Reporting Detection Limit

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

QC SUMMARY REPORT

WO#: 19040669

02-May-19

Client: Medford School District
Project: 18-16 Hoover 2019 Lead Testing

TestCode: ICPMS_200.8_DW

Sample ID: MB-236	SampType: MBLK	TestCode: ICPMS_200.8	Units: mg/L	Prep Date: 4/18/2019	RunNo: 708						
Client ID: PBW	Batch ID: 236	TestNo: E200.8	E200.8	Analysis Date: 4/29/2019	SeqNo: 12855						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	ND	0.000100									

Sample ID: LCS-236	SampType: LCS	TestCode: ICPMS_200.8	Units: mg/L	Prep Date: 4/18/2019	RunNo: 708						
Client ID: LCSW	Batch ID: 236	TestNo: E200.8	E200.8	Analysis Date: 4/29/2019	SeqNo: 12856						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	0.106	0.000100	0.1000	0	106	85	115				


Sample ID: 19040669-40AAMS	SampType: MS	TestCode: ICPMS_200.8	Units: mg/L	Prep Date:	RunNo: 708						
Client ID: Room 12-Sink	Batch ID: 236	TestNo: E200.8	E200.8	Analysis Date: 4/29/2019	SeqNo: 12867						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	0.109	0.000100	0.1000	0.003919	105	70	130				

Sample ID: 19040669-40AAMSD	SampType: MSD	TestCode: ICPMS_200.8	Units: mg/L	Prep Date:	RunNo: 708						
Client ID: Room 12-Sink	Batch ID: 236	TestNo: E200.8	E200.8	Analysis Date: 4/29/2019	SeqNo: 12868						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	0.109	0.000100	0.1000	0.003919	105	70	130	0.1085	0.465	20	

Qualifiers:

* Value exceeds Maximum Contaminant Level.	B Analyte detected in the associated Method Blank	C1 Sample container temperature is out of limit as sj
E Value above quantitation range	H Holding times for preparation or analysis exceeded	MI Recovery outside control limits due to Matrix In
ND Not Detected at the Reporting Limit	PL Permit Limit	RL Reporting Detection Limit

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

QC SUMMARY REPORT

WO#: 19040669
 02-May-19

Client: Medford School District
Project: 18-16 Hoover 2019 Lead Testing

TestCode: ICPMS_200.8_DW

Sample ID: MB-239	SampType: MBLK	TestCode: ICPMS_200.8	Units: mg/L	Prep Date: 4/18/2019	RunNo: 708						
Client ID: PBW	Batch ID: 239	TestNo: E200.8	E200.8	Analysis Date: 4/30/2019	SeqNo: 12883						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	ND	0.000100									

Sample ID: LCS-239	SampType: LCS	TestCode: ICPMS_200.8	Units: mg/L	Prep Date: 4/18/2019	RunNo: 708						
Client ID: LCSW	Batch ID: 239	TestNo: E200.8	E200.8	Analysis Date: 4/30/2019	SeqNo: 12884						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	0.107	0.000100	0.1000	0	107	85	115				

Sample ID: 19040669-57AMS	SampType: MS	TestCode: ICPMS_200.8	Units: mg/L	Prep Date: 4/18/2019	RunNo: 708						
Client ID: Room 34-Sink	Batch ID: 239	TestNo: E200.8	E200.8	Analysis Date: 4/30/2019	SeqNo: 12895						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	0.108	0.000100	0.1000	0.0003920	108	70	130				

Sample ID: 19040669-57AMSD	SampType: MSD	TestCode: ICPMS_200.8	Units: mg/L	Prep Date: 4/18/2019	RunNo: 708						
Client ID: Room 34-Sink	Batch ID: 239	TestNo: E200.8	E200.8	Analysis Date: 4/30/2019	SeqNo: 12896						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	0.107	0.000100	0.1000	0.0003920	106	70	130	0.1083	1.54	20	

Qualifiers:

* Value exceeds Maximum Contaminant Level.	B Analyte detected in the associated Method Blank	C1 Sample container temperature is out of limit as sj
E Value above quantitation range	H Holding times for preparation or analysis exceeded	MI Recovery outside control limits due to Matrix In
ND Not Detected at the Reporting Limit	PL Permit Limit	RL Reporting Detection Limit

Original



Environmental Testing Laboratory
 245 South Grape Street * Medford, OR 97501
 (541) 770-5678 fax (541) 770-2901

Chain of Custody Record

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Section A		Section B		Section C		Section D	
Required Client Information		Required Project Information		Invoice Information		Rush Status (Subject to Scheduling)	
Company: MSD 549C	Project Name: 2019 Lead Testing	Attention: Accounting	Standard 10-14 Days				
Address: 815 South Oakdale Avenue	Project Number: 18-16 Hoover	Company Name: Medford School District	5 Business Days (50% surcharge)				
Medford, OR 97501	Report To ron.havnjear@medford.k12.or.us	Address: 815 South Oakdale Avenue	3 Business Days (75% surcharge)				
Email: ron.havnjear@medford.k12.or.us	Copy To andy.chasteen@medford.k12.or.us	Medford, OR 97501	24 - 48 hours (100% surcharge)				
Phone: 541-840-4315 Fax:		P.O. # 61172	Other				
Collected By (Print):				Authorized Yes <input type="checkbox"/> No <input type="checkbox"/>			
Collected By (Sign):							
Email Report Yes <input type="checkbox"/> No <input type="checkbox"/> Mail Report Yes <input type="checkbox"/> No <input type="checkbox"/>							
Fax Report Yes <input type="checkbox"/> No <input type="checkbox"/>							

Section E Sample Information	Sample ID	Bottle #	Matrix*	Date Collected	Time Collected	No. of Containers	Analysis Requested										NRC Workorder # (Lab Use Only)	Remarks/Field Data	NRC Sample # (Lab Use Only)
Boys Restroom Across From The Office - Sink (Left)		58980	DW	4/16/2019	6:06	1												1904009	251A
Boys Restroom Across From The Office - Sink (Right)		58981	DW	4/16/2019	6:08	1													30A
Girls Restroom Across From The Office - Sink (Left)		59012	DW	4/16/2019	6:05	1													31A
Girls Restroom Across From The Office - Sink (Right)		58981	DW	4/16/2019	6:05	1													32A
Kitchen - Sink		59011	DW	4/16/2019	6:12	1													33A
Kitchen - Sink (Dishwasher)		59057	DW	4/16/2019	6:11	1													34A
Kitchen - Sink (Restroom)		59012	DW	4/16/2019	6:10	1													35A
Media Center - Sink (in Server Room)		59022	DW	4/16/2019	6:16	1													30A
Room 3 - Sink		59044	DW	4/16/2019	6:20	1													37A
Room 3 - Sink		59010	DW	4/16/2019	6:45	1													38A
Room 11 - Sink		59026	DW	4/16/2019	6:28	1													35A
Room 12 - Sink		59033	DW	4/16/2019	6:32	1													40A
Room 13 - Sink		59042	DW	4/16/2019	6:34	1													41A
Room 14 - Sink		59057	DW	4/16/2019	6:36	1													42A
West Side Ramp 2 Mens Restroom (Staff Only) - Sink		59071	DW	4/16/2019	6:47	1													43A
West Side Ramp 2 Womens Restroom (Staff Only) - Sink (Left)		59050	DW	4/16/2019	6:47	1													44A
West Side Ramp 2 Womens Restroom (Staff Only) - Sink (Right)		59014	DW	4/16/2019	6:47	1													45A
Room 21 - Sink		59077	DW	4/16/2019	6:47	1													46A
Room 22 - Sink		59010	DW	4/16/2019	6:48	1													47A
Room 23 - Sink		59006	DW	4/16/2019	6:49	1													48A
Room 24 - Sink		59034	DW	4/16/2019	6:50	1													49A
West Side Ramp 3 Boys Restroom - Sink (Left)		59038	DW	4/16/2019	6:52	1													50A
West Side Ramp 3 Boys Restroom - Sink (Right)		59070	DW	4/16/2019	6:53	1													51A
West Side Ramp 3 Girls Restroom - Sink (Left)		59063	DW	4/16/2019	6:56	1													52A
West Side Ramp 3 Girls Restroom - Sink (Right)		59068	DW	4/16/2019	6:56	1													53A

-
- B Analyte detected in the associated method blank.
 - BA BOD Alternative Calculation: The initial results performed by Standard Methods did not fall within parameters of the Standard Methods calculation. An alternate approved calculation was performed using the HACH method and the value reported is an estimated concentration.
 - C Sample(s) does not meet NELAP/ORELAP sample acceptance criteria. See Case Narrative.
 - C1 Sample(s) does not meet NELAP/ORELAP sample acceptance criteria for temperature.
 - CF Results confirmed by re-analysis.
 - CU Cleanup performed as specified by method.
 - D1 The diesel elution pattern for the sample is not typical.
 - D2 The sample appears to be a heavier hydrocarbon range than diesel.
 - D3 The sample appears to be a lighter hydrocarbon range than diesel.
 - D4 Detected hydrocarbons do not have pattern and range consistent with typical petroleum products and may be due to biogenic interference.
 - D5 Detected hydrocarbons in the diesel range appear to be weathered diesel.
 - E Estimated value.
 - ER Elevated reporting limit due to matrix. Report limits (MDLs, MRLs & PQLs) are adjusted based on variations in sample preparation amounts, analytical dilutions, and percent solids, where applicable.
 - FC Fecal Coliforms: Sample(s) received past 40 CFR Part 136 specified holding time. Results reported as estimated values.
 - G1 The gasoline elution pattern for the sample is not typical.
 - G2 The sample appears to be a heavier hydrocarbon range than gasoline.
 - G3 The sample appears to be a lighter hydrocarbon range than gasoline.
 - G4 Detected hydrocarbons in the gasoline range appear to be weathered gasoline.
 - HP Sample re-analysis performed outside of method specified holding time.
 - HR Sample received outside of method specified holding time.
 - HS Sample analyzed for volatile organics contained headspace.
 - HT At the client's request, the sample was analyzed outside of method specified holding time.
 - H Analysis performed outside of method specified holding time.
 - J Analyte detected below the Minimum Reporting Limit (MRL) and above the Method Detection Limit (MDL). The J flag result is an estimated value and the user should be aware that this data is of limited reliability.
 - L Dissolved metals were not filtered within 15 minutes of collection per 40 CFR Part 136.
 - MI Surrogate, Duplicate Sample (DUP) or Matrix Spikes recoveries are out of control limits due to matrix interference. Sample results may be biased.
 - N See Case Narrative on page 2 of report.
 - NLR No Legionella Recovered.
 - PLR Presence of Legionella Recovered.
 - Q Initial calibration verification (ICV), continuing calibration verification (CCV) or laboratory control sample (LCS) exceeded high recovery limits, but associated samples are non-detect and the sample results are not affected. Data meets EPA/NELAP requirements.
 - R Relative percent difference (RPD) is outside of the accepted recovery limits.
 - R1 Relative percent difference (RPD) is outside of the accepted recovery limits. However, analyses are not controlled on RPD values for sample concentrations that are less than the reporting limit.
 - R3 The relative percent difference (RPD) and/or percent recovery for the duplicate (DUP) or matrix spike (MS)/matrix spike duplicate (MSD) cannot be accurately calculated due to the concentration of analyte already present in the sample.
 - R4 Duplicate analysis failed due to result being at or near the method reporting limit.
 - S Surrogate and/or matrix spike recovery is outside of the accepted recovery limits. Sample results may be biased.
 - S1 Surrogate or matrix spike recovery is outside of control limits due to dilution necessary for analysis.
 - SC Sub-contracted to another laboratory for analysis.
 - SP Sample(s) were not collected per EPA Method 5035A protocols. The results are considered minimum values.
 - # Value exceeds regulatory level for TCLP contaminant.
 - X1 The motor oil elution pattern for the sample is not typical.
 - X2 The sample appears to be a heavier hydrocarbon range than motor oil.
 - X3 The sample appears to be a lighter hydrocarbon range than motor oil.
 - * Value exceeds Maximum Contaminant Level or is outside the acceptable range.