



NEILSON RESEARCH CORPORATION

Environmental Testing Laboratory

9/6/2016

Rick Rose
Medford School District
815 S Oakdale Ave
Medford, OR 97501

TEL: (541) 842-1138
FAX 541-842-1160

RE: 2016 Hoover Lead Study

Order No.: 1609039

Dear Rick Rose:

Neilson Research Corporation received 1 sample(s) on 9/1/2016 for the analyses presented in the following report.

The results relate only to the parameters tested or to the sample as received by the laboratory. This report shall not be reproduced except in full, without the written approval of Neilson Research Corporation. If you have any questions regarding these test results, please feel free to call.

Sincerely,
Neilson Research Corporation

Alec C Smith
Project Manager

245 S Grape St • Medford, OR 97501 • (541) 770-5678
400 SE G St, Suite B • Grants Pass, OR 97526 • (541) 479-4053

www.nrclabs.com

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

CLIENT: Medford School District
Project: 2016 Hoover Lead Study
Lab Order: 1609039

Date: 06-Sep-16

CASE NARRATIVE

The analyses were performed according to the guidelines in the Neilson Research Corporation Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

Neilson Research Corporation certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: **1609039**
NRC Sample ID: **1609039-01A**
Collection Date: **9/1/2016 2:19:00 PM**
Received Date: **9/1/2016 2:42:00 PM**
Reported Date: **9/6/2016 3:53:10 PM**

Sample Information:

2016 Hoover Lead Study

Client Sample ID: Bottle #05906
Collectors Name: John Jessen
Sample Location: Room 48 DF
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.00886		0.0001	mg/L	0.020 AL	9/2/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

CLIENT: Medford School District
Work Order: 1609039
Project: 2016 Hoover Lead Study

ANALYTICAL QC SUMMARY REPORT

TestCode: ICPMS_200.8_SCHOOL

Sample ID MB-36454	SampType: MBLK	TestCode: ICPMS_200.8	Units: mg/L	Prep Date: 9/2/2016	RunNo: 89700						
Client ID: ZZZZZ	Batch ID: 36454	TestNo: EPA 200.8	(EPA 200.8)	Analysis Date: 9/2/2016	SeqNo: 1356146						
Analyte	Result	MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead ND 0.000100

Sample ID LCS-36454	SampType: LCS	TestCode: ICPMS_200.8	Units: mg/L	Prep Date: 9/2/2016	RunNo: 89700						
Client ID: ZZZZZ	Batch ID: 36454	TestNo: EPA 200.8	(EPA 200.8)	Analysis Date: 9/2/2016	SeqNo: 1356147						
Analyte	Result	MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead 0.09858 0.000100 0.1 0 98.6 85 115

Sample ID 1609002-41AMS	SampType: MS	TestCode: ICPMS_200.8	Units: mg/L	Prep Date: 9/2/2016	RunNo: 89700						
Client ID: ZZZZZ	Batch ID: 36454	TestNo: EPA 200.8	(EPA 200.8)	Analysis Date: 9/2/2016	SeqNo: 1356154						
Analyte	Result	MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead 0.09689 0.000100 0.1 0.000093 96.8 70 130

Sample ID 1609002-41AMSD	SampType: MSD	TestCode: ICPMS_200.8	Units: mg/L	Prep Date: 9/2/2016	RunNo: 89700						
Client ID: ZZZZZ	Batch ID: 36454	TestNo: EPA 200.8	(EPA 200.8)	Analysis Date: 9/2/2016	SeqNo: 1356155						
Analyte	Result	MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead 0.09706 0.000100 0.1 0.000093 97.0 70 130 0.09689 0.175 20

Qualifiers: E Value above quantitation range H Holding times for preparation or analysis exceeded J Analyte detected below quantitation limits
 ND Not Detected at the Minimum Reporting Limit R RPD outside accepted recovery limits S Spike Recovery outside accepted recovery limits

