

Site Radon Inspection Report

Date : 03/25/2019

Bryan Hogan / Ron Havnear
MEDFORD SCHOOL DISTRICT
815 South Oakdale Avenue
Medford, OR 97501-

Client: Hoover E.S.
Test Location: 2323 Siskiyou Boulevard
Medford, OR 97504-

Individual Canister Results

Canister ID# :	2679162	Test Start :	03/18/2019 @ 06:34
Canister Type :	Charcoal Canister 3 inch	Test Stop :	03/20/2019 @ 06:47
Location :	1st FL = Rm 21 DP	Received:	03/25/2019 @ 09:34
Radon Level :	0.8 pCi/L	Analyzed:	03/25/2019 @ 17:19
Error for Measurement is:	± 0.5 pCi/L		

Canister ID# :	2679164	Test Start :	03/18/2019 @ 05:45
Canister Type :	Charcoal Canister 3 inch	Test Stop :	03/20/2019 @ 06:00
Location :	1st FL=Media Ctr Off.	Received:	03/25/2019 @ 09:34
Radon Level :	2.8 pCi/L	Analyzed:	03/25/2019 @ 13:26
Error for Measurement is:	± 0.5 pCi/L		

Canister ID# :	2679167	Test Start :	03/18/2019 @ 06:12
Canister Type :	Charcoal Canister 3 inch	Test Stop :	03/20/2019 @ 06:13
Location :	1st FL=Sm Staff Break Rm	Received:	03/25/2019 @ 09:34
Radon Level :	0.2 pCi/L	Analyzed:	03/25/2019 @ 17:39
Error for Measurement is:	± 0.4 pCi/L		

Canister ID# :	2679223	Test Start :	03/18/2019 @ 05:43
Canister Type :	Charcoal Canister 3 inch	Test Stop :	03/20/2019 @ 05:49
Location :	1st FL = Rm 12 BLANK	Received:	03/25/2019 @ 09:34
Radon Level :	0.1 pCi/L	Analyzed:	03/25/2019 @ 18:08
Error for Measurement is:	± 0.2 pCi/L		

Canister ID# :	2679234	Test Start :	03/18/2019 @ 06:49
Canister Type :	Charcoal Canister 3 inch	Test Stop :	03/20/2019 @ 06:55
Location :	1st FL = Rm 34	Received:	03/25/2019 @ 09:34
Radon Level :	0.4 pCi/L	Analyzed:	03/25/2019 @ 17:35
Error for Measurement is:	± 0.5 pCi/L		

Canister ID# :	2679236	Test Start :	03/18/2019 @ 05:50
Canister Type :	Charcoal Canister 3 inch	Test Stop :	03/20/2019 @ 06:04
Location :	1st FL = Comp. Rm Off.	Received:	03/25/2019 @ 09:34
Radon Level :	1.0 pCi/L	Analyzed:	03/25/2019 @ 13:26
Error for Measurement is:	± 0.5 pCi/L		

*Andreas C. George*

Andreas C. George
Radon Measurement Specialist

NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201



Site Radon Inspection Report

Date : 03/25/2019

Bryan Hogan / Ron Havnear
MEDFORD SCHOOL DISTRICT
815 South Oakdale Avenue
Medford, OR 97501-

Client: Hoover E.S.
Test Location: 2323 Siskiyou Boulevard
Medford, OR 97504-

Individual Canister Results

Canister ID# : 2679243 Test Start : 03/18/2019 @ 06:00
Canister Type : Charcoal Canister 3 inch Test Stop : 03/20/2019 @ 06:10
Location : 1st FL = Rm 48 Received: 03/25/2019 @ 09:34
Radon Level : 0.4 pCi/L Analyzed: 03/25/2019 @ 18:11
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 2679253 Test Start : 03/18/2019 @ 05:23
Canister Type : Charcoal Canister 3 inch Test Stop : 03/20/2019 @ 05:23
Location : 1st FL = Staff Work Rm Received: 03/25/2019 @ 09:34
Radon Level : 1.4 pCi/L Analyzed: 03/25/2019 @ 17:35
Error for Measurement is: ± 0.6 pCi/L

Canister ID# : 2679254 Test Start : 03/18/2019 @ 06:33
Canister Type : Charcoal Canister 3 inch Test Stop : 03/20/2019 @ 06:47
Location : 1st FL = Rm 31 Received: 03/25/2019 @ 09:34
Radon Level : 0.2 pCi/L Analyzed: 03/26/2019 @ 09:28
Error for Measurement is: ± 0.6 pCi/L

Canister ID# : 2679260 Test Start : 03/18/2019 @ 06:15
Canister Type : Charcoal Canister 3 inch Test Stop : 03/20/2019 @ 06:20
Location : 1st FL = Rm 61 DP Received: 03/25/2019 @ 09:34
Radon Level : 0.1 pCi/L Analyzed: 03/25/2019 @ 13:26
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 2679262 Test Start : 03/18/2019 @ 06:06
Canister Type : Charcoal Canister 3 inch Test Stop : 03/20/2019 @ 06:06
Location : 1st FL = Rm 45 BLANK Received: 03/25/2019 @ 09:34
Radon Level : 0.1 pCi/L Analyzed: 03/25/2019 @ 10:32
Error for Measurement is: ± No Result

Canister ID# : 2679269 Test Start : 03/18/2019 @ 05:57
Canister Type : Charcoal Canister 3 inch Test Stop : 03/20/2019 @ 06:10
Location : 1st FL = Custodial Off. Received: 03/25/2019 @ 09:34
Radon Level : 0.5 pCi/L Analyzed: 03/25/2019 @ 18:08
Error for Measurement is: ± 0.4 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201



Site Radon Inspection Report

Date : 03/25/2019

Bryan Hogan / Ron Havniar
MEDFORD SCHOOL DISTRICT
815 South Oakdale Avenue
Medford, OR 97501-

Client: Hoover E.S.
Test Location: 2323 Siskiyou Boulevard
Medford, OR 97504-

Individual Canister Results

Canister ID# : 2679270
Canister Type : Charcoal Canister 3 inch
Location : 1st FL = Staff Break Rm
Radon Level : 0.2 pCi/L
Error for Measurement is: \pm 0.4 pCi/L

Test Start : 03/18/2019 @ 06:11
Test Stop : 03/20/2019 @ 06:13
Received: 03/25/2019 @ 09:33
Analyzed: 03/25/2019 @ 17:55

Canister ID# : 2679271
Canister Type : Charcoal Canister 3 inch
Location : 1st FL = Rm 11
Radon Level : 0.6 pCi/L
Error for Measurement is: \pm 0.5 pCi/L

Test Start : 03/18/2019 @ 05:37
Test Stop : 03/20/2019 @ 05:45
Received: 03/25/2019 @ 09:34
Analyzed: 03/25/2019 @ 18:08

Canister ID# : 2679272
Canister Type : Charcoal Canister 3 inch
Location : 1st FL = Main Off.
Radon Level : 0.7 pCi/L
Error for Measurement is: \pm 0.5 pCi/L

Test Start : 03/18/2019 @ 05:15
Test Stop : 03/20/2019 @ 05:17
Received: 03/25/2019 @ 09:34
Analyzed: 03/25/2019 @ 17:35

Canister ID# : 2679282
Canister Type : Charcoal Canister 3 inch
Location : 1st FL = Rm 64-A
Radon Level : 17.4 pCi/L
Error for Measurement is: \pm 0.8 pCi/L

Test Start : 03/18/2019 @ 09:45
Test Stop : 03/20/2019 @ 09:45
Received: 03/25/2019 @ 09:34
Analyzed: 03/25/2019 @ 13:23

This is a quality control test known as a spike. This canister has never been on the school site.

Canister ID# : 2679287
Canister Type : Charcoal Canister 3 inch
Location : 1st FL = Rm 62
Radon Level : 0.4 pCi/L
Error for Measurement is: \pm 0.4 pCi/L

Test Start : 03/18/2019 @ 06:20
Test Stop : 03/20/2019 @ 06:22
Received: 03/25/2019 @ 09:34
Analyzed: 03/25/2019 @ 17:52

Canister ID# : 2679289
Canister Type : Charcoal Canister 3 inch
Location : 1st FL = Rm 1
Radon Level : 0.4 pCi/L
Error for Measurement is: \pm 0.5 pCi/L

Test Start : 03/18/2019 @ 05:24
Test Stop : 03/20/2019 @ 05:25
Received: 03/25/2019 @ 09:34
Analyzed: 03/25/2019 @ 17:35



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 03/25/2019

Bryan Hogan / Ron Havniar
MEDFORD SCHOOL DISTRICT
815 South Oakdale Avenue
Medford, OR 97501-

Client: Hoover E.S.
Test Location: 2323 Siskiyou Boulevard
Medford, OR 97504-

Individual Canister Results

Canister ID# : 2679291 Test Start : 03/18/2019 @ 06:34
Canister Type : Charcoal Canister 3 inch Test Stop : 03/20/2019 @ 06:47
Location : 1st FL = Rm 21 Received: 03/25/2019 @ 09:34
Radon Level : 0.5 pCi/L Analyzed: 03/25/2019 @ 17:39
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2679293 Test Start : 03/18/2019 @ 06:15
Canister Type : Charcoal Canister 3 inch Test Stop : 03/20/2019 @ 06:20
Location : 1st FL = Rm 61 Received: 03/25/2019 @ 09:34
Radon Level : 0.3 pCi/L Analyzed: 03/25/2019 @ 17:56
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 2679294 Test Start : 03/18/2019 @ 06:38
Canister Type : Charcoal Canister 3 inch Test Stop : 03/20/2019 @ 06:49
Location : 1st FL = Rm 32 DP Received: 03/25/2019 @ 09:34
Radon Level : 1.0 pCi/L Analyzed: 03/25/2019 @ 13:23
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2679298 Test Start : 03/18/2019 @ 05:53
Canister Type : Charcoal Canister 3 inch Test Stop : 03/20/2019 @ 06:07
Location : 1st FL = Rm 5 Received: 03/25/2019 @ 09:34
Radon Level : 0.3 pCi/L Analyzed: 03/26/2019 @ 09:28
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2680422 Test Start : 03/18/2019 @ 06:01
Canister Type : Charcoal Canister 3 inch Test Stop : 03/20/2019 @ 06:02
Location : 1st FL = Rm 22 Received: 03/25/2019 @ 09:34
Radon Level : 1.4 pCi/L Analyzed: 03/25/2019 @ 17:19
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2680425 Test Start : 03/18/2019 @ 05:56
Canister Type : Charcoal Canister 3 inch Test Stop : 03/20/2019 @ 06:07
Location : 1st FL = Rm 47 Received: 03/25/2019 @ 09:34
Radon Level : 0.5 pCi/L Analyzed: 03/25/2019 @ 17:38
Error for Measurement is: ± 0.5 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 03/25/2019

Bryan Hogan / Ron Havniar
MEDFORD SCHOOL DISTRICT
815 South Oakdale Avenue
Medford, OR 97501-

Client: Hoover E.S.
Test Location: 2323 Siskiyou Boulevard
Medford, OR 97504-

Individual Canister Results

Canister ID# :	2680426	Test Start :	03/18/2019 @ 05:51
Canister Type :	Charcoal Canister 3 inch	Test Stop :	03/20/2019 @ 06:05
Location :	1st FL = Rm 54	Received:	03/25/2019 @ 09:34
Radon Level :	0.6 pCi/L	Analyzed:	03/25/2019 @ 13:26
Error for Measurement is: ±	0.4 pCi/L		

Canister ID# :	2680429	Test Start :	03/18/2019 @ 06:11
Canister Type :	Charcoal Canister 3 inch	Test Stop :	03/20/2019 @ 06:12
Location :	1st FL = Rm 46	Received:	03/25/2019 @ 09:34
Radon Level :	0.7 pCi/L	Analyzed:	03/26/2019 @ 09:28
Error for Measurement is: ±	0.5 pCi/L		

Canister ID# :	2680434	Test Start :	03/18/2019 @ 05:52
Canister Type :	Charcoal Canister 3 inch	Test Stop :	03/20/2019 @ 06:02
Location :	1st FL=Comp. Rm Study	Received:	03/25/2019 @ 09:34
Radon Level :	0.8 pCi/L	Analyzed:	03/25/2019 @ 10:32
Error for Measurement is: ±	0.5 pCi/L		

Canister ID# :	2680435	Test Start :	03/18/2019 @ 05:49
Canister Type :	Charcoal Canister 3 inch	Test Stop :	03/20/2019 @ 06:05
Location :	1st FL = Stage DP	Received:	03/25/2019 @ 09:34
Radon Level :	0.3 pCi/L	Analyzed:	03/25/2019 @ 18:08
Error for Measurement is: ±	0.4 pCi/L		

Canister ID# :	2680437	Test Start :	03/18/2019 @ 05:19
Canister Type :	Charcoal Canister 3 inch	Test Stop :	03/20/2019 @ 05:20
Location :	1st FL=Princ. Conf. Rm	Received:	03/25/2019 @ 09:34
Radon Level :	1.3 pCi/L	Analyzed:	03/25/2019 @ 17:35
Error for Measurement is: ±	0.5 pCi/L		

Canister ID# :	2680438	Test Start :	03/18/2019 @ 06:01
Canister Type :	Charcoal Canister 3 inch	Test Stop :	03/20/2019 @ 06:01
Location :	1st FL = Rm 22 BLANK	Received:	03/25/2019 @ 09:34
Radon Level :	0.1 pCi/L	Analyzed:	03/26/2019 @ 09:27
Error for Measurement is: ±	0.1 pCi/L		



Andreas C. George

Dante Galan

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201



Site Radon Inspection Report

Date : 03/25/2019

Bryan Hogan / Ron Havniar
MEDFORD SCHOOL DISTRICT
815 South Oakdale Avenue
Medford, OR 97501-

Client: Hoover E.S.
Test Location: 2323 Siskiyou Boulevard
Medford, OR 97504-

Individual Canister Results

Canister ID# : 2680446 Test Start : 03/18/2019 @ 05:54
Canister Type : Charcoal Canister 3 inch Test Stop : 03/20/2019 @ 05:56
Location : 1st FL = Rm 14 Received: 03/25/2019 @ 09:34
Radon Level : 0.8 pCi/L Analyzed: 03/25/2019 @ 17:39
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 2680450 Test Start : 03/18/2019 @ 05:56
Canister Type : Charcoal Canister 3 inch Test Stop : 03/20/2019 @ 05:56
Location : 1st FL = Rm 55 BLANK Received: 03/25/2019 @ 09:34
Radon Level : 0.1 pCi/L Analyzed: 03/25/2019 @ 17:36
Error for Measurement is: ± 0.2 pCi/L

Canister ID# : 2680458 Test Start : 03/18/2019 @ 05:21
Canister Type : Charcoal Canister 3 inch Test Stop : 03/20/2019 @ 05:21
Location : 1st FL = Health Rm Received: 03/25/2019 @ 09:34
Radon Level : 0.8 pCi/L Analyzed: 03/25/2019 @ 18:11
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2680628 Test Start : 03/18/2019 @ 05:55
Canister Type : Charcoal Canister 3 inch Test Stop : 03/20/2019 @ 06:06
Location : 1st FL = Rm 55 Received: 03/25/2019 @ 09:34
Radon Level : 0.6 pCi/L Analyzed: 03/25/2019 @ 18:08
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 2680632 Test Start : 03/18/2019 @ 06:42
Canister Type : Charcoal Canister 3 inch Test Stop : 03/20/2019 @ 06:53
Location : 1st FL = Rm 44 Received: 03/25/2019 @ 09:34
Radon Level : 0.9 pCi/L Analyzed: 03/25/2019 @ 18:11
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 2680645 Test Start : 03/18/2019 @ 05:40
Canister Type : Charcoal Canister 3 inch Test Stop : 03/20/2019 @ 05:40
Location : 1st FL=Media Ctr #1 Received: 03/25/2019 @ 09:34
Radon Level : 1.5 pCi/L Analyzed: 03/25/2019 @ 13:27
Error for Measurement is: ± 0.4 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 03/25/2019

Bryan Hogan / Ron Havnear
 MEDFORD SCHOOL DISTRICT
 815 South Oakdale Avenue
 Medford, OR 97501-

Client: Hoover E.S.

Test Location: 2323 Siskiyou Boulevard
 Medford, OR 97504-

Individual Canister Results

Canister ID# : 2680654 Test Start : 03/18/2019 @ 06:42
 Canister Type : Charcoal Canister 3 inch Test Stop : 03/20/2019 @ 06:42
 Location : 1st FL = Rm 44 BLANK Received: 03/25/2019 @ 09:34
 Radon Level : 0.1 pCi/L Analyzed: 03/25/2019 @ 13:23
 Error for Measurement is: \pm 0.6 pCi/L


Canister ID# : 2680659 Test Start : 03/18/2019 @ 05:48
 Canister Type : Charcoal Canister 3 inch Test Stop : 03/20/2019 @ 06:03
 Location : 1st FL = Computer Rm Received: 03/25/2019 @ 09:33
 Radon Level : 1.1 pCi/L Analyzed: 03/25/2019 @ 17:52
 Error for Measurement is: \pm 0.5 pCi/L

Canister ID# : 2680663 Test Start : 03/18/2019 @ 06:40
 Canister Type : Charcoal Canister 3 inch Test Stop : 03/20/2019 @ 06:51
 Location : 1st FL = Rm 43 Received: 03/25/2019 @ 09:34
 Radon Level : 0.3 pCi/L Analyzed: 03/25/2019 @ 13:26
 Error for Measurement is: \pm 0.4 pCi/L

Canister ID# : 2680671 Test Start : 03/18/2019 @ 06:38
 Canister Type : Charcoal Canister 3 inch Test Stop : 03/20/2019 @ 06:50
 Location : 1st FL = Rm 42 Received: 03/25/2019 @ 09:34
 Radon Level : 0.4 pCi/L Analyzed: 03/25/2019 @ 18:12
 Error for Measurement is: \pm 0.4 pCi/L

Canister ID# : 2680673 Test Start : 03/18/2019 @ 06:20
 Canister Type : Charcoal Canister 3 inch Test Stop : 03/20/2019 @ 06:20
 Location : 1st FL = Rm 62 BL Received: 03/25/2019 @ 09:33
 Radon Level : 0.4 pCi/L Analyzed: 03/25/2019 @ 17:55
 Error for Measurement is: \pm 0.5 pCi/L

Canister ID# : 2680686 Test Start : 03/18/2019 @ 06:06
 Canister Type : Charcoal Canister 3 inch Test Stop : 03/20/2019 @ 06:15
 Location : 1st FL = Rm 45 Received: 03/25/2019 @ 09:34
 Radon Level : 0.2 pCi/L Analyzed: 03/25/2019 @ 17:39
 Error for Measurement is: \pm 0.4 pCi/L

Andreas C. George
 Radon Measurement Specialist

NJ MES 11089



Dante Galan
 Laboratory Director

NRSB ARL0001
 NYS ELAP ID: 10806
 PADEP ID: 0346
 NJDEP ID: NY933
 NJ MEB 90036
 FL DOH RB1609
 IL RNL2000201

Site Radon Inspection Report

Date : 03/25/2019

Bryan Hogan / Ron Havnear
MEDFORD SCHOOL DISTRICT
815 South Oakdale Avenue
Medford, OR 97501-

Client: Hoover E.S.
Test Location: 2323 Siskiyou Boulevard
Medford, OR 97504-

Individual Canister Results

Canister ID# : 2680919 Test Start : 03/18/2019 @ 05:43
Canister Type : Charcoal Canister 3 inch Test Stop : 03/20/2019 @ 05:49
Location : 1st FL = Rm 12 Received: 03/25/2019 @ 09:34
Radon Level : 0.6 pCi/L Analyzed: 03/25/2019 @ 17:39
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 2680928 Test Start : 03/18/2019 @ 05:44
Canister Type : Charcoal Canister 3 inch Test Stop : 03/20/2019 @ 06:03
Location : 1st FL = Rm 52 DP Received: 03/25/2019 @ 09:33
Radon Level : 0.7 pCi/L Analyzed: 03/25/2019 @ 17:55
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 2680929 Test Start : 03/18/2019 @ 05:37
Canister Type : Charcoal Canister 3 inch Test Stop : 03/20/2019 @ 06:00
Location : 1st FL = Rm 51 Received: 03/25/2019 @ 09:34
Radon Level : 0.6 pCi/L Analyzed: 03/25/2019 @ 18:08
Error for Measurement is: ± 0.6 pCi/L

Canister ID# : 2680933 Test Start : 03/18/2019 @ 06:07
Canister Type : Charcoal Canister 3 inch Test Stop : 03/20/2019 @ 06:09
Location : 1st FL = Rm 24 Received: 03/25/2019 @ 09:34
Radon Level : 1.6 pCi/L Analyzed: 03/25/2019 @ 18:11
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2680938 Test Start : 03/18/2019 @ 05:47
Canister Type : Charcoal Canister 3 inch Test Stop : 03/20/2019 @ 05:47
Location : 1st FL = Rm 53 BLANK Received: 03/25/2019 @ 09:34
Radon Level : 0.1 pCi/L Analyzed: 03/25/2019 @ 17:56
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 2680941 Test Start : 03/18/2019 @ 05:40
Canister Type : Charcoal Canister 3 inch Test Stop : 03/20/2019 @ 05:40
Location : 1st FL=Media Ctr BL Received: 03/25/2019 @ 09:33
Radon Level : 0.1 pCi/L Analyzed: 03/25/2019 @ 17:52
Error for Measurement is: ± 0.2 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 03/25/2019

Bryan Hogan / Ron Havnear
MEDFORD SCHOOL DISTRICT
815 South Oakdale Avenue
Medford, OR 97501-

Client: Hoover E.S.
Test Location: 2323 Siskiyou Boulevard
Medford, OR 97504-

Individual Canister Results

Canister ID# : 2680942 Test Start : 03/18/2019 @ 06:49
Canister Type : Charcoal Canister 3 inch Test Stop : 03/20/2019 @ 06:49
Location : 1st FL = Rm 34 BLANK Received: 03/25/2019 @ 09:34
Radon Level : 0.1 pCi/L Analyzed: 03/25/2019 @ 17:39
Error for Measurement is: ± 0.3 pCi/L

Canister ID# : 2680943 Test Start : 03/18/2019 @ 05:58
Canister Type : Charcoal Canister 3 inch Test Stop : 03/20/2019 @ 06:07
Location : 1st FL = Rm 56 Received: 03/25/2019 @ 09:34
Radon Level : 0.8 pCi/L Analyzed: 03/25/2019 @ 10:32
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2680944 Test Start : 03/18/2019 @ 06:35
Canister Type : Charcoal Canister 3 inch Test Stop : 03/20/2019 @ 06:48
Location : 1st FL = Rm 41 DP Received: 03/25/2019 @ 09:34
Radon Level : 0.6 pCi/L Analyzed: 03/25/2019 @ 18:08
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2680945 Test Start : 03/18/2019 @ 05:48
Canister Type : Charcoal Canister 3 inch Test Stop : 03/20/2019 @ 05:53
Location : 1st FL = Rm 13 Received: 03/25/2019 @ 09:34
Radon Level : 0.6 pCi/L Analyzed: 03/25/2019 @ 18:12
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 2680949 Test Start : 03/18/2019 @ 06:05
Canister Type : Charcoal Canister 3 inch Test Stop : 03/20/2019 @ 06:13
Location : 1st FL = Cafe #2 Received: 03/25/2019 @ 09:34
Radon Level : 0.2 pCi/L Analyzed: 03/25/2019 @ 17:39
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2681495 Test Start : 03/18/2019 @ 06:46
Canister Type : Charcoal Canister 3 inch Test Stop : 03/20/2019 @ 06:52
Location : 1st FL = Rm 33 Received: 03/25/2019 @ 09:34
Radon Level : 2.6 pCi/L Analyzed: 03/25/2019 @ 17:35
Error for Measurement is: ± 0.5 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201



Site Radon Inspection Report

Date : 03/25/2019

Bryan Hogan / Ron Havnear
MEDFORD SCHOOL DISTRICT
815 South Oakdale Avenue
Medford, OR 97501-

Client: Hoover E.S.
Test Location: 2323 Siskiyou Boulevard
Medford, OR 97504-

Individual Canister Results

Canister ID# : 2681502 Test Start : 03/18/2019 @ 05:41
Canister Type : Charcoal Canister 3 inch Test Stop : 03/20/2019 @ 06:02
Location : 1st FL = Rm 52 Received: 03/25/2019 @ 09:34
Radon Level : 0.7 pCi/L Analyzed: 03/25/2019 @ 10:32
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2681504 Test Start : 03/18/2019 @ 05:41
Canister Type : Charcoal Canister 3 inch Test Stop : 03/20/2019 @ 06:03
Location : 1st FL = Gym #3 Received: 03/25/2019 @ 09:33
Radon Level : 0.2 pCi/L Analyzed: 03/25/2019 @ 17:55
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 2681505 Test Start : 03/18/2019 @ 06:35
Canister Type : Charcoal Canister 3 inch Test Stop : 03/20/2019 @ 06:48
Location : 1st FL = Rm 41 Received: 03/25/2019 @ 09:34
Radon Level : 0.3 pCi/L Analyzed: 03/25/2019 @ 17:56
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2681513 Test Start : 03/18/2019 @ 05:46
Canister Type : Charcoal Canister 3 inch Test Stop : 03/20/2019 @ 06:04
Location : 1st FL = Rm 53 Received: 03/25/2019 @ 09:34
Radon Level : 0.6 pCi/L Analyzed: 03/25/2019 @ 13:26
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 2681519 Test Start : 03/18/2019 @ 05:42
Canister Type : Charcoal Canister 3 inch Test Stop : 03/20/2019 @ 05:42
Location : 1st FL=Media Ctr #2 Received: 03/25/2019 @ 09:34
Radon Level : 1.4 pCi/L Analyzed: 03/25/2019 @ 17:35
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2681594 Test Start : 03/18/2019 @ 05:39
Canister Type : Charcoal Canister 3 inch Test Stop : 03/20/2019 @ 06:01
Location : 1st FL = Gym #2 Received: 03/25/2019 @ 09:34
Radon Level : 0.4 pCi/L Analyzed: 03/25/2019 @ 18:08
Error for Measurement is: ± 0.4 pCi/L



Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201



Site Radon Inspection Report

Date : 03/25/2019

Bryan Hogan / Ron Havnear
MEDFORD SCHOOL DISTRICT
815 South Oakdale Avenue
Medford, OR 97501-

Client: Hoover E.S.
Test Location: 2323 Siskiyou Boulevard
Medford, OR 97504-

Individual Canister Results

Canister ID# : 2681601
Canister Type : Charcoal Canister 3 inch
Location : 1st FL = Principals Off.
Radon Level : 1.8 pCi/L
Error for Measurement is: ± 0.5 pCi/L
Test Start : 03/18/2019 @ 05:16
Test Stop : 03/20/2019 @ 05:19
Received: 03/25/2019 @ 09:33
Analyzed: 03/25/2019 @ 17:52

Canister ID# : 2681602
Canister Type : Charcoal Canister 3 inch
Location : 1st FL = Rm 32
Radon Level : 0.9 pCi/L
Error for Measurement is: ± 0.4 pCi/L
Test Start : 03/18/2019 @ 06:38
Test Stop : 03/20/2019 @ 06:48
Received: 03/25/2019 @ 09:34
Analyzed: 03/25/2019 @ 17:56

Canister ID# : 2681611
Canister Type : Charcoal Canister 3 inch
Location : 1st FL = Rm 14 DP
Radon Level : 0.9 pCi/L
Error for Measurement is: ± 0.4 pCi/L
Test Start : 03/18/2019 @ 05:54
Test Stop : 03/20/2019 @ 05:56
Received: 03/25/2019 @ 09:34
Analyzed: 03/25/2019 @ 13:26

Canister ID# : 2681618
Canister Type : Charcoal Canister 3 inch
Location : 1st FL = Rm 23
Radon Level : 0.5 pCi/L
Error for Measurement is: ± 0.5 pCi/L
Test Start : 03/18/2019 @ 06:05
Test Stop : 03/20/2019 @ 06:05
Received: 03/25/2019 @ 09:34
Analyzed: 03/25/2019 @ 17:52

Canister ID# : 2681625
Canister Type : Charcoal Canister 3 inch
Location : 1st FL = Rm 64-B
Radon Level : 17.7 pCi/L
Error for Measurement is: ± 0.8 pCi/L
Test Start : 03/18/2019 @ 09:45
Test Stop : 03/20/2019 @ 09:45
Received: 03/25/2019 @ 09:34
Analyzed: 03/25/2019 @ 18:11

This is a quality control test known as a spike. This canister has never been on the school site.

Canister ID# : 2681634
Canister Type : Charcoal Canister 3 inch
Location : 1st FL = Cafe #1
Radon Level : 0.1 pCi/L
Error for Measurement is: ± 0.4 pCi/L
Test Start : 03/18/2019 @ 06:02
Test Stop : 03/20/2019 @ 06:13
Received: 03/25/2019 @ 09:34
Analyzed: 03/25/2019 @ 13:23



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 03/25/2019

Bryan Hogan / Ron Havnear
 MEDFORD SCHOOL DISTRICT
 815 South Oakdale Avenue
 Medford, OR 97501-

Client: Hoover E.S.

Test Location: 2323 Siskiyou Boulevard
 Medford, OR 97504-

Individual Canister Results

Canister ID# :	2681639	Test Start :	03/18/2019 @ 05:24
Canister Type :	Charcoal Canister 3 inch	Test Stop :	03/20/2019 @ 05:24
Location :	1st FL = Rm 1 BLANK	Received:	03/25/2019 @ 09:34
Radon Level :	0.1 pCi/L	Analyzed:	03/25/2019 @ 17:19
Error for Measurement is: ±	0.3 pCi/L		


Canister ID# :	2681645	Test Start :	03/18/2019 @ 05:56
Canister Type :	Charcoal Canister 3 inch	Test Stop :	03/20/2019 @ 06:07
Location :	1st FL = Rm 47 DP	Received:	03/25/2019 @ 09:34
Radon Level :	0.1 pCi/L	Analyzed:	03/25/2019 @ 18:11
Error for Measurement is: ±	0.4 pCi/L		

Canister ID# :	2681659	Test Start :	03/18/2019 @ 05:36
Canister Type :	Charcoal Canister 3 inch	Test Stop :	03/20/2019 @ 05:59
Location :	1st FL = Gym #1	Received:	03/25/2019 @ 09:33
Radon Level :	0.3 pCi/L	Analyzed:	03/25/2019 @ 17:52
Error for Measurement is: ±	0.6 pCi/L		

Canister ID# :	2681661	Test Start :	03/18/2019 @ 06:00
Canister Type :	Charcoal Canister 3 inch	Test Stop :	03/20/2019 @ 06:08
Location :	1st FL = Rm 56 DP	Received:	03/25/2019 @ 09:34
Radon Level :	0.2 pCi/L	Analyzed:	03/25/2019 @ 17:19
Error for Measurement is: ±	0.4 pCi/L		

Canister ID# :	2681685	Test Start :	03/18/2019 @ 05:49
Canister Type :	Charcoal Canister 3 inch	Test Stop :	03/20/2019 @ 06:05
Location :	1st FL = Stage	Received:	03/25/2019 @ 09:33
Radon Level :	0.4 pCi/L	Analyzed:	03/25/2019 @ 17:52
Error for Measurement is: ±	0.5 pCi/L		

Canister ID# :	2736500	Test Start :	03/18/2019 @ 05:48
Canister Type :	Charcoal Canister 3 inch	Test Stop :	03/20/2019 @ 06:03
Location :	1st FL = Comp. Rm DP	Received:	03/25/2019 @ 09:34
Radon Level :	1.5 pCi/L	Analyzed:	03/25/2019 @ 17:52
Error for Measurement is: ±	0.5 pCi/L		

Andreas C. George
 Radon Measurement Specialist

NJ MES 11089



Dante Galan
 Laboratory Director

NRSB ARL0001
 NYS ELAP ID: 10806
 PADEP ID: 0346
 NJDEP ID: NY933
 NJ MEB 90036
 FL DOH RB1609
 IL RNL2000201

Site Radon Inspection Report

Date : 03/25/2019

Bryan Hogan / Ron Havnear
 MEDFORD SCHOOL DISTRICT
 815 South Oakdale Avenue
 Medford, OR 97501-

Client: Hoover E.S.

Test Location: 2323 Siskiyou Boulevard
 Medford, OR 97504-

Individual Canister Results

The results indicate that at least one testing device registered at or above the United States Environmental Protection Agency (EPA) action level of 4.0 picoCuries per liter of air (pCi/L). The EPA recommends mitigation if the average of two short-term tests taken in the lowest level of the building suitable for occupancy show radon levels that are equal to or greater than 4.0 pCi/L.


For information on how to reduce radon levels in your home, please review the EPA booklet: Consumer's Guide to Radon Reduction (www.epa.gov/radon/pdfs/consguid.pdf) and contact your state health department. The EPA maintains a radon information website, including copies of its publications, at www.epa.gov/iaq/radon.

For New Jersey clients: Please see the attached guidance document entitled Radon Testing and Mitigation: The Basics for further information.

For New York clients: If the radon level of one or more testing devices is equal to or exceeds 20 pCi/L please contact the New York State Department of Health, Bureau of Environmental Radiation Protection, for technical advice and assistance at 518-402-7556 or toll free 1-800-458-1158.

PLEDGE OF ASSURED QUALITY

All procedures used for generating this report are in complete accordance with the current EPA protocols for the analysis of radon in air (EPA 402-R-92-004). The analytical results relate only to the samples tested, in the condition received by the lab, and that calculations were based upon the information supplied by client. RTCA and its personnel do not assume responsibility or liability, collectively and individually, for analysis results when detectors have been improperly handled or placed by the consumer, nor does RTCA and its personnel accept responsibility for any financial or health consequences of subsequent action or lack of action, taken by the customer or its consultants based on RTCA-provided results.

Andreas C. George
 Radon Measurement Specialist
 NJ MES 11089



Dante Galan
 Laboratory Director

NRSB ARL0001
 NYS ELAP ID: 10806
 PADEP ID: 0346
 NJDEP ID: NY933
 NJ MEB 90036
 FL DOH RB1609
 IL RNL2000201