

Howard Elementary School						
Lead Tests - Howard Elementary School - Main Building - # 20480300						
#	Fixture ID #	Sample ID #	Location/Type	Date Tested	Lead Test Results	Remarks
1	20480300-001SF	20480300-001SF21A	Staff Work Room - Sink	2/11/2020	Passed with 0.00140	None.
2	20480300-002NS	20480300-002NS21A	Health Room - Sink (Left)	2/11/2020	Passed with 0.00614	None.
3	20480300-003NS	20480300-003NS21A	Health Room - Sink (Right)	2/11/2020	Passed with 0.00475	None.
4	20480300-004DW	20480300-004DW21A	Health Room - Drinking Fountain (Right Sink)	2/11/2020	Passed with 0.00276	None.
5	20480300-005BF	20480300-005BF21A	Health Room - Sink (Bathroom)	2/11/2020	Passed with 0.00217	None.
6	20480300-006SF	20480300-006SF21A	Staff Break Room - Sink	2/11/2020	Passed with 0.000767	None.
7	20480300-007BF	20480300-007BF21A	Girls Restroom (Across From Staff Break Room) - Sink (Left)	2/11/2020	Passed with 0.000947	None.
8	20480300-008BF	20480300-008BF21A	Girls Restroom (Across From Staff Break Room) - Sink (Right)	2/11/2020	Passed with 0.00100	None.
9	20480300-009BF	20480300-009BF21A	Boys Restroom (Across From Music Room) - Sink (Left)	2/11/2020	Passed with 0.00124	None.
10	20480300-010BF	20480300-010BF21A	Boys Restroom (Across From Music Room) - Sink (Right)	2/11/2020	Passed with 0.00136	None.
11	20480300-011DW	20480300-011DW21A	Room 2 - Drinking Fountain	2/11/2020	Passed with 0.000352	None.
12	20480300-012CF	20480300-012CF21A	Room 2 - Sink	2/11/2020	Passed with 0.00108	None.
13	20480300-013DW	20480300-013DW21A	Room 3 - Drinking Fountain	2/11/2020	Passed with 0.00278	None.
14	20480300-014CF	20480300-014CF21A	Room 3 - Sink	2/11/2020	Passed with 0.000894	None.
15	20480300-015DW	20480300-015DW21A	Room 4 - Drinking Fountain	2/11/2020	Passed with 0.000859	None.
16	20480300-016CF	20480300-016CF21A	Room 4 - Sink	2/11/2020	Passed with 0.000672	None.
17	20480300-017DW	20480300-017DW21A	Room 5 - Drinking Fountain	2/11/2020	Passed with 0.000478	None.
18	20480300-018CF	20480300-018CF21A	Room 5 - Sink	2/11/2020	Passed with 0.000518	None.
19	20480300-019DW	20480300-019DW21A	Room 6 - Drinking Fountain	2/11/2020	Passed with 0.00166	None.
20	20480300-020CF	20480300-020CF21A	Room 6 - Sink	2/11/2020	Passed with 0.000499	None.
21	20480300-021DW	20480300-021DW21A	Room 7 - Drinking Fountain	2/11/2020	Passed with 0.000623	None.
22	20480300-022CF	20480300-022CF21A	Room 7 - Sink	2/11/2020	Passed with 0.000338	None.
23	20480300-023CF	20480300-023CF21A	Room 8 - Sink	2/11/2020	Passed with 0.00134	None.
24	20480300-024CF	20480300-024CF21A	Room 9 - Sink	2/11/2020	Passed with 0.000271	None.
25	20480300-025DW	20480300-025DW21A	Room 11 - Drinking Fountain	2/11/2020	Passed with 0.00152	None.
26	20480300-026CF	20480300-026CF21A	Room 11 - Sink	2/11/2020	Passed with 0.000896	None.
27	20480300-027DW	20480300-027DW21A	Room 12 - Drinking Fountain	2/11/2020	Passed with 0.000161	This drinking fountain has a lead filter on it.
28	20480300-028CF	20480300-028CF21A	Room 12 - Sink	2/11/2020	Passed with 0.000425	None.
29	20480300-029DW	20480300-029DW21A	Room 13 - Drinking Fountain	2/11/2020	Passed with 0.00102	None.
30	20480300-030CF	20480300-030CF21A	Room 13 - Sink	2/11/2020	Passed with 0.000536	None.
31	20480300-031DW	20480300-031DW21A	Room 14 - Drinking Fountain	2/11/2020	Passed with 0.00103	None.
32	20480300-032CF	20480300-032CF21A	Room 14 - Sink	2/11/2020	Passed with 0.000933	None.
33	20480300-033DW	20480300-033DW21A	Room 15 - Drinking Fountain	2/11/2020	Passed with 0.00156	None.
34	20480300-034CF	20480300-034CF21A	Room 15 - Sink	2/11/2020	Passed with 0.00102	None.
35	20480300-035BF	20480300-035BF21A	Room 15 - Sink (Restroom)	2/11/2020	Passed with 0.00158	None.
36	20480300-036DW	20480300-036DW21A	Room 16 - Drinking Fountain	2/11/2020	Passed with 0.000870	None.
37	20480300-037CF	20480300-037CF21A	Room 16 - Sink	2/11/2020	Passed with 0.000361	None.
38	20480300-038BF	20480300-038BF21A	Room 16 - Sink (Restroom)	2/11/2020	Passed with 0.000476	None.
39	20480300-039DW	20480300-039DW21A	Room 17 - Drinking Fountain	2/11/2020	Passed with 0.00148	None.
40	20480300-040CF	20480300-040CF21A	Room 17 - Sink	2/11/2020	Passed with 0.000776	None.
41	20480300-041BF	20480300-041BF21A	Room 17 - Sink (Restroom)	2/11/2020	Passed with 0.00102	None.
42	20480300-042DW	20480300-042DW21A	Room 18 - Drinking Fountain	2/11/2020	Passed with 0.00127	None.
43	20480300-043CF	20480300-043CF21A	Room 18 - Sink	2/11/2020	Passed with 0.000472	None.
44	20480300-044DW	20480300-044DW21A	Room 19 - Drinking Fountain	2/11/2020	Passed with 0.00107	None.
45	20480300-045CF	20480300-045CF21A	Room 19 - Sink	2/11/2020	Passed with 0.00261	None.
46	20480300-046DW	20480300-046DW21A	Room 20 - Drinking Fountain	2/11/2020	Passed with 0.00267	None.
47	20480300-047CF	20480300-047CF21A	Room 20 - Sink	2/11/2020	Passed with 0.00159	None.
Lead Tests - Howard Elementary School - Gymnasium/Cafeteria Building - # 20480301						
#	Fixture ID #	Sample ID #	Location/Type	Date Tested	Lead Test Results	Remarks
1	20480301-001DW	20480301-001DW21A	Cafeteria - Drinking Fountain	2/11/2020	Passed with 0.000970	None.
2	20480301-002KF	20480301-002KF21A	Cafeteria - Sink (Utility)	2/11/2020	Passed with 0.000587	None.
3	20480301-003KF	20480301-003KF21A	Kitchen - Sink (Small)	2/11/2020	Passed with 0.00113	None.
4	20480301-004KF	20480301-004KF21A	Kitchen - Sink (Dishwasher Pre-Rinse)	2/11/2020	Passed with 0.000700	None.
5	20480301-005DW	20480301-005DW21A	Gym - Drinking Fountain	2/11/2020	Passed with 0.00108	None.
6	20480301-006DW	20480301-006DW21A	Gym Stage - Drinking Fountain	2/11/2020	Passed with 0.0108	None.
7	20480301-007OT	20480301-007OT21A	Gym Stage - Sink	2/11/2020	Passed with 0.0100	None.
8	20480301-008SF	20480301-008SF21A	Room 161 - Sink (Utility)	2/11/2020	Passed with 0.00471	None.
9	20480301-009DW	20480301-009DW21A	Outside Gym - Drinking Fountain	2/11/2020	Passed with 0.00145	None.
10	20480301-010DW	20480301-010DW21A	Room 21 - Drinking Fountain	2/11/2020	Passed with 0.00136	None.
11	20480301-011CF	20480301-011CF21A	Room 21 - Sink	2/11/2020	Passed with 0.00829	None.
12	20480301-012DW	20480301-012DW21A	Room 22 - Drinking Fountain	2/11/2020	Passed with None Detected	None.
13	20480301-013CF	20480301-013CF21A	Room 22 - Sink	2/11/2020	Passed with 0.00119	None.

14	20480301-014BF	20480301-014BF21A	Boys Restroom Outside Room 21 (South Side) - Sink (Right)	2/11/2020	Passed with 0.00365	None.
15	20480301-015BF	20480301-015BF21A	Boys Restroom Outside Room 21 (South Side) - Sink (Left)	2/11/2020	Passed with 0.00415	None.
16	20480301-016BF	20480301-016BF21A	STEPs Restroom Outside Room 21 (North Side) - Sink (Right)	2/11/2020	Passed with 0.00195	None.
17	20480301-017BF	20480301-017BF21A	STEPs Restroom Outside Room 21 (North Side) - Sink (Left)	2/11/2020	Passed with 0.00137	None.
18	20480301-018DW	20480301-018DW21A	Room 23 - Drinking Fountain	2/11/2020	Passed with 0.000225	None.
19	20480301-019CF	20480301-019CF21A	Room 23 - Sink	2/11/2020	Passed with 0.000651	None.
Lead Tests - Howard Elementary School - "B" Classrooms Building - # 20480302						
#	Fixture ID #	Sample ID #	Location/Type	Date Tested	Lead Test Results	Remarks
1	20480302-001DW	20480302-001DW21A	Room 24 - Drinking Fountain	2/11/2020	Passed with 0.000765	None.
2	20480302-002CF	20480302-002CF21A	Room 24 - Sink	2/11/2020	Passed with 0.000647	None.
3	20480302-003BF	20480302-003BF21A	Boys Restroom Outside Room 24 (North Side) - Sink (Left)	2/11/2020	Passed with 0.00183	None.
4	20480302-004BF	20480302-004BF21A	Boys Restroom Outside Room 24 (North Side) - Sink (Right)	2/11/2020	Passed with 0.00216	None.
5	20480302-005BF	20480302-005BF21A	Girls Restroom Outside Room 24 (North Side) - Sink (Left)	2/11/2020	Passed with 0.00229	None.
6	20480302-006BF	20480302-006BF21A	Girls Restroom Outside Room 24 (North Side) - Sink (Right)	2/11/2020	Passed with 0.00222	None.
7	20480302-007DW	20480302-007DW21A	Room 25 - Drinking Fountain	2/11/2020	Passed with 0.00182	None.
8	20480302-008CF	20480302-008CF21A	Room 25 - Sink	2/11/2020	Passed with 0.000399	None.
9	20480302-009SF	20480302-009SF21A	Common Area of 24/25/26 - Sink	3/5/2020	Passed with 0.00144	This fixture has a lead filter on it.
10	20480302-010DW	20480302-010DW21A	Room 26 - Drinking Fountain	2/11/2020	Passed with 0.000352	None.
11	20480302-011CF	20480302-011CF21A	Room 26 - Sink	2/11/2020	Passed with 0.000689	None.
Lead Tests - Howard Elementary School - "E" Classrooms Building - # 20480303						
#	Fixture ID #	Sample ID #	Location/Type	Date Tested	Lead Test Results	Remarks
1	20480303-001DW	20480303-001DW21A	Room 27 - Drinking Fountain	3/5/2020	Passed with 0.000721	This fixture has a lead filter on it.
2	20480303-002CF	20480303-002CF21A	Room 27 - Sink	3/5/2020	Passed with 0.00355	This fixture has a lead filter on it.
3	20480303-003BF	20480303-003BF21A	Girls Restroom Outside Room 27 (South/East Side) - Sink (Left)	2/11/2020	Passed with 0.00547	None.
4	20480303-004BF	20480303-004BF21A	Girls Restroom Outside Room 27 (South/East Side) - Sink (Right)	2/11/2020	Passed with 0.00351	None.
5	20480303-005BF	20480303-005BF21A	Boys Restroom Outside Room 27 (South/West Side) - Sink (Left)	2/11/2020	Passed with 0.00753	None.
6	20480303-006BF	20480303-006BF21A	Boys Restroom Outside Room 27 (South/West Side) - Sink (Right)	2/11/2020	Passed with 0.00649	None.
7	20480303-007DW	20480303-007DW21A	Room 28 - Drinking Fountain	2/11/2020	Passed with 0.00774	None.
8	20480303-008CF	20480303-008CF21A	Room 28 - Sink	2/11/2020	Passed with 0.00451	None.
9	20480303-009SF	20480303-009SF21A	Room South of Room 28 (A1) - Sink	3/5/2020	Passed with None Detected	This fixture has a lead filter on it.
10	20480303-010BF	20480303-010BF21A	Room South of Room 28 - Uni-sex Restroom Sink	2/11/2020	Passed with 0.0120	None.
11	20480303-011BF	20480303-011BF21A	Room South of Room 28 - Women's Restroom Sink	2/11/2020	Passed with 0.0117	None.
12	20480303-012DW	20480303-012DW21A	Room 29 - Drinking Fountain	2/11/2020	Passed with 0.0119	None.
13	20480303-013CF	20480303-013CF21A	Room 29 - Sink	2/11/2020	Passed with 0.00688	None.
14	20480303-014DW	20480303-014DW21A	Room 30 - Drinking Fountain	3/5/2020	Passed with 0.00161	This fixture has a lead filter on it.
15	20480303-015CF	20480303-015CF21A	Room 30 - Sink	3/5/2020	Passed with 0.00485	This fixture has a lead filter on it.
16	20480303-016DW	20480303-016DW21A	Room 31 - Drinking Fountain	2/11/2020	Passed with 0.00994	None.
17	20480303-017CF	20480303-017CF21A	Room 31 - Sink	2/11/2020	Passed with 0.00823	None.
18	20480303-018DW	20480303-018DW21A	Room 32 - Drinking Fountain	2/11/2020	Passed with 0.0123	None.
19	20480303-019CF	20480303-019CF21A	Room 32 - Sink	2/11/2020	Passed with 0.00728	None.

*None Detected (ND) = .005 Or Less

 = Fixture Where Water Has The Potential of Being Consumed (All of These Will Be Tested When Testing The Whole School)

*ODE's required action level is 15 parts per billion (PPB)

*The E.P.A.'s recommended action level for lead in schools is 0.020. Oregon's action level for schools changed to 0.015 in 2019 in accordance with OAR 333-061-0400. In 2021, ODE changed the unit of measurement for reporting to parts per billion (PPB)

*The E.P.A. action level for copper is 1.30

*Lead test results will be posted on the MSD/Facilities website within 5 days minus the school map for security purposes.