



NEILSON RESEARCH CORPORATION

Environmental Testing Laboratory

7/29/2016

Rick Rose
Medford School District
815 S Oakdale Ave
Medford, OR 97501

TEL: (541) 842-1138
FAX 541-842-1160

RE: 16-24 Jackson Lead Study

Order No.: 1607780

Dear Rick Rose:

Neilson Research Corporation received 49 sample(s) on 7/19/2016 for the analyses presented in the following report.

The results relate only to the parameters tested or to the sample as received by the laboratory. This report shall not be reproduced except in full, without the written approval of Neilson Research Corporation. If you have any questions regarding these test results, please feel free to call.

Sincerely,
Neilson Research Corporation

Alec C Smith
Project Manager

245 S Grape St • Medford, OR 97501 • (541) 770-5678
400 SE G St, Suite B • Grants Pass, OR 97526 • (541) 479-4053

www.nrclabs.com

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

CLIENT: Medford School District
Project: 16-24 Jackson Lead Study
Lab Order: 1607780

Date: 29-Jul-16

CASE NARRATIVE

The analyses were performed according to the guidelines in the Neilson Research Corporation Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

Neilson Research Corporation certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: **1607780**
NRC Sample ID: **1607780-01A**
Collection Date: **7/15/2016 1:53:00 PM**
Received Date: **7/19/2016 9:31:00 AM**
Reported Date: **7/29/2016 10:49:09 AM**

Sample Information:

16-24 Jackson Lead Study

Client Sample ID: Bottle #11248
Collectors Name: Roger Newland
Sample Location: Rm 111 DF
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP		Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
		Accredited	Result						
Copper	EPA 200.8	A	1.84	*	0.00515	mg/L	1.3 AL	7/28/2016	OML
Lead	EPA 200.8	A	0.0748	*	0.000103	mg/L	0.020 AL	7/25/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: **1607780**
NRC Sample ID: **1607780-02A**
Collection Date: **7/15/2016 1:54:00 PM**
Received Date: **7/19/2016 9:31:00 AM**
Reported Date: **7/29/2016 10:49:09 AM**

Sample Information:

16-24 Jackson Lead Study

Client Sample ID: Bottle #17089
Collectors Name: Roger Newland
Sample Location: Rm 112 DF
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.0169		0.000103	mg/L	0.020 AL	7/25/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: **1607780**
NRC Sample ID: **1607780-03A**
Collection Date: **7/15/2016 1:56:00 PM**
Received Date: **7/19/2016 9:31:00 AM**
Reported Date: **7/29/2016 10:49:09 AM**

Sample Information:

16-24 Jackson Lead Study

Client Sample ID: Bottle #17081
Collectors Name: Roger Newland
Sample Location: Rm 113 DF
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP		Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
		Accredited	Result						
Copper	EPA 200.8	A	1.58	*	0.00103	mg/L	1.3 AL	7/28/2016	OML
Lead	EPA 200.8	A	0.0548	*	0.000103	mg/L	0.020 AL	7/25/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: **1607780**
NRC Sample ID: **1607780-04A**
Collection Date: **7/15/2016 2:02:00 PM**
Received Date: **7/19/2016 9:31:00 AM**
Reported Date: **7/29/2016 10:49:09 AM**

Sample Information:

16-24 Jackson Lead Study

Client Sample ID: Bottle #17079
Collectors Name: Roger Newland
Sample Location: Near 1st Flr Elev DF Upr
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.0292	*	0.000103	mg/L	0.020 AL	7/25/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: **1607780**
NRC Sample ID: **1607780-05A**
Collection Date: **7/15/2016 2:02:00 PM**
Received Date: **7/19/2016 9:31:00 AM**
Reported Date: **7/29/2016 10:49:09 AM**

Sample Information:

16-24 Jackson Lead Study

Client Sample ID: Bottle #17023
Collectors Name: Roger Newland
Sample Location: Near 1st Flr Elev DF Lwr
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.0142		0.000103	mg/L	0.020 AL	7/25/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: **1607780**
NRC Sample ID: **1607780-06A**
Collection Date: **7/15/2016 2:03:00 PM**
Received Date: **7/19/2016 9:31:00 AM**
Reported Date: **7/29/2016 10:49:09 AM**

Sample Information:

16-24 Jackson Lead Study

Client Sample ID: Bottle #17088
Collectors Name: Roger Newland
Sample Location: Rm 141 DF
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.140	*	0.000103	mg/L	0.020 AL	7/25/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: **1607780**
NRC Sample ID: **1607780-07A**
Collection Date: **7/15/2016 2:08:00 PM**
Received Date: **7/19/2016 9:31:00 AM**
Reported Date: **7/29/2016 10:49:09 AM**

Sample Information:

16-24 Jackson Lead Study

Client Sample ID: Bottle #17075
Collectors Name: Roger Newland
Sample Location: Rm 142 DF
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP		Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
		Accredited	Result						
Copper	EPA 200.8	A	1.81	*	0.00515	mg/L	1.3 AL	7/28/2016	OML
Lead	EPA 200.8	A	0.128	*	0.000103	mg/L	0.020 AL	7/25/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: **1607780**
NRC Sample ID: **1607780-08A**
Collection Date: **7/15/2016 2:07:00 PM**
Received Date: **7/19/2016 9:31:00 AM**
Reported Date: **7/29/2016 10:49:09 AM**

Sample Information:

16-24 Jackson Lead Study

Client Sample ID: Bottle #19466
Collectors Name: Roger Newland
Sample Location: Rm 143 DF
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.0535	*	0.000103	mg/L	0.020 AL	7/25/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: **1607780**
NRC Sample ID: **1607780-09A**
Collection Date: **7/15/2016 1:56:00 PM**
Received Date: **7/19/2016 9:31:00 AM**
Reported Date: **7/29/2016 10:49:09 AM**

Sample Information:

16-24 Jackson Lead Study

Client Sample ID: Bottle #17082
Collectors Name: Roger Newland
Sample Location: Rm 120 DF (A)
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP		Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
		Accredited	Result						
Copper	EPA 200.8	A	2.23	*	0.00515	mg/L	1.3 AL	7/28/2016	OML
Lead	EPA 200.8	A	0.156	*	0.000103	mg/L	0.020 AL	7/25/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: **1607780**
NRC Sample ID: **1607780-10A**
Collection Date: **7/15/2016 1:35:00 PM**
Received Date: **7/19/2016 9:31:00 AM**
Reported Date: **7/29/2016 10:49:10 AM**

Sample Information:

16-24 Jackson Lead Study

Client Sample ID: Bottle #19476
Collectors Name: Roger Newland
Sample Location: Rm 120 DF (B)
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.0196		0.000103	mg/L	0.020 AL	7/25/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: **1607780**
NRC Sample ID: **1607780-11A**
Collection Date: **7/15/2016 1:37:00 PM**
Received Date: **7/19/2016 9:31:00 AM**
Reported Date: **7/29/2016 10:49:10 AM**

Sample Information:

16-24 Jackson Lead Study

Client Sample ID: Bottle #17055
Collectors Name: Roger Newland
Sample Location: Rm 120 DF (C)
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.0500	*	0.000103	mg/L	0.020 AL	7/25/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: **1607780**
NRC Sample ID: **1607780-12A**
Collection Date: **7/15/2016 1:41:00 PM**
Received Date: **7/19/2016 9:31:00 AM**
Reported Date: **7/29/2016 10:49:10 AM**

Sample Information:

16-24 Jackson Lead Study

Client Sample ID: Bottle #17018
Collectors Name: Roger Newland
Sample Location: Rm 121 DF
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP		Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
		Accredited	Result						
Copper	EPA 200.8	A	1.83	*	0.00515	mg/L	1.3 AL	7/28/2016	OML
Lead	EPA 200.8	A	0.154	*	0.000103	mg/L	0.020 AL	7/26/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: **1607780**
NRC Sample ID: **1607780-13A**
Collection Date: **7/15/2016 1:44:00 PM**
Received Date: **7/19/2016 9:31:00 AM**
Reported Date: **7/29/2016 10:49:10 AM**

Sample Information:

16-24 Jackson Lead Study

Client Sample ID: Bottle #17052
Collectors Name: Roger Newland
Sample Location: Rm 122 DF
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP		Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
		Accredited	Result						
Copper	EPA 200.8	A	1.55	*	0.00103	mg/L	1.3 AL	7/28/2016	OML
Lead	EPA 200.8	A	0.0935	*	0.000103	mg/L	0.020 AL	7/26/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: **1607780**
NRC Sample ID: **1607780-14A**
Collection Date: **7/15/2016 1:45:00 PM**
Received Date: **7/19/2016 9:31:00 AM**
Reported Date: **7/29/2016 10:49:10 AM**

Sample Information:

16-24 Jackson Lead Study

Client Sample ID: Bottle #17077
Collectors Name: Roger Newland
Sample Location: Rm 123 DF
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.0352	*	0.000103	mg/L	0.020 AL	7/26/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: **1607780**
NRC Sample ID: **1607780-15A**
Collection Date: **7/15/2016 1:48:00 PM**
Received Date: **7/19/2016 9:31:00 AM**
Reported Date: **7/29/2016 10:49:10 AM**

Sample Information:

16-24 Jackson Lead Study

Client Sample ID: Bottle #17072
Collectors Name: Roger Newland
Sample Location: Behind Slider Rm 110 DF
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.0420	*	0.000103	mg/L	0.020 AL	7/26/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: **1607780**
NRC Sample ID: **1607780-16A**
Collection Date: **7/15/2016 1:49:00 PM**
Received Date: **7/19/2016 9:31:00 AM**
Reported Date: **7/29/2016 10:49:10 AM**

Sample Information:

16-24 Jackson Lead Study

Client Sample ID: Bottle #19473
Collectors Name: Roger Newland
Sample Location: Behind Slider Rm 110 Sink
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.0337	*	0.000103	mg/L	0.020 AL	7/26/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: **1607780**
NRC Sample ID: **1607780-17A**
Collection Date: **7/15/2016 1:50:00 PM**
Received Date: **7/19/2016 9:31:00 AM**
Reported Date: **7/29/2016 10:49:10 AM**

Sample Information:

16-24 Jackson Lead Study

Client Sample ID: Bottle #17060
Collectors Name: Roger Newland
Sample Location: Rm 110 DF (A)
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP		Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
		Accredited	Result						
Copper	EPA 200.8	A	1.99	*	0.00515	mg/L	1.3 AL	7/28/2016	OML
Lead	EPA 200.8	A	0.118	*	0.000103	mg/L	0.020 AL	7/26/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: **1607780**
NRC Sample ID: **1607780-18A**
Collection Date: **7/15/2016 1:51:00 PM**
Received Date: **7/19/2016 9:31:00 AM**
Reported Date: **7/29/2016 10:49:10 AM**

Sample Information:

16-24 Jackson Lead Study

Client Sample ID: Bottle #17054
Collectors Name: Roger Newland
Sample Location: Rm 110 DF (B)
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP		Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
		Accredited	Result						
Copper	EPA 200.8	A	1.38	*	0.00103	mg/L	1.3 AL	7/28/2016	OML
Lead	EPA 200.8	A	0.0648	*	0.000103	mg/L	0.020 AL	7/26/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: **1607780**
NRC Sample ID: **1607780-19A**
Collection Date: **7/15/2016 2:18:00 PM**
Received Date: **7/19/2016 9:31:00 AM**
Reported Date: **7/29/2016 10:49:10 AM**

Sample Information:

16-24 Jackson Lead Study

Client Sample ID: Bottle #11277
Collectors Name: Larry Anderson
Sample Location: Rm 210 DF (B)
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP		Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
		Accredited	Result						
Copper	EPA 200.8	A	1.72	*	0.00103	mg/L	1.3 AL	7/28/2016	OML
Lead	EPA 200.8	A	0.130	*	0.000103	mg/L	0.020 AL	7/26/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: **1607780**
NRC Sample ID: **1607780-20A**
Collection Date: **7/15/2016 2:19:00 PM**
Received Date: **7/19/2016 9:31:00 AM**
Reported Date: **7/29/2016 10:49:10 AM**

Sample Information:

16-24 Jackson Lead Study

Client Sample ID: Bottle #19479
Collectors Name: Larry Anderson
Sample Location: Rm 210 DF (C)
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.00650		0.000103	mg/L	0.020 AL	7/26/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: **1607780**
NRC Sample ID: **1607780-21A**
Collection Date: **7/15/2016 2:08:00 PM**
Received Date: **7/19/2016 9:31:00 AM**
Reported Date: **7/29/2016 10:49:10 AM**

Sample Information:

16-24 Jackson Lead Study

Client Sample ID: Bottle #19485
Collectors Name: Larry Anderson
Sample Location: Rm 213 DF
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.0259	*	0.000103	mg/L	0.020 AL	7/26/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: **1607780**
NRC Sample ID: **1607780-22A**
Collection Date: **7/15/2016 2:11:00 PM**
Received Date: **7/19/2016 9:31:00 AM**
Reported Date: **7/29/2016 10:49:10 AM**

Sample Information:

16-24 Jackson Lead Study

Client Sample ID: Bottle #19471
Collectors Name: Larry Anderson
Sample Location: Rm 214 DF
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.139	*	0.000103	mg/L	0.020 AL	7/26/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: **1607780**
NRC Sample ID: **1607780-23A**
Collection Date: **7/15/2016 2:23:00 PM**
Received Date: **7/19/2016 9:31:00 AM**
Reported Date: **7/29/2016 10:49:10 AM**

Sample Information:

16-24 Jackson Lead Study

Client Sample ID: Bottle #17022
Collectors Name: Larry Anderson
Sample Location: Rm 241 DF
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.0349	*	0.000103	mg/L	0.020 AL	7/26/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: **1607780**
NRC Sample ID: **1607780-24A**
Collection Date: **7/15/2016 2:25:00 PM**
Received Date: **7/19/2016 9:31:00 AM**
Reported Date: **7/29/2016 10:49:10 AM**

Sample Information:

16-24 Jackson Lead Study

Client Sample ID: Bottle #19465
Collectors Name: Larry Anderson
Sample Location: Rm 242 DF
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.0315	*	0.000103	mg/L	0.020 AL	7/26/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: **1607780**
NRC Sample ID: **1607780-25A**
Collection Date: **7/15/2016 2:26:00 PM**
Received Date: **7/19/2016 9:31:00 AM**
Reported Date: **7/29/2016 10:49:10 AM**

Sample Information:

16-24 Jackson Lead Study

Client Sample ID: Bottle #17074
Collectors Name: Larry Anderson
Sample Location: Rm 243 DF
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.0152		0.000103	mg/L	0.020 AL	7/26/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: **1607780**
NRC Sample ID: **1607780-26A**
Collection Date: **7/15/2016 1:44:00 PM**
Received Date: **7/19/2016 9:31:00 AM**
Reported Date: **7/29/2016 10:49:10 AM**

Sample Information:

16-24 Jackson Lead Study

Client Sample ID: Bottle #19472
Collectors Name: Larry Anderson
Sample Location: Rm 220 DF (A)
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP		Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
		Accredited	Result						
Copper	EPA 200.8	A	2.16	*	0.00515	mg/L	1.3 AL	7/28/2016	OML
Lead	EPA 200.8	A	0.0905	*	0.000103	mg/L	0.020 AL	7/26/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: **1607780**
NRC Sample ID: **1607780-27A**
Collection Date: **7/15/2016 1:35:00 PM**
Received Date: **7/19/2016 9:31:00 AM**
Reported Date: **7/29/2016 10:49:10 AM**

Sample Information:

16-24 Jackson Lead Study

Client Sample ID: Bottle #19461
Collectors Name: Larry Anderson
Sample Location: Rm 220 DF (B)
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.00809		0.000103	mg/L	0.020 AL	7/26/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: **1607780**
NRC Sample ID: **1607780-28A**
Collection Date: **7/15/2016 1:37:00 PM**
Received Date: **7/19/2016 9:31:00 AM**
Reported Date: **7/29/2016 10:49:10 AM**

Sample Information:

16-24 Jackson Lead Study

Client Sample ID: Bottle # 17076
Collectors Name: Larry Anderson
Sample Location: Rm 220 DF (C)
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.0455	*	0.000103	mg/L	0.020 AL	7/26/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: **1607780**
NRC Sample ID: **1607780-29A**
Collection Date: **7/15/2016 1:50:00 PM**
Received Date: **7/19/2016 9:31:00 AM**
Reported Date: **7/29/2016 10:49:10 AM**

Sample Information:

16-24 Jackson Lead Study

Client Sample ID: Bottle #19484
Collectors Name: Larry Anderson
Sample Location: Rm 221 DF
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.0495	*	0.000103	mg/L	0.020 AL	7/26/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: **1607780**
NRC Sample ID: **1607780-30A**
Collection Date: **7/15/2016 1:51:00 PM**
Received Date: **7/19/2016 9:31:00 AM**
Reported Date: **7/29/2016 10:49:10 AM**

Sample Information:

16-24 Jackson Lead Study

Client Sample ID: Bottle #19488
Collectors Name: Larry Anderson
Sample Location: Rm 222 DF
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP		Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
		Accredited	Result						
Copper	EPA 200.8	A	1.50	*	0.00103	mg/L	1.3 AL	7/28/2016	OML
Lead	EPA 200.8	A	0.0546	*	0.000103	mg/L	0.020 AL	7/26/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: **1607780**
NRC Sample ID: **1607780-31A**
Collection Date: **7/15/2016 1:54:00 PM**
Received Date: **7/19/2016 9:31:00 AM**
Reported Date: **7/29/2016 10:49:10 AM**

Sample Information:

16-24 Jackson Lead Study

Client Sample ID: Bottle #19462
Collectors Name: Larry Anderson
Sample Location: Rm 223 DF
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP		Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
		Accredited	Result						
Copper	EPA 200.8	A	1.46	*	0.00103	mg/L	1.3 AL	7/28/2016	OML
Lead	EPA 200.8	A	0.0861	*	0.000103	mg/L	0.020 AL	7/26/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: **1607780**
NRC Sample ID: **1607780-32A**
Collection Date: **7/15/2016 1:56:00 PM**
Received Date: **7/19/2016 9:31:00 AM**
Reported Date: **7/29/2016 10:49:10 AM**

Sample Information:

16-24 Jackson Lead Study

Client Sample ID: Bottle #17024
Collectors Name: Larry Anderson
Sample Location: Rm 224 DF
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.0318	*	0.000103	mg/L	0.020 AL	7/26/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: **1607780**
NRC Sample ID: **1607780-33A**
Collection Date: **7/15/2016 2:01:00 PM**
Received Date: **7/19/2016 9:31:00 AM**
Reported Date: **7/29/2016 10:49:10 AM**

Sample Information:

16-24 Jackson Lead Study

Client Sample ID: Bottle #19481
Collectors Name: Larry Anderson
Sample Location: Rm 211 DF
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.0280	*	0.000103	mg/L	0.020 AL	7/26/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: **1607780**
NRC Sample ID: **1607780-34A**
Collection Date: **7/15/2016 2:03:00 PM**
Received Date: **7/19/2016 9:31:00 AM**
Reported Date: **7/29/2016 10:49:10 AM**

Sample Information:

16-24 Jackson Lead Study

Client Sample ID: Bottle #17084
Collectors Name: Larry Anderson
Sample Location: Rm 212 DF
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Copper	EPA 200.8	A	1.64	*	0.00103	mg/L	1.3 AL	7/28/2016	OML
Lead	EPA 200.8	A	0.0678	*	0.000103	mg/L	0.020 AL	7/26/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: **1607780**
NRC Sample ID: **1607780-35A**
Collection Date: **7/15/2016 2:16:00 PM**
Received Date: **7/19/2016 9:31:00 AM**
Reported Date: **7/29/2016 10:49:10 AM**

Sample Information:

16-24 Jackson Lead Study

Client Sample ID: Bottle #19489
Collectors Name: Larry Anderson
Sample Location: Rm 210 DF (A)
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP		Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
		Accredited	Result						
Copper	EPA 200.8	A	1.84	*	0.00515	mg/L	1.3 AL	7/28/2016	OML
Lead	EPA 200.8	A	0.0715	*	0.000103	mg/L	0.020 AL	7/26/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: **1607780**
NRC Sample ID: **1607780-36A**
Collection Date: **7/15/2016 1:33:00 PM**
Received Date: **7/19/2016 9:31:00 AM**
Reported Date: **7/29/2016 10:49:10 AM**

Sample Information:

16-24 Jackson Lead Study

Client Sample ID: Bottle #17033
Collectors Name: Bill Bartlett
Sample Location: Caf DF (Upper)
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.00920		0.0001	mg/L	0.020 AL	7/25/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: **1607780**
NRC Sample ID: **1607780-37A**
Collection Date: **7/15/2016 1:33:00 PM**
Received Date: **7/19/2016 9:31:00 AM**
Reported Date: **7/29/2016 10:49:10 AM**

Sample Information:

16-24 Jackson Lead Study

Client Sample ID: Bottle #17016
Collectors Name: Bill Bartlett
Sample Location: Caf DF (Lower)
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.0191		0.0001	mg/L	0.020 AL	7/25/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: **1607780**
NRC Sample ID: **1607780-38A**
Collection Date: **7/15/2016 1:33:00 PM**
Received Date: **7/19/2016 9:31:00 AM**
Reported Date: **7/29/2016 10:49:10 AM**

Sample Information:

16-24 Jackson Lead Study

Client Sample ID: Bottle #11250
Collectors Name: Bill Bartlett
Sample Location: Caf DF Bottle Filler
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.0252	*	0.0001	mg/L	0.020 AL	7/25/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: **1607780**
NRC Sample ID: **1607780-39A**
Collection Date: **7/15/2016 1:37:00 PM**
Received Date: **7/19/2016 9:31:00 AM**
Reported Date: **7/29/2016 10:49:10 AM**

Sample Information:

16-24 Jackson Lead Study

Client Sample ID: Bottle #17031
Collectors Name: Bill Bartlett
Sample Location: Playground DF (Outside)
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.00193		0.000103	mg/L	0.020 AL	7/26/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: **1607780**
NRC Sample ID: **1607780-40A**
Collection Date: **7/15/2016 1:46:00 PM**
Received Date: **7/19/2016 9:31:00 AM**
Reported Date: **7/29/2016 10:49:10 AM**

Sample Information:

16-24 Jackson Lead Study

Client Sample ID: Bottle #17020
Collectors Name: Bill Bartlett
Sample Location: Rm 145 DF
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.00131		0.000103	mg/L	0.020 AL	7/26/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: **1607780**
NRC Sample ID: **1607780-41A**
Collection Date: **7/15/2016 1:47:00 PM**
Received Date: **7/19/2016 9:31:00 AM**
Reported Date: **7/29/2016 10:49:10 AM**

Sample Information:

16-24 Jackson Lead Study

Client Sample ID: Bottle #17017
Collectors Name: Bill Bartlett
Sample Location: Rm 144 DF
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.00147		0.000103	mg/L	0.020 AL	7/26/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: **1607780**
NRC Sample ID: **1607780-42A**
Collection Date: **7/15/2016 1:42:00 PM**
Received Date: **7/19/2016 9:31:00 AM**
Reported Date: **7/29/2016 10:49:10 AM**

Sample Information:

16-24 Jackson Lead Study

Client Sample ID: Bottle #17032
Collectors Name: Bill Bartlett
Sample Location: Gym DF (Upper)
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP		Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
		Accredited	Result						
Copper	EPA 200.8	A	2.61	*	0.00515	mg/L	1.3 AL	7/28/2016	OML
Lead	EPA 200.8	A	0.122	*	0.000103	mg/L	0.020 AL	7/26/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: **1607780**
NRC Sample ID: **1607780-43A**
Collection Date: **7/15/2016 1:42:00 PM**
Received Date: **7/19/2016 9:31:00 AM**
Reported Date: **7/29/2016 10:49:10 AM**

Sample Information:

16-24 Jackson Lead Study

Client Sample ID: Bottle #11271
Collectors Name: Bill Bartlett
Sample Location: Gym DF (Lower)
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Copper	EPA 200.8	A	1.54	*	0.00103	mg/L	1.3 AL	7/28/2016	OML
Lead	EPA 200.8	A	0.0609	*	0.000103	mg/L	0.020 AL	7/26/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: **1607780**
NRC Sample ID: **1607780-44A**
Collection Date: **7/15/2016 1:51:00 PM**
Received Date: **7/19/2016 9:31:00 AM**
Reported Date: **7/29/2016 10:49:10 AM**

Sample Information:

16-24 Jackson Lead Study

Client Sample ID: Bottle #17034
Collectors Name: Bill Bartlett
Sample Location: Health Rm Sink (L)
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.0454	*	0.000103	mg/L	0.020 AL	7/26/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: **1607780**
NRC Sample ID: **1607780-45A**
Collection Date: **7/15/2016 1:51:00 PM**
Received Date: **7/19/2016 9:31:00 AM**
Reported Date: **7/29/2016 10:49:10 AM**

Sample Information:

16-24 Jackson Lead Study

Client Sample ID: Bottle #11270
Collectors Name: Bill Bartlett
Sample Location: Health Rm Bottle Filler (R)
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.0262	*	0.000103	mg/L	0.020 AL	7/26/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: **1607780**
NRC Sample ID: **1607780-46A**
Collection Date: **7/15/2016 1:57:00 PM**
Received Date: **7/19/2016 9:31:00 AM**
Reported Date: **7/29/2016 10:49:10 AM**

Sample Information:

16-24 Jackson Lead Study

Client Sample ID: Bottle #17064
Collectors Name: Bill Bartlett
Sample Location: Staff Brk Rm 101D Sink
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.00611		0.000103	mg/L	0.020 AL	7/26/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: **1607780**
NRC Sample ID: **1607780-47A**
Collection Date: **7/15/2016 1:57:00 PM**
Received Date: **7/19/2016 9:31:00 AM**
Reported Date: **7/29/2016 10:49:10 AM**

Sample Information:

16-24 Jackson Lead Study

Client Sample ID: Bottle #11287
Collectors Name: Bill Bartlett
Sample Location: Staff Brk Rm 101D Insta-Hot
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	ND		0.000103	mg/L	0.020 AL	7/26/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: **1607780**
NRC Sample ID: **1607780-48A**
Collection Date: **7/15/2016 2:00:00 PM**
Received Date: **7/19/2016 9:31:00 AM**
Reported Date: **7/29/2016 10:49:10 AM**

Sample Information:

16-24 Jackson Lead Study

Client Sample ID: Bottle #11262
Collectors Name: Bill Bartlett
Sample Location: Near 2nd Flr Elev DF (Upper)
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.0718	*	0.000103	mg/L	0.020 AL	7/26/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: **1607780**
NRC Sample ID: **1607780-49A**
Collection Date: **7/15/2016 2:00:00 PM**
Received Date: **7/19/2016 9:31:00 AM**
Reported Date: **7/29/2016 10:49:10 AM**

Sample Information:

16-24 Jackson Lead Study

Client Sample ID: Bottle #11268
Collectors Name: Bill Bartlett
Sample Location: Near 2nd Flr Elev DF (Lower)
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.0267	*	0.000103	mg/L	0.020 AL	7/26/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation
DATA FLAGS

B	Analyte detected in the associated method blank.
BA	BOD Alternative Calculation: The initial results performed by Standard Methods did not fall within parameters of the Standard Methods calculation. An alternate approved calculation was performed using the HACH method and the value reported is an estimated concentration.
C	Sample(s) does not meet NELAP/ORELAP sample acceptance criteria. See Case Narrative.
C1	Sample(s) does not meet NELAP/ORELAP sample acceptance criteria for temperature.
CF	Results confirmed by re-analysis.
CU	Cleanup performed as specified by method.
D1	The diesel elution pattern for the sample is not typical.
D2	The sample appears to be a heavier hydrocarbon range than diesel.
D3	The sample appears to be a lighter hydrocarbon range than diesel.
D4	Detected hydrocarbons do not have pattern and range consistent with typical petroleum products and may be due to biogenic interference.
D5	Detected hydrocarbons in the diesel range appear to be weathered diesel.
E	Estimated value.
ER	Elevated reporting limit due to matrix. Report limits (MDLs, MRLs & PQLs) are adjusted based on variations in sample preparation amounts, analytical dilutions, and percent solids, where applicable.
FC	Fecal Coliforms: Sample(s) received past 40 CFR Part 136 specified holding time. Results reported as estimated values.
G1	The gasoline elution pattern for the sample is not typical.
G2	The sample appears to be a heavier hydrocarbon range than gasoline.
G3	The sample appears to be a lighter hydrocarbon range than gasoline.
G4	Detected hydrocarbons in the gasoline range appear to be weathered gasoline.
HP	Sample re-analysis performed outside of method specified holding time.
HR	Sample received outside of method specified holding time.
HS	Sample analyzed for volatile organics contained headspace.
HT	At the client's request, the sample was analyzed outside of method specified holding time.
H	Analysis performed outside of method specified holding time.
J	Analyte detected below the Minimum Reporting Limit (MRL) and above the Method Detection Limit (MDL). The J flag result is an estimated value and the user should be aware that this data is of limited reliability.
MI	Surrogate or Matrix Spike recovery is out of control limits due to matrix interference. Sample results may be biased.
N	See Case Narrative on page 2 of report.
Q	Closing continuing calibration verification (CCV) or laboratory control sample (LCS) exceeded high recovery limits, but associated samples are non-detect and the sample results are not affected. Data meets EPA/NELAP requirements.
R	Relative percent difference (RPD) is outside of the accepted recovery limits.
R1	Relative percent difference (RPD) is outside of the accepted recovery limits. However, analyses are not controlled on RPD values for sample concentrations that are less than the reporting limit.
R3	The relative percent difference (RPD) and/or percent recovery for the duplicate (DUP) or matrix spike (MS)/matrix spike duplicate (MSD) cannot be accurately calculated due to the concentration of analyte already present in the sample.
R4	Duplicate analysis failed due to result being at or near method reporting limit.
S	Surrogate and/or matrix spike recovery is outside of the accepted recovery limits. Sample results may be biased.
S1	Surrogate or matrix spike recovery is outside of control limits due to dilution necessary for analysis.
SC	Sub-contracted to another laboratory for analysis.
SP	Sample(s) were not collected per EPA Method 5035A protocols. The results are considered minimum values.
T	Toxicity Characteristic Leaching Procedure – Sample submitted contained < 0.5% solids. If the waste contains <0.5% dry solids, the liquid portion of the waste, after filtration, is defined as the TCLP extract.
#	Value exceeds regulatory level for TCLP contaminant.
X1	The motor oil elution pattern for the sample is not typical.
X2	The sample appears to be a heavier hydrocarbon range than motor oil.
X3	The sample appears to be a lighter hydrocarbon range than motor oil.
*	Value exceeds Maximum Contaminant Level or is outside the acceptable range.

NRC SOP QA-1104/AD-3100
Revision 3
Effective Date: 6/3/16

CLIENT: Medford School District
Work Order: 1607780
Project: 16-24 Jackson Lead Study

ANALYTICAL QC SUMMARY REPORT

TestCode: ICPMS_200.8_SCHOOL

Sample ID MB-35935	SampType: MBLK	TestCode: ICPMS_200.8	Units: mg/L	Prep Date: 7/25/2016	RunNo: 88716						
Client ID: ZZZZZ	Batch ID: 35935	TestNo: EPA 200.8	(EPA 200.8)	Analysis Date: 7/25/2016	SeqNo: 1331621						
Analyte	Result	MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead ND 0.000100

Sample ID MB-35932	SampType: MBLK	TestCode: ICPMS_200.8	Units: mg/L	Prep Date: 7/25/2016	RunNo: 88716						
Client ID: ZZZZZ	Batch ID: 35932	TestNo: EPA 200.8	(EPA 200.8)	Analysis Date: 7/25/2016	SeqNo: 1331639						
Analyte	Result	MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Copper ND 0.000515
 Lead ND 0.000103

Sample ID MB-35933	SampType: MBLK	TestCode: ICPMS_200.8	Units: mg/L	Prep Date: 7/25/2016	RunNo: 88740						
Client ID: ZZZZZ	Batch ID: 35933	TestNo: EPA 200.8	(EPA 200.8)	Analysis Date: 7/26/2016	SeqNo: 1332251						
Analyte	Result	MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Copper ND 0.000515
 Lead ND 0.000103

Sample ID MB-35934	SampType: MBLK	TestCode: ICPMS_200.8	Units: mg/L	Prep Date: 7/25/2016	RunNo: 88740						
Client ID: ZZZZZ	Batch ID: 35934	TestNo: EPA 200.8	(EPA 200.8)	Analysis Date: 7/26/2016	SeqNo: 1332279						
Analyte	Result	MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Copper ND 0.000515
 Lead ND 0.000103

Sample ID LCS-35935	SampType: LCS	TestCode: ICPMS_200.8	Units: mg/L	Prep Date: 7/25/2016	RunNo: 88716						
Client ID: ZZZZZ	Batch ID: 35935	TestNo: EPA 200.8	(EPA 200.8)	Analysis Date: 7/25/2016	SeqNo: 1331622						
Analyte	Result	MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead 0.09171 0.000100 0.1 0 91.7 85 115

Qualifiers: E Value above quantitation range H Holding times for preparation or analysis exceeded J Analyte detected below quantitation limits
 ND Not Detected at the Minimum Reporting Limit R RPD outside accepted recovery limits S Spike Recovery outside accepted recovery limits

CLIENT: Medford School District
Work Order: 1607780
Project: 16-24 Jackson Lead Study

ANALYTICAL QC SUMMARY REPORT

TestCode: ICPMS_200.8_SCHOOL

Sample ID	LCS-35932	SampType: LCS	TestCode: ICPMS_200.8	Units: mg/L	Prep Date: 7/25/2016	RunNo: 88716					
Client ID:	ZZZZZ	Batch ID: 35932	TestNo: EPA 200.8	(EPA 200.8)	Analysis Date: 7/25/2016	SeqNo: 1331640					
Analyte	Result	MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Copper	0.1002	0.000520	0.1	0.00005526	100	85	115				
Lead	0.09188	0.000104	0.1	0	91.9	85	115				

Sample ID	LCS-35933	SampType: LCS	TestCode: ICPMS_200.8	Units: mg/L	Prep Date: 7/25/2016	RunNo: 88740					
Client ID:	ZZZZZ	Batch ID: 35933	TestNo: EPA 200.8	(EPA 200.8)	Analysis Date: 7/26/2016	SeqNo: 1332252					
Analyte	Result	MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Copper	0.09195	0.000520	0.1	0.0000558	91.9	85	115				
Lead	0.09879	0.000104	0.1	0	98.8	85	115				

Sample ID	LCS-35934	SampType: LCS	TestCode: ICPMS_200.8	Units: mg/L	Prep Date: 7/25/2016	RunNo: 88740					
Client ID:	ZZZZZ	Batch ID: 35934	TestNo: EPA 200.8	(EPA 200.8)	Analysis Date: 7/26/2016	SeqNo: 1332280					
Analyte	Result	MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Copper	0.09108	0.000520	0.1	0.00004751	91.0	85	115				
Lead	0.09662	0.000104	0.1	0	96.6	85	115				

Sample ID	1607780-38AMS	SampType: MS	TestCode: ICPMS_200.8	Units: mg/L	Prep Date: 7/25/2016	RunNo: 88716					
Client ID:	Bottle #11250	Batch ID: 35935	TestNo: EPA 200.8	(EPA 200.8)	Analysis Date: 7/25/2016	SeqNo: 1331633					
Analyte	Result	MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	0.1162	0.000100	0.1	0.02521	91.0	70	130				
------	--------	----------	-----	---------	------	----	-----	--	--	--	--

Sample ID	1607780-11AMS	SampType: MS	TestCode: ICPMS_200.8	Units: mg/L	Prep Date: 7/25/2016	RunNo: 88716					
Client ID:	Bottle #17055	Batch ID: 35932	TestNo: EPA 200.8	(EPA 200.8)	Analysis Date: 7/25/2016	SeqNo: 1331654					
Analyte	Result	MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	0.1403	0.000104	0.1	0.04997	90.3	70	130				
------	--------	----------	-----	---------	------	----	-----	--	--	--	--

Qualifiers: E Value above quantitation range H Holding times for preparation or analysis exceeded J Analyte detected below quantitation limits
 ND Not Detected at the Minimum Reporting Limit R RPD outside accepted recovery limits S Spike Recovery outside accepted recovery limits

CLIENT: Medford School District
Work Order: 1607780
Project: 16-24 Jackson Lead Study

ANALYTICAL QC SUMMARY REPORT

TestCode: ICPMS_200.8_SCHOOL

Sample ID	1607780-11AMS	SampType: MS	TestCode: ICPMS_200.8	Units: mg/L	Prep Date: 7/25/2016	RunNo: 88740					
Client ID:	Bottle #17055	Batch ID: 35932	TestNo: EPA 200.8	(EPA 200.8)	Analysis Date: 7/26/2016	SeqNo: 1332245					
Analyte	Result	MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Copper 1.138 0.00104 0.1 1.042 96.0 70 130

Sample ID	1607780-31AMS	SampType: MS	TestCode: ICPMS_200.8	Units: mg/L	Prep Date: 7/25/2016	RunNo: 88740					
Client ID:	Bottle #19462	Batch ID: 35933	TestNo: EPA 200.8	(EPA 200.8)	Analysis Date: 7/26/2016	SeqNo: 1332275					
Analyte	Result	MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead 0.1913 0.000104 0.1 0.08615 105 70 130

Sample ID	1607780-49AMS	SampType: MS	TestCode: ICPMS_200.8	Units: mg/L	Prep Date: 7/25/2016	RunNo: 88740					
Client ID:	Bottle #11268	Batch ID: 35934	TestNo: EPA 200.8	(EPA 200.8)	Analysis Date: 7/26/2016	SeqNo: 1332298					
Analyte	Result	MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Copper 0.8669 0.000520 0.1 0.7834 83.5 70 130

Lead 0.1227 0.000104 0.1 0.02675 96.0 70 130

Sample ID	1607780-31AMS	SampType: MS	TestCode: ICPMS_200.8	Units: mg/L	Prep Date: 7/25/2016	RunNo: 88754					
Client ID:	Bottle #19462	Batch ID: 35933	TestNo: EPA 200.8	(EPA 200.8)	Analysis Date: 7/28/2016	SeqNo: 1332994					
Analyte	Result	MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Copper 1.559 0.00104 0.1 1.458 101 70 130

Sample ID	1607780-38AMSD	SampType: MSD	TestCode: ICPMS_200.8	Units: mg/L	Prep Date: 7/25/2016	RunNo: 88716					
Client ID:	Bottle #11250	Batch ID: 35935	TestNo: EPA 200.8	(EPA 200.8)	Analysis Date: 7/25/2016	SeqNo: 1331634					
Analyte	Result	MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead 0.1198 0.000100 0.1 0.02521 94.6 70 130 0.1162 3.05 20

Qualifiers: E Value above quantitation range H Holding times for preparation or analysis exceeded J Analyte detected below quantitation limits
 ND Not Detected at the Minimum Reporting Limit R RPD outside accepted recovery limits S Spike Recovery outside accepted recovery limits

CLIENT: Medford School District
Work Order: 1607780
Project: 16-24 Jackson Lead Study

ANALYTICAL QC SUMMARY REPORT

TestCode: ICPMS_200.8_SCHOOL

Sample ID	1607780-11AMSD	SampType: MSD	TestCode: ICPMS_200.8	Units: mg/L	Prep Date: 7/25/2016	RunNo: 88716					
Client ID:	Bottle #17055	Batch ID: 35932	TestNo: EPA 200.8	(EPA 200.8)	Analysis Date: 7/25/2016	SeqNo: 1331655					
Analyte	Result	MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	0.1405	0.000104	0.1	0.04997	90.5	70	130	0.1403	0.148	20
------	--------	----------	-----	---------	------	----	-----	--------	-------	----

Sample ID	1607780-11AMSD	SampType: MSD	TestCode: ICPMS_200.8	Units: mg/L	Prep Date: 7/25/2016	RunNo: 88740					
Client ID:	Bottle #17055	Batch ID: 35932	TestNo: EPA 200.8	(EPA 200.8)	Analysis Date: 7/26/2016	SeqNo: 1332246					
Analyte	Result	MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Copper	1.158	0.00104	0.1	1.042	116	70	130	1.138	1.76	20
--------	-------	---------	-----	-------	-----	----	-----	-------	------	----

Sample ID	1607780-31AMSD	SampType: MSD	TestCode: ICPMS_200.8	Units: mg/L	Prep Date: 7/25/2016	RunNo: 88740					
Client ID:	Bottle #19462	Batch ID: 35933	TestNo: EPA 200.8	(EPA 200.8)	Analysis Date: 7/26/2016	SeqNo: 1332276					
Analyte	Result	MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	0.1906	0.000104	0.1	0.08615	104	70	130	0.1913	0.327	20
------	--------	----------	-----	---------	-----	----	-----	--------	-------	----

Sample ID	1607780-49AMSD	SampType: MSD	TestCode: ICPMS_200.8	Units: mg/L	Prep Date: 7/25/2016	RunNo: 88740					
Client ID:	Bottle #11268	Batch ID: 35934	TestNo: EPA 200.8	(EPA 200.8)	Analysis Date: 7/26/2016	SeqNo: 1332299					
Analyte	Result	MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Copper	0.8654	0.000520	0.1	0.7834	82.0	70	130	0.8669	0.180	20
Lead	0.1226	0.000104	0.1	0.02675	95.9	70	130	0.1227	0.0848	20

Sample ID	1607780-31AMSD	SampType: MSD	TestCode: ICPMS_200.8	Units: mg/L	Prep Date: 7/25/2016	RunNo: 88754					
Client ID:	Bottle #19462	Batch ID: 35933	TestNo: EPA 200.8	(EPA 200.8)	Analysis Date: 7/28/2016	SeqNo: 1332995					
Analyte	Result	MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Copper	1.574	0.00104	0.1	1.458	117	70	130	1.559	0.996	20
--------	-------	---------	-----	-------	-----	----	-----	-------	-------	----

Qualifiers: E Value above quantitation range H Holding times for preparation or analysis exceeded J Analyte detected below quantitation limits
 ND Not Detected at the Minimum Reporting Limit R RPD outside accepted recovery limits S Spike Recovery outside accepted recovery limits



Environmental Testing Laboratory
 245 South Grape Street • Medford, OR 97501
 (541) 770-5678 fax (541) 770-2901

Chain of Custody Record

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Section A Required Client Information

Company: Medford School District 549C
 Address: 815 S. Oakdale,
 Medford, Or, 97501
 Email: rick.rose@medford.k12.or.us
 Phone: 541.842.1138 Fax: 541.842.1160
 Collected By (Print): *Roger Rose*
 Collected By (Sig): *[Signature]*
 Email Report Yes No
 Fax Report Yes No

Section B Required Project Information

Project Name: 2016 Lead testing
 Project Number: 16-24 / Jackson
 Report To: rick.rose@medford.k12.or.us
 Copy To: ron.havnear@medford.k12.or.us
 P.O. # P112894

Section C Invoice Information

Attention: Accounting
 Company Name: Medford School
 Address: 815 S. Oakdale
 Medford, Or, 97501

Section D Rush Status (Subject to Scheduling)

Standard 10-14 Days
 5 Business Days (50% surcharge)
 3 Business Days (75% surcharge)
 24 - 48 hours (100% surcharge)
 Other _____
 Authorized Yes No

Section E Sample Information

Sample ID	Complete	Matrix	Date Collected	Time Collected	No. of Containers	Analysis Requested	NRC Workorder # (Lab Use Only)	NRC Sample # (Lab Use Only)
Rm 111 DF			7/15/16	11:53	1		K07786	01
Rm 112 DF				1:34	1			03
Rm 113 DF				1:56	1			05
Near 1st Floor Elev. DF (Upper)				2:02	1			07
Alex 1st Floor Elev. DF (Lower)				2:02	1			05
Rm 141 DF				2:05	1			06
Rm 142 DF				2:06	1			07
Rm 143 DF				2:07	1			08

Section F Relinquish/Receive

Relinquished By:	Sign	Print	Date	Time
Received By:	<i>[Signature]</i>	Roger Rose	7-19-16	6:25 PM
Relinquished By:	<i>[Signature]</i>	Jon Jensen	7/19/16	9:34 AM
Received By:	<i>[Signature]</i>	Jon Jensen	7/19/16	9:34 AM
Relinquished By:	<i>[Signature]</i>	Jon Jensen	7-19-16	9:37

Section G Lab Use Only

Temp: *21.0*
 4°C +/- 2°C: Yes No
 Received on Ice: Yes No
 Number of Bottles Received: *3*
 pH Checked: *NA*
 COC Seals Intact: Yes No NA
 Field Blank Included: Yes No
 Received Via: Invoice Cash VISA, MC Check # Amount
 UPS FedEx Other Hand



Environmental Testing Laboratory
 245 South Grape Street • Medford, OR 97501
 (541) 770-5678 Fax (541) 770-2901

Chain of Custody Record

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Section A
Required Client Information
 Company: Medford School District 549C
 Address: 815 S. Oakdale,
 Medford, Or, 97501
 Email: rick.rose@medford.k12.or.us
 Phone: 541.842.1138 Fax 541.842.1160
 Collected By (Print): Ron Havnicar
 Collected By (Sign): [Signature]
 Email Report Yes No
 Fax Report Yes No

Section B
Required Project Information
 Project Name: 2016 Lead testing
 Project Number: 16-24 / Jackson
 Report To: rick.rose@medford.k12.or.us
 Copy To: ron.havnicar@medford.k12.or.us

Section C
Invoice Information
 Attention: Accounting
 Company Name: Medford School
 Address: 815 S. Oakdale
 Medford, Or, 97501
 P.O. # P112894

Section D
Rush Status (Subject to Scheduling)
 Standard 10-14 Days
 5 Business Days (50% surcharge)
 3 Business Days (75% surcharge)
 24 - 48 hours (100% surcharge)
 Other _____
 Authorized Yes No

Section E
Sample Information

Sample ID	Comp/Grab	Matrix	Date Collected	Time Collected	No. of Containers	Analysis Requested	NRC Workorder # (Lab Use Only)	NRC Sample # (Lab Use Only)
Rm 120 DF (A)			7/15/16	1:54			160776D	09
Rm 120 DF (B)				1:35				10
Rm 120 DF (C)				1:37				12
Rm 121 DF				1:41				13
Rm 122 DF				1:44				14
Rm 123 DF				1:48				15
Boiler Slide Door Front of Rm 110-DF				1:49				16
Boiler Slide Door Front of Rm 110-SINK				1:49				17
Rm 110 DF (A)				1:50				18
Rm 110 DF (B)				1:51				19

*Matrix: DW - Drinking Water WW - Wastewater W1 Water S - Soil/Solid SL - Sludge O - Oil WP - Wipe OT - Other

Section F
Relinquish/Receive

Relinquish/Receive	Sign	Date	Time
Relinquished By: <u>[Signature]</u>	<u>[Signature]</u>	7-19-16	6:25 AM
Received By: <u>[Signature]</u>	<u>[Signature]</u>	7/19/16	6:25 AM
Relinquished By:			
Received By:			
Relinquished By:			
Received By:			
Relinquished By:			
Received By Laboratory: <u>[Signature]</u>	<u>[Signature]</u>	7/19/16	01:31

Section G
Lab Use Only

Temp: Water
 4°C +/ 2°C: Yes No
 Received on Ice: Yes No
 Number of Bottles Received: 10
 pH Checked: MP
 COC Seals Intact: Yes No
 Field Blank Included: Yes No

Received Via UPS FedEx Other Hand
 Payment: Invoice Cash VISA, MC Check # Amount



Environmental Testing Laboratory
 245 South Grape Street • Medford, OR 97501
 (541) 770-5678 Fax (541) 770-2901

Chain of Custody Record

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Section A Required Client Information

Company: Medford School District 549C
 Address: 815 S. Oakdale,
 Medford, Or, 97501
 Email: rick.rose@medford.k12.or.us
 Phone: 541.842.1138 Fax 541.842.1160
 Collected By (Print): Lacey Anderson
 Collected By (Sign): [Signature]
 Email Report Yes No Mail Report Yes No
 Fax Report Yes No

Section B Required Project Information

Project Name: 2016 Lead testing
 Project Number: 16-24 / Jackson
 Report To: rick.rose@medford.k12.or.us
 Copy To: ron.havlicar@medford.k12.or.us

Section C Invoice Information

Attention: Accounting
 Company Name: Medford School
 Address: 815 S. Oakdale
 Medford, Or, 97501
 P.O. # P112894

Section D Rush Status (Subject to Scheduling)

Standard 10-14 Days
 5 Business Days (50% surcharge)
 3 Business Days (75% surcharge)
 24 - 48 hours (100% surcharge)
 Other _____
 Authorized Yes No

Section E Sample Information

Sample ID	Compl/Grabs	Matrix*	Date Collected	Time Collected	No. of Containers	Analysis Requested	NRC Workorder # <small>(Lab Use Only)</small>	NRC Sample # <small>(Lab Use Only)</small>
Rm 210 DF (B)	11277		7/15/16	2:19 PM			1607760	19
Rm 210 DF (C)	19479			2:19				20
Rm 213 DF	19485			2:08				21
Rm 214 DF	19471			2:11				22
Rm 211 DF	17022			2:25				23
Rm 242 DF	19465			2:25				24
Rm 243 DF	17074			2:26				25

Section F Relinquish/Receive

Relinquished By	Sign	Date	Time
Relinquished By: <u>[Signature]</u>	Sign: <u>Lacey Anderson</u>	7-15-16	6:30 am
Relinquished By: <u>[Signature]</u>	Sign: <u>Van Vescen</u>	7/19/16	9:30 am
Relinquished By: <u>[Signature]</u>	Sign: <u>Van Vescen</u>	7/19/16	9:30 am
Relinquished By: <u>[Signature]</u>	Sign: <u>Van Vescen</u>	7/19/16	9:31

Section G Lab Use Only

Temp:
 4°C +/- 2°C: Yes No
 Received on Ice: Yes No
 Number of Bottles Received: 7
 pH Checked: NA
 COC Seals Intact: Yes No NA
 Field Blank Included: Yes No
 Received Via: UPS FedEx Other Hand
 Payment: Invoice Cash VISA, M/C Check # Amount



Environmental Testing Laboratory
 245 South Grape Street • Medford, OR 97501
 (541) 770-5678 Fax (541) 770-2901

Stetson

Chain of Custody Record

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Section A Required Client Information		Section B Required Project Information		Section C Invoice Information		Section D Rush Status (Subject to Scheduling)	
Company: Medford School District 549C		Project Name: 2016 Lead testing		Attention: Accounting		Standard 10-14 Days	
Address: 815 S. Oakdale		Project Number: 16-24 / Jackson		Company Name: Medford School		5 Business Days (50% surcharge)	
Medford, Or, 97501		Report To: rick.rose@medford.k12.or.us		Address: 815 S. Oakdale		3 Business Days (75% surcharge)	
Email: rick.rose@medford.k12.or.us		Copy To: ron.havntear@medford.k12.or.us		P.O. # P112894		24 - 48 hours (100% surcharge)	
Phone: 541.842.1138 Fax: 541.842.1160		Collected By (Print): <i>[Signature]</i>		P.O. # P112894		Other	
Collected By (Sign): <i>[Signature]</i>		Email Report <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		Fax Report <input type="checkbox"/> Yes <input type="checkbox"/> No		Authorized <input type="checkbox"/> Yes <input type="checkbox"/> No	

Section E Sample Information			No. of Containers		Analysis Requested		NRC Workorder # (Lab Use Only)		NRC Sample # (Lab Use Only)	
Sample ID	Temp/Grab	Matrix	Date Collected	Time Collected						
Rm 220 DF (A)	19478		7/19/16	1:24 PM						
Rm 220 DF (B)	19468			1:35						
Rm 220 DF (C)	19476			1:37						
Rm 221 DF	19484			1:50						
Rm 222 DF	19488			1:51						
Rm 223 DF	19462			1:54						
Rm 224 DF	17024			1:58						
Rm 211 DF	19481			2:01						
Rm 212 DF	17054			2:03						
Rm 210 DF (A)	19489			2:16						

Section F Relinquish/Receive		Section G Lab Use Only	
Relinquished By: <i>[Signature]</i>	Sign: <i>[Signature]</i>	Temp: <i>4.0</i>	Temp: <i>4.0</i>
Received By: <i>[Signature]</i>	Print: Larry Anderson	Received on ice: <i>Yes</i>	Received on ice: <i>Yes</i>
Relinquished By: <i>[Signature]</i>	Date: 7-19-16	Number of Bottles Received: <i>4</i>	Number of Bottles Received: <i>4</i>
Received By: <i>[Signature]</i>	Time: 6:30 AM	pH Checked: <i>NA</i>	pH Checked: <i>NA</i>
Relinquished By: <i>[Signature]</i>	Date: 7/19/16	COC Seals Intact: <i>Yes</i>	COC Seals Intact: <i>Yes</i>
Received By: <i>[Signature]</i>	Time: 9:39 AM	Field Blank Included: <i>Yes</i>	Field Blank Included: <i>Yes</i>
Relinquished By: <i>[Signature]</i>	Date: 7/19/16	Received Via: <i>Hand</i>	Received Via: <i>Hand</i>
Received By: <i>[Signature]</i>	Time: 9:31	Payment: <input checked="" type="checkbox"/> Invoice <input type="checkbox"/> Cash	Payment: <input type="checkbox"/> Invoice <input type="checkbox"/> Cash



Environmental Testing Laboratory
 245 South Grape Street • Medford, OR 97501
 (541) 770-5678 fax (541) 770-2901

Jackson

Chain of Custody Record

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Section A		Section B		Section C		Section D	
Required Client Information		Required Project Information		Invoice Information		Rush Status (Subject to Scheduling)	
Company: Medford School District 549C		Project Name: 2016 Lead testing		Attention: Accounting		Standard 10-14 Days	
Address: 815 S. Oakdale		Project Number: 16-24 / Jackson		Company Name: Medford School		5 Business Days (50% surcharge)	
Medford, Or, 97501		Report To: rick.rose@medford.k12.or.us		Address: 815 S. Oakdale		3 Business Days (75% surcharge)	
Email: rick.rose@medford.k12.or.us		Copy To: ron.havntear@medford.k12.or.us		Medford, Or, 97501		24 - 48 hours (100% surcharge)	
Phone: 541.842.1138 Fax: 541.842.1160		P.O. # P112894		P.O. # P112894		Other	
Collected By (Print): Bill Batten		Analysis Requested		Authorized		Yes <input type="checkbox"/> No <input type="checkbox"/>	
Collected By (Sign): <i>Bill Batten</i>							
Email Report <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No							
Fax Report <input type="checkbox"/> Yes <input type="checkbox"/> No							

Section E		Sample Information		Date		Time		No. of Containers		Analysis Requested		NRC Workorder #		NRC Sample #	
Sample ID	Completer	Matrix	Collected	Collected											
Caf. DF (Upper)	17033		7/15/16	1:33 PM									KA0780		
Caf. DF (Lower)	17016			1:33 PM											
Caf. DF (Bottle Filter)	11250			1:33 PM											
Playground DF (Outside)	17031			1:37 PM											
RM 145 DF	17030			1:46 PM											
RM 144 DF	17017			1:47 PM											
Gym DF (Upper)	17032			1:42 PM											
Gym DF (Lower)	11271			1:42 PM											
Head Rm Sink (L)	17034			1:51 PM											
Head Rm Bottle Filter (R)	11276			1:51 PM											

Section F		Section G	
Relinquish/Receive		Lab Use Only	
Relinquished By: <i>Bill Batten</i>	Sign	Temp: <i>4/20/16</i>	Temp: <i>4/20/16</i>
Received By: <i>John Jensen</i>	Print	Received on Ice: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	Received on Ice: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
Relinquished By: <i>John Jensen</i>	Date	Number of Bottles Received: 10	Number of Bottles Received: 10
Received By: <i>John Jensen</i>	Time	pH Checked: <i>NA</i>	pH Checked: <i>NA</i>
Relinquished By: <i>John Jensen</i>		COC Seals Intact: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	COC Seals Intact: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
Received By: <i>John Jensen</i>		Field Blank Included: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	Field Blank Included: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
Relinquished By: <i>John Jensen</i>		Received Via: <input checked="" type="checkbox"/> UPS <input type="checkbox"/> FedEx <input type="checkbox"/> Other <input type="checkbox"/> Hand	Received Via: <input checked="" type="checkbox"/> UPS <input type="checkbox"/> FedEx <input type="checkbox"/> Other <input type="checkbox"/> Hand
Received By Laboratory: <i>John Jensen</i>		Payment: <input checked="" type="checkbox"/> Invoice <input type="checkbox"/> Cash <input type="checkbox"/> VISA, M/C <input type="checkbox"/> Check # <input type="checkbox"/> Amount	Payment: <input checked="" type="checkbox"/> Invoice <input type="checkbox"/> Cash <input type="checkbox"/> VISA, M/C <input type="checkbox"/> Check # <input type="checkbox"/> Amount



Environmental Testing Laboratory
 245 South Grape Street • Medford, OR 97501
 (541) 770-5678 fax (541) 770-2901

Jackson

Chain of Custody Record

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Page 1 of 1

Section A
 Required Client Information
 Company: Medford School District 549C
 Address: 815 S. Oakdale,
 Medford, Or, 97501
 Email: rick.rose@medford.k12.or.us
 Phone: 541.842.1138 Fax 541.842.1160
 Collected By (Print): Bill Bartlett
 Email Report Yes No Mail Report Yes No
 Fax Report Yes No

Section B
 Required Project Information
 Project Name: 2016 Lead testing
 Project Number: 16-24 / Jackson
 Report To: rick.rose@medford.k12.or.us
 Copy To: ron.havnicar@medford.k12.or.us
 P.O. # P112894

Section C
 Invoice Information
 Attention: Accounting
 Company Name: Medford School
 Address: 815 S. Oakdale
 Medford, Or, 97501

Section D
 Rush Status (Subject to Scheduling)
 Standard 10-14 Days
 5 Business Days (50% surcharge)
 3 Business Days (75% surcharge)
 24 - 48 hours (100% surcharge)
 Other _____
 Authorized Yes No

Section E
 Sample Information

Sample ID	Matrix*	Date Collected	Time Collected	No. of Containers	Analysis Requested	NRC Workorder # (Lab Use Only)	NRC Sample # (Lab Use Only)
STAFF BK Rm 101D SINK		7/19/16	11:57 PM	1		102780	49
STAFF BK Rm 101D INSPECTOR			11:57 PM	1			49
Near 2nd Floor Elev. DF (Up)			2:00 PM	1			48
Near 2nd Floor Elev. DF (Down)			2:00 PM	1			48

Bill Bartlett

Section F
 Matrix: DW - Drinking Water WW - Wastewater W - Water S - Soil/Solid SL - Sludge O - Oil WP - Wipe OT - Other

Section G
 Lab Use Only
 Temp: Ambient
 4°C +/- 2°C: Yes No
 Received on Ice: Yes No
 Number of Bottles Received: 4
 pH Checked: WT
 COC Seals Intact: Yes No NA
 Field Blank Included: Yes No

Relinquish/Receive	Sign	Print	Date	Time
Relinquished By: <u>Bill Bartlett</u>	<i>[Signature]</i>	Bill Bartlett	7-19-16	6:22am
Received By: <u>John Sassen</u>	<i>[Signature]</i>	John Sassen	7/19/16	6:22am
Relinquished By: <u>John Sassen</u>	<i>[Signature]</i>	John Sassen	7/19/16	9:27am
Received By: <u>Tom Sawyer</u>	<i>[Signature]</i>	Tom Sawyer	7-19-16	9:31

Section H
 Payment: Invoice Cash VISA, MC Check # _____
 Received Via: UPS FedEx Other Hand
 Amount: _____