

Site Radon Inspection Report

Date : 05/23/2023

Mr. Seth Barry
MEDFORD SCHOOL DISTRICT
900 Kenyon Street
Medford, OR 97501-

Client: Jackson E.S.
Test Location: 713 Summit Avenue
Medford, OR 97501-

Individual Canister Results

Canister ID# : 2916589 Test Start : 05/15/2023 @ 06:23
Canister Type : Charcoal Canister 3 inch Test Stop : 05/17/2023 @ 06:44
Location : 1st FL = Main Office Received: 05/23/2023 @ 09:47
Radon Level : 0.6 pCi/L Analyzed: 05/24/2023 @ 10:35
Error for Measurement is: \pm 0.6 pCi/L

Canister ID# : 2916573 Test Start : 05/15/2023 @ 06:25
Canister Type : Charcoal Canister 3 inch Test Stop : 05/17/2023 @ 06:26
Location : 1st FL = Gym 1 Received: 05/23/2023 @ 09:48
Radon Level : 0.4 pCi/L Analyzed: 05/24/2023 @ 09:25
Error for Measurement is: \pm 0.7 pCi/L

Canister ID# : 2916028 Test Start : 05/15/2023 @ 06:25
Canister Type : Charcoal Canister 3 inch Test Stop : 05/17/2023 @ 06:44
Location : 1st FL = Principals Office Received: 05/23/2023 @ 09:47
Radon Level : 0.8 pCi/L Analyzed: 05/24/2023 @ 10:13
Error for Measurement is: \pm 0.6 pCi/L

Canister ID# : 2916080 Test Start : 05/15/2023 @ 06:26
Canister Type : Charcoal Canister 3 inch Test Stop : 05/17/2023 @ 06:45
Location : 1st FL = Health Rm Received: 05/23/2023 @ 09:47
Radon Level : 0.1 pCi/L Analyzed: 05/24/2023 @ 09:12
Error for Measurement is: \pm 0.5 pCi/L

Canister ID# : 2916093 Test Start : 05/15/2023 @ 06:27
Canister Type : Charcoal Canister 3 inch Test Stop : 05/17/2023 @ 06:28
Location : 1st FL = Gym 2 Received: 05/23/2023 @ 09:48
Radon Level : 0.7 pCi/L Analyzed: 05/24/2023 @ 09:26
Error for Measurement is: \pm 0.8 pCi/L

Canister ID# : 2913718 Test Start : 05/15/2023 @ 06:27
Canister Type : Charcoal Canister 3 inch Test Stop : 05/17/2023 @ 06:45
Location : 1st FL = Rm 143 Received: 05/23/2023 @ 09:47
Radon Level : 0.2 pCi/L Analyzed: 05/24/2023 @ 10:45
Error for Measurement is: \pm 0.5 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 05/23/2023

Mr. Seth Barry
MEDFORD SCHOOL DISTRICT
900 Kenyon Street
Medford, OR 97501-

Client: Jackson E.S.
Test Location: 713 Summit Avenue
Medford, OR 97501-

Individual Canister Results

Canister ID# : 2916560 Test Start : 05/15/2023 @ 06:28
Canister Type : Charcoal Canister 3 inch Test Stop : 05/17/2023 @ 06:45
Location : 1st FL = Break Rm Received: 05/23/2023 @ 09:47
Radon Level : 0.5 pCi/L Analyzed: 05/24/2023 @ 09:43
Error for Measurement is: ± 0.6 pCi/L

Canister ID# : 2916541 Test Start : 05/15/2023 @ 06:28
Canister Type : Charcoal Canister 3 inch Test Stop : 05/17/2023 @ 06:47
Location : 1st FL = Rm 142 Received: 05/23/2023 @ 09:47
Radon Level : 0.3 pCi/L Analyzed: 05/24/2023 @ 10:35
Error for Measurement is: ± 0.6 pCi/L

Canister ID# : 2916078 Test Start : 05/15/2023 @ 06:29
Canister Type : Charcoal Canister 3 inch Test Stop : 05/17/2023 @ 06:30
Location : 1st FL = Gym DP ? Received: 05/23/2023 @ 09:48
Radon Level : 0.1 pCi/L Analyzed: 05/24/2023 @ 09:56
Error for Measurement is: ± 0.2 pCi/L

Canister ID# : 2916533 Test Start : 05/15/2023 @ 06:30
Canister Type : Charcoal Canister 3 inch Test Stop : 05/17/2023 @ 06:49
Location : 1st FL = Rm 141 Received: 05/23/2023 @ 09:47
Radon Level : 0.4 pCi/L Analyzed: 05/24/2023 @ 10:36
Error for Measurement is: ± 0.6 pCi/L

Canister ID# : 2916643 Test Start : 05/15/2023 @ 06:31
Canister Type : Charcoal Canister 3 inch Test Stop : 05/17/2023 @ 06:32
Location : 1st FL = Gym BLANK Received: 05/23/2023 @ 09:48
Radon Level : 0.6 pCi/L Analyzed: 05/24/2023 @ 09:03
Error for Measurement is: ± 0.6 pCi/L

Canister ID# : 2916088 Test Start : 05/15/2023 @ 06:31
Canister Type : Charcoal Canister 3 inch Test Stop : 05/17/2023 @ 06:46
Location : 1st FL = Commons 1 Received: 05/23/2023 @ 09:47
Radon Level : 0.1 pCi/L Analyzed: 05/24/2023 @ 09:26
Error for Measurement is: ± 0.5 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 05/23/2023

Mr. Seth Barry
MEDFORD SCHOOL DISTRICT
900 Kenyon Street
Medford, OR 97501-

Client: Jackson E.S.
Test Location: 713 Summit Avenue
Medford, OR 97501-

Individual Canister Results

Canister ID# : 2916003 Test Start : 05/15/2023 @ 06:32
Canister Type : Charcoal Canister 3 inch Test Stop : 05/17/2023 @ 06:46
Location : 1st FL = Commons 2 Received: 05/23/2023 @ 09:47
Radon Level : 0.2 pCi/L Analyzed: 05/24/2023 @ 10:18
Error for Measurement is: ± 0.7 pCi/L

Canister ID# : 2896372 Test Start : 05/15/2023 @ 06:32
Canister Type : Charcoal Canister 3 inch Test Stop : 05/17/2023 @ 06:50
Location : 1st FL = Rm 105 Received: 05/23/2023 @ 09:47
Radon Level : 0.6 pCi/L Analyzed: 05/24/2023 @ 09:12
Error for Measurement is: ± 0.6 pCi/L

Canister ID# : 2916085 Test Start : 05/15/2023 @ 06:33
Canister Type : Charcoal Canister 3 inch Test Stop : 05/17/2023 @ 06:34
Location : 1st FL = HC A Received: 05/23/2023 @ 09:48
Radon Level : 0.7 pCi/L Analyzed: 05/24/2023 @ 09:25
Error for Measurement is: ± 0.6 pCi/L

Canister ID# : 2916011 Test Start : 05/15/2023 @ 06:33
Canister Type : Charcoal Canister 3 inch Test Stop : 05/17/2023 @ 06:52
Location : 1st FL = Rm 113 Received: 05/23/2023 @ 09:47
Radon Level : 0.4 pCi/L Analyzed: 05/24/2023 @ 09:25
Error for Measurement is: ± 0.7 pCi/L

Canister ID# : 2901012 Test Start : 05/15/2023 @ 06:33
Canister Type : Charcoal Canister 3 inch Test Stop : 05/17/2023 @ 06:53
Location : 1st FL = Rm 112 Received: 05/23/2023 @ 09:47
Radon Level : 0.8 pCi/L Analyzed: 05/24/2023 @ 10:45
Error for Measurement is: ± 0.6 pCi/L

Canister ID# : 2916098 Test Start : 05/15/2023 @ 06:34
Canister Type : Charcoal Canister 3 inch Test Stop : 05/17/2023 @ 06:48
Location : 1st FL = Rm 123 Received: 05/23/2023 @ 09:47
Radon Level : 0.1 pCi/L Analyzed: 05/24/2023 @ 09:43
Error for Measurement is: ± 0.2 pCi/L



Andreas C. George

Dante Galan

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 05/23/2023

Mr. Seth Barry
MEDFORD SCHOOL DISTRICT
900 Kenyon Street
Medford, OR 97501-

Client: Jackson E.S.
Test Location: 713 Summit Avenue
Medford, OR 97501-

Individual Canister Results

Canister ID# : 2916010 Test Start : 05/15/2023 @ 06:35
Canister Type : Charcoal Canister 3 inch Test Stop : 05/17/2023 @ 06:36
Location : 1st FL = HC A BLANK Received: 05/23/2023 @ 09:48
Radon Level : 0.1 pCi/L Analyzed: 05/24/2023 @ 10:13
Error for Measurement is: ± 0.7 pCi/L

Canister ID# : 2901031 Test Start : 05/15/2023 @ 06:35
Canister Type : Charcoal Canister 3 inch Test Stop : 05/17/2023 @ 06:49
Location : 1st FL = Rm 120 Received: 05/23/2023 @ 09:47
Radon Level : 0.1 pCi/L Analyzed: 05/24/2023 @ 10:22
Error for Measurement is: ± 0.6 pCi/L

Canister ID# : 2918224 Test Start : 05/15/2023 @ 06:36
Canister Type : Charcoal Canister 3 inch Test Stop : 05/17/2023 @ 06:54
Location : 1st FL = Rm 110 Received: 05/23/2023 @ 09:47
Radon Level : 0.1 pCi/L Analyzed: 05/24/2023 @ 10:45
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 2916037 Test Start : 05/15/2023 @ 06:37
Canister Type : Charcoal Canister 3 inch Test Stop : 05/17/2023 @ 06:38
Location : 1st FL = HC B Received: 05/23/2023 @ 09:48
Radon Level : 0.1 pCi/L Analyzed: 05/24/2023 @ 10:13
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 2916549 Test Start : 05/15/2023 @ 06:37
Canister Type : Charcoal Canister 3 inch Test Stop : 05/17/2023 @ 06:50
Location : 1st FL = Rm 120-B Received: 05/23/2023 @ 09:47
Radon Level : 0.4 pCi/L Analyzed: 05/24/2023 @ 09:25
Error for Measurement is: ± 0.7 pCi/L

Canister ID# : 2916642 Test Start : 05/15/2023 @ 06:39
Canister Type : Charcoal Canister 3 inch Test Stop : 05/17/2023 @ 06:40
Location : 1st FL = HC C Received: 05/23/2023 @ 09:48
Radon Level : 0.6 pCi/L Analyzed: 05/24/2023 @ 09:42
Error for Measurement is: ± 0.7 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 05/23/2023

Mr. Seth Barry
MEDFORD SCHOOL DISTRICT
900 Kenyon Street
Medford, OR 97501-

Client: Jackson E.S.
Test Location: 713 Summit Avenue
Medford, OR 97501-

Individual Canister Results

Canister ID# : 2918278 Test Start : 05/15/2023 @ 06:39
Canister Type : Charcoal Canister 3 inch Test Stop : 05/17/2023 @ 06:51
Location : 1st FL = Rm 122 Received: 05/23/2023 @ 09:47
Radon Level : 0.2 pCi/L Analyzed: 05/24/2023 @ 10:22
Error for Measurement is: \pm 0.5 pCi/L

Canister ID# : 2916946 Test Start : 05/15/2023 @ 06:39
Canister Type : Charcoal Canister 3 inch Test Stop : 05/17/2023 @ 06:51
Location : 1st FL = Rm 122 BLANK Received: 05/23/2023 @ 09:47
Radon Level : 0.5 pCi/L Analyzed: 05/24/2023 @ 10:22
Error for Measurement is: \pm 0.6 pCi/L

Canister ID# : 2916953 Test Start : 05/15/2023 @ 06:39
Canister Type : Charcoal Canister 3 inch Test Stop : 05/17/2023 @ 06:55
Location : 1st FL = Rm 111 Received: 05/23/2023 @ 09:47
Radon Level : 0.6 pCi/L Analyzed: 05/24/2023 @ 10:35
Error for Measurement is: \pm 0.7 pCi/L

Canister ID# : 2916204 Test Start : 05/15/2023 @ 06:40
Canister Type : Charcoal Canister 3 inch Test Stop : 05/17/2023 @ 06:55
Location : 1st FL = Rm 110-B Received: 05/23/2023 @ 09:47
Radon Level : 0.6 pCi/L Analyzed: 05/24/2023 @ 10:36
Error for Measurement is: \pm 0.6 pCi/L

Canister ID# : 2916007 Test Start : 05/15/2023 @ 06:41
Canister Type : Charcoal Canister 3 inch Test Stop : 05/17/2023 @ 06:44
Location : 1st FL = HC D DP Received: 05/23/2023 @ 09:48
Radon Level : 0.5 pCi/L Analyzed: 05/24/2023 @ 09:39
Error for Measurement is: \pm 0.6 pCi/L

Canister ID# : 2916954 Test Start : 05/15/2023 @ 06:41
Canister Type : Charcoal Canister 3 inch Test Stop : 05/17/2023 @ 06:44
Location : 1st FL = HC D DP Received: 05/23/2023 @ 09:48
Radon Level : 0.4 pCi/L Analyzed: 05/24/2023 @ 10:45

Average of Side by Side Canisters 0.5 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 05/23/2023

Mr. Seth Barry
MEDFORD SCHOOL DISTRICT
900 Kenyon Street
Medford, OR 97501-

Client: Jackson E.S.
Test Location: 713 Summit Avenue
Medford, OR 97501-

Individual Canister Results

Error for Measurement is: ± 0.6 pCi/L

Canister ID# :	2916101	Test Start :	05/15/2023 @ 06:41
Canister Type :	Charcoal Canister 3 inch	Test Stop :	05/17/2023 @ 06:52
Location :	1st FL = Rm 121	Received:	05/23/2023 @ 09:47
Radon Level :	0.3 pCi/L	Analyzed:	05/24/2023 @ 10:20
Error for Measurement is: ±	0.7 pCi/L		

Canister ID# :	2916017	Test Start :	05/15/2023 @ 06:43
Canister Type :	Charcoal Canister 3 inch	Test Stop :	05/17/2023 @ 06:52
Location :	1st FL = Media Ctr 1	Received:	05/23/2023 @ 09:47
Radon Level :	0.2 pCi/L	Analyzed:	05/24/2023 @ 10:35
Error for Measurement is: ±	0.8 pCi/L		

Canister ID# :	2913688	Test Start :	05/15/2023 @ 06:43
Canister Type :	Charcoal Canister 3 inch	Test Stop :	05/17/2023 @ 06:57
Location :	1st FL = Cafeteria BL	Received:	05/23/2023 @ 09:47
Radon Level :	0.3 pCi/L	Analyzed:	05/24/2023 @ 09:56
Error for Measurement is: ±	0.8 pCi/L		

Canister ID# :	2915065	Test Start :	05/15/2023 @ 06:43
Canister Type :	Charcoal Canister 3 inch	Test Stop :	05/17/2023 @ 06:57
Location :	1st FL = Cafeteria DP	Received:	05/23/2023 @ 09:47
Radon Level :	0.3 pCi/L	Analyzed:	05/24/2023 @ 10:35
Error for Measurement is: ±	0.7 pCi/L		

Canister ID# :	2916570	Test Start :	05/15/2023 @ 06:43
Canister Type :	Charcoal Canister 3 inch	Test Stop :	05/17/2023 @ 06:57
Location :	1st FL = Cafeteria DP	Received:	05/23/2023 @ 09:47
Radon Level :	0.4 pCi/L	Analyzed:	05/24/2023 @ 10:35

Average of Side by Side Canisters 0.4 pCi/L

Error for Measurement is: ± 0.8 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 05/23/2023

Mr. Seth Barry
MEDFORD SCHOOL DISTRICT
900 Kenyon Street
Medford, OR 97501-

Client: Jackson E.S.
Test Location: 713 Summit Avenue
Medford, OR 97501-

Individual Canister Results

Canister ID# : 2901022 Test Start : 05/15/2023 @ 06:45
Canister Type : Charcoal Canister 3 inch Test Stop : 05/17/2023 @ 06:46
Location : 1st FL = HC E Received: 05/23/2023 @ 09:48
Radon Level : 0.8 pCi/L Analyzed: 05/24/2023 @ 10:22
Error for Measurement is: ± 0.6 pCi/L

Canister ID# : 2916106 Test Start : 05/15/2023 @ 06:45
Canister Type : Charcoal Canister 3 inch Test Stop : 05/17/2023 @ 06:52
Location : 1st FL = Media Ctr 2 Received: 05/23/2023 @ 09:47
Radon Level : 0.1 pCi/L Analyzed: 05/24/2023 @ 10:20
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 2916959 Test Start : 05/15/2023 @ 06:46
Canister Type : Charcoal Canister 3 inch Test Stop : 05/17/2023 @ 06:52
Location : 1st FL = Media Ctr DP Received: 05/23/2023 @ 09:47
Radon Level : 0.5 pCi/L Analyzed: 05/24/2023 @ 10:13
Error for Measurement is: ± 0.6 pCi/L

Canister ID# : 2916105 Test Start : 05/15/2023 @ 06:47
Canister Type : Charcoal Canister 3 inch Test Stop : 05/17/2023 @ 06:48
Location : 1st FL = HC F Received: 05/23/2023 @ 09:48
Radon Level : 0.1 pCi/L Analyzed: 05/24/2023 @ 09:56
Error for Measurement is: ± 0.3 pCi/L

Canister ID# : 2916569 Test Start : 05/15/2023 @ 06:47
Canister Type : Charcoal Canister 3 inch Test Stop : 05/17/2023 @ 06:53
Location : 1st FL = Media Ctr 130-A Received: 05/23/2023 @ 09:47
Radon Level : 0.5 pCi/L Analyzed: 05/24/2023 @ 10:18
Error for Measurement is: ± 0.6 pCi/L

Canister ID# : 2918227 Test Start : 05/15/2023 @ 06:48
Canister Type : Charcoal Canister 3 inch Test Stop : 05/17/2023 @ 06:55
Location : 1st FL = Media Ctr 132 Received: 05/23/2023 @ 09:47
Radon Level : 0.7 pCi/L Analyzed: 05/24/2023 @ 09:39
Error for Measurement is: ± 0.7 pCi/L



Andreas C. George

Dante Galan

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 05/23/2023

Mr. Seth Barry
MEDFORD SCHOOL DISTRICT
900 Kenyon Street
Medford, OR 97501-

Client: Jackson E.S.
Test Location: 713 Summit Avenue
Medford, OR 97501-

Individual Canister Results

Canister ID# : 2916002 Test Start : 05/15/2023 @ 06:49
Canister Type : Charcoal Canister 3 inch Test Stop : 05/17/2023 @ 06:50
Location : 1st FL = HC G Received: 05/23/2023 @ 09:48
Radon Level : 0.1 pCi/L Analyzed: 05/24/2023 @ 09:39
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 2916588 Test Start : 05/15/2023 @ 06:49
Canister Type : Charcoal Canister 3 inch Test Stop : 05/17/2023 @ 07:00
Location : 1st FL = Rm 144 Received: 05/23/2023 @ 09:47
Radon Level : 0.8 pCi/L Analyzed: 05/24/2023 @ 09:56
Error for Measurement is: ± 0.7 pCi/L

Canister ID# : 2916005 Test Start : 05/15/2023 @ 06:49
Canister Type : Charcoal Canister 3 inch Test Stop : 05/17/2023 @ 07:00
Location : 1st FL = Rm 144 BL Received: 05/23/2023 @ 09:47
Radon Level : 0.1 pCi/L Analyzed: 05/24/2023 @ 10:36
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 2916550 Test Start : 05/15/2023 @ 06:50
Canister Type : Charcoal Canister 3 inch Test Stop : 05/17/2023 @ 06:54
Location : 1st FL=Media Ctr Comp. Rm Received: 05/23/2023 @ 09:47
Radon Level : 0.1 pCi/L Analyzed: 05/24/2023 @ 10:20
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 2916081 Test Start : 05/15/2023 @ 06:50
Canister Type : Charcoal Canister 3 inch Test Stop : 05/17/2023 @ 07:02
Location : 1st FL = Rm 145 DP Received: 05/23/2023 @ 09:48
Radon Level : 0.1 pCi/L Analyzed: 05/24/2023 @ 10:36
Error for Measurement is: ± 0.3 pCi/L

Canister ID# : 2916202 Test Start : 05/15/2023 @ 06:50
Canister Type : Charcoal Canister 3 inch Test Stop : 05/17/2023 @ 07:02
Location : 1st FL = Rm 145 DP Received: 05/23/2023 @ 09:48
Radon Level : 0.3 pCi/L Analyzed: 05/24/2023 @ 10:35

Average of Side by Side Canisters 0.2 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 05/23/2023

Mr. Seth Barry
MEDFORD SCHOOL DISTRICT
900 Kenyon Street
Medford, OR 97501-

Client: Jackson E.S.
Test Location: 713 Summit Avenue
Medford, OR 97501-

Individual Canister Results

Error for Measurement is: \pm 0.6 pCi/L

Canister ID# :	2916921	Test Start :	05/15/2023 @ 06:51
Canister Type :	Charcoal Canister 3 inch	Test Stop :	05/17/2023 @ 06:52
Location :	1st FL = HC H	Received:	05/23/2023 @ 09:48
Radon Level :	0.2 pCi/L	Analyzed:	05/24/2023 @ 09:26
Error for Measurement is: \pm	0.6 pCi/L		

Canister ID# :	2916208	Test Start :	05/15/2023 @ 06:51
Canister Type :	Charcoal Canister 3 inch	Test Stop :	05/17/2023 @ 06:56
Location :	1st FL = Media Ctr 130-B	Received:	05/23/2023 @ 09:47
Radon Level :	0.2 pCi/L	Analyzed:	05/24/2023 @ 09:43
Error for Measurement is: \pm	0.6 pCi/L		

Canister ID# :	2913766	Test Start :	05/15/2023 @ 06:51
Canister Type :	Charcoal Canister 3 inch	Test Stop :	05/17/2023 @ 07:03
Location :	1st FL = Rm 140	Received:	05/23/2023 @ 09:48
Radon Level :	19.6 pCi/L	Analyzed:	05/24/2023 @ 10:18
Error for Measurement is: \pm	1.0 pCi/L		

Canister ID# :	2913675	Test Start :	05/15/2023 @ 06:52
Canister Type :	Charcoal Canister 3 inch	Test Stop :	05/17/2023 @ 07:04
Location :	1st FL = Rm 141	Received:	05/23/2023 @ 09:48
Radon Level :	21.5 pCi/L	Analyzed:	05/24/2023 @ 10:18
Error for Measurement is: \pm	1.0 pCi/L		



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 05/23/2023

Mr. Seth Barry
MEDFORD SCHOOL DISTRICT
900 Kenyon Street
Medford, OR 97501-

Client: Jackson E.S.
Test Location: 713 Summit Avenue
Medford, OR 97501-

Individual Canister Results

The results indicate that at least one testing device registered at or above the United States Environmental Protection Agency (EPA) action level of 4.0 picoCuries per liter of air (pCi/L). The EPA recommends mitigation if the average of two short-term tests taken in the lowest level of the building suitable for occupancy show radon levels that are equal to or greater than 4.0 pCi/L.

For information on how to reduce radon levels in your home, please review the EPA booklet: Consumer's Guide to Radon Reduction (www.epa.gov/radon/pdfs/consguid.pdf) and contact your state health department. The EPA maintains a radon information website, including copies of its publications, at www.epa.gov/iaq/radon.

For New Jersey clients: Please see the attached guidance document entitled Radon Testing and Mitigation: The Basics for further information.

For New York clients: If the radon level of one or more testing devices is equal to or exceeds 20 pCi/L please contact the New York State Department of Health, Bureau of Environmental Radiation Protection, for technical advice and assistance at 518-402-7556 or toll free 1-800-458-1158.

PLEDGE OF ASSURED QUALITY

All procedures used for generating this report are in complete accordance with the current EPA protocols for the analysis of radon in air (EPA 402-R-92-004). The analytical results relate only to the samples tested, in the condition received by the lab, and that calculations were based upon the information supplied by client. RTCA and its personnel do not assume responsibility or liability, collectively and individually, for analysis results when detectors have been improperly handled or placed by the consumer, nor does RTCA and its personnel accept responsibility for any financial or health consequences of subsequent action or lack of action, taken by the customer or its consultants based on RTCA-provided results.



Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201