

Jefferson Elementary School

Main									
#	Location/Type	Placement Description	Serial #	Dated Opened	Time Opened	Date Closed	Time Closed	Radon Test Results	Remarks
1	Main Office	Northwest Countertop	2817623	19-Nov-19	5:25 AM	21-Nov-19	5:42 AM	0.3	None.
2	Principal's Office	Bookshelf	2756618	19-Nov-19	5:27 AM	21-Nov-19	5:43 AM	0.8	None.
3	Health Room	Top of Fridge	2756539	19-Nov-19	5:28 AM	21-Nov-19	5:44 AM	0.8	None.
4	Room 7	North Wall - Countertop	2817631	19-Nov-19	5:35 AM	21-Nov-19	5:46 AM	0.1	None.
5	Room 7 - Duplicate	North Wall - Countertop	2817871	19-Nov-19	5:35 AM	21-Nov-19	5:46 AM	0.1	None.
6	Room 9	West Wall - Cubby	2817913	19-Nov-19	5:37 AM	21-Nov-19	5:48 AM	0.5	None.
7	Room 11	West Wall - Cubby	2817630	19-Nov-19	5:40 AM	21-Nov-19	5:50 AM	0.5	None.
8	Room 13	Bookshelf	2817857	19-Nov-19	5:43 AM	21-Nov-19	5:53 AM	0.8	None.
9	Room 12	East Wall - Cabinet	2817872	19-Nov-19	5:45 AM	21-Nov-19	5:57 AM	0.5	None.
10	Room 10	East Wall - Countertop	2817843	19-Nov-19	5:48 AM	21-Nov-19	5:59 AM	0.7	None.
11	Room 10 - Blank	East Wall - Countertop	2817888	19-Nov-19	5:48 AM	19-Nov-19	5:48 AM	0.1	None.
12	Room 6	West Wall - Bookshelf	2817837	19-Nov-19	5:29 AM	21-Nov-19	5:42 AM	0.9	None.
13	Room 14	Northeast Corner	2756533	19-Nov-19	5:32 AM	21-Nov-19	5:44 AM	1.7	None.
14	Media Center # 1	Southeast Wall - Bookshelf	2817876	19-Nov-19	5:35 AM	21-Nov-19	5:45 AM	1.2	None.
15	Media Center # 2	North Wall - Counter	2817612	19-Nov-19	5:37 AM	21-Nov-19	5:45 AM	1.0	None.
16	Room 21	Northwest Wall - Countertop	2817916	19-Nov-19	5:44 AM	21-Nov-19	5:48 AM	1.5	None.
17	Room 23	East Wall - Filing Cabinet	2817835	19-Nov-19	5:47 AM	21-Nov-19	5:49 AM	1.1	None.
18	Room 25	West Wall - Shelf	2817853	19-Nov-19	5:52 AM	21-Nov-19	5:52 AM	1.3	None.
19	Room 27	Northwest Wall - Countertop	2817910	19-Nov-19	5:57 AM	21-Nov-19	6:01 AM	1.5	None.
20	Room 29	West Wall - Cubby	2817903	19-Nov-19	6:00 AM	21-Nov-19	6:02 AM	0.2	None.
21	Room 31	West Wall - Countertop	2817917	19-Nov-19	6:02 AM	21-Nov-19	6:04 AM	0.1	None.
22	Room 33	East Wall - Countertop	2817873	19-Nov-19	6:04 AM	21-Nov-19	6:06 AM	0.2	None.
23	Room 33 - Blank	East Wall - Countertop	2817841	19-Nov-19	6:04 AM	19-Nov-19	6:04 AM	0.1	None.
24	Room 34	Southeast Wall - Bookshelf	2817891	19-Nov-19	6:07 AM	21-Nov-19	6:07 AM	0.1	None.
25	Room 34 Office	South Wall - Bookshelf	2817897	19-Nov-19	6:17 AM	21-Nov-19	6:11 AM	0.4	None.
26	Room 35	West Wall - Filing Cabinet	2817875	19-Nov-19	6:09 AM	21-Nov-19	6:17 AM	0.4	None.
27	Room 35 Office	Filing Cabinet	2817898	19-Nov-19	6:20 AM	21-Nov-19	6:20 AM	0.3	None.
28	Modular # 1	Northeast Wall - Office Bookcase	2817904	19-Nov-19	5:43 AM	21-Nov-19	5:53 AM	0.1	None.
29	Modular # 1 - Duplicate	North East Wall - Office Bookcase	2817862	19-Nov-19	5:43 AM	21-Nov-19	5:53 AM	0.4	None.
30	Modular # 2	East Wall - Conference Room Shelf	2817847	19-Nov-19	5:47 AM	21-Nov-19	5:54 AM	0.5	None.
31	Modular # 3	East Wall - Kid's Room - Filing Cabinet	2817622	19-Nov-19	5:48 AM	21-Nov-19	5:53 AM	0.4	None.
32	Modular # 4	Southeast Wall - Office Shelf	2817855	19-Nov-19	5:50 AM	21-Nov-19	5:57 AM	0.8	None.
33	Modular # 5	Southwest Wall - Break Room	2817646	19-Nov-19	5:53 AM	21-Nov-19	5:58 AM	0.4	None.
34	Modular - # 5 - Blank	Southwest Wall - Break Room	2817900	19-Nov-19	5:53 AM	19-Nov-19	5:53 AM	0.1	None.
35	Modular # 6	North Wall - Office Desk	2817902	19-Nov-19	5:55 AM	21-Nov-19	5:59 AM	0.7	None.
36	Modular - #7	Common Room Shelf	2817824	19-Nov-19	6:02 AM	21-Nov-19	6:02 AM	0.4	None.
37	Modular # 8	Kitchen	2817628	19-Nov-19	6:03 AM	21-Nov-19	6:03 AM	0.4	None.
38	Room 32	South Wall - BookCase	2817608	19-Nov-19	5:40 AM	21-Nov-19	5:50 AM	0.6	None.
39	Room 30	North Wall - Table	2756319	19-Nov-19	5:38 AM	21-Nov-19	5:48 AM	0.3	None.
40	Room 30 - Duplicate	North Wall - Table	2817606	19-Nov-19	5:38 AM	21-Nov-19	5:48 AM	0.1	None.
41	Room 28	West Wall - Bookcase	2817924	19-Nov-19	5:34 AM	21-Nov-19	5:46 AM	0.6	None.
42	Room 26	North Wall - Cabinet By Clock	2817909	19-Nov-19	5:29 AM	21-Nov-19	5:43 AM	1.1	None.
43	Room 24	Desk	2817839	19-Nov-19	5:21 AM	21-Nov-19	5:42 AM	0.6	None.
44	Room 22	By Door	2817613	19-Nov-19	5:25 AM	21-Nov-19	5:43 AM	0.4	None.
45	Room 20	North Wall - Countertop	2817874	19-Nov-19	5:27 AM	21-Nov-19	5:45 AM	0.3	None.
46	Room 20 - Duplicate	North Wall - Countertop	2817634	19-Nov-19	5:27 AM	21-Nov-19	5:46 AM	0.1	None.
47	Room 18	North Wall - Countertop	2817865	19-Nov-19	5:30 AM	21-Nov-19	5:47 AM	0.3	None.
48	Room 17	South Wall - Table	2756323	19-Nov-19	5:33 AM	21-Nov-19	5:49 AM	1.2	None.
49	Room 19	By Sink	2817856	19-Nov-19	5:36 AM	21-Nov-19	5:50 AM	2.1	None.
50	Stage	South Wall	2817607	19-Nov-19	5:39 AM	21-Nov-19	5:52 AM	1.1	None.
51	Gymnasium # 1	West Wall	2817848	19-Nov-19	5:29 AM	21-Nov-19	5:42 AM	0.5	None.
52	Gymnasium # 2	East Wall	2817635	19-Nov-19	5:30 AM	21-Nov-19	5:43 AM	1.1	None.
53	Gymnasium # 3	South Wall	2817858	19-Nov-19	5:31 AM	21-Nov-19	5:46 AM	1.6	None.
54	Gymnasium # 4	West Wall	2817879	19-Nov-19	5:33 AM	21-Nov-19	5:45 AM	1.2	None.
55	Staff Work Room	East Wall - Countertop	2817892	19-Nov-19	5:36 AM	21-Nov-19	5:49 AM	0.8	None.
56	Room 3 East of Staff Work Room	Southeast Wall - Countertop	2817834	19-Nov-19	5:38 AM	21-Nov-19	5:51 AM	1.2	None.
57	Cafeteria # 1	East Wall - Fire Extinguisher	2817363	19-Nov-19	5:39 AM	21-Nov-19	5:53 AM	0.1	None.
58	Cafeteria # 2	West Wall - Bulletin Board	2817906	19-Nov-19	5:41 AM	21-Nov-19	5:55 AM	0.8	None.
59	Staff Break Room	East Wall - Countertop	2817880	19-Nov-19	5:44 AM	21-Nov-19	5:58 AM	1.2	None.
60	Staff Break Room - Duplicate	East Wall - Countertop	2817846	19-Nov-19	5:45 AM	21-Nov-19	5:58 AM	1.4	None.
61	Custodial Office	Desk Top	2817901	19-Nov-19	5:46 AM	21-Nov-19	6:01 AM	1.1	None.

#	Type	Description	Serial #	Dated Opened	Time Opened	Date Closed	Time Closed	Radon Test Results	Remarks
62	Spike #1 (Room 41)	KSU Radon Chamber Pike to 26.8	2817845	18-Nov-19	10:35 AM	20-Nov-19	10:35 AM	26.3	Central Time.
63	Spike #2 (Room 42)	KSU Radon Chamber Pike to 26.8	2817884	18-Nov-19	10:35 AM	20-Nov-19	10:35 AM	25.7	Central Time.
#	Type	Description	Serial #	Dated Started	Time Started	Date Stopped	Time Stopped	EPA Average	Remarks
1	CRM-3	Main Office - Desk	238515015	19-Nov-19	7:03 AM	21-Nov-19	6:03 AM	0.7	Not adjusted for Day Light Savings Time (DST)
2	CRM-4	Principal's Office - Desk	238515010	19-Nov-19	7:05 AM	21-Nov-19	6:05 AM	0.7	Not adjusted for Day Light Savings Time (DST)

*The E.P.A.'s recommended action level for radon is 4.0 pCi/L.

*This is not a health based number.

*Outdoor radon levels across the country average 0.4 pCi/L.

*If an RPD test result over 4.0 pCi/L differs by 28% or more, the data quality should be questioned.

*A trend in RPE values that are more than ± 30% should be investigated