

Site Radon Inspection Report

Date : 11/25/2019

Bryan Hogan / Ron Havnear  
MEDFORD SCHOOL DISTRICT  
815 South Oakdale Avenue  
Medford, OR 97501-

Client: Jefferson E.S.  
Test Location: 333 Holmes Avenue  
Medford, OR 97501-  
Individual Canister Results

Canister ID# :	2756319	Test Start :	11/19/2019 @ 05:38
Canister Type :	Charcoal Canister 3 inch	Test Stop :	11/21/2019 @ 05:48
Location :	1st FL = Rm 30	Received:	11/25/2019 @ 10:20
Radon Level :	0.3 pCi/L	Analyzed:	11/25/2019 @ 16:53
Error for Measurement is: ±	0.4 pCi/L		

Canister ID# :	2756323	Test Start :	11/19/2019 @ 05:33
Canister Type :	Charcoal Canister 3 inch	Test Stop :	11/21/2019 @ 05:49
Location :	1st FL = Rm 17	Received:	11/25/2019 @ 10:20
Radon Level :	1.2 pCi/L	Analyzed:	11/25/2019 @ 16:30
Error for Measurement is: ±	0.4 pCi/L		

Canister ID# :	2756533	Test Start :	11/19/2019 @ 05:32
Canister Type :	Charcoal Canister 3 inch	Test Stop :	11/21/2019 @ 05:44
Location :	1st FL = Rm 14	Received:	11/25/2019 @ 10:20
Radon Level :	1.7 pCi/L	Analyzed:	11/26/2019 @ 10:31
Error for Measurement is: ±	0.4 pCi/L		

Canister ID# :	2756539	Test Start :	11/19/2019 @ 05:28
Canister Type :	Charcoal Canister 3 inch	Test Stop :	11/21/2019 @ 05:44
Location :	1st FL = Health Rm	Received:	11/25/2019 @ 10:20
Radon Level :	0.8 pCi/L	Analyzed:	11/25/2019 @ 15:55
Error for Measurement is: ±	0.3 pCi/L		

Canister ID# :	2756618	Test Start :	11/19/2019 @ 05:27
Canister Type :	Charcoal Canister 3 inch	Test Stop :	11/21/2019 @ 05:43
Location :	1st FL = Principals Office	Received:	11/25/2019 @ 10:20
Radon Level :	0.8 pCi/L	Analyzed:	11/25/2019 @ 15:55
Error for Measurement is: ±	0.4 pCi/L		

Canister ID# :	2817363	Test Start :	11/19/2019 @ 05:40
Canister Type :	Charcoal Canister 3 inch	Test Stop :	11/21/2019 @ 05:54
Location :	1st FL = Cafeteria 1	Received:	11/25/2019 @ 10:20
Radon Level :	0.1 pCi/L	Analyzed:	11/25/2019 @ 16:12
Error for Measurement is: ±	0.5 pCi/L		



*Andreas C. George*

Andreas C. George  
Radon Measurement Specialist  
NJ MES 11089

*Dante Galan*

Dante Galan  
Laboratory Director

NRSB ARL0001  
NYS ELAP ID: 10806  
PADEP ID: 0346  
NJDEP ID: NY933  
NJ MEB 90036  
FL DOH RB1609  
IL RNL2000201



Site Radon Inspection Report

Date : 11/25/2019

Bryan Hogan / Ron Havnear  
MEDFORD SCHOOL DISTRICT  
815 South Oakdale Avenue  
Medford, OR 97501-

Client: Jefferson E.S.  
Test Location: 333 Holmes Avenue  
Medford, OR 97501-

Individual Canister Results

Canister ID# : 2817606  
Canister Type : Charcoal Canister 3 inch  
Location : 1st FL = Rm 30 DP  
Radon Level : 0.1 pCi/L  
Error for Measurement is:  $\pm$  0.8 pCi/L  
Test Start : 11/19/2019 @ 05:38  
Test Stop : 11/21/2019 @ 05:48  
Received: 11/25/2019 @ 10:20  
Analyzed: 11/25/2019 @ 16:29

Canister ID# : 2817607  
Canister Type : Charcoal Canister 3 inch  
Location : 1st FL = Stage  
Radon Level : 1.1 pCi/L  
Error for Measurement is:  $\pm$  0.4 pCi/L  
Test Start : 11/19/2019 @ 05:39  
Test Stop : 11/21/2019 @ 05:52  
Received: 11/25/2019 @ 10:20  
Analyzed: 11/25/2019 @ 16:53

Canister ID# : 2817608  
Canister Type : Charcoal Canister 3 inch  
Location : 1st FL = Rm 32  
Radon Level : 0.6 pCi/L  
Error for Measurement is:  $\pm$  0.4 pCi/L  
Test Start : 11/19/2019 @ 05:40  
Test Stop : 11/21/2019 @ 05:50  
Received: 11/25/2019 @ 10:20  
Analyzed: 11/25/2019 @ 16:24

Canister ID# : 2817612  
Canister Type : Charcoal Canister 3 inch  
Location : 1st FL = Media Ctr 2  
Radon Level : 1.0 pCi/L  
Error for Measurement is:  $\pm$  0.3 pCi/L  
Test Start : 11/19/2019 @ 05:37  
Test Stop : 11/21/2019 @ 05:45  
Received: 11/25/2019 @ 10:20  
Analyzed: 11/25/2019 @ 16:12

Canister ID# : 2817613  
Canister Type : Charcoal Canister 3 inch  
Location : 1st FL = Rm 22  
Radon Level : 0.4 pCi/L  
Error for Measurement is:  $\pm$  0.4 pCi/L  
Test Start : 11/19/2019 @ 05:25  
Test Stop : 11/21/2019 @ 05:43  
Received: 11/25/2019 @ 10:20  
Analyzed: 11/26/2019 @ 10:31

Canister ID# : 2817622  
Canister Type : Charcoal Canister 3 inch  
Location : 1st FL=Mod.3 E.Play.Rm  
Radon Level : 0.4 pCi/L  
Error for Measurement is:  $\pm$  0.5 pCi/L  
Test Start : 11/19/2019 @ 05:48  
Test Stop : 11/21/2019 @ 05:56  
Received: 11/25/2019 @ 10:20  
Analyzed: 11/26/2019 @ 09:52



*Andreas C. George*

Andreas C. George  
Radon Measurement Specialist  
NJ MES 11089

*Dante Galan*

Dante Galan  
Laboratory Director

NRSB ARL0001  
NYS ELAP ID: 10806  
PADEP ID: 0346  
NJDEP ID: NY933  
NJ MEB 90036  
FL DOH RB1609  
IL RNL2000201



Site Radon Inspection Report

Date : 11/25/2019

Bryan Hogan / Ron Havnear  
MEDFORD SCHOOL DISTRICT  
815 South Oakdale Avenue  
Medford, OR 97501-

Client: Jefferson E.S.  
Test Location: 333 Holmes Avenue  
Medford, OR 97501-

Individual Canister Results

Canister ID# : 2817623                      Test Start : 11/19/2019 @ 05:25  
Canister Type : Charcoal Canister 3 inch                      Test Stop : 11/21/2019 @ 05:42  
Location : 1st FL = Main Office                      Received: 11/25/2019 @ 10:20  
Radon Level : 0.3 pCi/L                      Analyzed: 11/25/2019 @ 15:55  
Error for Measurement is:  $\pm$  0.3 pCi/L

Canister ID# : 2817628                      Test Start : 11/19/2019 @ 06:03  
Canister Type : Charcoal Canister 3 inch                      Test Stop : 11/21/2019 @ 06:03  
Location : 1st FL=Mod.8 Kitchen                      Received: 11/25/2019 @ 10:20  
Radon Level : 0.4 pCi/L                      Analyzed: 11/25/2019 @ 16:30  
Error for Measurement is:  $\pm$  0.3 pCi/L

Canister ID# : 2817630                      Test Start : 11/19/2019 @ 05:40  
Canister Type : Charcoal Canister 3 inch                      Test Stop : 11/21/2019 @ 05:50  
Location : 1st FL = Rm 11                      Received: 11/25/2019 @ 10:20  
Radon Level : 0.5 pCi/L                      Analyzed: 11/25/2019 @ 16:12  
Error for Measurement is:  $\pm$  0.4 pCi/L

Canister ID# : 2817631                      Test Start : 11/19/2019 @ 05:35  
Canister Type : Charcoal Canister 3 inch                      Test Stop : 11/21/2019 @ 05:46  
Location : 1st FL = Rm 7                      Received: 11/25/2019 @ 10:20  
Radon Level : 0.1 pCi/L                      Analyzed: 11/25/2019 @ 16:07  
Error for Measurement is:  $\pm$  0.3 pCi/L

Canister ID# : 2817634                      Test Start : 11/19/2019 @ 05:27  
Canister Type : Charcoal Canister 3 inch                      Test Stop : 11/21/2019 @ 05:46  
Location : 1st FL = Rm 20 DP                      Received: 11/25/2019 @ 10:20  
Radon Level : 0.1 pCi/L                      Analyzed: 11/25/2019 @ 16:07  
Error for Measurement is:  $\pm$  0.2 pCi/L

Canister ID# : 2817635                      Test Start : 11/19/2019 @ 05:31  
Canister Type : Charcoal Canister 3 inch                      Test Stop : 11/21/2019 @ 05:43  
Location : 1st FL = Gym 2 E                      Received: 11/25/2019 @ 10:20  
Radon Level : 1.1 pCi/L                      Analyzed: 11/25/2019 @ 13:06  
Error for Measurement is:  $\pm$  0.5 pCi/L



Andreas C. George  
Radon Measurement Specialist  
NJ MES 11089

Dante Galan  
Laboratory Director

NRSB ARL0001  
NYS ELAP ID: 10806  
PADEP ID: 0346  
NJDEP ID: NY933  
NJ MEB 90036  
FL DOH RB1609  
IL RNL2000201



Site Radon Inspection Report

Date : 11/25/2019

Bryan Hogan / Ron Havnear  
MEDFORD SCHOOL DISTRICT  
815 South Oakdale Avenue  
Medford, OR 97501-

Client: Jefferson E.S.  
Test Location: 333 Holmes Avenue  
Medford, OR 97501-  
Individual Canister Results

Canister ID# : 2817646                      Test Start : 11/19/2019 @ 05:53  
Canister Type : Charcoal Canister 3 inch                      Test Stop : 11/21/2019 @ 05:53  
Location : 1st FL=Mod.5 SW. Brk/Rm                      Received: 11/25/2019 @ 10:20  
Radon Level : 0.4 pCi/L                      Analyzed: 11/25/2019 @ 16:24  
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 2817824                      Test Start : 11/19/2019 @ 06:02  
Canister Type : Charcoal Canister 3 inch                      Test Stop : 11/21/2019 @ 06:02  
Location : 1st FL=Mod.7 Comm.Rm.                      Received: 11/25/2019 @ 10:20  
Radon Level : 0.4 pCi/L                      Analyzed: 11/25/2019 @ 16:12  
Error for Measurement is: ± 0.3 pCi/L

Canister ID# : 2817834                      Test Start : 11/19/2019 @ 05:38  
Canister Type : Charcoal Canister 3 inch                      Test Stop : 11/21/2019 @ 05:51  
Location : 1st FL=Rm 3 Staff Wrk/Rm                      Received: 11/25/2019 @ 10:20  
Radon Level : 1.2 pCi/L                      Analyzed: 11/25/2019 @ 15:50  
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 2817835                      Test Start : 11/19/2019 @ 05:47  
Canister Type : Charcoal Canister 3 inch                      Test Stop : 11/21/2019 @ 05:49  
Location : 1st FL = Rm 23                      Received: 11/25/2019 @ 10:20  
Radon Level : 1.1 pCi/L                      Analyzed: 11/25/2019 @ 15:55  
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 2817837                      Test Start : 11/19/2019 @ 05:29  
Canister Type : Charcoal Canister 3 inch                      Test Stop : 11/21/2019 @ 05:42  
Location : 1st FL = Rm 6                      Received: 11/25/2019 @ 10:20  
Radon Level : 0.9 pCi/L                      Analyzed: 11/25/2019 @ 16:30  
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 2817839                      Test Start : 11/19/2019 @ 05:21  
Canister Type : Charcoal Canister 3 inch                      Test Stop : 11/21/2019 @ 05:42  
Location : 1st FL = Rm 24                      Received: 11/25/2019 @ 10:20  
Radon Level : 0.6 pCi/L                      Analyzed: 11/25/2019 @ 15:55  
Error for Measurement is: ± 0.3 pCi/L



*Andreas C. George*

Andreas C. George  
Radon Measurement Specialist  
NJ MES 11089

*Dante Galan*

Dante Galan  
Laboratory Director

NRSB ARL0001  
NYS ELAP ID: 10806  
PADEP ID: 0346  
NJDEP ID: NY933  
NJ MEB 90036  
FL DOH RB1609  
IL RNL2000201



Site Radon Inspection Report

Date : 11/25/2019

Bryan Hogan / Ron Havnear  
MEDFORD SCHOOL DISTRICT  
815 South Oakdale Avenue  
Medford, OR 97501-

Client: Jefferson E.S.  
Test Location: 333 Holmes Avenue  
Medford, OR 97501-  
Individual Canister Results

Canister ID# : 2817841                      Test Start : 11/19/2019 @ 06:04  
Canister Type : Charcoal Canister 3 inch                      Test Stop : 11/21/2019 @ 06:04  
Location : 1st FL = Rm 33 BL                      Received: 11/25/2019 @ 10:20  
Radon Level : 0.1 pCi/L                      Analyzed: 11/25/2019 @ 16:58  
Error for Measurement is: ± 0.6 pCi/L

Canister ID# : 2817843                      Test Start : 11/19/2019 @ 05:48  
Canister Type : Charcoal Canister 3 inch                      Test Stop : 11/21/2019 @ 06:00  
Location : 1st FL = Rm 10                      Received: 11/25/2019 @ 10:20  
Radon Level : 0.7 pCi/L                      Analyzed: 11/25/2019 @ 16:12  
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 2817845                      Test Start : 11/18/2019 @ 09:35  
Canister Type : Charcoal Canister 3 inch                      Test Stop : 11/20/2019 @ 09:35  
Location : 1st FL = Rm 41                      Received: 11/25/2019 @ 10:20  
Radon Level : 26.3 pCi/L                      Analyzed: 11/25/2019 @ 15:50  
Error for Measurement is: ± 0.9 pCi/L

This is a quality control test known as a spike. This canister has never been on the school site.

Canister ID# : 2817846                      Test Start : 11/19/2019 @ 05:45  
Canister Type : Charcoal Canister 3 inch                      Test Stop : 11/21/2019 @ 05:58  
Location : 1st FL = Staff Brk/Rm DP                      Received: 11/25/2019 @ 10:20  
Radon Level : 1.4 pCi/L                      Analyzed: 11/26/2019 @ 09:52  
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2817847                      Test Start : 11/19/2019 @ 05:47  
Canister Type : Charcoal Canister 3 inch                      Test Stop : 11/21/2019 @ 05:54  
Location : 1st FL=Mod. 2 E.Conf.Rm                      Received: 11/25/2019 @ 10:20  
Radon Level : 0.5 pCi/L                      Analyzed: 11/26/2019 @ 10:31  
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 2817848                      Test Start : 11/19/2019 @ 05:29  
Canister Type : Charcoal Canister 3 inch                      Test Stop : 11/21/2019 @ 05:42  
Location : 1st FL = Gym 1 W                      Received: 11/25/2019 @ 10:20  
Radon Level : 0.9 pCi/L                      Analyzed: 11/26/2019 @ 10:31  
Error for Measurement is: ± 0.5 pCi/L



*Andreas C. George*

Andreas C. George  
Radon Measurement Specialist  
NJ MES 11089

*Dante Galan*

Dante Galan  
Laboratory Director

NRSB ARL0001  
NYS ELAP ID: 10806  
PADEP ID: 0346  
NJDEP ID: NY933  
NJ MEB 90036  
FL DOH RB1609  
IL RNL2000201

Site Radon Inspection Report

Date : 11/25/2019

Bryan Hogan / Ron Havnear  
 MEDFORD SCHOOL DISTRICT  
 815 South Oakdale Avenue  
 Medford, OR 97501-

Client: Jefferson E.S.

Test Location: 333 Holmes Avenue  
 Medford, OR 97501-

## Individual Canister Results

Canister ID# : 2817853                      Test Start : 11/19/2019 @ 05:52  
 Canister Type : Charcoal Canister 3 inch      Test Stop : 11/21/2019 @ 05:52  
 Location : 1st FL = Rm 25                      Received: 11/25/2019 @ 10:20  
 Radon Level : 1.3 pCi/L                      Analyzed: 11/25/2019 @ 16:07  
 Error for Measurement is:  $\pm$  0.4 pCi/L


Canister ID# : 2817855                      Test Start : 11/19/2019 @ 05:50  
 Canister Type : Charcoal Canister 3 inch      Test Stop : 11/21/2019 @ 05:57  
 Location : 1st FL=Mod.4 SE. Off.              Received: 11/25/2019 @ 10:20  
 Radon Level : 0.8 pCi/L                      Analyzed: 11/26/2019 @ 09:52  
 Error for Measurement is:  $\pm$  0.4 pCi/L

Canister ID# : 2817856                      Test Start : 11/19/2019 @ 05:36  
 Canister Type : Charcoal Canister 3 inch      Test Stop : 11/21/2019 @ 05:50  
 Location : 1st FL = Rm 19                      Received: 11/25/2019 @ 10:20  
 Radon Level : 2.1 pCi/L                      Analyzed: 11/25/2019 @ 16:28  
 Error for Measurement is:  $\pm$  0.5 pCi/L

Canister ID# : 2817857                      Test Start : 11/19/2019 @ 05:43  
 Canister Type : Charcoal Canister 3 inch      Test Stop : 11/21/2019 @ 05:53  
 Location : 1st FL = Rm 13                      Received: 11/25/2019 @ 10:20  
 Radon Level : 0.8 pCi/L                      Analyzed: 11/25/2019 @ 15:50  
 Error for Measurement is:  $\pm$  0.4 pCi/L

Canister ID# : 2817858                      Test Start : 11/19/2019 @ 05:32  
 Canister Type : Charcoal Canister 3 inch      Test Stop : 11/21/2019 @ 05:46  
 Location : 1st FL = Gym 3 S                      Received: 11/25/2019 @ 10:20  
 Radon Level : 1.6 pCi/L                      Analyzed: 11/25/2019 @ 16:28  
 Error for Measurement is:  $\pm$  0.5 pCi/L

Canister ID# : 2817862                      Test Start : 11/19/2019 @ 05:43  
 Canister Type : Charcoal Canister 3 inch      Test Stop : 11/21/2019 @ 05:53  
 Location : 1st FL=Mod. 1 NE Off. DP              Received: 11/25/2019 @ 10:20  
 Radon Level : 0.4 pCi/L                      Analyzed: 11/26/2019 @ 09:53  
 Error for Measurement is:  $\pm$  0.4 pCi/L

Andreas C. George  
 Radon Measurement Specialist

NJ MES 11089



Dante Galan  
 Laboratory Director

NRSB ARL0001  
 NYS ELAP ID: 10806  
 PADEP ID: 0346  
 NJDEP ID: NY933  
 NJ MEB 90036  
 FL DOH RB1609  
 IL RNL2000201

Site Radon Inspection Report

Date : 11/25/2019

Bryan Hogan / Ron Havnear  
MEDFORD SCHOOL DISTRICT  
815 South Oakdale Avenue  
Medford, OR 97501-

Client: Jefferson E.S.  
Test Location: 333 Holmes Avenue  
Medford, OR 97501-  
Individual Canister Results

Canister ID# : 2817865                      Test Start : 11/19/2019 @ 05:30  
Canister Type : Charcoal Canister 3 inch                      Test Stop : 11/21/2019 @ 05:47  
Location : 1st FL = Rm 18                      Received: 11/25/2019 @ 10:20  
Radon Level : 0.3 pCi/L                      Analyzed: 11/25/2019 @ 13:06  
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 2817871                      Test Start : 11/19/2019 @ 05:35  
Canister Type : Charcoal Canister 3 inch                      Test Stop : 11/21/2019 @ 05:46  
Location : 1st FL = Rm 7 DP                      Received: 11/25/2019 @ 10:20  
Radon Level : 0.1 pCi/L                      Analyzed: 11/25/2019 @ 16:12  
Error for Measurement is: ± 0.3 pCi/L

Canister ID# : 2817872                      Test Start : 11/19/2019 @ 05:45  
Canister Type : Charcoal Canister 3 inch                      Test Stop : 11/21/2019 @ 05:57  
Location : 1st FL = Rm 12                      Received: 11/25/2019 @ 10:20  
Radon Level : 0.5 pCi/L                      Analyzed: 11/25/2019 @ 16:12  
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 2817873                      Test Start : 11/19/2019 @ 06:04  
Canister Type : Charcoal Canister 3 inch                      Test Stop : 11/21/2019 @ 06:06  
Location : 1st FL = Rm 33                      Received: 11/25/2019 @ 10:20  
Radon Level : 0.2 pCi/L                      Analyzed: 11/25/2019 @ 16:07  
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2817874                      Test Start : 11/19/2019 @ 05:27  
Canister Type : Charcoal Canister 3 inch                      Test Stop : 11/21/2019 @ 05:45  
Location : 1st FL = Rm 20                      Received: 11/25/2019 @ 10:20  
Radon Level : 0.3 pCi/L                      Analyzed: 11/25/2019 @ 16:28  
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2817875                      Test Start : 11/19/2019 @ 06:09  
Canister Type : Charcoal Canister 3 inch                      Test Stop : 11/21/2019 @ 06:11  
Location : 1st FL = Rm 35                      Received: 11/25/2019 @ 10:20  
Radon Level : 0.4 pCi/L                      Analyzed: 11/25/2019 @ 16:53  
Error for Measurement is: ± 0.4 pCi/L



*Andreas C. George*

Andreas C. George  
Radon Measurement Specialist  
NJ MES 11089

*Dante Galan*

Dante Galan  
Laboratory Director

NRSB ARL0001  
NYS ELAP ID: 10806  
PADEP ID: 0346  
NJDEP ID: NY933  
NJ MEB 90036  
FL DOH RB1609  
IL RNL2000201



Site Radon Inspection Report

Date : 11/25/2019

Bryan Hogan / Ron Havnear  
MEDFORD SCHOOL DISTRICT  
815 South Oakdale Avenue  
Medford, OR 97501-

Client: Jefferson E.S.  
Test Location: 333 Holmes Avenue  
Medford, OR 97501-  
Individual Canister Results

Canister ID# : 2817876  
Canister Type : Charcoal Canister 3 inch  
Location : 1st FL = Media Ctr 1  
Radon Level : 1.2 pCi/L  
Error for Measurement is: ± 0.4 pCi/L  
Test Start : 11/19/2019 @ 05:35  
Test Stop : 11/21/2019 @ 05:45  
Received: 11/25/2019 @ 10:20  
Analyzed: 11/25/2019 @ 16:07

Canister ID# : 2817879  
Canister Type : Charcoal Canister 3 inch  
Location : 1st FL = Gym 4 W  
Radon Level : 1.2 pCi/L  
Error for Measurement is: ± 0.5 pCi/L  
Test Start : 11/19/2019 @ 05:34  
Test Stop : 11/21/2019 @ 05:45  
Received: 11/25/2019 @ 10:20  
Analyzed: 11/25/2019 @ 13:06

Canister ID# : 2817880  
Canister Type : Charcoal Canister 3 inch  
Location : 1st FL = Staff Brk/Rm  
Radon Level : 1.2 pCi/L  
Error for Measurement is: ± 0.5 pCi/L  
Test Start : 11/19/2019 @ 05:44  
Test Stop : 11/21/2019 @ 05:58  
Received: 11/25/2019 @ 10:20  
Analyzed: 11/25/2019 @ 13:06

Canister ID# : 2817884  
Canister Type : Charcoal Canister 3 inch  
Location : 1st FL = Rm 42  
Radon Level : 25.7 pCi/L  
Error for Measurement is: ± 0.9 pCi/L  
Test Start : 11/18/2019 @ 09:35  
Test Stop : 11/20/2019 @ 09:35  
Received: 11/25/2019 @ 10:20  
Analyzed: 11/25/2019 @ 16:30

This is a quality control test known as a spike. This canister has never been on the school site.

Canister ID# : 2817888  
Canister Type : Charcoal Canister 3 inch  
Location : 1st FL = Rm 10 BL  
Radon Level : 0.1 pCi/L  
Error for Measurement is: ± 0.2 pCi/L  
Test Start : 11/19/2019 @ 05:48  
Test Stop : 11/21/2019 @ 06:00  
Received: 11/25/2019 @ 10:20  
Analyzed: 11/25/2019 @ 16:12

Canister ID# : 2817891  
Canister Type : Charcoal Canister 3 inch  
Location : 1st FL = Rm 34  
Radon Level : 0.1 pCi/L  
Error for Measurement is: ± 0.7 pCi/L  
Test Start : 11/19/2019 @ 06:07  
Test Stop : 11/21/2019 @ 06:07  
Received: 11/25/2019 @ 10:20  
Analyzed: 11/25/2019 @ 16:28



*Andreas C. George*

Andreas C. George  
Radon Measurement Specialist  
NJ MES 11089

*Dante Galan*

Dante Galan  
Laboratory Director

NRSB ARL0001  
NYS ELAP ID: 10806  
PADEP ID: 0346  
NJDEP ID: NY933  
NJ MEB 90036  
FL DOH RB1609  
IL RNL2000201





Site Radon Inspection Report

Date : 11/25/2019

Bryan Hogan / Ron Havnear  
MEDFORD SCHOOL DISTRICT  
815 South Oakdale Avenue  
Medford, OR 97501-

Client: Jefferson E.S.  
Test Location: 333 Holmes Avenue  
Medford, OR 97501-  
Individual Canister Results

Canister ID# : 2817892                      Test Start : 11/19/2019 @ 05:37  
Canister Type : Charcoal Canister 3 inch                      Test Stop : 11/21/2019 @ 05:49  
Location : 1st FL = Staff Wrk/Rm                      Received: 11/25/2019 @ 10:20  
Radon Level : 0.8 pCi/L                      Analyzed: 11/25/2019 @ 15:55  
Error for Measurement is: ± 0.3 pCi/L

Canister ID# : 2817897                      Test Start : 11/19/2019 @ 06:17  
Canister Type : Charcoal Canister 3 inch                      Test Stop : 11/21/2019 @ 06:17  
Location : 1st FL = Rm 34 Office                      Received: 11/25/2019 @ 10:20  
Radon Level : 0.4 pCi/L                      Analyzed: 11/25/2019 @ 16:58  
Error for Measurement is: ± 0.3 pCi/L

Canister ID# : 2817898                      Test Start : 11/19/2019 @ 06:20  
Canister Type : Charcoal Canister 3 inch                      Test Stop : 11/21/2019 @ 06:20  
Location : 1st FL = Rm 35 Office                      Received: 11/25/2019 @ 10:20  
Radon Level : 0.3 pCi/L                      Analyzed: 11/25/2019 @ 16:07  
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 2817900                      Test Start : 11/19/2019 @ 05:53  
Canister Type : Charcoal Canister 3 inch                      Test Stop : 11/21/2019 @ 05:53  
Location : 1st FL=Mod.5 BLANK                      Received: 11/25/2019 @ 10:20  
Radon Level : 0.1 pCi/L                      Analyzed: 11/25/2019 @ 16:24  
Error for Measurement is: ± 0.1 pCi/L

Canister ID# : 2817901                      Test Start : 11/19/2019 @ 05:46  
Canister Type : Charcoal Canister 3 inch                      Test Stop : 11/21/2019 @ 06:01  
Location : 1st FL = Custodial Off.                      Received: 11/25/2019 @ 10:20  
Radon Level : 1.1 pCi/L                      Analyzed: 11/25/2019 @ 15:55  
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 2817902                      Test Start : 11/19/2019 @ 05:55  
Canister Type : Charcoal Canister 3 inch                      Test Stop : 11/21/2019 @ 05:59  
Location : 1st FL=Mod. 6                      Received: 11/25/2019 @ 10:20  
Radon Level : 0.7 pCi/L                      Analyzed: 11/25/2019 @ 16:29  
Error for Measurement is: ± 0.4 pCi/L



*Andreas C. George*

Andreas C. George  
Radon Measurement Specialist  
NJ MES 11089

*Dante Galan*

Dante Galan  
Laboratory Director

NRSB ARL0001  
NYS ELAP ID: 10806  
PADEP ID: 0346  
NJDEP ID: NY933  
NJ MEB 90036  
FL DOH RB1609  
IL RNL2000201

Site Radon Inspection Report

Date : 11/25/2019

Bryan Hogan / Ron Havnear  
 MEDFORD SCHOOL DISTRICT  
 815 South Oakdale Avenue  
 Medford, OR 97501-

Client: Jefferson E.S.

Test Location: 333 Holmes Avenue  
 Medford, OR 97501-

## Individual Canister Results

Canister ID# :	2817903	Test Start :	11/19/2019 @ 06:00
Canister Type :	Charcoal Canister 3 inch	Test Stop :	11/21/2019 @ 06:02
Location :	1st FL = Rm 29	Received:	11/25/2019 @ 10:20
Radon Level :	0.2 pCi/L	Analyzed:	11/25/2019 @ 15:55
Error for Measurement is: ±	0.3 pCi/L		


Canister ID# :	2817904	Test Start :	11/19/2019 @ 05:43
Canister Type :	Charcoal Canister 3 inch	Test Stop :	11/21/2019 @ 05:53
Location :	1st FL=Mod. 1 NE Off.	Received:	11/25/2019 @ 10:20
Radon Level :	0.1 pCi/L	Analyzed:	11/25/2019 @ 16:45
Error for Measurement is: ±	0.8 pCi/L		

Canister ID# :	2817906	Test Start :	11/19/2019 @ 05:42
Canister Type :	Charcoal Canister 3 inch	Test Stop :	11/21/2019 @ 05:55
Location :	1st FL = Cafeteria 2	Received:	11/25/2019 @ 10:20
Radon Level :	0.8 pCi/L	Analyzed:	11/25/2019 @ 16:07
Error for Measurement is: ±	0.4 pCi/L		

Canister ID# :	2817909	Test Start :	11/19/2019 @ 05:29
Canister Type :	Charcoal Canister 3 inch	Test Stop :	11/21/2019 @ 05:43
Location :	1st FL = Rm 26	Received:	11/25/2019 @ 10:20
Radon Level :	1.1 pCi/L	Analyzed:	11/26/2019 @ 10:31
Error for Measurement is: ±	0.4 pCi/L		

Canister ID# :	2817910	Test Start :	11/19/2019 @ 05:57
Canister Type :	Charcoal Canister 3 inch	Test Stop :	11/21/2019 @ 06:01
Location :	1st FL = Rm 27	Received:	11/25/2019 @ 10:20
Radon Level :	1.5 pCi/L	Analyzed:	11/25/2019 @ 16:07
Error for Measurement is: ±	0.4 pCi/L		

Canister ID# :	2817913	Test Start :	11/19/2019 @ 05:37
Canister Type :	Charcoal Canister 3 inch	Test Stop :	11/21/2019 @ 05:48
Location :	1st FL = Rm 9	Received:	11/25/2019 @ 10:20
Radon Level :	0.5 pCi/L	Analyzed:	11/25/2019 @ 15:50
Error for Measurement is: ±	0.4 pCi/L		

Andreas C. George  
 Radon Measurement Specialist  
 NJ MES 11089



Dante Galan  
 Laboratory Director

NRSB ARL0001  
 NYS ELAP ID: 10806  
 PADEP ID: 0346  
 NJDEP ID: NY933  
 NJ MEB 90036  
 FL DOH RB1609  
 IL RNL2000201



Site Radon Inspection Report

Date : 11/25/2019

Bryan Hogan / Ron Havnear  
MEDFORD SCHOOL DISTRICT  
815 South Oakdale Avenue  
Medford, OR 97501-

Client: Jefferson E.S.  
Test Location: 333 Holmes Avenue  
Medford, OR 97501-  
Individual Canister Results

Canister ID# :	2817916	Test Start :	11/19/2019 @ 05:44
Canister Type :	Charcoal Canister 3 inch	Test Stop :	11/21/2019 @ 05:48
Location :	1st FL = Rm 21	Received:	11/25/2019 @ 10:20
Radon Level :	1.5 pCi/L	Analyzed:	11/25/2019 @ 16:29
Error for Measurement is: ±	0.4 pCi/L		

Canister ID# :	2817917	Test Start :	11/19/2019 @ 06:02
Canister Type :	Charcoal Canister 3 inch	Test Stop :	11/21/2019 @ 06:04
Location :	1st FL = Rm 31	Received:	11/25/2019 @ 10:20
Radon Level :	0.1 pCi/L	Analyzed:	11/25/2019 @ 16:53
Error for Measurement is: ±	0.3 pCi/L		

Canister ID# :	2817924	Test Start :	11/19/2019 @ 05:34
Canister Type :	Charcoal Canister 3 inch	Test Stop :	11/21/2019 @ 05:46
Location :	1st FL = Rm 28	Received:	11/25/2019 @ 10:20
Radon Level :	0.6 pCi/L	Analyzed:	11/25/2019 @ 16:24
Error for Measurement is: ±	0.4 pCi/L		

The results indicate that at least one testing device registered at or above the United States Environmental Protection Agency (EPA) action level of 4.0 picoCuries per liter of air (pCi/L). The EPA recommends mitigation if the average of two short-term tests taken in the lowest level of the building suitable for occupancy show radon levels that are equal to or greater than 4.0 pCi/L.

For information on how to reduce radon levels in your home, please review the EPA booklet: Consumer's Guide to Radon Reduction ([www.epa.gov/radon/pdfs/consguid.pdf](http://www.epa.gov/radon/pdfs/consguid.pdf)) and contact your state health department. The EPA maintains a radon information website, including copies of its publications, at [www.epa.gov/iaq/radon](http://www.epa.gov/iaq/radon).

**For New Jersey clients:** Please see the attached guidance document entitled Radon Testing and Mitigation: The Basics for further information.

**For New York clients:** If the radon level of one or more testing devices is equal to or exceeds 20 pCi/L please contact the New York State Department of Health, Bureau of Environmental Radiation Protection, for technical advice and assistance at 518-402-7556 or toll free 1-800-458-1158.



Andreas C. George  
Radon Measurement Specialist  
NJ MES 11089

Dante Galan  
Laboratory Director

NRSB ARL0001  
NYS ELAP ID: 10806  
PADEP ID: 0346  
NJDEP ID: NY933  
NJ MEB 90036  
FL DOH RB1609  
IL RNL2000201

Site Radon Inspection Report

Date : 11/25/2019

Bryan Hogan / Ron Havnear  
MEDFORD SCHOOL DISTRICT  
815 South Oakdale Avenue  
Medford, OR 97501-

Client: Jefferson E.S.  
Test Location: 333 Holmes Avenue  
Medford, OR 97501-  
Individual Canister Results

---

**PLEDGE OF ASSURED QUALITY**

All procedures used for generating this report are in complete accordance with the current EPA protocols for the analysis of radon in air (EPA 402-R-92-004). The analytical results relate only to the samples tested, in the condition received by the lab, and that calculations were based upon the information supplied by client. RTCA and its personnel do not assume responsibility or liability, collectively and individually, for analysis results when detectors have been improperly handled or placed by the consumer, nor does RTCA and its personnel accept responsibility for any financial or health consequences of subsequent action or lack of action, taken by the customer or it's consultants based on RTCA-provided results.



*Andreas C. George*

Andreas C. George  
Radon Measurement Specialist  
NJ MES 11089

*Dante Galan*

Dante Galan  
Laboratory Director

NRSB ARL0001  
NYS ELAP ID: 10806  
PADEP ID: 0346  
NJDEP ID: NY933  
NJ MEB 90036  
FL DOH RB1609  
IL RNL2000201