



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

April 05, 2022

Larry Anderson
Medford School District
815 S Oakdale Ave
Medford, OR 97501
TEL: 541-842-3646
FAX 541-842-1160

RE: 38-Kennedy 2022 Lead Testing

Order No.: 22030715

Dear Larry Anderson:

Neilson Research Corporation received 22 sample(s) on 3/15/2022 for the analyses presented in the following report.

The results relate only to the parameters tested or to the sample as received by the laboratory. This report shall not be reproduced except in full, without the written approval of Neilson Research Corporation. If you have any questions regarding these test results, please feel free to call.

Sincerely,
Neilson Research Corporation

Tamra Schmedemann
Senior Project Manager
245 S Grape St
Medford, OR 97501



Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Case Narrative

WO#: 22030715
Date: 4/5/2022

CLIENT: Medford School District

Project: 38-Kennedy 2022 Lead Testing

The analyses were performed according to the guidelines in the Neilson Research Corporation Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

Neilson Research Corporation certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 22030715

Date Reported: 4/5/2022

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: 22030715
Received Date: 3/15/2022 8:45:00 AM
Reported Date: 4/5/2022 12:05:00 PM

Sample Information:

Lab ID: 22030715-01 **Client Sample ID:** Health Room- DF
Collection Date: 3/15/2022 6:07:00 AM **Collected By:** Seth Barry
Matrix: Drinking Water **Sample Location:** Health Room- DF

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.99		0.515	ppb	1	3/26/2022	15.0	A

Lab ID: 22030715-02 **Client Sample ID:** Health Room- Sink
Collection Date: 3/15/2022 6:07:00 AM **Collected By:** Seth Barry
Matrix: Drinking Water **Sample Location:** Health Room- Sink

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.39		0.515	ppb	1	3/26/2022	15.0	A

Lab ID: 22030715-03 **Client Sample ID:** Health Room- RR Sink
Collection Date: 3/15/2022 6:07:00 AM **Collected By:** Seth Barry
Matrix: Drinking Water **Sample Location:** Health Room- RR Sink

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	3/26/2022	15.0	A

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 22030715
Date Reported: 4/5/2022

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: 22030715
Received Date: 3/15/2022 8:45:00 AM
Reported Date: 4/5/2022 12:05:00 PM

Sample Information:

Lab ID: 22030715-04 **Client Sample ID:** Main Office Women's RR (L) Sink
Collection Date: 3/15/2022 6:09:00 AM **Collected By:** Seth Barry
Matrix: Drinking Water **Sample Location:** Main Office Women's RR (L) Sink

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	3/26/2022	15.0	A

Lab ID: 22030715-05 **Client Sample ID:** Main Office Unisex RR (Rt) Sink
Collection Date: 3/15/2022 6:09:00 AM **Collected By:** Seth Barry
Matrix: Drinking Water **Sample Location:** Main Office Unisex RR (Rt) Sink

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	3/26/2022	15.0	A

Lab ID: 22030715-06 **Client Sample ID:** Main Office Conf Rm (Main) Sink
Collection Date: 3/15/2022 6:10:00 AM **Collected By:** Seth Barry
Matrix: Drinking Water **Sample Location:** Main Office Conf Rm (Main) Sink

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	3.94		0.515	ppb	1	3/26/2022	15.0	A

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 22030715
Date Reported: 4/5/2022

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: 22030715
Received Date: 3/15/2022 8:45:00 AM
Reported Date: 4/5/2022 12:05:00 PM

Sample Information:

Lab ID: 22030715-07 **Client Sample ID:** Main Office Conf Rm (Insta-Hot) Sink
Collection Date: 3/15/2022 6:10:00 AM **Collected By:** Seth Barry
Matrix: Drinking Water **Sample Location:** Main Office Conf Rm (Insta-Hot) Sink

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.681		0.515	ppb	1	3/26/2022	15.0	A

Lab ID: 22030715-08 **Client Sample ID:** Staff Brk Room (Rm 2) Sink
Collection Date: 3/15/2022 6:11:00 AM **Collected By:** Seth Barry
Matrix: Drinking Water **Sample Location:** Staff Brk Room (Rm 2) Sink

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.66		0.515	ppb	1	3/26/2022	15.0	A

Lab ID: 22030715-09 **Client Sample ID:** Girl's RR Outside Main Office (L) Sink
Collection Date: 3/15/2022 6:14:00 AM **Collected By:** Seth Barry
Matrix: Drinking Water **Sample Location:** Girl's RR Outside Main Office (L) Sink

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	4.81		0.515	ppb	1	3/26/2022	15.0	A

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 22030715
Date Reported: 4/5/2022

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: 22030715
Received Date: 3/15/2022 8:45:00 AM
Reported Date: 4/5/2022 12:05:00 PM

Sample Information:

Lab ID: 22030715-10 **Client Sample ID:** Girl's RR Outside Main Office (Ctr) Sink
Collection Date: 3/15/2022 6:14:00 AM **Collected By:** Seth Barry
Matrix: Drinking Water **Sample Location:** Girl's RR Outside Main Office (Ctr) Sink

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.795		0.515	ppb	1	3/26/2022	15.0	A

Lab ID: 22030715-11 **Client Sample ID:** Girl's RR Outside Main Office (R) Sink
Collection Date: 3/15/2022 6:14:00 AM **Collected By:** Seth Barry
Matrix: Drinking Water **Sample Location:** Girl's RR Outside Main Office (R) Sink

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	3.20		0.515	ppb	1	3/26/2022	15.0	A

Lab ID: 22030715-12 **Client Sample ID:** Boy's RR Outside Main Office (L) Sink
Collection Date: 3/15/2022 6:15:00 AM **Collected By:** Seth Barry
Matrix: Drinking Water **Sample Location:** Boy's RR Outside Main Office (L) Sink

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.673		0.515	ppb	1	3/26/2022	15.0	A

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 22030715
Date Reported: 4/5/2022

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: 22030715
Received Date: 3/15/2022 8:45:00 AM
Reported Date: 4/5/2022 12:05:00 PM

Sample Information:

Lab ID: 22030715-13 **Client Sample ID:** Boy's RR Outside Main Office (Ctr) Sink
Collection Date: 3/15/2022 6:15:00 AM **Collected By:** Seth Barry
Matrix: Drinking Water **Sample Location:** Boy's RR Outside Main Office (Ctr) Sink

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	3.61		0.515	ppb	1	3/26/2022	15.0	A

Lab ID: 22030715-14 **Client Sample ID:** Boy's RR Outside Main Office (R) Sink
Collection Date: 3/15/2022 6:15:00 AM **Collected By:** Seth Barry
Matrix: Drinking Water **Sample Location:** Boy's RR Outside Main Office (R) Sink

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	8.53		0.515	ppb	1	3/26/2022	15.0	A

Lab ID: 22030715-15 **Client Sample ID:** Music Room DF
Collection Date: 3/15/2022 6:20:00 AM **Collected By:** Seth Barry
Matrix: Drinking Water **Sample Location:** Music Room DF

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	2.00		0.515	ppb	1	3/26/2022	15.0	A

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 22030715
Date Reported: 4/5/2022

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: 22030715
Received Date: 3/15/2022 8:45:00 AM
Reported Date: 4/5/2022 12:05:00 PM

Sample Information:

Lab ID: 22030715-16 **Client Sample ID:** Music Room Sink
Collection Date: 3/15/2022 6:20:00 AM **Collected By:** Seth Barry
Matrix: Drinking Water **Sample Location:** Music Room Sink

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.66		0.515	ppb	1	3/26/2022	15.0	A

Lab ID: 22030715-17 **Client Sample ID:** Hallway in Front of Music Room- DF
Collection Date: 3/15/2022 6:20:00 AM **Collected By:** Seth Barry
Matrix: Drinking Water **Sample Location:** Hallway in Front of Music Room- DF

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.08		0.515	ppb	1	3/26/2022	15.0	A

Lab ID: 22030715-18 **Client Sample ID:** Boy's RR in Music Room Hallway- Sink (L)
Collection Date: 3/15/2022 6:21:00 AM **Collected By:** Seth Barry
Matrix: Drinking Water **Sample Location:** Boy's RR in Music Room Hallway- Sink (L)

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.02		0.515	ppb	1	3/26/2022	15.0	A

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 22030715

Date Reported: 4/5/2022

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: 22030715
Received Date: 3/15/2022 8:45:00 AM
Reported Date: 4/5/2022 12:05:00 PM

Sample Information:

Lab ID: 22030715-19 **Client Sample ID:** Boy's RR in Music Room Hallway- Sink (R)
Collection Date: 3/15/2022 6:21:00 AM **Collected By:** Seth Barry
Matrix: Drinking Water **Sample Location:** Boy's RR in Music Room Hallway- Sink (R)

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	6.65		0.515	ppb	1	3/26/2022	15.0	A

Lab ID: 22030715-20 **Client Sample ID:** Girl's RR Sink in Music Rm Hallway
Collection Date: 3/15/2022 6:22:00 AM **Collected By:** Seth Barry
Matrix: Drinking Water **Sample Location:** Girl's RR Sink in Music Rm Hallway

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.515	ppb	1	3/26/2022	15.0	A

Lab ID: 22030715-21 **Client Sample ID:** Room 7 B- DF
Collection Date: 3/15/2022 6:24:00 AM **Collected By:** Seth Barry
Matrix: Drinking Water **Sample Location:** Room 7 B- DF

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	1.13		0.515	ppb	1	4/4/2022	15.0	A

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 22030715
Date Reported: 4/5/2022

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: 22030715
Received Date: 3/15/2022 8:45:00 AM
Reported Date: 4/5/2022 12:05:00 PM

Sample Information:

Lab ID: 22030715-22 **Client Sample ID:** Room 7 B- Sink
Collection Date: 3/15/2022 6:24:00 AM **Collected By:** Seth Barry
Matrix: Drinking Water **Sample Location:** Room 7 B- Sink

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.794		0.515	ppb	1	4/4/2022	15.0	A

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

NELAP NELAP A Accredited in accordance with NELAP ORELAP 100016, OR-028

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

QC SUMMARY REPORT

WO#: 22030715
05-Apr-22

Client: Medford School District
Project: 38-Kennedy 2022 Lead Testing

TestCode: LEAD_DW

Sample ID: MB-16085	SampType: MBLK	TestCode: LEAD_DW	Units: ppb	Prep Date: 3/17/2022	RunNo: 28717
Client ID: PBW	Batch ID: 16085	TestNo: E200.8	E200.8	Analysis Date: 3/26/2022	SeqNo: 467194
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead ND 0.515

Sample ID: LCS-16085	SampType: LCS	TestCode: LEAD_DW	Units: ppb	Prep Date: 3/17/2022	RunNo: 28717
Client ID: LCSW	Batch ID: 16085	TestNo: E200.8	E200.8	Analysis Date: 3/26/2022	SeqNo: 467195
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead 99.0 0.520 100 0 99.0 85 115

Sample ID: 22030715-20AMS	SampType: MS	TestCode: LEAD_DW	Units: ppb	Prep Date: 3/17/2022	RunNo: 28717
Client ID: Girl's RR Sink in Mu	Batch ID: 16085	TestNo: E200.8	E200.8	Analysis Date: 3/26/2022	SeqNo: 467218
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead 98.7 0.520 100 0.228 98.5 70 130

Sample ID: 22030715-20AMSD	SampType: MSD	TestCode: LEAD_DW	Units: ppb	Prep Date: 3/17/2022	RunNo: 28717
Client ID: Girl's RR Sink in Mu	Batch ID: 16085	TestNo: E200.8	E200.8	Analysis Date: 3/26/2022	SeqNo: 467219
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead 95.8 0.520 100 0.228 95.6 70 130 98.7 2.98 20

Qualifiers: CI Sample container temperature is out of limit as specified at testcode H Holding times for preparation or analysis exceeded MI Recovery outside control limits due to Matrix Int
ND Not Detected at the Reporting Limit PL Permit Limit RL Reporting Detection Limit

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

QC SUMMARY REPORT

WO#: 22030715
05-Apr-22

Client: Medford School District
Project: 38-Kennedy 2022 Lead Testing

TestCode: LEAD_DW

Sample ID: MB-16087	SampType: MBLK	TestCode: LEAD_DW	Units: ppb	Prep Date: 3/17/2022	RunNo: 28881
Client ID: PBW	Batch ID: 16087	TestNo: E200.8	E200.8	Analysis Date: 4/4/2022	SeqNo: 470804
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead	ND	0.515			
------	----	-------	--	--	--

Sample ID: LCS-16087	SampType: LCS	TestCode: LEAD_DW	Units: ppb	Prep Date: 3/17/2022	RunNo: 28881
Client ID: LCSW	Batch ID: 16087	TestNo: E200.8	E200.8	Analysis Date: 4/4/2022	SeqNo: 470805
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead	100	0.520	100	0	100	85	115		
------	-----	-------	-----	---	-----	----	-----	--	--

Sample ID: 22030719-34AMS	SampType: MS	TestCode: LEAD_DW	Units: ppb	Prep Date: 3/17/2022	RunNo: 28881
Client ID: BatchQC	Batch ID: 16087	TestNo: E200.8	E200.8	Analysis Date: 4/4/2022	SeqNo: 470824
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead	103	0.520	100	1.18	102	70	130		
------	-----	-------	-----	------	-----	----	-----	--	--

Sample ID: 22030719-34AMSD	SampType: MSD	TestCode: LEAD_DW	Units: ppb	Prep Date: 3/17/2022	RunNo: 28881
Client ID: BatchQC	Batch ID: 16087	TestNo: E200.8	E200.8	Analysis Date: 4/4/2022	SeqNo: 470825
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead	101	0.520	100	1.18	100	70	130	103	1.40	20
------	-----	-------	-----	------	-----	----	-----	-----	------	----

Qualifiers: CI Sample container temperature is out of limit as specified at testcode H Holding times for preparation or analysis exceeded MI Recovery outside control limits due to Matrix Int
ND Not Detected at the Reporting Limit PL Permit Limit RL Reporting Detection Limit

Original

Sample Log-In Check List

Client Name: **MedfordSchoolDist**

Work Order Number: **22030715**

RcptNo: **1**

Logged by: **Dorie Maier** **3/15/2022 8:45:00 AM**

Completed By: **Katherine Root** **3/17/2022 11:38:51 AM**

Reviewed By: **Tamra Schmedemann** **4/5/2022 11:59:31 AM**

Dorie Maier

Katherine Root

Tamra Schmedemann

Chain of Custody

1. Is Chain of Custody complete? Yes ☒ No ☐ Not Present ☐
2. How was the sample delivered? Client

Log In

3. Coolers are present? Yes ☐ No ☐ NA ☒
4. Shipping container/cooler in good condition? Yes ☒ No ☐
Custody seals intact on shipping container/cooler? Yes ☐ No ☐ Not Present ☒
No. Seal Date: Signed By:
5. Was an attempt made to cool the samples? Yes ☒ No ☐ NA ☐
6. Were all samples received at a temperature of $>0^{\circ}\text{C}$ to 6.0°C ? Yes ☒ No ☐ NA ☐
7. Sample(s) in proper container(s)? Yes ☒ No ☐
8. Sufficient sample volume for indicated test(s)? Yes ☒ No ☐
9. Are samples (except VOA and ONG) properly preserved? Yes ☒ No ☐
10. Was preservative added to bottles? Yes ☒ No ☐ NA ☐
HNO₃ pH<2
11. Is the headspace in the VOA vials less than 1/4 inch or 6 mm? Yes ☐ No ☐ No VOA Vials ☒
12. Were any sample containers received broken? Yes ☐ No ☒
13. Does paperwork match bottle labels? Yes ☒ No ☐
(Note discrepancies on chain of custody)
14. Are matrices correctly identified on Chain of Custody? Yes ☒ No ☐
15. Is it clear what analyses were requested? Yes ☒ No ☐
16. Were all holding times able to be met? Yes ☒ No ☐
(If no, notify customer for authorization.)

Special Handling (if applicable)

17. Was client notified of all discrepancies with this order? Yes ☐ No ☐ NA ☒

Person Notified: Date
By Whom: Via: ☐ eMail ☐ Phone ☐ Fax ☐ In Person
Regarding:
Client Instructions:

18. Additional remarks:

Cooler Information

Cooler No	Temp °C	Condition	Seal Intact	Seal No	Seal Date	Signed By
-----------	---------	-----------	-------------	---------	-----------	-----------




Chain of Custody Record

Page 1 of 3

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Section A

Required Client Information

Company: MSD 549C	
Address: 815 South Oakdale Avenue	
Medford, OR 97501	
Email: Seth.barry@medford.k12.or.us	
Phone: 541-840-4315 Fax:	
Collected By (Print): <u>SETH BARRY</u>	
Collected By (Sign): 	
Email Report <input type="checkbox"/> Yes <input type="checkbox"/> No	Mail Report <input type="checkbox"/> Yes <input type="checkbox"/> No
Fax Report <input type="checkbox"/> Yes <input type="checkbox"/> No	

Section B

Required Project Information

Project Name:	2022 Lead Testing
Project Number:	38-Kennedy
Report	larry.anderson@medford.k12.or
Copy To	andy.chasteen@medford.k12.or

Section C
Invoice Information

Attention: Accounting
Company Name: Medford School District
Address: 815 South Oakdale Avenue
Medford, OR 97501
P.O. #P123000

Section D
Rush Status (Subject to Scheduling)

_____	Standard 10-14 Days	
_____	5 Business Days (50% surcharge)	
_____	3 Business Days (75% surcharge)	
_____	24 - 48 hours (100% surcharge)	
_____	Other _____	
_____	Authorized _____	Yes _____ No _____

Section E

Sample Information

[illegible]

[illegible]

Warranty and Limits of Liability: In accepting analytical work, we warrant the accuracy of test results for the sample as submitted. The foregoing express warranty is exclusive and is given in lieu of all other warranties, expressed or implied. We disclaim any other warranties, expressed or implied, including a Warranty of Fitness for Particular Purpose and Warranty of Merchantability. We accept no legal responsibility for the purposes for