

Site Radon Inspection Report

Date : 04/04/2022

Seth Barry / Andy Chasteen
MEDFORD SCHOOL DISTRICT
815 South Oakdale Avenue
Room 214
Medford, OR 97501-

Client: Kennedy E.S.
Test Location: 2860 North Keeneway Drive
Medford, OR 97504-

Individual Canister Results

Canister ID# : 2901038 Test Start : 03/29/2022 @ 06:26
Canister Type : Charcoal Canister 3 inch Test Stop : 03/31/2022 @ 06:33
Location : 1st FL= Rm 08 Received: 04/04/2022 @ 09:38
Radon Level : 0.1 pCi/L Analyzed: 04/05/2022 @ 10:41
Error for Measurement is: \pm 0.3 pCi/L

Canister ID# : 2913687 Test Start : 03/29/2022 @ 06:00
Canister Type : Charcoal Canister 3 inch Test Stop : 03/31/2022 @ 06:19
Location : 1st FL=Staff Work Rm Received: 04/04/2022 @ 09:38
Radon Level : 0.1 pCi/L Analyzed: 04/04/2022 @ 09:46
Error for Measurement is: \pm 0.3 pCi/L

Canister ID# : 2916031 Test Start : 03/29/2022 @ 06:19
Canister Type : Charcoal Canister 3 inch Test Stop : 03/31/2022 @ 06:25
Location : 1st FL=Gym 3 Received: 04/04/2022 @ 09:38
Radon Level : 0.1 pCi/L Analyzed: 04/04/2022 @ 09:46
Error for Measurement is: \pm 0.6 pCi/L

Canister ID# : 2916051 Test Start : 03/29/2022 @ 06:17
Canister Type : Charcoal Canister 3 inch Test Stop : 03/31/2022 @ 06:24
Location : 1st FL=Gym 2 Received: 04/04/2022 @ 09:38
Radon Level : 0.1 pCi/L Analyzed: 04/04/2022 @ 10:02
Error for Measurement is: \pm 0.8 pCi/L

Canister ID# : 2916530 Test Start : 03/29/2022 @ 06:37
Canister Type : Charcoal Canister 3 inch Test Stop : 03/31/2022 @ 06:40
Location : 1st FL= Rm 15 Received: 04/04/2022 @ 09:38
Radon Level : 0.1 pCi/L Analyzed: 04/05/2022 @ 09:51
Error for Measurement is: \pm 0.4 pCi/L

Canister ID# : 2916571 Test Start : 03/29/2022 @ 06:23
Canister Type : Charcoal Canister 3 inch Test Stop : 03/31/2022 @ 06:29
Location : 1st FL=Music Rm Received: 04/04/2022 @ 09:38
Radon Level : 0.3 pCi/L Analyzed: 04/04/2022 @ 10:02
Error for Measurement is: \pm 0.3 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 04/04/2022

Seth Barry / Andy Chasteen
MEDFORD SCHOOL DISTRICT
815 South Oakdale Avenue
Room 214
Medford, OR 97501-

Client: Kennedy E.S.
Test Location: 2860 North Keeneway Drive
Medford, OR 97504-

Individual Canister Results

Canister ID# : 2916590 Test Start : 03/29/2022 @ 06:34
Canister Type : Charcoal Canister 3 inch Test Stop : 03/31/2022 @ 06:48
Location : 1st FL= Rm 24 Received: 04/04/2022 @ 09:38
Radon Level : 0.1 pCi/L Analyzed: 04/04/2022 @ 09:59
Error for Measurement is: \pm 2.0 pCi/L

Canister ID# : 2916920 Test Start : 03/29/2022 @ 05:55
Canister Type : Charcoal Canister 3 inch Test Stop : 03/31/2022 @ 06:17
Location : 1st FL= Rm 04 Received: 04/04/2022 @ 09:38
Radon Level : 0.1 pCi/L Analyzed: 04/04/2022 @ 09:59
Error for Measurement is: \pm 0.5 pCi/L

Canister ID# : 2917597 Test Start : 03/29/2022 @ 05:59
Canister Type : Charcoal Canister 3 inch Test Stop : 03/31/2022 @ 06:18
Location : 1st FL=Principal's Off. Received: 04/04/2022 @ 09:38
Radon Level : 0.2 pCi/L Analyzed: 04/04/2022 @ 09:46
Error for Measurement is: \pm 0.4 pCi/L

Canister ID# : 2917605 Test Start : 03/29/2022 @ 06:25
Canister Type : Charcoal Canister 3 inch Test Stop : 03/31/2022 @ 06:32
Location : 1st FL= Rm 09 Received: 04/04/2022 @ 09:38
Radon Level : 0.1 pCi/L Analyzed: 04/05/2022 @ 09:50
Error for Measurement is: \pm 0.3 pCi/L

Canister ID# : 2917613 Test Start : 03/29/2022 @ 06:29
Canister Type : Charcoal Canister 3 inch Test Stop : 03/31/2022 @ 06:35
Location : 1st FL= Rm 25 BL Received: 04/04/2022 @ 09:38
Radon Level : 0.1 pCi/L Analyzed: 04/04/2022 @ 09:27
Error for Measurement is: \pm 0.2 pCi/L

Canister ID# : 2917617 Test Start : 03/29/2022 @ 05:55
Canister Type : Charcoal Canister 3 inch Test Stop : 03/31/2022 @ 06:16
Location : 1st FL=Health Rm Received: 04/04/2022 @ 09:38
Radon Level : 0.1 pCi/L Analyzed: 04/05/2022 @ 10:47
Error for Measurement is: \pm 0.5 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 04/04/2022

Seth Barry / Andy Chasteen
MEDFORD SCHOOL DISTRICT
815 South Oakdale Avenue
Room 214
Medford, OR 97501-

Client: Kennedy E.S.
Test Location: 2860 North Keeneway Drive
Medford, OR 97504-

Individual Canister Results

Canister ID# : 2917623 Test Start : 03/29/2022 @ 05:54
Canister Type : Charcoal Canister 3 inch Test Stop : 03/31/2022 @ 06:15
Location : 1st FL= Rm 03 Received: 04/04/2022 @ 09:38
Radon Level : 0.1 pCi/L Analyzed: 04/05/2022 @ 10:31
Error for Measurement is: ± 0.3 pCi/L

Canister ID# : 2917637 Test Start : 03/29/2022 @ 06:00
Canister Type : Charcoal Canister 3 inch Test Stop : 03/31/2022 @ 06:00
Location : 1st FL= Rm 02 Received: 04/04/2022 @ 09:38
Radon Level : 18.5 pCi/L Analyzed: 04/05/2022 @ 09:32
Error for Measurement is: ± 0.8 pCi/L

Canister ID# : 2917650 Test Start : 03/29/2022 @ 05:58
Canister Type : Charcoal Canister 3 inch Test Stop : 03/31/2022 @ 06:19
Location : 1st FL= Rm 06 Received: 04/04/2022 @ 09:38
Radon Level : 0.1 pCi/L Analyzed: 04/04/2022 @ 09:09
Error for Measurement is: ± 0.7 pCi/L

Canister ID# : 2918195 Test Start : 03/29/2022 @ 06:22
Canister Type : Charcoal Canister 3 inch Test Stop : 03/31/2022 @ 06:30
Location : 1st FL= Rm 10 DP Received: 04/04/2022 @ 09:38
Radon Level : 0.1 pCi/L Analyzed: 04/04/2022 @ 09:25
Error for Measurement is: ± 0.3 pCi/L

Canister ID# : 2918232 Test Start : 03/29/2022 @ 06:21
Canister Type : Charcoal Canister 3 inch Test Stop : 03/31/2022 @ 06:28
Location : 1st FL=Stage DP Received: 04/04/2022 @ 09:38
Radon Level : 0.1 pCi/L Analyzed: 04/04/2022 @ 09:59
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 2918235 Test Start : 03/29/2022 @ 06:00
Canister Type : Charcoal Canister 3 inch Test Stop : 03/31/2022 @ 06:00
Location : 1st FL= Rm 01 Received: 04/04/2022 @ 09:38
Radon Level : 17.3 pCi/L Analyzed: 04/05/2022 @ 09:32
Error for Measurement is: ± 0.8 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 04/04/2022

Seth Barry / Andy Chasteen
MEDFORD SCHOOL DISTRICT
815 South Oakdale Avenue
Room 214
Medford, OR 97501-

Client: Kennedy E.S.
Test Location: 2860 North Keeneway Drive
Medford, OR 97504-

Individual Canister Results

Canister ID# : 2918237 Test Start : 03/29/2022 @ 06:21
Canister Type : Charcoal Canister 3 inch Test Stop : 03/31/2022 @ 06:28
Location : 1st FL=Stage DP Received: 04/04/2022 @ 09:38
Radon Level : 0.1 pCi/L Analyzed: 04/04/2022 @ 09:59
Error for Measurement is: \pm 0.2 pCi/L

Canister ID# : 2918241 Test Start : 03/29/2022 @ 05:57
Canister Type : Charcoal Canister 3 inch Test Stop : 03/31/2022 @ 06:17
Location : 1st FL= Rm 05 DP Received: 04/04/2022 @ 09:38
Radon Level : 0.1 pCi/L Analyzed: 04/05/2022 @ 10:05
Error for Measurement is: \pm 0.3 pCi/L

Canister ID# : 2918273 Test Start : 03/29/2022 @ 06:32
Canister Type : Charcoal Canister 3 inch Test Stop : 03/31/2022 @ 06:45
Location : 1st FL= Rm 27 DP Received: 04/04/2022 @ 09:38
Radon Level : 0.3 pCi/L Analyzed: 04/05/2022 @ 10:05
Error for Measurement is: \pm 0.4 pCi/L

Canister ID# : 2989187 Test Start : 03/29/2022 @ 06:09
Canister Type : Charcoal Canister 3 inch Test Stop : 03/31/2022 @ 06:23
Location : 1st FL=Computer Rm BL Received: 04/04/2022 @ 09:38
Radon Level : 0.2 pCi/L Analyzed: 04/04/2022 @ 09:27
Error for Measurement is: \pm 0.4 pCi/L

Canister ID# : 2989215 Test Start : 03/29/2022 @ 06:20
Canister Type : Charcoal Canister 3 inch Test Stop : 03/31/2022 @ 06:31
Location : 1st FL=Cafeteria 1 Received: 04/04/2022 @ 09:38
Radon Level : 0.2 pCi/L Analyzed: 04/05/2022 @ 10:33
Error for Measurement is: \pm 0.5 pCi/L

Canister ID# : 2989244 Test Start : 03/29/2022 @ 06:35
Canister Type : Charcoal Canister 3 inch Test Stop : 03/31/2022 @ 06:38
Location : 1st FL= Rm 12 Received: 04/04/2022 @ 09:38
Radon Level : 0.1 pCi/L Analyzed: 04/05/2022 @ 10:07
Error for Measurement is: \pm 0.4 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 04/04/2022

Seth Barry / Andy Chasteen
MEDFORD SCHOOL DISTRICT
815 South Oakdale Avenue
Room 214
Medford, OR 97501-

Client: Kennedy E.S.
Test Location: 2860 North Keeneway Drive
Medford, OR 97504-

Individual Canister Results

Canister ID# : 2989245 Test Start : 03/29/2022 @ 06:12
Canister Type : Charcoal Canister 3 inch Test Stop : 03/31/2022 @ 06:24
Location : 1st FL= Rm 23 DP Received: 04/04/2022 @ 09:38
Radon Level : 0.1 pCi/L Analyzed: 04/05/2022 @ 10:44
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 2989258 Test Start : 03/29/2022 @ 06:05
Canister Type : Charcoal Canister 3 inch Test Stop : 03/31/2022 @ 06:20
Location : 1st FL=Media Ctr 2 DP Received: 04/04/2022 @ 09:38
Radon Level : 0.2 pCi/L Analyzed: 04/04/2022 @ 09:25
Error for Measurement is: ± 0.3 pCi/L

Canister ID# : 2989264 Test Start : 03/29/2022 @ 06:30
Canister Type : Charcoal Canister 3 inch Test Stop : 03/31/2022 @ 06:34
Location : 1st FL=Off. by Gym Received: 04/04/2022 @ 09:38
Radon Level : 0.1 pCi/L Analyzed: 04/04/2022 @ 09:46
Error for Measurement is: ± 0.3 pCi/L

Canister ID# : 2989275 Test Start : 03/29/2022 @ 06:24
Canister Type : Charcoal Canister 3 inch Test Stop : 03/31/2022 @ 06:31
Location : 1st FL=Rm S of Music Rm Received: 04/04/2022 @ 09:38
Radon Level : 0.1 pCi/L Analyzed: 04/05/2022 @ 10:47
BLANK

Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 2989276 Test Start : 03/29/2022 @ 06:05
Canister Type : Charcoal Canister 3 inch Test Stop : 03/31/2022 @ 06:21
Location : 1st FL=Staff Break Rm Received: 04/04/2022 @ 09:38
Radon Level : 0.2 pCi/L Analyzed: 04/04/2022 @ 10:02
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2989282 Test Start : 03/29/2022 @ 06:21
Canister Type : Charcoal Canister 3 inch Test Stop : 03/31/2022 @ 06:30
Location : 1st FL=Cafeteria 2 DP Received: 04/04/2022 @ 09:38
Radon Level : 0.4 pCi/L Analyzed: 04/04/2022 @ 09:41



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 04/04/2022

Seth Barry / Andy Chasteen
MEDFORD SCHOOL DISTRICT
815 South Oakdale Avenue
Room 214
Medford, OR 97501-

Client: Kennedy E.S.
Test Location: 2860 North Keeneway Drive
Medford, OR 97504-

Individual Canister Results

DETECTOR MOVED OVER (6) FEET

Error for Measurement is: \pm 0.4 pCi/L

Canister ID# :	2989293	Test Start :	03/29/2022 @ 06:29
Canister Type :	Charcoal Canister 3 inch	Test Stop :	03/31/2022 @ 06:35
Location :	1st FL= Rm 14	Received:	04/04/2022 @ 09:38
Radon Level :	0.1 pCi/L	Analyzed:	04/04/2022 @ 09:41
Error for Measurement is: \pm	0.6 pCi/L		

Canister ID# :	2989944	Test Start :	03/29/2022 @ 06:16
Canister Type :	Charcoal Canister 3 inch	Test Stop :	03/31/2022 @ 06:27
Location :	1st FL= Rm 28 DP	Received:	04/04/2022 @ 09:38
Radon Level :	0.3 pCi/L	Analyzed:	04/05/2022 @ 09:11
Error for Measurement is: \pm	0.4 pCi/L		

Canister ID# :	2989948	Test Start :	03/29/2022 @ 06:00
Canister Type :	Charcoal Canister 3 inch	Test Stop :	03/31/2022 @ 06:20
Location :	1st FL=Staff Work Rm BL	Received:	04/04/2022 @ 09:38
Radon Level :	0.4 pCi/L	Analyzed:	04/05/2022 @ 10:05
Error for Measurement is: \pm	0.4 pCi/L		

Canister ID# :	2989950	Test Start :	03/29/2022 @ 05:54
Canister Type :	Charcoal Canister 3 inch	Test Stop :	03/31/2022 @ 06:15
Location :	1st FL=Main Office DP	Received:	04/04/2022 @ 09:38
Radon Level :	0.6 pCi/L	Analyzed:	04/05/2022 @ 10:31
Error for Measurement is: \pm	0.4 pCi/L		

Canister ID# :	2989953	Test Start :	03/29/2022 @ 06:26
Canister Type :	Charcoal Canister 3 inch	Test Stop :	03/31/2022 @ 06:33
Location :	1st FL=NW Rm in Caf.	Received:	04/04/2022 @ 09:38
Radon Level :	0.5 pCi/L	Analyzed:	04/05/2022 @ 10:07
Error for Measurement is: \pm	0.5 pCi/L		



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 04/04/2022

Seth Barry / Andy Chasteen
MEDFORD SCHOOL DISTRICT
815 South Oakdale Avenue
Room 214
Medford, OR 97501-

Client: Kennedy E.S.
Test Location: 2860 North Keeneway Drive
Medford, OR 97504-

Individual Canister Results

Canister ID# : 2989956 Test Start : 03/29/2022 @ 06:22
Canister Type : Charcoal Canister 3 inch Test Stop : 03/31/2022 @ 06:30
Location : 1st FL= Rm 10 DP Received: 04/04/2022 @ 09:38
Radon Level : 0.3 pCi/L Analyzed: 04/05/2022 @ 10:44
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2989958 Test Start : 03/29/2022 @ 06:15
Canister Type : Charcoal Canister 3 inch Test Stop : 03/31/2022 @ 06:23
Location : 1st FL=Gym 1 Received: 04/04/2022 @ 09:38
Radon Level : 1.3 pCi/L Analyzed: 04/05/2022 @ 09:51
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 2989960 Test Start : 03/29/2022 @ 06:31
Canister Type : Charcoal Canister 3 inch Test Stop : 03/31/2022 @ 06:37
Location : 1st FL= Rm 13 DP Received: 04/04/2022 @ 09:38
Radon Level : 0.6 pCi/L Analyzed: 04/05/2022 @ 10:07
Error for Measurement is: ± 0.6 pCi/L

Canister ID# : 2989961 Test Start : 03/29/2022 @ 06:20
Canister Type : Charcoal Canister 3 inch Test Stop : 03/31/2022 @ 06:26
Location : 1st FL= Rm 29 BL Received: 04/04/2022 @ 09:38
Radon Level : 0.1 pCi/L Analyzed: 04/05/2022 @ 10:10
Error for Measurement is: ± 0.3 pCi/L

Canister ID# : 2989963 Test Start : 03/29/2022 @ 05:54
Canister Type : Charcoal Canister 3 inch Test Stop : 03/31/2022 @ 06:15
Location : 1st FL=Main Office DP Received: 04/04/2022 @ 09:38
Radon Level : 0.1 pCi/L Analyzed: 04/05/2022 @ 09:50
Error for Measurement is: ± 0.2 pCi/L

Canister ID# : 2989964 Test Start : 03/29/2022 @ 06:21
Canister Type : Charcoal Canister 3 inch Test Stop : 03/31/2022 @ 06:30
Location : 1st FL=Cafeteria 2 DP Received: 04/04/2022 @ 09:38
Radon Level : 0.2 pCi/L Analyzed: 04/05/2022 @ 10:47
DETECTOR MOVED OVER (6) FEET



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 04/04/2022

Seth Barry / Andy Chasteen
MEDFORD SCHOOL DISTRICT
815 South Oakdale Avenue
Room 214
Medford, OR 97501-

Client: Kennedy E.S.
Test Location: 2860 North Keeneway Drive
Medford, OR 97504-

Individual Canister Results

Error for Measurement is: \pm 0.3 pCi/L

Canister ID# :	2989969	Test Start :	03/29/2022 @ 05:58
Canister Type :	Charcoal Canister 3 inch	Test Stop :	03/31/2022 @ 06:19
Location :	1st FL= Rm 18	Received:	04/04/2022 @ 09:38
Radon Level :	0.2 pCi/L	Analyzed:	04/05/2022 @ 10:08
Error for Measurement is: \pm	0.3 pCi/L		

Canister ID# :	2989971	Test Start :	03/29/2022 @ 06:08
Canister Type :	Charcoal Canister 3 inch	Test Stop :	03/31/2022 @ 06:22
Location :	1st FL=Amy's Closet	Received:	04/04/2022 @ 09:38
Radon Level :	0.4 pCi/L	Analyzed:	04/04/2022 @ 10:02
Error for Measurement is: \pm	0.4 pCi/L		

Canister ID# :	2989972	Test Start :	03/29/2022 @ 06:05
Canister Type :	Charcoal Canister 3 inch	Test Stop :	03/31/2022 @ 06:20
Location :	1st FL=Media Ctr 2 DP	Received:	04/04/2022 @ 09:38
Radon Level :	0.4 pCi/L	Analyzed:	04/05/2022 @ 09:11
Error for Measurement is: \pm	0.4 pCi/L		

Canister ID# :	2989973	Test Start :	03/29/2022 @ 06:27
Canister Type :	Charcoal Canister 3 inch	Test Stop :	03/31/2022 @ 06:33
Location :	1st FL= Rm 08 BL	Received:	04/04/2022 @ 09:38
Radon Level :	0.2 pCi/L	Analyzed:	04/05/2022 @ 10:33
Error for Measurement is: \pm	0.4 pCi/L		

Canister ID# :	2989976	Test Start :	03/29/2022 @ 06:14
Canister Type :	Charcoal Canister 3 inch	Test Stop :	03/31/2022 @ 06:27
Location :	1st FL= Rm 22	Received:	04/04/2022 @ 09:38
Radon Level :	0.3 pCi/L	Analyzed:	04/05/2022 @ 10:31
Error for Measurement is: \pm	0.5 pCi/L		

Canister ID# :	2989977	Test Start :	03/29/2022 @ 06:02
Canister Type :	Charcoal Canister 3 inch	Test Stop :	03/31/2022 @ 06:20
Location :	1st FL= Rm 17 DP	Received:	04/04/2022 @ 09:38
Radon Level :	0.3 pCi/L	Analyzed:	04/05/2022 @ 09:50



Andreas C. George

Dante Galan

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 04/04/2022

Seth Barry / Andy Chasteen
MEDFORD SCHOOL DISTRICT
815 South Oakdale Avenue
Room 214
Medford, OR 97501-

Client: Kennedy E.S.
Test Location: 2860 North Keeneway Drive
Medford, OR 97504-

Individual Canister Results

Error for Measurement is: \pm 0.4 pCi/L

Canister ID# :	2989979	Test Start :	03/29/2022 @ 05:55
Canister Type :	Charcoal Canister 3 inch	Test Stop :	03/31/2022 @ 06:18
Location :	1st FL= Rm 19 BL	Received:	04/04/2022 @ 09:38
Radon Level :	0.4 pCi/L	Analyzed:	04/05/2022 @ 10:07
Error for Measurement is: \pm	0.4 pCi/L		

Canister ID# :	2989982	Test Start :	03/29/2022 @ 06:31
Canister Type :	Charcoal Canister 3 inch	Test Stop :	03/31/2022 @ 06:37
Location :	1st FL= Rm 13 DP	Received:	04/04/2022 @ 09:38
Radon Level :	0.2 pCi/L	Analyzed:	04/04/2022 @ 09:41
Error for Measurement is: \pm	0.4 pCi/L		

Canister ID# :	2989983	Test Start :	03/29/2022 @ 06:12
Canister Type :	Charcoal Canister 3 inch	Test Stop :	03/31/2022 @ 06:22
Location :	1st FL=Lactation Rm	Received:	04/04/2022 @ 09:38
Radon Level :	0.1 pCi/L	Analyzed:	04/05/2022 @ 10:05
Error for Measurement is: \pm	0.4 pCi/L		

Canister ID# :	2989985	Test Start :	03/29/2022 @ 06:31
Canister Type :	Charcoal Canister 3 inch	Test Stop :	03/31/2022 @ 06:44
Location :	1st FL= Rm 26	Received:	04/04/2022 @ 09:38
Radon Level :	0.2 pCi/L	Analyzed:	04/04/2022 @ 09:11
Error for Measurement is: \pm	0.4 pCi/L		

Canister ID# :	2989986	Test Start :	03/29/2022 @ 06:30
Canister Type :	Charcoal Canister 3 inch	Test Stop :	03/31/2022 @ 06:32
Location :	1st FL=Assit. Principal	Received:	04/04/2022 @ 09:38
Radon Level :	0.3 pCi/L	Analyzed:	04/04/2022 @ 09:09
Error for Measurement is: \pm	0.4 pCi/L		

Canister ID# :	2989990	Test Start :	03/29/2022 @ 06:19
Canister Type :	Charcoal Canister 3 inch	Test Stop :	03/31/2022 @ 06:26
Location :	1st FL= Rm 29	Received:	04/04/2022 @ 09:38
Radon Level :	0.6 pCi/L	Analyzed:	04/05/2022 @ 08:57



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 04/04/2022

Seth Barry / Andy Chasteen
MEDFORD SCHOOL DISTRICT
815 South Oakdale Avenue
Room 214
Medford, OR 97501-

Client: Kennedy E.S.
Test Location: 2860 North Keeneway Drive
Medford, OR 97504-

Individual Canister Results

Error for Measurement is: \pm 0.4 pCi/L

Canister ID# :	2989993	Test Start :	03/29/2022 @ 06:12
Canister Type :	Charcoal Canister 3 inch	Test Stop :	03/31/2022 @ 06:24
Location :	1st FL= Rm 23 DP	Received:	04/04/2022 @ 09:38
Radon Level :	0.1 pCi/L	Analyzed:	04/05/2022 @ 10:44
Error for Measurement is: \pm	0.4 pCi/L		

Canister ID# :	2989997	Test Start :	03/29/2022 @ 05:59
Canister Type :	Charcoal Canister 3 inch	Test Stop :	03/31/2022 @ 06:19
Location :	1st FL= Rm 06 BL	Received:	04/04/2022 @ 09:38
Radon Level :	0.1 pCi/L	Analyzed:	04/05/2022 @ 08:57
Error for Measurement is: \pm	0.4 pCi/L		

Canister ID# :	2990000	Test Start :	03/29/2022 @ 06:14
Canister Type :	Charcoal Canister 3 inch	Test Stop :	03/31/2022 @ 06:25
Location :	1st FL=Custodial Off.	Received:	04/04/2022 @ 09:38
Radon Level :	0.1 pCi/L	Analyzed:	04/04/2022 @ 09:42
Error for Measurement is: \pm	0.4 pCi/L		

Canister ID# :	2990008	Test Start :	03/29/2022 @ 06:37
Canister Type :	Charcoal Canister 3 inch	Test Stop :	03/31/2022 @ 06:40
Location :	1st FL= Rm 15 BL	Received:	04/04/2022 @ 09:38
Radon Level :	0.1 pCi/L	Analyzed:	04/05/2022 @ 10:33
Error for Measurement is: \pm	0.9 pCi/L		

Canister ID# :	2990010	Test Start :	03/29/2022 @ 06:26
Canister Type :	Charcoal Canister 3 inch	Test Stop :	03/31/2022 @ 06:33
Location :	1st FL=NW Rm in Caf. BL	Received:	04/04/2022 @ 09:38
Radon Level :	0.1 pCi/L	Analyzed:	04/04/2022 @ 09:25
Error for Measurement is: \pm	0.8 pCi/L		

Canister ID# :	2990011	Test Start :	03/29/2022 @ 06:07
Canister Type :	Charcoal Canister 3 inch	Test Stop :	03/31/2022 @ 06:22
Location :	1st FL=Computer Rm	Received:	04/04/2022 @ 09:38
Radon Level :	0.3 pCi/L	Analyzed:	04/05/2022 @ 10:33



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 04/04/2022

Seth Barry / Andy Chasteen
MEDFORD SCHOOL DISTRICT
815 South Oakdale Avenue
Room 214
Medford, OR 97501-

Client: Kennedy E.S.
Test Location: 2860 North Keeneway Drive
Medford, OR 97504-

Individual Canister Results

Error for Measurement is: \pm 0.4 pCi/L

Canister ID# :	2990013	Test Start :	03/29/2022 @ 06:05
Canister Type :	Charcoal Canister 3 inch	Test Stop :	03/31/2022 @ 06:20
Location :	1st FL=Media Ctr 1	Received:	04/04/2022 @ 09:38
Radon Level :	0.5 pCi/L	Analyzed:	04/05/2022 @ 08:57
Error for Measurement is: \pm	0.4 pCi/L		

Canister ID# :	2990016	Test Start :	03/29/2022 @ 06:10
Canister Type :	Charcoal Canister 3 inch	Test Stop :	03/31/2022 @ 06:22
Location :	1st FL= Rm 20	Received:	04/04/2022 @ 09:38
Radon Level :	0.2 pCi/L	Analyzed:	04/04/2022 @ 09:09
Error for Measurement is: \pm	0.3 pCi/L		

Canister ID# :	2990017	Test Start :	03/29/2022 @ 05:53
Canister Type :	Charcoal Canister 3 inch	Test Stop :	03/31/2022 @ 06:17
Location :	1st FL= Rm 16	Received:	04/04/2022 @ 09:38
Radon Level :	0.2 pCi/L	Analyzed:	04/05/2022 @ 10:41
Error for Measurement is: \pm	0.3 pCi/L		

Canister ID# :	2990018	Test Start :	03/29/2022 @ 05:57
Canister Type :	Charcoal Canister 3 inch	Test Stop :	03/31/2022 @ 06:17
Location :	1st FL= Rm 05 DP	Received:	04/04/2022 @ 09:38
Radon Level :	0.2 pCi/L	Analyzed:	04/04/2022 @ 09:09
Error for Measurement is: \pm	0.3 pCi/L		

Canister ID# :	2990047	Test Start :	03/29/2022 @ 06:17
Canister Type :	Charcoal Canister 3 inch	Test Stop :	03/31/2022 @ 06:23
Location :	1st FL= Rm 21	Received:	04/04/2022 @ 09:38
Radon Level :	0.1 pCi/L	Analyzed:	04/05/2022 @ 10:31
Error for Measurement is: \pm	0.3 pCi/L		

Canister ID# :	2990051	Test Start :	03/29/2022 @ 06:21
Canister Type :	Charcoal Canister 3 inch	Test Stop :	03/31/2022 @ 06:29
Location :	1st FL= Rm 11	Received:	04/04/2022 @ 09:38
Radon Level :	0.7 pCi/L	Analyzed:	04/05/2022 @ 10:44



Andreas C. George

Dante Galan

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 04/04/2022

Seth Barry / Andy Chasteen
MEDFORD SCHOOL DISTRICT
815 South Oakdale Avenue
Room 214
Medford, OR 97501-

Client: Kennedy E.S.
Test Location: 2860 North Keeneway Drive
Medford, OR 97504-

Individual Canister Results

Error for Measurement is: \pm 0.5 pCi/L

Canister ID# :	2990052	Test Start :	03/29/2022 @ 05:57
Canister Type :	Charcoal Canister 3 inch	Test Stop :	03/31/2022 @ 06:17
Location :	1st FL=Conf. Rm	Received:	04/04/2022 @ 09:38
Radon Level :	0.3 pCi/L	Analyzed:	04/05/2022 @ 10:41
Error for Measurement is: \pm	0.4 pCi/L		

Canister ID# :	2990053	Test Start :	03/29/2022 @ 06:24
Canister Type :	Charcoal Canister 3 inch	Test Stop :	03/31/2022 @ 06:30
Location :	1st FL=Rm S of Music Rm	Received:	04/04/2022 @ 09:38
Radon Level :	0.1 pCi/L	Analyzed:	04/05/2022 @ 09:51
Error for Measurement is: \pm	0.3 pCi/L		

Canister ID# :	2990057	Test Start :	03/29/2022 @ 06:29
Canister Type :	Charcoal Canister 3 inch	Test Stop :	03/31/2022 @ 06:35
Location :	1st FL= Rm 25	Received:	04/04/2022 @ 09:38
Radon Level :	0.6 pCi/L	Analyzed:	04/05/2022 @ 08:57
Error for Measurement is: \pm	0.4 pCi/L		

Canister ID# :	2990065	Test Start :	03/29/2022 @ 06:16
Canister Type :	Charcoal Canister 3 inch	Test Stop :	03/31/2022 @ 06:27
Location :	1st FL= Rm 28 DP	Received:	04/04/2022 @ 09:38
Radon Level :	0.4 pCi/L	Analyzed:	04/05/2022 @ 09:51
Error for Measurement is: \pm	0.4 pCi/L		

Canister ID# :	2990067	Test Start :	03/29/2022 @ 06:32
Canister Type :	Charcoal Canister 3 inch	Test Stop :	03/31/2022 @ 06:45
Location :	1st FL= Rm 27 DP	Received:	04/04/2022 @ 09:38
Radon Level :	0.1 pCi/L	Analyzed:	04/05/2022 @ 10:41
Error for Measurement is: \pm	1.9 pCi/L		

Canister ID# :	2990147	Test Start :	03/29/2022 @ 06:17
Canister Type :	Charcoal Canister 3 inch	Test Stop :	03/31/2022 @ 06:23
Location :	1st FL= Rm 21 BL	Received:	04/04/2022 @ 09:38
Radon Level :	0.4 pCi/L	Analyzed:	04/05/2022 @ 10:47



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 04/04/2022

Seth Barry / Andy Chasteen
MEDFORD SCHOOL DISTRICT
815 South Oakdale Avenue
Room 214
Medford, OR 97501-

Client: Kennedy E.S.
Test Location: 2860 North Keeneway Drive
Medford, OR 97504-

Individual Canister Results

Error for Measurement is: \pm 0.4 pCi/L

Canister ID# :	2990157	Test Start :	03/29/2022 @ 06:02
Canister Type :	Charcoal Canister 3 inch	Test Stop :	03/31/2022 @ 06:20
Location :	1st FL= Rm 17 DP	Received:	04/04/2022 @ 09:38
Radon Level :	0.6 pCi/L	Analyzed:	04/05/2022 @ 09:50
Error for Measurement is: \pm	0.4 pCi/L		

Canister ID# :	2990502	Test Start :	03/29/2022 @ 05:55
Canister Type :	Charcoal Canister 3 inch	Test Stop :	03/31/2022 @ 06:18
Location :	1st FL= Rm 19	Received:	04/04/2022 @ 09:38
Radon Level :	0.3 pCi/L	Analyzed:	04/04/2022 @ 09:25
Error for Measurement is: \pm	0.4 pCi/L		

The results indicate that at least one testing device registered at or above the United States Environmental Protection Agency (EPA) action level of 4.0 picoCuries per liter of air (pCi/L). The EPA recommends mitigation if the average of two short-term tests taken in the lowest level of the building suitable for occupancy show radon levels that are equal to or greater than 4.0 pCi/L.

For information on how to reduce radon levels in your home, please review the EPA booklet: Consumer's Guide to Radon Reduction (www.epa.gov/radon/pdfs/consgrid.pdf) and contact your state health department. The EPA maintains a radon information website, including copies of its publications, at www.epa.gov/iaq/radon.

For New Jersey clients: Please see the attached guidance document entitled Radon Testing and Mitigation: The Basics for further information.

For New York clients: If the radon level of one or more testing devices is equal to or exceeds 20 pCi/L please contact the New York State Department of Health, Bureau of Environmental Radiation Protection, for technical advice and assistance at 518-402-7556 or toll free 1-800-458-1158.

PLEDGE OF ASSURED QUALITY

All procedures used for generating this report are in complete accordance with the current EPA protocols for the analysis of radon in air (EPA 402-R-92-004). The analytical results relate only to the samples tested, in the condition received by the lab, and that calculations were based upon the information supplied by client. RTCA and its personnel do not assume responsibility or liability, collectively and individually, for analysis results when detectors have been improperly handled or placed by the consumer, nor does RTCA and its personnel accept responsibility for any financial or health consequences of subsequent action or lack of action, taken by the customer or its consultants based on RTCA-provided results.



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201