

Site Radon Inspection Report

Date : 05/23/2023

Mr. Seth Barry
MEDFORD SCHOOL DISTRICT
900 Kenyon Street
Medford, OR 97501-

Client: Lone Pine E.S.
Test Location: 3158 Lone Pine Road
Medford, OR 97504-

Individual Canister Results

Canister ID# : 2915696 Test Start : 05/16/2023 @ 06:22
Canister Type : Charcoal Canister 3 inch Test Stop : 05/18/2023 @ 06:50
Location : 1st FL=Main Office Received: 05/23/2023 @ 09:51
Radon Level : 0.8 pCi/L Analyzed: 05/24/2023 @ 08:56
Error for Measurement is: \pm 0.7 pCi/L

Canister ID# : 2916531 Test Start : 05/16/2023 @ 06:23
Canister Type : Charcoal Canister 3 inch Test Stop : 05/18/2023 @ 06:24
Location : 1st FL = Gym 1 Received: 05/23/2023 @ 09:50
Radon Level : 0.3 pCi/L Analyzed: 05/24/2023 @ 08:56
Error for Measurement is: \pm 0.5 pCi/L

Canister ID# : 2896360 Test Start : 05/16/2023 @ 06:23
Canister Type : Charcoal Canister 3 inch Test Stop : 05/18/2023 @ 06:51
Location : 1st FL=Main Off. BL Received: 05/23/2023 @ 09:51
Radon Level : 0.1 pCi/L Analyzed: 05/24/2023 @ 08:37
Error for Measurement is: \pm 0.2 pCi/L

Canister ID# : 2916077 Test Start : 05/16/2023 @ 06:25
Canister Type : Charcoal Canister 3 inch Test Stop : 05/18/2023 @ 06:26
Location : 1st FL = Gym 2 Received: 05/23/2023 @ 09:50
Radon Level : 0.1 pCi/L Analyzed: 05/24/2023 @ 08:44
Error for Measurement is: \pm 0.4 pCi/L

Canister ID# : 2916543 Test Start : 05/16/2023 @ 06:25
Canister Type : Charcoal Canister 3 inch Test Stop : 05/18/2023 @ 06:52
Location : 1st FL = Rm 22 Received: 05/23/2023 @ 09:50
Radon Level : 0.4 pCi/L Analyzed: 05/23/2023 @ 11:13
Error for Measurement is: \pm 0.4 pCi/L

Canister ID# : 2916025 Test Start : 05/16/2023 @ 06:25
Canister Type : Charcoal Canister 3 inch Test Stop : 05/18/2023 @ 06:52
Location : 1st FL=Main Off. Conf. Rm Received: 05/23/2023 @ 09:51
Radon Level : 0.6 pCi/L Analyzed: 05/24/2023 @ 08:56
Error for Measurement is: \pm 0.6 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 05/23/2023

Mr. Seth Barry
MEDFORD SCHOOL DISTRICT
900 Kenyon Street
Medford, OR 97501-

Client: Lone Pine E.S.
Test Location: 3158 Lone Pine Road
Medford, OR 97504-

Individual Canister Results

Canister ID# : 2916016 Test Start : 05/16/2023 @ 06:26
Canister Type : Charcoal Canister 3 inch Test Stop : 05/18/2023 @ 06:53
Location : 1st FL=Principals Off. Received: 05/23/2023 @ 09:51
Radon Level : 1.0 pCi/L Analyzed: 05/24/2023 @ 09:42
Error for Measurement is: \pm 0.6 pCi/L

Canister ID# : 2916198 Test Start : 05/16/2023 @ 06:27
Canister Type : Charcoal Canister 3 inch Test Stop : 05/18/2023 @ 06:30
Location : 1st FL = Music Rm DP Received: 05/23/2023 @ 09:50
Radon Level : 0.6 pCi/L Analyzed: 05/24/2023 @ 08:44
Error for Measurement is: \pm 0.5 pCi/L

Canister ID# : 2916206 Test Start : 05/16/2023 @ 06:27
Canister Type : Charcoal Canister 3 inch Test Stop : 05/18/2023 @ 06:30
Location : 1st FL = Music Rm DP Received: 05/23/2023 @ 09:50
Radon Level : 0.7 pCi/L Analyzed: 05/24/2023 @ 08:44

Average of Side by Side Canisters 0.7 pCi/L
Error for Measurement is: \pm 0.5 pCi/L

Canister ID# : 2916562 Test Start : 05/16/2023 @ 06:28
Canister Type : Charcoal Canister 3 inch Test Stop : 05/18/2023 @ 06:54
Location : 1st FL = Health Rm Received: 05/23/2023 @ 09:51
Radon Level : 0.5 pCi/L Analyzed: 05/24/2023 @ 09:08
Error for Measurement is: \pm 0.5 pCi/L

Canister ID# : 2916207 Test Start : 05/16/2023 @ 06:29
Canister Type : Charcoal Canister 3 inch Test Stop : 05/18/2023 @ 06:54
Location : 1st FL = Rm 21 DP Received: 05/23/2023 @ 09:50
Radon Level : 0.4 pCi/L Analyzed: 05/23/2023 @ 11:13
Error for Measurement is: \pm 0.4 pCi/L

Canister ID# : 2916566 Test Start : 05/16/2023 @ 06:29
Canister Type : Charcoal Canister 3 inch Test Stop : 05/18/2023 @ 06:54
Location : 1st FL = Rm 21 DP Received: 05/23/2023 @ 09:50
Radon Level : 0.4 pCi/L Analyzed: 05/24/2023 @ 09:34



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 05/23/2023

Mr. Seth Barry
MEDFORD SCHOOL DISTRICT
900 Kenyon Street
Medford, OR 97501-

Client: Lone Pine E.S.
Test Location: 3158 Lone Pine Road
Medford, OR 97504-

Individual Canister Results

Average of Side by Side Canisters 0.4 pCi/L

Error for Measurement is: \pm 0.5 pCi/L

Canister ID# :	2913714	Test Start :	05/16/2023 @ 06:30
Canister Type :	Charcoal Canister 3 inch	Test Stop :	05/18/2023 @ 06:54
Location :	1st FL = Work Rm	Received:	05/23/2023 @ 09:51
Radon Level :	0.7 pCi/L	Analyzed:	05/24/2023 @ 09:08
Error for Measurement is: \pm	0.5 pCi/L		

Canister ID# :	2916099	Test Start :	05/16/2023 @ 06:31
Canister Type :	Charcoal Canister 3 inch	Test Stop :	05/18/2023 @ 06:32
Location :	1st FL = Media Ctr	Received:	05/23/2023 @ 09:50
Radon Level :	0.6 pCi/L	Analyzed:	05/24/2023 @ 09:43
Error for Measurement is: \pm	0.5 pCi/L		

Canister ID# :	2896326	Test Start :	05/16/2023 @ 06:31
Canister Type :	Charcoal Canister 3 inch	Test Stop :	05/18/2023 @ 06:56
Location :	1st FL = Rm 20	Received:	05/23/2023 @ 09:50
Radon Level :	0.1 pCi/L	Analyzed:	05/23/2023 @ 11:13
Error for Measurement is: \pm	0.8 pCi/L		

Canister ID# :	2896311	Test Start :	05/16/2023 @ 06:32
Canister Type :	Charcoal Canister 3 inch	Test Stop :	05/18/2023 @ 06:55
Location :	1st FL=Main Bldg. A	Received:	05/23/2023 @ 09:51
Radon Level :	0.3 pCi/L	Analyzed:	05/24/2023 @ 08:53
Error for Measurement is: \pm	0.6 pCi/L		

Canister ID# :	2916540	Test Start :	05/16/2023 @ 06:33
Canister Type :	Charcoal Canister 3 inch	Test Stop :	05/18/2023 @ 06:34
Location :	1st FL=Media Ctr BL	Received:	05/23/2023 @ 09:51
Radon Level :	0.1 pCi/L	Analyzed:	05/24/2023 @ 09:12
Error for Measurement is: \pm	0.4 pCi/L		



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 05/23/2023

Mr. Seth Barry
MEDFORD SCHOOL DISTRICT
900 Kenyon Street
Medford, OR 97501-

Client: Lone Pine E.S.
Test Location: 3158 Lone Pine Road
Medford, OR 97504-

Individual Canister Results

Canister ID# : 2916547 Test Start : 05/16/2023 @ 06:33
Canister Type : Charcoal Canister 3 inch Test Stop : 05/18/2023 @ 06:56
Location : 1st FL=Main Bldg. B Received: 05/23/2023 @ 09:51
Radon Level : 0.3 pCi/L Analyzed: 05/24/2023 @ 08:37
Error for Measurement is: \pm 0.5 pCi/L

Canister ID# : 2913770 Test Start : 05/16/2023 @ 06:33
Canister Type : Charcoal Canister 3 inch Test Stop : 05/18/2023 @ 06:57
Location : 1st FL = Rm 19 Received: 05/23/2023 @ 09:50
Radon Level : 0.1 pCi/L Analyzed: 05/24/2023 @ 09:03
Error for Measurement is: \pm 0.5 pCi/L

Canister ID# : 2916581 Test Start : 05/16/2023 @ 06:34
Canister Type : Charcoal Canister 3 inch Test Stop : 05/18/2023 @ 06:57
Location : 1st FL=Main Bldg. C Received: 05/23/2023 @ 09:51
Radon Level : 0.1 pCi/L Analyzed: 05/24/2023 @ 09:42
Error for Measurement is: \pm 0.5 pCi/L

Canister ID# : 2916558 Test Start : 05/16/2023 @ 06:35
Canister Type : Charcoal Canister 3 inch Test Stop : 05/18/2023 @ 06:36
Location : 1st FL=Media Ctr Comp Rm Received: 05/23/2023 @ 09:51
Radon Level : 1.0 pCi/L Analyzed: 05/24/2023 @ 09:08
Error for Measurement is: \pm 0.5 pCi/L

Canister ID# : 2916539 Test Start : 05/16/2023 @ 06:35
Canister Type : Charcoal Canister 3 inch Test Stop : 05/18/2023 @ 06:57
Location : 1st FL = Rm 1 DP Received: 05/23/2023 @ 09:51
Radon Level : 0.7 pCi/L Analyzed: 05/24/2023 @ 08:53
Error for Measurement is: \pm 0.5 pCi/L

Canister ID# : 2916551 Test Start : 05/16/2023 @ 06:35
Canister Type : Charcoal Canister 3 inch Test Stop : 05/18/2023 @ 06:57
Location : 1st FL = Rm 1 DP Received: 05/23/2023 @ 09:51
Radon Level : 0.1 pCi/L Analyzed: 05/23/2023 @ 11:14

Average of Side by Side Canisters 0.4 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 05/23/2023

Mr. Seth Barry
MEDFORD SCHOOL DISTRICT
900 Kenyon Street
Medford, OR 97501-

Client: Lone Pine E.S.
Test Location: 3158 Lone Pine Road
Medford, OR 97504-

Individual Canister Results

Error for Measurement is: \pm 0.5 pCi/L

Canister ID# :	2916542	Test Start :	05/16/2023 @ 06:35
Canister Type :	Charcoal Canister 3 inch	Test Stop :	05/18/2023 @ 06:58
Location :	1st FL = Rm 18	Received:	05/23/2023 @ 09:50
Radon Level :	0.4 pCi/L	Analyzed:	05/24/2023 @ 08:56
Error for Measurement is:	\pm 0.5 pCi/L		

Canister ID# :	2916919	Test Start :	05/16/2023 @ 06:35
Canister Type :	Charcoal Canister 3 inch	Test Stop :	05/18/2023 @ 06:58
Location :	1st FL = Rm 18 BL	Received:	05/23/2023 @ 09:50
Radon Level :	0.6 pCi/L	Analyzed:	05/24/2023 @ 09:03
Error for Measurement is:	\pm 0.5 pCi/L		

Canister ID# :	2916940	Test Start :	05/16/2023 @ 06:37
Canister Type :	Charcoal Canister 3 inch	Test Stop :	05/18/2023 @ 06:38
Location :	1st FL=Media Ctr Conf. Rm	Received:	05/23/2023 @ 09:51
Radon Level :	0.4 pCi/L	Analyzed:	05/24/2023 @ 09:08
Error for Measurement is:	\pm 0.6 pCi/L		

Canister ID# :	2902643	Test Start :	05/16/2023 @ 06:38
Canister Type :	Charcoal Canister 3 inch	Test Stop :	05/18/2023 @ 06:58
Location :	1st FL = Rm 6	Received:	05/23/2023 @ 09:51
Radon Level :	0.5 pCi/L	Analyzed:	05/24/2023 @ 08:37
Error for Measurement is:	\pm 0.5 pCi/L		

Canister ID# :	2916197	Test Start :	05/16/2023 @ 06:38
Canister Type :	Charcoal Canister 3 inch	Test Stop :	05/18/2023 @ 07:01
Location :	1st FL = Rm 17	Received:	05/23/2023 @ 09:50
Radon Level :	0.1 pCi/L	Analyzed:	05/24/2023 @ 09:34
Error for Measurement is:	\pm 0.4 pCi/L		

Canister ID# :	2916046	Test Start :	05/16/2023 @ 06:39
Canister Type :	Charcoal Canister 3 inch	Test Stop :	05/18/2023 @ 06:42
Location :	1st FL=Computer Rm DP	Received:	05/23/2023 @ 09:51
Radon Level :	0.9 pCi/L	Analyzed:	05/24/2023 @ 09:08
Error for Measurement is:	\pm 0.5 pCi/L		



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 05/23/2023

Mr. Seth Barry
MEDFORD SCHOOL DISTRICT
900 Kenyon Street
Medford, OR 97501-

Client: Lone Pine E.S.
Test Location: 3158 Lone Pine Road
Medford, OR 97504-

Individual Canister Results

Canister ID# :	2916952	Test Start :	05/16/2023 @ 06:39
Canister Type :	Charcoal Canister 3 inch	Test Stop :	05/18/2023 @ 06:42
Location :	1st FL=Computer Rm DP	Received:	05/23/2023 @ 09:51
Radon Level :	0.4 pCi/L	Analyzed:	05/24/2023 @ 08:56

Average of Side by Side Canisters 0.7 pCi/L

Error for Measurement is: ± 0.6 pCi/L

Canister ID# :	2916096	Test Start :	05/16/2023 @ 06:39
Canister Type :	Charcoal Canister 3 inch	Test Stop :	05/18/2023 @ 06:59
Location :	1st FL = Rm 7	Received:	05/23/2023 @ 09:51
Radon Level :	0.6 pCi/L	Analyzed:	05/23/2023 @ 11:00

Error for Measurement is: ± 0.4 pCi/L

Canister ID# :	2916004	Test Start :	05/16/2023 @ 06:39
Canister Type :	Charcoal Canister 3 inch	Test Stop :	05/18/2023 @ 07:01
Location :	1st FL = Rm 17 BL	Received:	05/23/2023 @ 09:50
Radon Level :	0.1 pCi/L	Analyzed:	05/23/2023 @ 11:00

Error for Measurement is: ± 0.1 pCi/L

Canister ID# :	2913723	Test Start :	05/16/2023 @ 06:40
Canister Type :	Charcoal Canister 3 inch	Test Stop :	05/18/2023 @ 07:00
Location :	1st FL = Rm 8	Received:	05/23/2023 @ 09:51
Radon Level :	0.6 pCi/L	Analyzed:	05/24/2023 @ 08:56

Error for Measurement is: ± 0.6 pCi/L

Canister ID# :	2896345	Test Start :	05/16/2023 @ 06:41
Canister Type :	Charcoal Canister 3 inch	Test Stop :	05/18/2023 @ 07:01
Location :	1st FL = Rm 9	Received:	05/23/2023 @ 09:51
Radon Level :	0.5 pCi/L	Analyzed:	05/24/2023 @ 08:49

Error for Measurement is: ± 0.5 pCi/L

Canister ID# :	2916092	Test Start :	05/16/2023 @ 06:41
Canister Type :	Charcoal Canister 3 inch	Test Stop :	05/18/2023 @ 07:02
Location :	1st FL = Rm 16	Received:	05/23/2023 @ 09:50
Radon Level :	0.1 pCi/L	Analyzed:	05/23/2023 @ 11:14



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 05/23/2023

Mr. Seth Barry
MEDFORD SCHOOL DISTRICT
900 Kenyon Street
Medford, OR 97501-

Client: Lone Pine E.S.
Test Location: 3158 Lone Pine Road
Medford, OR 97504-

Individual Canister Results

Error for Measurement is: ± 0.4 pCi/L

Canister ID# :	2915699	Test Start :	05/16/2023 @ 06:43
Canister Type :	Charcoal Canister 3 inch	Test Stop :	05/18/2023 @ 06:44
Location :	1st FL=Custodial Off.	Received:	05/23/2023 @ 09:51
Radon Level :	1.0 pCi/L	Analyzed:	05/24/2023 @ 08:49
Error for Measurement is: ±	0.5 pCi/L		

Canister ID# :	2901016	Test Start :	05/16/2023 @ 06:43
Canister Type :	Charcoal Canister 3 inch	Test Stop :	05/18/2023 @ 07:03
Location :	1st FL = Rm 15	Received:	05/23/2023 @ 09:50
Radon Level :	0.6 pCi/L	Analyzed:	05/24/2023 @ 09:12
COVERED W/PAPERS. MOVED BY WINDOW			

Error for Measurement is: ± 0.6 pCi/L

Canister ID# :	2901010	Test Start :	05/16/2023 @ 06:44
Canister Type :	Charcoal Canister 3 inch	Test Stop :	05/18/2023 @ 07:03
Location :	1st FL = Break Rm	Received:	05/23/2023 @ 09:51
Radon Level :	0.6 pCi/L	Analyzed:	05/24/2023 @ 09:34
Error for Measurement is: ±	0.5 pCi/L		

Canister ID# :	2896301	Test Start :	05/16/2023 @ 06:45
Canister Type :	Charcoal Canister 3 inch	Test Stop :	05/18/2023 @ 06:48
Location :	1st FL = Rm 26 DP	Received:	05/23/2023 @ 09:51
Radon Level :	0.1 pCi/L	Analyzed:	05/24/2023 @ 08:49
Error for Measurement is: ±	0.4 pCi/L		

Canister ID# :	2916020	Test Start :	05/16/2023 @ 06:45
Canister Type :	Charcoal Canister 3 inch	Test Stop :	05/18/2023 @ 06:48
Location :	1st FL = Rm 26 DP	Received:	05/23/2023 @ 09:51
Radon Level :	0.1 pCi/L	Analyzed:	05/24/2023 @ 08:56

Average of Side by Side Canisters 0.1 pCi/L

Error for Measurement is: ± 1.2 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 05/23/2023

Mr. Seth Barry
MEDFORD SCHOOL DISTRICT
900 Kenyon Street
Medford, OR 97501-

Client: Lone Pine E.S.
Test Location: 3158 Lone Pine Road
Medford, OR 97504-

Individual Canister Results

Canister ID# : 2915695 Test Start : 05/16/2023 @ 06:45
Canister Type : Charcoal Canister 3 inch Test Stop : 05/18/2023 @ 07:04
Location : 1st FL = Rm 14 Received: 05/23/2023 @ 09:50
Radon Level : 0.1 pCi/L Analyzed: 05/24/2023 @ 08:49
Error for Measurement is: ± 0.3 pCi/L

Canister ID# : 2916097 Test Start : 05/16/2023 @ 06:46
Canister Type : Charcoal Canister 3 inch Test Stop : 05/18/2023 @ 07:05
Location : 1st FL=Cafeteria 1 Received: 05/23/2023 @ 09:51
Radon Level : 0.4 pCi/L Analyzed: 05/24/2023 @ 08:28
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2916095 Test Start : 05/16/2023 @ 06:47
Canister Type : Charcoal Canister 3 inch Test Stop : 05/18/2023 @ 07:04
Location : 1st FL=Cafeteria 2 Received: 05/23/2023 @ 09:51
Radon Level : 0.2 pCi/L Analyzed: 05/24/2023 @ 09:39
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2916534 Test Start : 05/16/2023 @ 06:48
Canister Type : Charcoal Canister 3 inch Test Stop : 05/18/2023 @ 07:05
Location : 1st FL=Cafe BL Received: 05/23/2023 @ 09:51
Radon Level : 0.1 pCi/L Analyzed: 05/23/2023 @ 11:00
Error for Measurement is: ± 0.6 pCi/L

Canister ID# : 2916564 Test Start : 05/16/2023 @ 06:48
Canister Type : Charcoal Canister 3 inch Test Stop : 05/18/2023 @ 07:06
Location : 1st FL = Rm 13 DP Received: 05/23/2023 @ 09:50
Radon Level : 0.4 pCi/L Analyzed: 05/23/2023 @ 11:13
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 2916957 Test Start : 05/16/2023 @ 06:48
Canister Type : Charcoal Canister 3 inch Test Stop : 05/18/2023 @ 07:06
Location : 1st FL = Rm 13 DP Received: 05/23/2023 @ 09:50
Radon Level : 0.7 pCi/L Analyzed: 05/24/2023 @ 09:03

Average of Side by Side Canisters 0.6 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 05/23/2023

Mr. Seth Barry
MEDFORD SCHOOL DISTRICT
900 Kenyon Street
Medford, OR 97501-

Client: Lone Pine E.S.
Test Location: 3158 Lone Pine Road
Medford, OR 97504-

Individual Canister Results

Error for Measurement is: \pm 0.5 pCi/L

Canister ID# :	2915064	Test Start :	05/16/2023 @ 06:49
Canister Type :	Charcoal Canister 3 inch	Test Stop :	05/18/2023 @ 06:50
Location :	1st FL = Rm 25	Received:	05/23/2023 @ 09:51
Radon Level :	0.3 pCi/L	Analyzed:	05/24/2023 @ 08:53
Error for Measurement is: \pm	0.5 pCi/L		

Canister ID# :	2916951	Test Start :	05/16/2023 @ 06:50
Canister Type :	Charcoal Canister 3 inch	Test Stop :	05/18/2023 @ 07:07
Location :	1st FL = Rm 12	Received:	05/23/2023 @ 09:50
Radon Level :	0.5 pCi/L	Analyzed:	05/24/2023 @ 09:08
Error for Measurement is: \pm	0.6 pCi/L		

Canister ID# :	2916019	Test Start :	05/16/2023 @ 06:51
Canister Type :	Charcoal Canister 3 inch	Test Stop :	05/18/2023 @ 06:52
Location :	1st FL = Rm 25 BL	Received:	05/23/2023 @ 09:51
Radon Level :	0.4 pCi/L	Analyzed:	05/24/2023 @ 08:44
Error for Measurement is: \pm	0.5 pCi/L		

Canister ID# :	2915697	Test Start :	05/16/2023 @ 06:52
Canister Type :	Charcoal Canister 3 inch	Test Stop :	05/18/2023 @ 07:08
Location :	1st FL = Rm 11	Received:	05/23/2023 @ 09:50
Radon Level :	0.1 pCi/L	Analyzed:	05/24/2023 @ 09:08
Error for Measurement is: \pm	0.4 pCi/L		

Canister ID# :	2916006	Test Start :	05/16/2023 @ 06:53
Canister Type :	Charcoal Canister 3 inch	Test Stop :	05/18/2023 @ 06:54
Location :	1st FL = Rm 24	Received:	05/23/2023 @ 09:51
Radon Level :	0.1 pCi/L	Analyzed:	05/24/2023 @ 08:37
Error for Measurement is: \pm	0.3 pCi/L		

Canister ID# :	2916948	Test Start :	05/16/2023 @ 06:54
Canister Type :	Charcoal Canister 3 inch	Test Stop :	05/18/2023 @ 07:09
Location :	1st FL = Rm 10	Received:	05/23/2023 @ 09:50
Radon Level :	0.1 pCi/L	Analyzed:	05/24/2023 @ 09:08
Error for Measurement is: \pm	0.7 pCi/L		



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 05/23/2023

Mr. Seth Barry
MEDFORD SCHOOL DISTRICT
900 Kenyon Street
Medford, OR 97501-

Client: Lone Pine E.S.
Test Location: 3158 Lone Pine Road
Medford, OR 97504-

Individual Canister Results

The results indicate that at least one testing device registered at or above the United States Environmental Protection Agency (EPA) action level of 4.0 picoCuries per liter of air (pCi/L). The EPA recommends mitigation if the average of two short-term tests taken in the lowest level of the building suitable for occupancy show radon levels that are equal to or greater than 4.0 pCi/L.

For information on how to reduce radon levels in your home, please review the EPA booklet: Consumer's Guide to Radon Reduction (www.epa.gov/radon/pdfs/consguid.pdf) and contact your state health department. The EPA maintains a radon information website, including copies of its publications, at www.epa.gov/iaq/radon.

For New Jersey clients: Please see the attached guidance document entitled Radon Testing and Mitigation: The Basics for further information.

For New York clients: If the radon level of one or more testing devices is equal to or exceeds 20 pCi/L please contact the New York State Department of Health, Bureau of Environmental Radiation Protection, for technical advice and assistance at 518-402-7556 or toll free 1-800-458-1158.

PLEDGE OF ASSURED QUALITY

All procedures used for generating this report are in complete accordance with the current EPA protocols for the analysis of radon in air (EPA 402-R-92-004). The analytical results relate only to the samples tested, in the condition received by the lab, and that calculations were based upon the information supplied by client. RTCA and its personnel do not assume responsibility or liability, collectively and individually, for analysis results when detectors have been improperly handled or placed by the consumer, nor does RTCA and its personnel accept responsibility for any financial or health consequences of subsequent action or lack of action, taken by the customer or its consultants based on RTCA-provided results.



Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201