

NEILSON RESEARCH CORPORATION

Environmental Testing Laboratory

8/16/2016

Rick Rose
Medford School District
815 S Oakdale Ave
Medford, OR 97501

TEL: (541) 842-1138

FAX 541-842-1160

RE: 16-48 Roosevelt Lead Study

Order No.: 1608749

Dear Rick Rose:

Neilson Research Corporation received 55 sample(s) on 8/12/2016 for the analyses presented in the following report.

The results relate only to the parameters tested or to the sample as received by the laboratory. This report shall not be reproduced except in full, without the written approval of Neilson Research Corporation. If you have any questions regarding these test results, please feel free to call.

Sincerely,
Neilson Research Corporation

Alec C Smith
Project Manager

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

CLIENT: Medford School District
Project: 16-48 Roosevelt Lead Study
Lab Order: 1608749

Date: 16-Aug-16

CASE NARRATIVE

The analyses were performed according to the guidelines in the Neilson Research Corporation Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

Neilson Research Corporation certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: **1608749**
NRC Sample ID: **1608749-01A**
Collection Date: **8/11/2016 4:48:00 PM**
Received Date: **8/12/2016 8:49:00 AM**
Reported Date: **8/16/2016 2:51:07 PM**

Sample Information:

16-48 Roosevelt Lead Study

Client Sample ID: Bottle #05618
Collectors Name: Larry Anderson
Sample Location: Room 110 DF A
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.00749		0.000103	mg/L	0.020 AL	8/12/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: **1608749**
NRC Sample ID: **1608749-02A**
Collection Date: **8/11/2016 4:50:00 PM**
Received Date: **8/12/2016 8:49:00 AM**
Reported Date: **8/16/2016 2:51:07 PM**

Sample Information:

16-48 Roosevelt Lead Study

Client Sample ID: Bottle #05787
Collectors Name: Larry Anderson
Sample Location: Room 110 DF B
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.00816		0.000103	mg/L	0.020 AL	8/12/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: **1608749**
NRC Sample ID: **1608749-03A**
Collection Date: **8/11/2016 4:53:00 PM**
Received Date: **8/12/2016 8:49:00 AM**
Reported Date: **8/16/2016 2:51:07 PM**

Sample Information:

16-48 Roosevelt Lead Study

Client Sample ID: Bottle #05793
Collectors Name: Larry Anderson
Sample Location: Room 110 DF C
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.00920		0.000103	mg/L	0.020 AL	8/12/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District

815 S Oakdale Ave
Medford, OR 97501

Lab Order: **1608749**

NRC Sample ID: **1608749-04A**

Collection Date: **8/11/2016 4:56:00 PM**

Received Date: **8/12/2016 8:49:00 AM**

Reported Date: **8/16/2016 2:51:07 PM**

Sample Information:

16-48 Roosevelt Lead Study

Client Sample ID: Bottle #05795

Collectors Name: Larry Anderson

Sample Location: In Front of Rm 110 DF

Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.00462		0.000103	mg/L	0.020 AL	8/12/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: **1608749**
NRC Sample ID: **1608749-05A**
Collection Date: **8/11/2016 4:57:00 PM**
Received Date: **8/12/2016 8:49:00 AM**
Reported Date: **8/16/2016 2:51:07 PM**

Sample Information:

16-48 Roosevelt Lead Study

Client Sample ID: Bottle #05794
Collectors Name: Larry Anderson
Sample Location: In Front of Rm 110 Sink
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.00995		0.000103	mg/L	0.020 AL	8/12/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: **1608749**
NRC Sample ID: **1608749-06A**
Collection Date: **8/11/2016 5:01:00 PM**
Received Date: **8/12/2016 8:49:00 AM**
Reported Date: **8/16/2016 2:51:07 PM**

Sample Information:

16-48 Roosevelt Lead Study

Client Sample ID: Bottle #05622
Collectors Name: Larry Anderson
Sample Location: Room 114 DF
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.00956		0.000103	mg/L	0.020 AL	8/12/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR0028

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: **1608749**
NRC Sample ID: **1608749-07A**
Collection Date: **8/11/2016 5:01:00 PM**
Received Date: **8/12/2016 8:49:00 AM**
Reported Date: **8/16/2016 2:51:07 PM**

Sample Information:

16-48 Roosevelt Lead Study

Client Sample ID: Bottle #05834
Collectors Name: Larry Anderson
Sample Location: Room 114 DF Flush
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.0116		0.000103	mg/L	0.020 AL	8/12/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: **1608749**
NRC Sample ID: **1608749-08A**
Collection Date: **8/11/2016 5:03:00 PM**
Received Date: **8/12/2016 8:49:00 AM**
Reported Date: **8/16/2016 2:51:07 PM**

Sample Information:

16-48 Roosevelt Lead Study

Client Sample ID: Bottle #05628
Collectors Name: Larry Anderson
Sample Location: Room 113 DF
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.00635		0.000103	mg/L	0.020 AL	8/12/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR0028

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: **1608749**
NRC Sample ID: **1608749-09A**
Collection Date: **8/11/2016 5:10:00 PM**
Received Date: **8/12/2016 8:49:00 AM**
Reported Date: **8/16/2016 2:51:07 PM**

Sample Information:

16-48 Roosevelt Lead Study

Client Sample ID: Bottle #05605
Collectors Name: Larry Anderson
Sample Location: Room 112 DF
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.0252	*CF	0.000103	mg/L	0.020 AL	8/12/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: **1608749**
NRC Sample ID: **1608749-10A**
Collection Date: **8/11/2016 5:13:00 PM**
Received Date: **8/12/2016 8:49:00 AM**
Reported Date: **8/16/2016 2:51:07 PM**

Sample Information:

16-48 Roosevelt Lead Study

Client Sample ID: Bottle #05610
Collectors Name: Larry Anderson
Sample Location: Room 111 DF
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.00998		0.000103	mg/L	0.020 AL	8/12/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: **1608749**
NRC Sample ID: **1608749-11A**
Collection Date: **8/11/2016 5:19:00 PM**
Received Date: **8/12/2016 8:49:00 AM**
Reported Date: **8/16/2016 2:51:07 PM**

Sample Information:

16-48 Roosevelt Lead Study

Client Sample ID: Bottle #05798
Collectors Name: Larry Anderson
Sample Location: Health Rm Sink Left
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.00656		0.0001	mg/L	0.020 AL	8/13/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: **1608749**
NRC Sample ID: **1608749-12A**
Collection Date: **8/11/2016 5:21:00 PM**
Received Date: **8/12/2016 8:49:00 AM**
Reported Date: **8/16/2016 2:51:07 PM**

Sample Information:

16-48 Roosevelt Lead Study

Client Sample ID: Bottle #05631
Collectors Name: Larry Anderson
Sample Location: Health Rm Sink Right
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.0105		0.0001	mg/L	0.020 AL	8/13/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: **1608749**
NRC Sample ID: **1608749-13A**
Collection Date: **8/11/2016 5:21:00 PM**
Received Date: **8/12/2016 8:49:00 AM**
Reported Date: **8/16/2016 2:51:07 PM**

Sample Information:

16-48 Roosevelt Lead Study

Client Sample ID: Bottle #05820
Collectors Name: Larry Anderson
Sample Location: Health Rm Sink R Flush
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.000538		0.000103	mg/L	0.020 AL	8/12/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR0028

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: **1608749**
NRC Sample ID: **1608749-14A**
Collection Date: **8/11/2016 5:25:00 PM**
Received Date: **8/12/2016 8:49:00 AM**
Reported Date: **8/16/2016 2:51:07 PM**

Sample Information:

16-48 Roosevelt Lead Study

Client Sample ID: Bottle #05638
Collectors Name: Larry Anderson
Sample Location: Room 140 DF A
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.00944		0.0001	mg/L	0.020 AL	8/13/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: **1608749**
NRC Sample ID: **1608749-15A**
Collection Date: **8/11/2016 5:27:00 PM**
Received Date: **8/12/2016 8:49:00 AM**
Reported Date: **8/16/2016 2:51:07 PM**

Sample Information:

16-48 Roosevelt Lead Study

Client Sample ID: Bottle #05651
Collectors Name: Larry Anderson
Sample Location: Room 140 DF B
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.00673		0.000103	mg/L	0.020 AL	8/12/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: **1608749**
NRC Sample ID: **1608749-16A**
Collection Date: **8/11/2016 5:28:00 PM**
Received Date: **8/12/2016 8:49:00 AM**
Reported Date: **8/16/2016 2:51:07 PM**

Sample Information:

16-48 Roosevelt Lead Study

Client Sample ID: Bottle #05629
Collectors Name: Larry Anderson
Sample Location: Room 141 DF
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.0117		0.000103	mg/L	0.020 AL	8/12/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District

815 S Oakdale Ave
Medford, OR 97501

Lab Order: **1608749**

NRC Sample ID: **1608749-17A**

Collection Date: **8/11/2016 5:30:00 PM**

Received Date: **8/12/2016 8:49:00 AM**

Reported Date: **8/16/2016 2:51:07 PM**

Sample Information:

16-48 Roosevelt Lead Study

Client Sample ID: Bottle #05626

Collectors Name: Larry Anderson

Sample Location: Room 142 DF

Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.00872		0.000103	mg/L	0.020 AL	8/12/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District

815 S Oakdale Ave
Medford, OR 97501

Lab Order: **1608749**

NRC Sample ID: **1608749-18A**

Collection Date: **8/11/2016 5:31:00 PM**

Received Date: **8/12/2016 8:49:00 AM**

Reported Date: **8/16/2016 2:51:07 PM**

Sample Information:

16-48 Roosevelt Lead Study

Client Sample ID: Bottle #05788

Collectors Name: Larry Anderson

Sample Location: Room 143 DF

Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.00810		0.000103	mg/L	0.020 AL	8/12/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: **1608749**
NRC Sample ID: **1608749-19A**
Collection Date: **8/11/2016 4:51:00 PM**
Received Date: **8/12/2016 8:49:00 AM**
Reported Date: **8/16/2016 2:51:07 PM**

Sample Information:

16-48 Roosevelt Lead Study

Client Sample ID: Bottle #05796
Collectors Name: Bill Bartlett
Sample Location: Room 240 DF A
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.00501		0.000103	mg/L	0.020 AL	8/12/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: **1608749**
NRC Sample ID: **1608749-20A**
Collection Date: **8/11/2016 4:52:00 PM**
Received Date: **8/12/2016 8:49:00 AM**
Reported Date: **8/16/2016 2:51:07 PM**

Sample Information:

16-48 Roosevelt Lead Study

Client Sample ID: Bottle #05797
Collectors Name: Bill Bartlett
Sample Location: Room 240 DF B
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.00252		0.0001	mg/L	0.020 AL	8/13/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: **1608749**
NRC Sample ID: **1608749-21A**
Collection Date: **8/11/2016 4:54:00 PM**
Received Date: **8/12/2016 8:49:00 AM**
Reported Date: **8/16/2016 2:51:07 PM**

Sample Information:

16-48 Roosevelt Lead Study

Client Sample ID: Bottle #05810
Collectors Name: Bill Bartlett
Sample Location: Room 240 DF C
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.0113		0.000103	mg/L	0.020 AL	8/12/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR0028

Medford School District

815 S Oakdale Ave
Medford, OR 97501

Lab Order: **1608749**

NRC Sample ID: **1608749-22A**

Collection Date: **8/11/2016 4:55:00 PM**

Received Date: **8/12/2016 8:49:00 AM**

Reported Date: **8/16/2016 2:51:07 PM**

Sample Information:

16-48 Roosevelt Lead Study

Client Sample ID: Bottle #05634

Collectors Name: Bill Bartlett

Sample Location: Room 240 DF C Flush

Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.00159		0.000103	mg/L	0.020 AL	8/12/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR0028

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: **1608749**
NRC Sample ID: **1608749-23A**
Collection Date: **8/11/2016 4:57:00 PM**
Received Date: **8/12/2016 8:49:00 AM**
Reported Date: **8/16/2016 2:51:07 PM**

Sample Information:

16-48 Roosevelt Lead Study

Client Sample ID: Bottle #05806
Collectors Name: Bill Bartlett
Sample Location: Room 241 DF
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.00823		0.000103	mg/L	0.020 AL	8/12/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR0028

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: **1608749**
NRC Sample ID: **1608749-24A**
Collection Date: **8/11/2016 4:58:00 PM**
Received Date: **8/12/2016 8:49:00 AM**
Reported Date: **8/16/2016 2:51:07 PM**

Sample Information:

16-48 Roosevelt Lead Study

Client Sample ID: Bottle #05611
Collectors Name: Bill Bartlett
Sample Location: Room 241 DF Flush
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.00118		0.000103	mg/L	0.020 AL	8/12/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR0028

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: **1608749**
NRC Sample ID: **1608749-25A**
Collection Date: **8/11/2016 5:00:00 PM**
Received Date: **8/12/2016 8:49:00 AM**
Reported Date: **8/16/2016 2:51:07 PM**

Sample Information:

16-48 Roosevelt Lead Study

Client Sample ID: Bottle #05809
Collectors Name: Bill Bartlett
Sample Location: Room 242 DF
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.00254		0.000103	mg/L	0.020 AL	8/12/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR0028

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: **1608749**
NRC Sample ID: **1608749-26A**
Collection Date: **8/11/2016 5:02:00 PM**
Received Date: **8/12/2016 8:49:00 AM**
Reported Date: **8/16/2016 2:51:07 PM**

Sample Information:

16-48 Roosevelt Lead Study

Client Sample ID: Bottle #05807
Collectors Name: Bill Bartlett
Sample Location: Room 243 DF
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.0112		0.0001	mg/L	0.020 AL	8/13/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: **1608749**
NRC Sample ID: **1608749-27A**
Collection Date: **8/11/2016 5:06:00 PM**
Received Date: **8/12/2016 8:49:00 AM**
Reported Date: **8/16/2016 2:51:07 PM**

Sample Information:

16-48 Roosevelt Lead Study

Client Sample ID: Bottle #05799
Collectors Name: Bill Bartlett
Sample Location: Staff Brk Rm 204 Sink
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.00158		0.0001	mg/L	0.020 AL	8/13/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR0028

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: **1608749**
NRC Sample ID: **1608749-28A**
Collection Date: **8/11/2016 5:07:00 PM**
Received Date: **8/12/2016 8:49:00 AM**
Reported Date: **8/16/2016 2:51:07 PM**

Sample Information:

16-48 Roosevelt Lead Study

Client Sample ID: Bottle #05789
Collectors Name: Bill Bartlett
Sample Location: Staff Brk Rm 204 Insta-Hot
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.000125		0.000103	mg/L	0.020 AL	8/12/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR0028

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: **1608749**
NRC Sample ID: **1608749-29A**
Collection Date: **8/11/2016 5:10:00 PM**
Received Date: **8/12/2016 8:49:00 AM**
Reported Date: **8/16/2016 2:51:07 PM**

Sample Information:

16-48 Roosevelt Lead Study

Client Sample ID: Bottle #05802
Collectors Name: Bill Bartlett
Sample Location: Room 210 DF A
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.0132		0.000103	mg/L	0.020 AL	8/12/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: **1608749**
NRC Sample ID: **1608749-30A**
Collection Date: **8/11/2016 5:11:00 PM**
Received Date: **8/12/2016 8:49:00 AM**
Reported Date: **8/16/2016 2:51:07 PM**

Sample Information:

16-48 Roosevelt Lead Study

Client Sample ID: Bottle #05633
Collectors Name: Bill Bartlett
Sample Location: Room 210 DF A Flush
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.00142		0.000103	mg/L	0.020 AL	8/12/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR0028

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: **1608749**
NRC Sample ID: **1608749-31A**
Collection Date: **8/11/2016 5:13:00 PM**
Received Date: **8/12/2016 8:49:00 AM**
Reported Date: **8/16/2016 2:51:07 PM**

Sample Information:

16-48 Roosevelt Lead Study

Client Sample ID: Bottle #05652
Collectors Name: Bill Bartlett
Sample Location: Room 210 DF B
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.00733		0.000103	mg/L	0.020 AL	8/12/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: **1608749**
NRC Sample ID: **1608749-32A**
Collection Date: **8/11/2016 5:15:00 PM**
Received Date: **8/12/2016 8:49:00 AM**
Reported Date: **8/16/2016 2:51:07 PM**

Sample Information:

16-48 Roosevelt Lead Study

Client Sample ID: Bottle #05646
Collectors Name: Bill Bartlett
Sample Location: Room 210 DF C
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.0191	CF	0.000103	mg/L	0.020 AL	8/12/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District

815 S Oakdale Ave
Medford, OR 97501

Lab Order: **1608749**

NRC Sample ID: **1608749-33A**

Collection Date: **8/11/2016 5:17:00 PM**

Received Date: **8/12/2016 8:49:00 AM**

Reported Date: **8/16/2016 2:51:07 PM**

Sample Information:

16-48 Roosevelt Lead Study

Client Sample ID: Bottle #05642

Collectors Name: Bill Bartlett

Sample Location: Room 211 DF

Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.00721		0.000103	mg/L	0.020 AL	8/12/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR0028

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: **1608749**
NRC Sample ID: **1608749-34A**
Collection Date: **8/11/2016 5:19:00 PM**
Received Date: **8/12/2016 8:49:00 AM**
Reported Date: **8/16/2016 2:51:07 PM**

Sample Information:

16-48 Roosevelt Lead Study

Client Sample ID: Bottle #05632
Collectors Name: Bill Bartlett
Sample Location: Room 212 DF
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.00310		0.000103	mg/L	0.020 AL	8/12/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR0028

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: **1608749**
NRC Sample ID: **1608749-35A**
Collection Date: **8/11/2016 5:21:00 PM**
Received Date: **8/12/2016 8:49:00 AM**
Reported Date: **8/16/2016 2:51:07 PM**

Sample Information:

16-48 Roosevelt Lead Study

Client Sample ID: Bottle #05647
Collectors Name: Bill Bartlett
Sample Location: Room 213 DF
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.00757		0.000103	mg/L	0.020 AL	8/12/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR0028

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: **1608749**
NRC Sample ID: **1608749-36A**
Collection Date: **8/11/2016 5:23:00 PM**
Received Date: **8/12/2016 8:49:00 AM**
Reported Date: **8/16/2016 2:51:07 PM**

Sample Information:

16-48 Roosevelt Lead Study

Client Sample ID: Bottle #05648
Collectors Name: Bill Bartlett
Sample Location: Room 214 DF
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.0152	CF	0.000103	mg/L	0.020 AL	8/12/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR0028

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: **1608749**
NRC Sample ID: **1608749-37A**
Collection Date: **8/11/2016 5:24:00 PM**
Received Date: **8/12/2016 8:49:00 AM**
Reported Date: **8/16/2016 2:51:07 PM**

Sample Information:

16-48 Roosevelt Lead Study

Client Sample ID: Bottle #05601
Collectors Name: Bill Bartlett
Sample Location: Room 214 DF Flush
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.00106		0.000103	mg/L	0.020 AL	8/12/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: **1608749**
NRC Sample ID: **1608749-38A**
Collection Date: **8/11/2016 4:49:00 PM**
Received Date: **8/12/2016 8:49:00 AM**
Reported Date: **8/16/2016 2:51:07 PM**

Sample Information:

16-48 Roosevelt Lead Study

Client Sample ID: Bottle #05833
Collectors Name: Caleb Dix
Sample Location: Room 130 DF
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.0278	*CF	0.0001	mg/L	0.020 AL	8/13/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR0028

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: **1608749**
NRC Sample ID: **1608749-39A**
Collection Date: **8/11/2016 4:50:00 PM**
Received Date: **8/12/2016 8:49:00 AM**
Reported Date: **8/16/2016 2:51:07 PM**

Sample Information:

16-48 Roosevelt Lead Study

Client Sample ID: Bottle #05817
Collectors Name: Caleb Dix
Sample Location: Room 130 DF Flush
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.00101		0.000103	mg/L	0.020 AL	8/12/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: **1608749**
NRC Sample ID: **1608749-40A**
Collection Date: **8/11/2016 4:56:00 PM**
Received Date: **8/12/2016 8:49:00 AM**
Reported Date: **8/16/2016 2:51:07 PM**

Sample Information:

16-48 Roosevelt Lead Study

Client Sample ID: Bottle #05835
Collectors Name: Caleb Dix
Sample Location: RR Near 120 DF Upr
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.0309	*CF	0.000103	mg/L	0.020 AL	8/12/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: **1608749**
NRC Sample ID: **1608749-41A**
Collection Date: **8/11/2016 4:57:00 PM**
Received Date: **8/12/2016 8:49:00 AM**
Reported Date: **8/16/2016 2:51:07 PM**

Sample Information:

16-48 Roosevelt Lead Study

Client Sample ID: Bottle #05819
Collectors Name: Caleb Dix
Sample Location: RR Near 120 DF Lwr
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.0152	CF	0.000103	mg/L	0.020 AL	8/12/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR0028

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: **1608749**
NRC Sample ID: **1608749-42A**
Collection Date: **8/11/2016 4:59:00 PM**
Received Date: **8/12/2016 8:49:00 AM**
Reported Date: **8/16/2016 2:51:07 PM**

Sample Information:

16-48 Roosevelt Lead Study

Client Sample ID: Bottle #05811
Collectors Name: Caleb Dix
Sample Location: RR Near 120 DF Lwr Flush
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.000567		0.000103	mg/L	0.020 AL	8/12/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR0028

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: **1608749**
NRC Sample ID: **1608749-43A**
Collection Date: **8/11/2016 5:02:00 PM**
Received Date: **8/12/2016 8:49:00 AM**
Reported Date: **8/16/2016 2:51:07 PM**

Sample Information:

16-48 Roosevelt Lead Study

Client Sample ID: Bottle #05832
Collectors Name: Caleb Dix
Sample Location: Room 120 DF
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.0248	*CF	0.000103	mg/L	0.020 AL	8/12/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: **1608749**
NRC Sample ID: **1608749-44A**
Collection Date: **8/11/2016 5:06:00 PM**
Received Date: **8/12/2016 8:49:00 AM**
Reported Date: **8/16/2016 2:51:07 PM**

Sample Information:

16-48 Roosevelt Lead Study

Client Sample ID: Bottle #05830
Collectors Name: Caleb Dix
Sample Location: Room 121 DF
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.0111		0.0001	mg/L	0.020 AL	8/13/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: **1608749**
NRC Sample ID: **1608749-45A**
Collection Date: **8/11/2016 5:09:00 PM**
Received Date: **8/12/2016 8:49:00 AM**
Reported Date: **8/16/2016 2:51:07 PM**

Sample Information:

16-48 Roosevelt Lead Study

Client Sample ID: Bottle #05827
Collectors Name: Caleb Dix
Sample Location: Room 122 DF
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.0111		0.0001	mg/L	0.020 AL	8/13/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR0028

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: **1608749**
NRC Sample ID: **1608749-46A**
Collection Date: **8/11/2016 5:13:00 PM**
Received Date: **8/12/2016 8:49:00 AM**
Reported Date: **8/16/2016 2:51:07 PM**

Sample Information:

16-48 Roosevelt Lead Study

Client Sample ID: Bottle #05804
Collectors Name: Caleb Dix
Sample Location: Gym DF Upper
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.00322		0.000103	mg/L	0.020 AL	8/12/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: **1608749**
NRC Sample ID: **1608749-47A**
Collection Date: **8/11/2016 5:14:00 PM**
Received Date: **8/12/2016 8:49:00 AM**
Reported Date: **8/16/2016 2:51:07 PM**

Sample Information:

16-48 Roosevelt Lead Study

Client Sample ID: Bottle #05800
Collectors Name: Caleb Dix
Sample Location: Gym DF Lower
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.00257		0.000103	mg/L	0.020 AL	8/12/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR0028

Medford School District

815 S Oakdale Ave
Medford, OR 97501

Lab Order: **1608749**

NRC Sample ID: **1608749-48A**

Collection Date: **8/11/2016 5:15:00 PM**

Received Date: **8/12/2016 8:49:00 AM**

Reported Date: **8/16/2016 2:51:07 PM**

Sample Information:

16-48 Roosevelt Lead Study

Client Sample ID: Bottle #05815

Collectors Name: Caleb Dix

Sample Location: Gym DF Lower Flush

Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.000662		0.000103	mg/L	0.020 AL	8/12/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR0028

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: **1608749**
NRC Sample ID: **1608749-49A**
Collection Date: **8/11/2016 5:20:00 PM**
Received Date: **8/12/2016 8:49:00 AM**
Reported Date: **8/16/2016 2:51:07 PM**

Sample Information:

16-48 Roosevelt Lead Study

Client Sample ID: Bottle #05824
Collectors Name: Caleb Dix
Sample Location: Play Shaded Struc DF
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.0120		0.0001	mg/L	0.020 AL	8/13/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: **1608749**
NRC Sample ID: **1608749-50A**
Collection Date: **8/11/2016 5:24:00 PM**
Received Date: **8/12/2016 8:49:00 AM**
Reported Date: **8/16/2016 2:51:07 PM**

Sample Information:

16-48 Roosevelt Lead Study

Client Sample ID: Bottle #05829
Collectors Name: Caleb Dix
Sample Location: 2nd Flr Out. B.R.R. DF Upr
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.0260	*CF	0.0001	mg/L	0.020 AL	8/13/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR0028

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: **1608749**
NRC Sample ID: **1608749-51A**
Collection Date: **8/11/2016 5:25:00 PM**
Received Date: **8/12/2016 8:49:00 AM**
Reported Date: **8/16/2016 2:51:07 PM**

Sample Information:

16-48 Roosevelt Lead Study

Client Sample ID: Bottle #05818
Collectors Name: Caleb Dix
Sample Location: 2nd Flr Out. B.R.R. DF Lwr
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.0250	*CF	0.000103	mg/L	0.020 AL	8/12/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR0028

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: **1608749**
NRC Sample ID: **1608749-52A**
Collection Date: **8/11/2016 5:29:00 PM**
Received Date: **8/12/2016 8:49:00 AM**
Reported Date: **8/16/2016 2:51:07 PM**

Sample Information:

16-48 Roosevelt Lead Study

Client Sample ID: Bottle #05808
Collectors Name: Caleb Dix
Sample Location: Room 231 DF
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.0160	CF	0.0001	mg/L	0.020 AL	8/13/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: **1608749**
NRC Sample ID: **1608749-53A**
Collection Date: **8/11/2016 8:21:00 PM**
Received Date: **8/12/2016 8:49:00 AM**
Reported Date: **8/16/2016 2:51:07 PM**

Sample Information:

16-48 Roosevelt Lead Study

Client Sample ID: Bottle #05823
Collectors Name: Caleb Dix
Sample Location: Caf DF Upper
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.00132		0.0001	mg/L	0.020 AL	8/13/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: **1608749**
NRC Sample ID: **1608749-54A**
Collection Date: **8/11/2016 8:22:00 PM**
Received Date: **8/12/2016 8:49:00 AM**
Reported Date: **8/16/2016 2:51:07 PM**

Sample Information:

16-48 Roosevelt Lead Study

Client Sample ID: Bottle #05821
Collectors Name: Caleb Dix
Sample Location: Caf DF Lower
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.00138		0.0001	mg/L	0.020 AL	8/13/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: **1608749**
NRC Sample ID: **1608749-55A**
Collection Date: **8/11/2016 8:18:00 PM**
Received Date: **8/12/2016 8:49:00 AM**
Reported Date: **8/16/2016 2:51:07 PM**

Sample Information:

16-48 Roosevelt Lead Study

Client Sample ID: Bottle #05801
Collectors Name: Caleb Dix
Sample Location: Kitchen Food Prep Sink
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.00199		0.0001	mg/L	0.020 AL	8/13/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

DATA FLAGS

B	Analyte detected in the associated method blank.
BA	BOD Alternative Calculation: The initial results performed by Standard Methods did not fall within parameters of the Standard Methods calculation. An alternate approved calculation was performed using the HACH method and the value reported is an estimated concentration.
C	Sample(s) does not meet NELAP/ORELAP sample acceptance criteria. See Case Narrative.
C1	Sample(s) does not meet NELAP/ORELAP sample acceptance criteria for temperature.
CF	Results confirmed by re-analysis.
CU	Cleanup performed as specified by method.
D1	The diesel elution pattern for the sample is not typical.
D2	The sample appears to be a heavier hydrocarbon range than diesel.
D3	The sample appears to be a lighter hydrocarbon range than diesel.
D4	Detected hydrocarbons do not have pattern and range consistent with typical petroleum products and may be due to biogenic interference.
D5	Detected hydrocarbons in the diesel range appear to be weathered diesel.
E	Estimated value.
ER	Elevated reporting limit due to matrix. Report limits (MDLs, MRLs & PQLs) are adjusted based on variations in sample preparation amounts, analytical dilutions, and percent solids, where applicable.
FC	Fecal Coliforms: Sample(s) received past 40 CFR Part 136 specified holding time. Results reported as estimated values.
G1	The gasoline elution pattern for the sample is not typical.
G2	The sample appears to be a heavier hydrocarbon range than gasoline.
G3	The sample appears to be a lighter hydrocarbon range than gasoline.
G4	Detected hydrocarbons in the gasoline range appear to be weathered gasoline.
HP	Sample re-analysis performed outside of method specified holding time.
HR	Sample received outside of method specified holding time.
HS	Sample analyzed for volatile organics contained headspace.
HT	At the client's request, the sample was analyzed outside of method specified holding time.
H	Analysis performed outside of method specified holding time.
J	Analyte detected below the Minimum Reporting Limit (MRL) and above the Method Detection Limit (MDL). The J flag result is an estimated value and the user should be aware that this data is of limited reliability.
MI	Surrogate or Matrix Spike recovery is out of control limits due to matrix interference. Sample results may be biased.
N	See Case Narrative on page 2 of report.
Q	Closing continuing calibration verification (CCV) or laboratory control sample (LCS) exceeded high recovery limits, but associated samples are non-detect and the sample results are not affected. Data meets EPA/NELAP requirements.
R	Relative percent difference (RPD) is outside of the accepted recovery limits.
R1	Relative percent difference (RPD) is outside of the accepted recovery limits. However, analyses are not controlled on RPD values for sample concentrations that are less than the reporting limit.
R3	The relative percent difference (RPD) and/or percent recovery for the duplicate (DUP) or matrix spike (MS)/matrix spike duplicate (MSD) cannot be accurately calculated due to the concentration of analyte already present in the sample.
R4	Duplicate analysis failed due to result being at or near method reporting limit.
S	Surrogate and/or matrix spike recovery is outside of the accepted recovery limits. Sample results may be biased.
S1	Surrogate or matrix spike recovery is outside of control limits due to dilution necessary for analysis.
SC	Sub-contracted to another laboratory for analysis.
SP	Sample(s) were not collected per EPA Method 5035A protocols. The results are considered minimum values.
T	Toxicity Characteristic Leaching Procedure – Sample submitted contained < 0.5% solids. If the waste contains <0.5% dry solids, the liquid portion of the waste, after filtration, is defined as the TCLP extract.
#	Value exceeds regulatory level for TCLP contaminant.
X1	The motor oil elution pattern for the sample is not typical.
X2	The sample appears to be a heavier hydrocarbon range than motor oil.
X3	The sample appears to be a lighter hydrocarbon range than motor oil.
*	Value exceeds Maximum Contaminant Level or is outside the acceptable range.

NRC SOP QA-1104/AD-3100

Revision 3

Effective Date: 6/3/16

CLIENT: Medford School District
Work Order: 1608749
Project: 16-48 Roosevelt Lead Study

ANALYTICAL QC SUMMARY REPORT

TestCode: ICPMS_200.8_SCHOOL

Sample ID MB-36229	SampType: MBLK	TestCode: ICPMS_200.8	Units: mg/L	Prep Date: 8/12/2016	RunNo: 89178						
Client ID: ZZZZZ	Batch ID: 36229	TestNo: EPA 200.8	(EPA 200.8)	Analysis Date: 8/12/2016	SeqNo: 1343666						
Analyte	Result	MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead ND 0.000103

Sample ID MB-36230	SampType: MBLK	TestCode: ICPMS_200.8	Units: mg/L	Prep Date: 8/12/2016	RunNo: 89178						
Client ID: ZZZZZ	Batch ID: 36230	TestNo: EPA 200.8	(EPA 200.8)	Analysis Date: 8/12/2016	SeqNo: 1343693						
Analyte	Result	MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead ND 0.000103

Sample ID MB-36231	SampType: MBLK	TestCode: ICPMS_200.8	Units: mg/L	Prep Date: 8/12/2016	RunNo: 89178						
Client ID: ZZZZZ	Batch ID: 36231	TestNo: EPA 200.8	(EPA 200.8)	Analysis Date: 8/12/2016	SeqNo: 1343720						
Analyte	Result	MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead ND 0.000103

Sample ID MB-36232	SampType: MBLK	TestCode: ICPMS_200.8	Units: mg/L	Prep Date: 8/12/2016	RunNo: 89182						
Client ID: ZZZZZ	Batch ID: 36232	TestNo: EPA 200.8	(EPA 200.8)	Analysis Date: 8/13/2016	SeqNo: 1343937						
Analyte	Result	MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead ND 0.000100

Sample ID LCS-36229	SampType: LCS	TestCode: ICPMS_200.8	Units: mg/L	Prep Date: 8/12/2016	RunNo: 89178						
Client ID: ZZZZZ	Batch ID: 36229	TestNo: EPA 200.8	(EPA 200.8)	Analysis Date: 8/12/2016	SeqNo: 1343667						
Analyte	Result	MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead 0.09681 0.000104 0.1 0 96.8 85 115

Qualifiers: E Value above quantitation range H Holding times for preparation or analysis exceeded J Analyte detected below quantitation limits
 ND Not Detected at the Minimum Reporting Limit R RPD outside accepted recovery limits S Spike Recovery outside accepted recovery limits

CLIENT: Medford School District
Work Order: 1608749
Project: 16-48 Roosevelt Lead Study

ANALYTICAL QC SUMMARY REPORT

TestCode: ICPMS_200.8_SCHOOL

Sample ID	LCS-36230	SampType:	LCS	TestCode:	ICPMS_200.8	Units:	mg/L	Prep Date:	8/12/2016	RunNo:	89178					
Client ID:	ZZZZZ	Batch ID:	36230	TestNo:	EPA 200.8		(EPA 200.8)	Analysis Date:	8/12/2016	SeqNo:	1343694					
Analyte		Result		MRL		SPK value		SPK Ref Val		%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead 0.09851 0.000104 0.1 0 98.5 85 115

Sample ID	LCS-36231	SampType:	LCS	TestCode:	ICPMS_200.8	Units:	mg/L	Prep Date:	8/12/2016	RunNo:	89178					
Client ID:	ZZZZZ	Batch ID:	36231	TestNo:	EPA 200.8		(EPA 200.8)	Analysis Date:	8/12/2016	SeqNo:	1343721					
Analyte		Result		MRL		SPK value		SPK Ref Val		%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead 0.09864 0.000104 0.1 0 98.6 85 115

Sample ID	LCS-36232	SampType:	LCS	TestCode:	ICPMS_200.8	Units:	mg/L	Prep Date:	8/12/2016	RunNo:	89182					
Client ID:	ZZZZZ	Batch ID:	36232	TestNo:	EPA 200.8		(EPA 200.8)	Analysis Date:	8/13/2016	SeqNo:	1343938					
Analyte		Result		MRL		SPK value		SPK Ref Val		%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead 0.1015 0.000100 0.1 0 102 85 115

Sample ID	1608749-21AMS	SampType:	MS	TestCode:	ICPMS_200.8	Units:	mg/L	Prep Date:	8/12/2016	RunNo:	89178					
Client ID:	Bottle #05810	Batch ID:	36229	TestNo:	EPA 200.8		(EPA 200.8)	Analysis Date:	8/12/2016	SeqNo:	1343689					
Analyte		Result		MRL		SPK value		SPK Ref Val		%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead 0.1084 0.000104 0.1 0.01127 97.1 70 130

Sample ID	1608749-43AMS	SampType:	MS	TestCode:	ICPMS_200.8	Units:	mg/L	Prep Date:	8/12/2016	RunNo:	89178					
Client ID:	Bottle #05832	Batch ID:	36230	TestNo:	EPA 200.8		(EPA 200.8)	Analysis Date:	8/12/2016	SeqNo:	1343716					
Analyte		Result		MRL		SPK value		SPK Ref Val		%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead 0.1194 0.000104 0.1 0.02478 94.6 70 130

Qualifiers: E Value above quantitation range H Holding times for preparation or analysis exceeded J Analyte detected below quantitation limits
 ND Not Detected at the Minimum Reporting Limit R RPD outside accepted recovery limits S Spike Recovery outside accepted recovery limits

CLIENT: Medford School District
 Work Order: 1608749
 Project: 16-48 Roosevelt Lead Study

ANALYTICAL QC SUMMARY REPORT

TestCode: ICPMS_200.8_SCHOOL

Sample ID	1608749-51AMS	SampType: MS	TestCode: ICPMS_200.8	Units: mg/L	Prep Date: 8/12/2016	RunNo: 89178					
Client ID:	Bottle #05818	Batch ID: 36231	TestNo: EPA 200.8	(EPA 200.8)	Analysis Date: 8/12/2016	SeqNo: 1343730					
Analyte	Result	MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	0.1211	0.000104	0.1	0.02502	96.0	70	130				
------	--------	----------	-----	---------	------	----	-----	--	--	--	--

Sample ID	1608749-55AMS	SampType: MS	TestCode: ICPMS_200.8	Units: mg/L	Prep Date: 8/12/2016	RunNo: 89182					
Client ID:	Bottle #05801	Batch ID: 36232	TestNo: EPA 200.8	(EPA 200.8)	Analysis Date: 8/13/2016	SeqNo: 1343958					
Analyte	Result	MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	0.09490	0.000100	0.1	0.001991	92.9	70	130				
------	---------	----------	-----	----------	------	----	-----	--	--	--	--

Sample ID	1608749-21AMSD	SampType: MSD	TestCode: ICPMS_200.8	Units: mg/L	Prep Date: 8/12/2016	RunNo: 89178					
Client ID:	Bottle #05810	Batch ID: 36229	TestNo: EPA 200.8	(EPA 200.8)	Analysis Date: 8/12/2016	SeqNo: 1343690					
Analyte	Result	MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	0.1070	0.000104	0.1	0.01127	95.7	70	130	0.1084	1.26	20	
------	--------	----------	-----	---------	------	----	-----	--------	------	----	--

Sample ID	1608749-43AMSD	SampType: MSD	TestCode: ICPMS_200.8	Units: mg/L	Prep Date: 8/12/2016	RunNo: 89178					
Client ID:	Bottle #05832	Batch ID: 36230	TestNo: EPA 200.8	(EPA 200.8)	Analysis Date: 8/12/2016	SeqNo: 1343717					
Analyte	Result	MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	0.1212	0.000104	0.1	0.02478	96.4	70	130	0.1194	1.47	20	
------	--------	----------	-----	---------	------	----	-----	--------	------	----	--

Sample ID	1608749-51AMSD	SampType: MSD	TestCode: ICPMS_200.8	Units: mg/L	Prep Date: 8/12/2016	RunNo: 89178					
Client ID:	Bottle #05818	Batch ID: 36231	TestNo: EPA 200.8	(EPA 200.8)	Analysis Date: 8/12/2016	SeqNo: 1343731					
Analyte	Result	MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	0.1226	0.000104	0.1	0.02502	97.6	70	130	0.1211	1.28	20	
------	--------	----------	-----	---------	------	----	-----	--------	------	----	--

Qualifiers: E Value above quantitation range H Holding times for preparation or analysis exceeded J Analyte detected below quantitation limits
 ND Not Detected at the Minimum Reporting Limit R RPD outside accepted recovery limits S Spike Recovery outside accepted recovery limits

CLIENT: Medford School District
Work Order: 1608749
Project: 16-48 Roosevelt Lead Study

ANALYTICAL QC SUMMARY REPORT

TestCode: ICPMS_200.8_SCHOOL

Sample ID 1608749-55AMSD	SampType: MSD	TestCode: ICPMS_200.8	Units: mg/L	Prep Date: 8/12/2016	RunNo: 89182						
Client ID: Bottle #05801	Batch ID: 36232	TestNo: EPA 200.8	(EPA 200.8)	Analysis Date: 8/13/2016	SeqNo: 1343959						
Analyte	Result	MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	0.09579	0.000100	0.1	0.001991	93.8	70	130	0.0949	0.933	20	

Qualifiers: E Value above quantitation range
 ND Not Detected at the Minimum Reporting Limit

H Holding times for preparation or analysis exceeded
 R RPD outside accepted recovery limits

J Analyte detected below quantitation limits
 S Spike Recovery outside accepted recovery limits



Environmental Testing Laboratory
 245 South Grape Street * Medford, OR 97501
 (541) 770-5678 Fax (541) 770-2901

Roosevelt Chain of Custody Record

Page 1 of 1

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Section A Required Client Information		Section B Required Project Information		Section C Invoice Information		Section D Rush Status (Subject to Scheduling)	
Company: <u>Hell Sch. Dist. 549C</u>		Project Name: <u>2016 Lead Testing</u>		Attention:		Standard 10-14 Days	
Address: <u>815 S. Oakdale</u>		Project Number:		Company Name:		5 Business Days (50% surcharge)	
City: <u>Medford, OR 97501</u>		Report To: <u>Trk. Rose @ medford.k12.or.us</u>		Address:		3 Business Days (75% surcharge)	
Email: <u>trk.rose@medford.k12.or.us</u>		Copy To: <u>con.hovind@medford.k12.or.us</u>		P.O. #		<input checked="" type="checkbox"/> 24-48 hours (100% surcharge)	
Phone: <u>541-944-5613</u> Fax:						Other	
Collected By (Print): <u>Larry Anderson</u>						Authorized Yes <input type="checkbox"/> No <input type="checkbox"/>	
Collected By (Sign): <u>[Signature]</u>							
Email Report <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		Mail Report <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No					
Fax Report <input type="checkbox"/> Yes <input type="checkbox"/> No							

Section E	Sample Information	Comp/Grab	Matrix	Date Collected	Time Collected	No. of Containers	Analysis Requested
	Room 110 - DE A	05618		8-11-16	4:08 PM	1	
	Room 110 - DE B	05787			4:30 PM	1	
	Room 110 - DE C	05793			4:33	1	
	Behind Study door, Infirmary Rm 110 DF	05795			4:36	1	
	Behind Study door, Infirmary Rm 110 Sink	05794			4:57	1	
	Room 114 DF	05622			5:01	2	
	Room 113 DF	05628			5:03	1	
	Room 112 DF	05605			5:10	1	
	Room 111 DF	05610			5:13	1	
	Health Room Sink Left Entry	05798			5:19	1	

NRC Workorder # (Lab Use Only)	1608749
Remarks/Field Data	Test Bank PC
NRC Sample # (Lab Use Only)	01
	02
	03
	04
	05
	06 107
	07 08
	08 09
	09 10
	10 11

Section F Relinquish/Receive		Section G Lab Use Only	
Relinquished By: <u>[Signature]</u>	Sign	Temp:	<u>10/10/16</u>
Received By: <u>[Signature]</u>	Sign	4°C +/- 2°C: Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>	
Relinquished By: <u>[Signature]</u>	Sign	Received on Ice: Yes <input type="checkbox"/> No <input checked="" type="checkbox"/>	
Received By: <u>[Signature]</u>	Sign	Number of Bottles Received: <u>11</u>	
Relinquished By: <u>[Signature]</u>	Sign	pH Checked: <u>NA</u>	
Received By: <u>[Signature]</u>	Sign	COC Seals Intact: Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> NA	
		Field Blank Included: Yes <input type="checkbox"/> No <input checked="" type="checkbox"/>	

Payment: Invoice Cash VISA, M/C Check # Amount

Received Via UPS FedEX Other Hand



Environmental Testing Laboratory
245 South Grape Street * Medford, OR 97501
(541) 770-5678 fax (541) 770-2901

Chain of Custody Record

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Page 3 of 2

Section A Required Client Information
 Company: Med. Sch. Dist. 599C
 Address: 815 S. Oakdale Medford, OR 97501
 Email: vick.ober@medsch.k12.or.us
 Phone: 541-944-5613 Fax:
 Collected By (Print): Bill Bertlett
 Collected By (Sign): Bill Bertlett
 Email Report Yes No Mail Report Yes No
 Fax Report Yes No

Section B Required Project Information
 Project Name: 2016 Lead Testing
 Project Number: Koesevelt
 Report To: Trk. Rose Checked: K12.or.us
 Copy To: Tom Koesevelt medsch.k12.or.us

Section C Invoice Information
 Attention: Koesevelt
 Company Name:
 Address:
 P.O. #

Section D Rush Status (Subject to Scheduling)
 Standard 10-14 Days
 5 Business Days (50% surcharge)
 3 Business Days (75% surcharge)
 24 - 48 hours (100% surcharge)
 Other:
 Authorized Yes No

Test 2 - 30 sec re-test of fixture

Section E Sample Information	Section F Matrix	Section G Date Collected	Section G Time Collected	Section G No. of Containers	Section G Analysis Requested	Section G NRC Workorder # (Lab Use Only)	Section G Remarks/Field Data (Lab Use Only)	Section G NRC Sample # (Lab Use Only)
Rm 240 - P.F.A	05796	8-11-16	4:57 PM	1		1608749		
Rm 240 - P.F.B	05797		4:52 PM	1				
Rm 240 - P.F.C	05810		4:54 PM	2				
Rm 241 - P.F.	05806		4:57 AM	2				
Rm 242 - P.F.	05809		5:00 PM	1				
Rm 243 - P.F.	05802		5:02 PM	1				
Staff Room, 204 Sink	05799		5:06 PM	1				
Staff Room, 204 Ins. Hot	05789		5:07 PM	1				
Rm 210 - P.F. A	05802		5:10 PM	2				
Rm 210 - P.F. B	05852		5:13 PM	1				

Section F Relinquish/Receive
 Relinquished By: Bill Bertlett Sign
 Received By: John Sessen
 Relinquished By: John Sessen
 Received By: Rick Ross
 Relinquished By:
 Received By Laboratory: John Sessen

Section G Lab Use Only
 Temp: 20.0
 4°C +/- 2°C: Yes No
 Received on Ice: Yes No
 Number of Bottles Received:
 pH Checked: MT
 COC Seals Intact: Yes No
 Field Blank Included: Yes No
 Received Via UPS FedEx Other Hand
 Payment Invoice Cash VISA/MC Check # Amount



Chain of Custody Record

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Roosevelt

Section A
Required Client Information
 Company: Mel Sch. Dist. 59C
 Address: 815 S. Oakdale
Medford, OR 97501
 Email: rick.rosenberg@medsch.k12.or.us
 Phone: 541-944-5813 Fax:
 Collected By (Print): Caleb Dix
 Collected By (Sign):
 Email Report Yes No Mail Report Yes No
 Fax Report Yes No

Section B
Required Project Information
 Project Name: 2016 Lead Testing
 Project Number: Roosevelt
 Report To: rick.rosenberg@medsch.k12.or.us
 Copy To: ron.davies@medsch.k12.or.us

Section C
Invoice Information
 Attention:
 Company Name:
 Address:
 P.O. #

Section D
Rush Status (Subject to Scheduling)
 Standard 10-14 Days
 5 Business Days (50% surcharge)
 3 Business Days (75% surcharge)
 24 - 48 hours (100% surcharge)
 Other:
 Authorized Yes No

Section E
Sample Information

Sample ID	Comp/Grab	Matrix*	Date Collected	Time Collected	No. of Containers	Analysis Requested
Rm. 130 - D.F.	05833		8/11/16	4:50 pm	2	Lead
Boy/Girl R.R. Near 130 - D.F. (Up)	05835			4:56 pm	1	
Boy/Girl R.R. Near 130 - D.F. (Low)	05819			4:57 pm	2	
Rm. 120 - D.F.	05832			5:02 pm	1	
Rm. 121 - D.F.	05830			5:06 pm	1	
Rm. 122 - D.F.	05827			5:04 pm	1	
Gym - D.F. (Upper)	05804			6:12 pm	1	
Gym - D.F. (Lower)	05800			6:14 pm	2	
Play. (Shade Struc.) - D.F.	05824			5:20 pm	1	
2nd Fir. Out. B.R.R. - D.F. (up)	05829			6:14 pm	1	


*Matrix: DW - Drinking Water WW - Wastewater W - Water S - Soil/Solid SL - Sludge O - Oil WP - Wipe OT - Other

Section F
Relinquish/Receive

Relinquished By:	Sign	Date	Time
John Jensen	[Signature]	8/11/16	5:34 pm
John Jensen	[Signature]	8/11/16	5:34 pm
John Jensen	[Signature]	8/12/16	7:45 am
John Jensen	[Signature]	8/12/16	7:45 am
John Jensen	[Signature]	8/12/16	7:45 am

Section G
Lab Use Only

Temp: <u>21.1°C</u>	Received on Ice: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
4°C +/- 2°C:	Number of Bottles Received: <u>13</u>
Received on Ice: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	pH Checked: <u>NA</u>
Number of Bottles Received: <u>13</u>	COG Seals Intact: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
pH Checked: <u>NA</u>	Field Blank Included: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
COG Seals Intact: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	Received Via: <input type="checkbox"/> UPS <input type="checkbox"/> FedEx <input checked="" type="checkbox"/> Other
Field Blank Included: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	Payment: <input checked="" type="checkbox"/> Invoice <input type="checkbox"/> Cash <input type="checkbox"/> VISA <input type="checkbox"/> M/C <input type="checkbox"/> Check #
Received Via: <input type="checkbox"/> UPS <input type="checkbox"/> FedEx <input checked="" type="checkbox"/> Other	Amount:



Environmental Testing Laboratory
245 South Grape Street * Medford, OR 97501
(541) 770-5678 fax (541) 770-2901

Chain of Custody Record

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Page 6 of

Section A Required Client Information
 Company: Med. Sch. Dist. 549C
 Address: 845 S. Oakdale Medford, OR 97501
 Email: vick.rose@medsch.k12.or.us
 Phone: 541-944-5613 Fax:
 Collected By (Print):
 Collected By (Sign):
 Email Report Yes No Mail Report Yes No
 Fax Report Yes No

Section B Required Project Information
 Project Name: 2016 Lead Testing
 Project Number: Roosevelt
 Report To: Vick. Rose@medsch.k12.or.us
 Copy To: Tom.Lovinger@medsch.k12.or.us

Section C Invoice Information
 Attention:
 Company Name:
 Address:
 P.O. #

Section D Rush Status (Subject to Scheduling)
 Standard 10-14 Days
 5 Business Days (50% surcharge)
 3 Business Days (75% surcharge)
 24 - 48 hours (100% surcharge)
 Other

Authorized Yes No

Section E Sample Information

Sample ID	Comp/Grab	Matrix	Date Collected	Time Collected	No. of Containers	Analysis Requested
<u>2nd Flr. Out. B.R.R. - D.F. (Low)</u>	<u>05818</u>	<u> </u>	<u>8/11/16</u>	<u>5:25 pm</u>	<u>1</u>	<u>Lead</u>
<u>Rm. 231 - D.F.</u>	<u>05808</u>	<u> </u>	<u> </u>	<u>5:24 pm</u>	<u>1</u>	<u> </u>
<u>Conf. DF (Upper)</u>	<u>05823</u>	<u> </u>	<u> </u>	<u>8:22 pm</u>	<u>1</u>	<u> </u>
<u>Conf. DF (Lower)</u>	<u>05821</u>	<u> </u>	<u> </u>	<u>8:22 pm</u>	<u>1</u>	<u> </u>
<u>Kitchen Food Prep Sink</u>	<u>05801</u>	<u> </u>	<u> </u>	<u>8:18 pm</u>	<u>1</u>	<u> </u>

Boiffett

Section F Relinquish/Receive

Relinquished By	Sign	Date	Time
<u>John Jensen</u>	<u> </u>	<u>8/11/16</u>	<u>6:34 am</u>
<u>John Jensen</u>	<u> </u>	<u>8/11/16</u>	<u>5:34 pm</u>
<u>John Jensen</u>	<u> </u>	<u>8/12/16</u>	<u>7:14 am</u>
<u>Rick Rose</u>	<u> </u>	<u>8/12/16</u>	<u>7:45 am</u>
<u>Tom Lovinger</u>	<u> </u>	<u>8/11/16</u>	<u>8:14 am</u>

Section G Lab Use Only

Temp: <u> </u>	Received on Ice: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
4°C +/- 2°C:	Number of Bottles Received: <u>5</u>
pH Checked: <u> </u>	COG Seals Intact: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
Field Blank Included: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	Received Via <u>UPS</u> FedEX <u> </u> Other <u> </u>
Amount	Payment: <input checked="" type="checkbox"/> Invoice <input type="checkbox"/> Cash <input type="checkbox"/> VISA <input type="checkbox"/> M/C <input type="checkbox"/> Check # <u> </u>

51
52
53
54
55