



# NEILSON RESEARCH CORPORATION

*Environmental Testing Laboratory*

7/29/2016

Rick Rose  
Medford School District  
815 S Oakdale Ave  
Medford, OR 97501

TEL: (541) 842-1138  
FAX 541-842-1160

RE: 16-48 Roosevelt Lead Study

Order No.: 1607444

Dear Rick Rose:

Neilson Research Corporation received 47 sample(s) on 7/12/2016 for the analyses presented in the following report.

The results relate only to the parameters tested or to the sample as received by the laboratory. This report shall not be reproduced except in full, without the written approval of Neilson Research Corporation. If you have any questions regarding these test results, please feel free to call.

Sincerely,  
Neilson Research Corporation

Alec C Smith  
Project Manager

# Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

## Analysis Report

ORELAP 100016  
EPA OR00028

**CLIENT:** Medford School District  
**Project:** 16-48 Roosevelt Lead Study  
**Lab Order:** 1607444

**Date:** 29-Jul-16

## CASE NARRATIVE

The analyses were performed according to the guidelines in the Neilson Research Corporation Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

Neilson Research Corporation certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

# Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

## Analysis Report

ORELAP 100016  
EPA OR00028

Medford School District  
815 S Oakdale Ave  
Medford, OR 97501

Lab Order: **1607444**  
NRC Sample ID: **1607444-01A**  
Collection Date: **7/12/2016 2:34:00 PM**  
Received Date: **7/12/2016 4:09:00 PM**  
Reported Date: **7/29/2016 7:55:39 AM**

### Sample Information:

16-48 Roosevelt Lead Study

Client Sample ID: Bottle #11373  
Collectors Name: Larry Anderson  
Sample Location: Room 110 DF A  
Source: City Water

## ANALYTICAL RESULTS

Analyses	Method	NELAP		Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
		Accredited	Result						
Copper	EPA 200.8	A	<b>2.75</b>	*	0.00515	mg/L	1.3 AL	7/21/2016	OML
Lead	EPA 200.8	A	<b>0.0730</b>	*	0.000103	mg/L	0.020 AL	7/21/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

# Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

## Analysis Report

ORELAP 100016  
EPA OR00028

Medford School District  
815 S Oakdale Ave  
Medford, OR 97501

Lab Order: **1607444**  
NRC Sample ID: **1607444-02A**  
Collection Date: **7/12/2016 2:38:00 PM**  
Received Date: **7/12/2016 4:09:00 PM**  
Reported Date: **7/29/2016 7:55:39 AM**

### Sample Information:

16-48 Roosevelt Lead Study

Client Sample ID: Bottle #11405  
Collectors Name: Larry Anderson  
Sample Location: Room 110 DF B  
Source: City Water

## ANALYTICAL RESULTS

Analyses	Method	NELAP		Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
		Accredited	Result						
Copper	EPA 200.8	A	<b>1.52</b>	*	0.00103	mg/L	1.3 AL	7/25/2016	OML
Lead	EPA 200.8	A	<b>0.0464</b>	*	0.000103	mg/L	0.020 AL	7/21/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

# Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

## Analysis Report

ORELAP 100016  
EPA OR00028

Medford School District  
815 S Oakdale Ave  
Medford, OR 97501

Lab Order: **1607444**  
NRC Sample ID: **1607444-03A**  
Collection Date: **7/12/2016 2:40:00 PM**  
Received Date: **7/12/2016 4:09:00 PM**  
Reported Date: **7/29/2016 7:55:39 AM**

### Sample Information:

16-48 Roosevelt Lead Study

Client Sample ID: Bottle #11379  
Collectors Name: Larry Anderson  
Sample Location: Room 110 DF C  
Source: City Water

## ANALYTICAL RESULTS

Analyses	Method	NELAP		Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
		Accredited	Result						
Copper	EPA 200.8	A	<b>2.02</b>	*	0.00515	mg/L	1.3 AL	7/25/2016	OML
Lead	EPA 200.8	A	<b>0.106</b>	*	0.000103	mg/L	0.020 AL	7/21/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

# Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

## Analysis Report

ORELAP 100016  
EPA OR00028

Medford School District  
815 S Oakdale Ave  
Medford, OR 97501

Lab Order: **1607444**  
NRC Sample ID: **1607444-04A**  
Collection Date: **7/12/2016 2:44:00 PM**  
Received Date: **7/12/2016 4:09:00 PM**  
Reported Date: **7/29/2016 7:55:39 AM**

### Sample Information:

16-48 Roosevelt Lead Study

Client Sample ID: Bottle #11378  
Collectors Name: Larry Anderson  
Sample Location: Behind Slider Frt Rm 110 DF  
Source: City Water

## ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.0361	*	0.000103	mg/L	0.020 AL	7/21/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

# Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

## Analysis Report

ORELAP 100016  
EPA OR00028

Medford School District  
815 S Oakdale Ave  
Medford, OR 97501

Lab Order: **1607444**  
NRC Sample ID: **1607444-05A**  
Collection Date: **7/12/2016 2:45:00 PM**  
Received Date: **7/12/2016 4:09:00 PM**  
Reported Date: **7/29/2016 7:55:39 AM**

### Sample Information:

16-48 Roosevelt Lead Study

Client Sample ID: Bottle #11380  
Collectors Name: Larry Anderson  
Sample Location: Behind Slider Frt Rm 110 Sk  
Source: City Water

## ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	<b>0.0363</b>	*	0.000103	mg/L	0.020 AL	7/21/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

# Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

## Analysis Report

ORELAP 100016  
EPA OR00028

Medford School District  
815 S Oakdale Ave  
Medford, OR 97501

Lab Order: **1607444**  
NRC Sample ID: **1607444-06A**  
Collection Date: **7/12/2016 2:48:00 PM**  
Received Date: **7/12/2016 4:09:00 PM**  
Reported Date: **7/29/2016 7:55:39 AM**

### Sample Information:

16-48 Roosevelt Lead Study

Client Sample ID: Bottle #11401  
Collectors Name: Larry Anderson  
Sample Location: Room 114 DF  
Source: City Water

## ANALYTICAL RESULTS

Analyses	Method	NELAP		Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
		Accredited	Result						
Copper	EPA 200.8	A	<b>2.42</b>	*	0.00515	mg/L	1.3 AL	7/21/2016	OML
Lead	EPA 200.8	A	<b>0.130</b>	*	0.000103	mg/L	0.020 AL	7/20/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

# Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

## Analysis Report

ORELAP 100016  
EPA OR00028

Medford School District  
815 S Oakdale Ave  
Medford, OR 97501

Lab Order: **1607444**  
NRC Sample ID: **1607444-07A**  
Collection Date: **7/12/2016 2:51:00 PM**  
Received Date: **7/12/2016 4:09:00 PM**  
Reported Date: **7/29/2016 7:55:39 AM**

### Sample Information:

16-48 Roosevelt Lead Study

Client Sample ID: Bottle #11393  
Collectors Name: Larry Anderson  
Sample Location: Room 113 DF  
Source: City Water

## ANALYTICAL RESULTS

Analyses	Method	NELAP		Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
		Accredited	Result						
Copper	EPA 200.8	A	1.31	*	0.00103	mg/L	1.3 AL	7/25/2016	OML
Lead	EPA 200.8	A	0.0537	*	0.000103	mg/L	0.020 AL	7/21/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

# Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

## Analysis Report

ORELAP 100016  
EPA OR00028

### Medford School District

815 S Oakdale Ave  
Medford, OR 97501

Lab Order: **1607444**

NRC Sample ID: **1607444-08A**

Collection Date: **7/12/2016 2:53:00 PM**

Received Date: **7/12/2016 4:09:00 PM**

Reported Date: **7/29/2016 7:55:39 AM**

### Sample Information:

### 16-48 Roosevelt Lead Study

Client Sample ID: Bottle #11364

Collectors Name: Larry Anderson

Sample Location: Room 112 DF

Source: City Water

## ANALYTICAL RESULTS

Analyses	Method	NELAP		Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
		Accredited	Result						
Copper	EPA 200.8	A	<b>2.10</b>	*	0.00515	mg/L	1.3 AL	7/25/2016	OML
Lead	EPA 200.8	A	<b>0.128</b>	*	0.000103	mg/L	0.020 AL	7/21/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

# Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

## Analysis Report

ORELAP 100016  
EPA OR00028

Medford School District  
815 S Oakdale Ave  
Medford, OR 97501

Lab Order: **1607444**  
NRC Sample ID: **1607444-09A**  
Collection Date: **7/12/2016 2:56:00 PM**  
Received Date: **7/12/2016 4:09:00 PM**  
Reported Date: **7/29/2016 7:55:39 AM**

### Sample Information:

16-48 Roosevelt Lead Study

Client Sample ID: Bottle #11398  
Collectors Name: Larry Anderson  
Sample Location: Room 111 DF  
Source: City Water

## ANALYTICAL RESULTS

Analyses	Method	NELAP		Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
		Accredited	Result						
Copper	EPA 200.8	A	1.55	*	0.00103	mg/L	1.3 AL	7/25/2016	OML
Lead	EPA 200.8	A	0.0589	*	0.000103	mg/L	0.020 AL	7/21/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

# Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

## Analysis Report

ORELAP 100016  
EPA OR00028

Medford School District  
815 S Oakdale Ave  
Medford, OR 97501

Lab Order: **1607444**  
NRC Sample ID: **1607444-10A**  
Collection Date: **7/12/2016 2:59:00 PM**  
Received Date: **7/12/2016 4:09:00 PM**  
Reported Date: **7/29/2016 7:55:39 AM**

### Sample Information:

16-48 Roosevelt Lead Study

Client Sample ID: Bottle #11385  
Collectors Name: Larry Anderson  
Sample Location: Health Rm Sink L Fixture  
Source: City Water

## ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.0648	*	0.000103	mg/L	0.020 AL	7/21/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

# Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

## Analysis Report

ORELAP 100016  
EPA OR00028

Medford School District  
815 S Oakdale Ave  
Medford, OR 97501

Lab Order: **1607444**  
NRC Sample ID: **1607444-11A**  
Collection Date: **7/12/2016 3:01:00 PM**  
Received Date: **7/12/2016 4:09:00 PM**  
Reported Date: **7/29/2016 7:55:39 AM**

### Sample Information:

16-48 Roosevelt Lead Study

Client Sample ID: Bottle #11399  
Collectors Name: Larry Anderson  
Sample Location: Health Rm Sink R Fixture  
Source: City Water

## ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.0693	*	0.000103	mg/L	0.020 AL	7/21/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

# Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

## Analysis Report

ORELAP 100016  
EPA OR00028

Medford School District  
815 S Oakdale Ave  
Medford, OR 97501

Lab Order: **1607444**  
NRC Sample ID: **1607444-12A**  
Collection Date: **7/12/2016 3:04:00 PM**  
Received Date: **7/12/2016 4:09:00 PM**  
Reported Date: **7/29/2016 7:55:39 AM**

### Sample Information:

16-48 Roosevelt Lead Study

Client Sample ID: Bottle #11371  
Collectors Name: Larry Anderson  
Sample Location: Room 140 DF A  
Source: City Water

## ANALYTICAL RESULTS

Analyses	Method	NELAP		Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
		Accredited	Result						
Copper	EPA 200.8	A	<b>1.73</b>	*	0.00515	mg/L	1.3 AL	7/25/2016	OML
Lead	EPA 200.8	A	<b>0.0716</b>	*	0.000103	mg/L	0.020 AL	7/21/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

# Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

## Analysis Report

ORELAP 100016  
EPA OR00028

Medford School District  
815 S Oakdale Ave  
Medford, OR 97501

Lab Order: **1607444**  
NRC Sample ID: **1607444-13A**  
Collection Date: **7/12/2016 3:07:00 PM**  
Received Date: **7/12/2016 4:09:00 PM**  
Reported Date: **7/29/2016 7:55:39 AM**

### Sample Information:

16-48 Roosevelt Lead Study

Client Sample ID: Bottle #11375  
Collectors Name: Larry Anderson  
Sample Location: Room 140 DF B  
Source: City Water

## ANALYTICAL RESULTS

Analyses	Method	NELAP		Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
		Accredited	Result						
Copper	EPA 200.8	A	<b>2.24</b>	*	0.00515	mg/L	1.3 AL	7/25/2016	OML
Lead	EPA 200.8	A	<b>0.0792</b>	*	0.000103	mg/L	0.020 AL	7/21/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

# Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

## Analysis Report

ORELAP 100016  
EPA OR00028

Medford School District  
815 S Oakdale Ave  
Medford, OR 97501

Lab Order: **1607444**  
NRC Sample ID: **1607444-14A**  
Collection Date: **7/12/2016 3:09:00 PM**  
Received Date: **7/12/2016 4:09:00 PM**  
Reported Date: **7/29/2016 7:55:39 AM**

### Sample Information:

16-48 Roosevelt Lead Study

Client Sample ID: Bottle #11394  
Collectors Name: Larry Anderson  
Sample Location: Room 141 DF  
Source: City Water

## ANALYTICAL RESULTS

Analyses	Method	NELAP		Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
		Accredited	Result						
Copper	EPA 200.8	A	<b>1.86</b>	*	0.00515	mg/L	1.3 AL	7/25/2016	OML
Lead	EPA 200.8	A	<b>0.105</b>	*	0.000103	mg/L	0.020 AL	7/21/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

# Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

## Analysis Report

ORELAP 100016  
EPA OR00028

Medford School District  
815 S Oakdale Ave  
Medford, OR 97501

Lab Order: **1607444**  
NRC Sample ID: **1607444-15A**  
Collection Date: **7/12/2016 3:12:00 PM**  
Received Date: **7/12/2016 4:09:00 PM**  
Reported Date: **7/29/2016 7:55:39 AM**

### Sample Information:

16-48 Roosevelt Lead Study

Client Sample ID: Bottle #19732  
Collectors Name: Larry Anderson  
Sample Location: Room 142 DF  
Source: City Water

## ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.0443	*	0.000103	mg/L	0.020 AL	7/21/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

# Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

## Analysis Report

ORELAP 100016  
EPA OR00028

Medford School District  
815 S Oakdale Ave  
Medford, OR 97501

Lab Order: **1607444**  
NRC Sample ID: **1607444-16A**  
Collection Date: **7/12/2016 3:14:00 PM**  
Received Date: **7/12/2016 4:09:00 PM**  
Reported Date: **7/29/2016 7:55:39 AM**

### Sample Information:

16-48 Roosevelt Lead Study

Client Sample ID: Bottle #11376  
Collectors Name: Larry Anderson  
Sample Location: Room 143 DF  
Source: City Water

## ANALYTICAL RESULTS

Analyses	Method	NELAP		Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
		Accredited	Result						
Copper	EPA 200.8	A	<b>1.94</b>	*	0.00515	mg/L	1.3 AL	7/25/2016	OML
Lead	EPA 200.8	A	<b>0.0761</b>	*	0.000103	mg/L	0.020 AL	7/21/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

# Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

## Analysis Report

ORELAP 100016  
EPA OR00028

Medford School District  
815 S Oakdale Ave  
Medford, OR 97501

Lab Order: **1607444**  
NRC Sample ID: **1607444-17A**  
Collection Date: **7/12/2016 3:17:00 PM**  
Received Date: **7/12/2016 4:09:00 PM**  
Reported Date: **7/29/2016 7:55:39 AM**

### Sample Information:

16-48 Roosevelt Lead Study

Client Sample ID: Bottle #11264  
Collectors Name: Larry Anderson  
Sample Location: Room 130 DF  
Source: City Water

## ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	<b>0.00272</b>		0.000103	mg/L	0.020 AL	7/21/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

# Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

## Analysis Report

ORELAP 100016  
EPA OR00028

Medford School District  
815 S Oakdale Ave  
Medford, OR 97501

Lab Order: **1607444**  
NRC Sample ID: **1607444-18A**  
Collection Date: **7/12/2016 3:12:00 PM**  
Received Date: **7/12/2016 4:09:00 PM**  
Reported Date: **7/29/2016 7:55:39 AM**

### Sample Information:

16-48 Roosevelt Lead Study

Client Sample ID: Bottle #11369  
Collectors Name: John Jessen  
Sample Location: Playground DF  
Source: City Water

## ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.0161		0.0001	mg/L	0.020 AL	7/20/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

# Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

## Analysis Report

ORELAP 100016  
EPA OR00028

Medford School District  
815 S Oakdale Ave  
Medford, OR 97501

Lab Order: **1607444**  
NRC Sample ID: **1607444-19A**  
Collection Date: **7/12/2016 2:41:00 PM**  
Received Date: **7/12/2016 4:09:00 PM**  
Reported Date: **7/29/2016 7:55:39 AM**

### Sample Information:

16-48 Roosevelt Lead Study

Client Sample ID: Bottle #11414  
Collectors Name: John Jessen  
Sample Location: Rm 204 Staff Brk Rm Sink  
Source: City Water

## ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.0769	*	0.000103	mg/L	0.020 AL	7/21/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

# Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

## Analysis Report

ORELAP 100016  
EPA OR00028

Medford School District  
815 S Oakdale Ave  
Medford, OR 97501

Lab Order: **1607444**  
NRC Sample ID: **1607444-20A**  
Collection Date: **7/12/2016 2:42:00 PM**  
Received Date: **7/12/2016 4:09:00 PM**  
Reported Date: **7/29/2016 7:55:39 AM**

### Sample Information:

16-48 Roosevelt Lead Study

Client Sample ID: Bottle #11365  
Collectors Name: John Jessen  
Sample Location: Rm 204 Staff Brk Rm Insta-Hot  
Source: City Water

## ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.000195		0.000103	mg/L	0.020 AL	7/21/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

# Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

## Analysis Report

ORELAP 100016  
EPA OR00028

Medford School District  
815 S Oakdale Ave  
Medford, OR 97501

Lab Order: **1607444**  
NRC Sample ID: **1607444-21A**  
Collection Date: **7/12/2016 2:57:00 PM**  
Received Date: **7/12/2016 4:09:00 PM**  
Reported Date: **7/29/2016 7:55:39 AM**

### Sample Information:

16-48 Roosevelt Lead Study

Client Sample ID: Bottle #11412  
Collectors Name: John Jessen  
Sample Location: Kitchen Food Prep Sink  
Source: City Water

## ANALYTICAL RESULTS

Analyses	Method	NELAP		Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
		Accredited	Result						
Copper	EPA 200.8	A	<b>2.68</b>	*	0.0025	mg/L	1.3 AL	7/21/2016	OML
Lead	EPA 200.8	A	<b>0.209</b>	*	0.0005	mg/L	0.020 AL	7/21/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

# Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

## Analysis Report

ORELAP 100016  
EPA OR00028

Medford School District  
815 S Oakdale Ave  
Medford, OR 97501

Lab Order: **1607444**  
NRC Sample ID: **1607444-22A**  
Collection Date: **7/12/2016 3:02:00 PM**  
Received Date: **7/12/2016 4:09:00 PM**  
Reported Date: **7/29/2016 7:55:39 AM**

### Sample Information:

16-48 Roosevelt Lead Study

Client Sample ID: Bottle #19701  
Collectors Name: Bill Bartlett  
Sample Location: Room 210 DF B  
Source: City Water

## ANALYTICAL RESULTS

Analyses	Method	NELAP		Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
		Accredited	Result						
Copper	EPA 200.8	A	<b>1.59</b>	*	0.00103	mg/L	1.3 AL	7/25/2016	OML
Lead	EPA 200.8	A	<b>0.0578</b>	*	0.000103	mg/L	0.020 AL	7/21/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

# Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

## Analysis Report

ORELAP 100016  
EPA OR00028

Medford School District  
815 S Oakdale Ave  
Medford, OR 97501

Lab Order: **1607444**  
NRC Sample ID: **1607444-23A**  
Collection Date: **7/12/2016 3:04:00 PM**  
Received Date: **7/12/2016 4:09:00 PM**  
Reported Date: **7/29/2016 7:55:39 AM**

### Sample Information:

16-48 Roosevelt Lead Study

Client Sample ID: Bottle #11397  
Collectors Name: Bill Bartlett  
Sample Location: Room 210 DF C  
Source: City Water

## ANALYTICAL RESULTS

Analyses	Method	NELAP		Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
		Accredited	Result						
Copper	EPA 200.8	A	<b>2.45</b>	*	0.00515	mg/L	1.3 AL	7/25/2016	OML
Lead	EPA 200.8	A	<b>0.100</b>	*	0.000103	mg/L	0.020 AL	7/21/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

# Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

## Analysis Report

ORELAP 100016  
EPA OR00028

Medford School District  
815 S Oakdale Ave  
Medford, OR 97501

Lab Order: **1607444**  
NRC Sample ID: **1607444-24A**  
Collection Date: **7/12/2016 3:06:00 PM**  
Received Date: **7/12/2016 4:09:00 PM**  
Reported Date: **7/29/2016 7:55:39 AM**

### Sample Information:

16-48 Roosevelt Lead Study

Client Sample ID: Bottle #19575  
Collectors Name: Bill Bartlett  
Sample Location: Room 211 DF  
Source: City Water

## ANALYTICAL RESULTS

Analyses	Method	NELAP		Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
		Accredited	Result						
Copper	EPA 200.8	A	<b>1.36</b>	*	0.00103	mg/L	1.3 AL	7/25/2016	OML
Lead	EPA 200.8	A	<b>0.0467</b>	*	0.000103	mg/L	0.020 AL	7/21/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

# Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

## Analysis Report

ORELAP 100016  
EPA OR00028

Medford School District  
815 S Oakdale Ave  
Medford, OR 97501

Lab Order: **1607444**  
NRC Sample ID: **1607444-25A**  
Collection Date: **7/12/2016 3:08:00 PM**  
Received Date: **7/12/2016 4:09:00 PM**  
Reported Date: **7/29/2016 7:55:39 AM**

### Sample Information:

16-48 Roosevelt Lead Study

Client Sample ID: Bottle #11267  
Collectors Name: Bill Bartlett  
Sample Location: Room 212 DF  
Source: City Water

## ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.0125		0.000103	mg/L	0.020 AL	7/21/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

# Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

## Analysis Report

ORELAP 100016  
EPA OR00028

Medford School District  
815 S Oakdale Ave  
Medford, OR 97501

Lab Order: **1607444**  
NRC Sample ID: **1607444-26A**  
Collection Date: **7/12/2016 3:10:00 PM**  
Received Date: **7/12/2016 4:09:00 PM**  
Reported Date: **7/29/2016 7:55:39 AM**

### Sample Information:

16-48 Roosevelt Lead Study

Client Sample ID: Bottle #11368  
Collectors Name: Bill Bartlett  
Sample Location: Room 213 DF  
Source: City Water

## ANALYTICAL RESULTS

Analyses	Method	NELAP		Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
		Accredited	Result						
Copper	EPA 200.8	A	<b>1.77</b>	*	0.00515	mg/L	1.3 AL	7/25/2016	OML
Lead	EPA 200.8	A	<b>0.0528</b>	*	0.000103	mg/L	0.020 AL	7/21/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

# Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

## Analysis Report

ORELAP 100016  
EPA OR00028

Medford School District  
815 S Oakdale Ave  
Medford, OR 97501

Lab Order: **1607444**  
NRC Sample ID: **1607444-27A**  
Collection Date: **7/12/2016 3:11:00 PM**  
Received Date: **7/12/2016 4:09:00 PM**  
Reported Date: **7/29/2016 7:55:39 AM**

### Sample Information:

16-48 Roosevelt Lead Study

Client Sample ID: Bottle #19569  
Collectors Name: Bill Bartlett  
Sample Location: Room 214 DF  
Source: City Water

## ANALYTICAL RESULTS

Analyses	Method	NELAP		Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
		Accredited	Result						
Copper	EPA 200.8	A	<b>1.56</b>	*	0.00515	mg/L	1.3 AL	7/22/2016	OML
Lead	EPA 200.8	A	<b>0.0353</b>	*	0.000103	mg/L	0.020 AL	7/22/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

# Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

## Analysis Report

ORELAP 100016  
EPA OR00028

Medford School District  
815 S Oakdale Ave  
Medford, OR 97501

Lab Order: **1607444**  
NRC Sample ID: **1607444-28A**  
Collection Date: **7/12/2016 3:14:00 PM**  
Received Date: **7/12/2016 4:09:00 PM**  
Reported Date: **7/29/2016 7:55:39 AM**

### Sample Information:

16-48 Roosevelt Lead Study

Client Sample ID: Bottle #19723  
Collectors Name: Bill Bartlett  
Sample Location: 2nd Flr OS Boys RR DF Upr  
Source: City Water

## ANALYTICAL RESULTS

Analyses	Method	NELAP		Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
		Accredited	Result						
Copper	EPA 200.8	A	<b>2.15</b>	*	0.00515	mg/L	1.3 AL	7/22/2016	OML
Lead	EPA 200.8	A	<b>0.0882</b>	*	0.000103	mg/L	0.020 AL	7/22/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

# Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

## Analysis Report

ORELAP 100016  
EPA OR00028

Medford School District  
815 S Oakdale Ave  
Medford, OR 97501

Lab Order: **1607444**  
NRC Sample ID: **1607444-29A**  
Collection Date: **7/12/2016 3:14:00 PM**  
Received Date: **7/12/2016 4:09:00 PM**  
Reported Date: **7/29/2016 7:55:39 AM**

### Sample Information:

**16-48 Roosevelt Lead Study**

Client Sample ID: Bottle #11275  
Collectors Name: Bill Bartlett  
Sample Location: 2nd Flr OS Boys RR DF Lwr  
Source: City Water

## ANALYTICAL RESULTS

Analyses	Method	NELAP		Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
		Accredited	Result						
Copper	EPA 200.8	A	<b>1.63</b>	*	0.00515	mg/L	1.3 AL	7/22/2016	OML
Lead	EPA 200.8	A	<b>0.0571</b>	*	0.000103	mg/L	0.020 AL	7/22/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

# Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

## Analysis Report

ORELAP 100016  
EPA OR00028

Medford School District  
815 S Oakdale Ave  
Medford, OR 97501

Lab Order: **1607444**  
NRC Sample ID: **1607444-30A**  
Collection Date: **7/12/2016 3:16:00 PM**  
Received Date: **7/12/2016 4:09:00 PM**  
Reported Date: **7/29/2016 7:55:39 AM**

### Sample Information:

16-48 Roosevelt Lead Study

Client Sample ID: Bottle #19705  
Collectors Name: Bill Bartlett  
Sample Location: Room 231 DF  
Source: City Water

## ANALYTICAL RESULTS

Analyses	Method	NELAP		Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
		Accredited	Result						
Copper	EPA 200.8	A	1.51	*	0.00515	mg/L	1.3 AL	7/22/2016	OML
Lead	EPA 200.8	A	0.0530	*	0.000103	mg/L	0.020 AL	7/22/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

# Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

## Analysis Report

ORELAP 100016  
EPA OR00028

Medford School District  
815 S Oakdale Ave  
Medford, OR 97501

Lab Order: **1607444**  
NRC Sample ID: **1607444-31A**  
Collection Date: **7/12/2016 2:50:00 PM**  
Received Date: **7/12/2016 4:09:00 PM**  
Reported Date: **7/29/2016 7:55:39 AM**

### Sample Information:

16-48 Roosevelt Lead Study

Client Sample ID: Bottle #11244  
Collectors Name: Bill Bartlett  
Sample Location: Room 240 DF A  
Source: City Water

## ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.00263		0.000103	mg/L	0.020 AL	7/22/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

# Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

## Analysis Report

ORELAP 100016  
EPA OR00028

Medford School District  
815 S Oakdale Ave  
Medford, OR 97501

Lab Order: **1607444**  
NRC Sample ID: **1607444-32A**  
Collection Date: **7/12/2016 2:51:00 PM**  
Received Date: **7/12/2016 4:09:00 PM**  
Reported Date: **7/29/2016 7:55:39 AM**

### Sample Information:

16-48 Roosevelt Lead Study

Client Sample ID: Bottle #11252  
Collectors Name: Bill Bartlett  
Sample Location: Room 240 DF B  
Source: City Water

## ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	<b>0.0288</b>	*	0.000103	mg/L	0.020 AL	7/22/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

# Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

## Analysis Report

ORELAP 100016  
EPA OR00028

Medford School District  
815 S Oakdale Ave  
Medford, OR 97501

Lab Order: **1607444**  
NRC Sample ID: **1607444-33A**  
Collection Date: **7/12/2016 2:54:00 PM**  
Received Date: **7/12/2016 4:09:00 PM**  
Reported Date: **7/29/2016 7:55:39 AM**

### Sample Information:

16-48 Roosevelt Lead Study

Client Sample ID: Bottle #11382  
Collectors Name: Bill Bartlett  
Sample Location: Room 240 DF C  
Source: City Water

## ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.000926		0.000103	mg/L	0.020 AL	7/22/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

# Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

## Analysis Report

ORELAP 100016  
EPA OR00028

Medford School District  
815 S Oakdale Ave  
Medford, OR 97501

Lab Order: **1607444**  
NRC Sample ID: **1607444-34A**  
Collection Date: **7/12/2016 2:55:00 PM**  
Received Date: **7/12/2016 4:09:00 PM**  
Reported Date: **7/29/2016 7:55:39 AM**

### Sample Information:

16-48 Roosevelt Lead Study

Client Sample ID: Bottle #11403  
Collectors Name: Bill Bartlett  
Sample Location: Room 241 DF  
Source: City Water

## ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.0292	*	0.000103	mg/L	0.020 AL	7/22/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

# Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

## Analysis Report

ORELAP 100016  
EPA OR00028

Medford School District  
815 S Oakdale Ave  
Medford, OR 97501

Lab Order: **1607444**  
NRC Sample ID: **1607444-35A**  
Collection Date: **7/12/2016 2:57:00 PM**  
Received Date: **7/12/2016 4:09:00 PM**  
Reported Date: **7/29/2016 7:55:39 AM**

### Sample Information:

16-48 Roosevelt Lead Study

Client Sample ID: Bottle #11441  
Collectors Name: Bill Bartlett  
Sample Location: Room 242 DF  
Source: City Water

## ANALYTICAL RESULTS

Analyses	Method	NELAP		Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
		Accredited	Result						
Copper	EPA 200.8	A	1.32	*	0.00515	mg/L	1.3 AL	7/22/2016	OML
Lead	EPA 200.8	A	0.00771		0.000103	mg/L	0.020 AL	7/22/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

# Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

## Analysis Report

ORELAP 100016  
EPA OR00028

Medford School District  
815 S Oakdale Ave  
Medford, OR 97501

Lab Order: **1607444**  
NRC Sample ID: **1607444-36A**  
Collection Date: **7/12/2016 2:52:00 PM**  
Received Date: **7/12/2016 4:09:00 PM**  
Reported Date: **7/29/2016 7:55:39 AM**

### Sample Information:

16-48 Roosevelt Lead Study

Client Sample ID: Bottle #11265  
Collectors Name: Bill Bartlett  
Sample Location: Room 243 DF  
Source: City Water

## ANALYTICAL RESULTS

Analyses	Method	NELAP		Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
		Accredited	Result						
Copper	EPA 200.8	A	<b>1.54</b>	*	0.00515	mg/L	1.3 AL	7/22/2016	OML
Lead	EPA 200.8	A	<b>0.0455</b>	*	0.000103	mg/L	0.020 AL	7/22/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

# Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

## Analysis Report

ORELAP 100016  
EPA OR00028

Medford School District  
815 S Oakdale Ave  
Medford, OR 97501

Lab Order: **1607444**  
NRC Sample ID: **1607444-37A**  
Collection Date: **7/12/2016 3:01:00 PM**  
Received Date: **7/12/2016 4:09:00 PM**  
Reported Date: **7/29/2016 7:55:39 AM**

### Sample Information:

16-48 Roosevelt Lead Study

Client Sample ID: Bottle #11402  
Collectors Name: Bill Bartlett  
Sample Location: Room 210 DF A  
Source: City Water

## ANALYTICAL RESULTS

Analyses	Method	NELAP		Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
		Accredited	Result						
Copper	EPA 200.8	A	<b>1.87</b>	*	0.00515	mg/L	1.3 AL	7/22/2016	OML
Lead	EPA 200.8	A	<b>0.0735</b>	*	0.000103	mg/L	0.020 AL	7/22/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

# Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

## Analysis Report

ORELAP 100016  
EPA OR00028

Medford School District  
815 S Oakdale Ave  
Medford, OR 97501

Lab Order: **1607444**  
NRC Sample ID: **1607444-38A**  
Collection Date: **7/12/2016 2:27:00 PM**  
Received Date: **7/12/2016 4:09:00 PM**  
Reported Date: **7/29/2016 7:55:39 AM**

### Sample Information:

16-48 Roosevelt Lead Study

Client Sample ID: Bottle #19531  
Collectors Name: John Jessen  
Sample Location: Boys/Girls RR By 120 DF Upr  
Source: City Water

## ANALYTICAL RESULTS

Analyses	Method	NELAP		Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
		Accredited	Result						
Copper	EPA 200.8	A	<b>2.10</b>	*	0.00515	mg/L	1.3 AL	7/22/2016	OML
Lead	EPA 200.8	A	<b>0.0900</b>	*	0.000103	mg/L	0.020 AL	7/22/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

# Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

## Analysis Report

ORELAP 100016  
EPA OR00028

Medford School District  
815 S Oakdale Ave  
Medford, OR 97501

Lab Order: **1607444**  
NRC Sample ID: **1607444-39A**  
Collection Date: **7/12/2016 2:26:00 PM**  
Received Date: **7/12/2016 4:09:00 PM**  
Reported Date: **7/29/2016 7:55:39 AM**

### Sample Information:

**16-48 Roosevelt Lead Study**

Client Sample ID: Bottle #11413  
Collectors Name: John Jessen  
Sample Location: Boys/Girls RR By 120 DF Lwr  
Source: City Water

## ANALYTICAL RESULTS

Analyses	Method	NELAP		Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
		Accredited	Result						
Copper	EPA 200.8	A	<b>1.93</b>	*	0.00515	mg/L	1.3 AL	7/22/2016	OML
Lead	EPA 200.8	A	<b>0.0594</b>	*	0.000103	mg/L	0.020 AL	7/22/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

# Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

## Analysis Report

ORELAP 100016  
EPA OR00028

Medford School District  
815 S Oakdale Ave  
Medford, OR 97501

Lab Order: **1607444**  
NRC Sample ID: **1607444-40A**  
Collection Date: **7/12/2016 2:31:00 PM**  
Received Date: **7/12/2016 4:09:00 PM**  
Reported Date: **7/29/2016 7:55:39 AM**

### Sample Information:

16-48 Roosevelt Lead Study

Client Sample ID: Bottle #19559  
Collectors Name: John Jessen  
Sample Location: Room 120 DF  
Source: City Water

## ANALYTICAL RESULTS

Analyses	Method	NELAP		Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
		Accredited	Result						
Copper	EPA 200.8	A	<b>1.48</b>	*	0.00515	mg/L	1.3 AL	7/22/2016	OML
Lead	EPA 200.8	A	<b>0.119</b>	*	0.000103	mg/L	0.020 AL	7/22/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

# Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

## Analysis Report

ORELAP 100016  
EPA OR00028

Medford School District  
815 S Oakdale Ave  
Medford, OR 97501

Lab Order: **1607444**  
NRC Sample ID: **1607444-41A**  
Collection Date: **7/12/2016 2:33:00 PM**  
Received Date: **7/12/2016 4:09:00 PM**  
Reported Date: **7/29/2016 7:55:39 AM**

### Sample Information:

16-48 Roosevelt Lead Study

Client Sample ID: Bottle #11281  
Collectors Name: John Jessen  
Sample Location: Room 121 DF  
Source: City Water

## ANALYTICAL RESULTS

Analyses	Method	NELAP		Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
		Accredited	Result						
Copper	EPA 200.8	A	<b>1.95</b>	*	0.00515	mg/L	1.3 AL	7/22/2016	OML
Lead	EPA 200.8	A	<b>0.107</b>	*	0.000103	mg/L	0.020 AL	7/22/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

# Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

## Analysis Report

ORELAP 100016  
EPA OR00028

Medford School District  
815 S Oakdale Ave  
Medford, OR 97501

Lab Order: **1607444**  
NRC Sample ID: **1607444-42A**  
Collection Date: **7/12/2016 2:38:00 PM**  
Received Date: **7/12/2016 4:09:00 PM**  
Reported Date: **7/29/2016 7:55:39 AM**

### Sample Information:

16-48 Roosevelt Lead Study

Client Sample ID: Bottle #11381  
Collectors Name: John Jessen  
Sample Location: Room 122 DF  
Source: City Water

## ANALYTICAL RESULTS

Analyses	Method	NELAP		Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
		Accredited	Result						
Copper	EPA 200.8	A	<b>1.39</b>	*	0.00515	mg/L	1.3 AL	7/22/2016	OML
Lead	EPA 200.8	A	<b>0.0718</b>	*	0.000103	mg/L	0.020 AL	7/22/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

# Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

## Analysis Report

ORELAP 100016  
EPA OR00028

Medford School District  
815 S Oakdale Ave  
Medford, OR 97501

Lab Order: **1607444**  
NRC Sample ID: **1607444-43A**  
Collection Date: **7/12/2016 2:54:00 PM**  
Received Date: **7/12/2016 4:09:00 PM**  
Reported Date: **7/29/2016 7:55:39 AM**

### Sample Information:

16-48 Roosevelt Lead Study

Client Sample ID: Bottle #11396  
Collectors Name: John Jessen  
Sample Location: Caf DF Upper  
Source: City Water

## ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	<b>0.0148</b>		0.0001	mg/L	0.020 AL	7/22/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

# Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

## Analysis Report

ORELAP 100016  
EPA OR00028

Medford School District  
815 S Oakdale Ave  
Medford, OR 97501

Lab Order: **1607444**  
NRC Sample ID: **1607444-44A**  
Collection Date: **7/12/2016 2:52:00 PM**  
Received Date: **7/12/2016 4:09:00 PM**  
Reported Date: **7/29/2016 7:55:39 AM**

### Sample Information:

16-48 Roosevelt Lead Study

Client Sample ID: Bottle #11409  
Collectors Name: John Jessen  
Sample Location: Caf DF Lower  
Source: City Water

## ANALYTICAL RESULTS

Analyses	Method	NELAP		Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
		Accredited	Result						
Copper	EPA 200.8	A	<b>1.60</b>	*	0.005	mg/L	1.3 AL	7/22/2016	OML
Lead	EPA 200.8	A	<b>0.184</b>	*	0.0001	mg/L	0.020 AL	7/22/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

# Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

## Analysis Report

ORELAP 100016  
EPA OR00028

Medford School District  
815 S Oakdale Ave  
Medford, OR 97501

Lab Order: **1607444**  
NRC Sample ID: **1607444-45A**  
Collection Date: **7/12/2016 2:53:00 PM**  
Received Date: **7/12/2016 4:09:00 PM**  
Reported Date: **7/29/2016 7:55:39 AM**

### Sample Information:

16-48 Roosevelt Lead Study

Client Sample ID: Bottle #11366  
Collectors Name: John Jessen  
Sample Location: Caf DF Bottle Filler  
Source: City Water

## ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.0472	*	0.0001	mg/L	0.020 AL	7/22/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

# Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

## Analysis Report

ORELAP 100016  
EPA OR00028

Medford School District  
815 S Oakdale Ave  
Medford, OR 97501

Lab Order: **1607444**  
NRC Sample ID: **1607444-46A**  
Collection Date: **7/12/2016 3:01:00 PM**  
Received Date: **7/12/2016 4:09:00 PM**  
Reported Date: **7/29/2016 7:55:39 AM**

### Sample Information:

16-48 Roosevelt Lead Study

Client Sample ID: Bottle #19702  
Collectors Name: John Jessen  
Sample Location: Gym DF Upper  
Source: City Water

## ANALYTICAL RESULTS

Analyses	Method	NELAP		Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
		Accredited	Result						
Copper	EPA 200.8	A	<b>1.64</b>	*	0.00515	mg/L	1.3 AL	7/22/2016	OML
Lead	EPA 200.8	A	<b>0.0252</b>	*	0.000103	mg/L	0.020 AL	7/22/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

# Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

## Analysis Report

ORELAP 100016  
EPA OR00028

Medford School District  
815 S Oakdale Ave  
Medford, OR 97501

Lab Order: **1607444**  
NRC Sample ID: **1607444-47A**  
Collection Date: **7/12/2016 3:00:00 PM**  
Received Date: **7/12/2016 4:09:00 PM**  
Reported Date: **7/29/2016 7:55:40 AM**

### Sample Information:

16-48 Roosevelt Lead Study

Client Sample ID: Bottle #11395  
Collectors Name: John Jessen  
Sample Location: Gym DF Lower  
Source: City Water

## ANALYTICAL RESULTS

Analyses	Method	NELAP		Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
		Accredited	Result						
Copper	EPA 200.8	A	<b>1.34</b>	*	0.00515	mg/L	1.3 AL	7/22/2016	OML
Lead	EPA 200.8	A	<b>0.0103</b>		0.000103	mg/L	0.020 AL	7/22/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

**Neilson Research Corporation**  
DATA FLAGS

B	Analyte detected in the associated method blank.
BA	BOD Alternative Calculation: The initial results performed by Standard Methods did not fall within parameters of the Standard Methods calculation. An alternate approved calculation was performed using the HACH method and the value reported is an estimated concentration.
C	Sample(s) does not meet NELAP/ORELAP sample acceptance criteria. See Case Narrative.
C1	Sample(s) does not meet NELAP/ORELAP sample acceptance criteria for temperature.
CF	Results confirmed by re-analysis.
CU	Cleanup performed as specified by method.
D1	The diesel elution pattern for the sample is not typical.
D2	The sample appears to be a heavier hydrocarbon range than diesel.
D3	The sample appears to be a lighter hydrocarbon range than diesel.
D4	Detected hydrocarbons do not have pattern and range consistent with typical petroleum products and may be due to biogenic interference.
D5	Detected hydrocarbons in the diesel range appear to be weathered diesel.
E	Estimated value.
ER	Elevated reporting limit due to matrix. Report limits (MDLs, MRLs & PQLs) are adjusted based on variations in sample preparation amounts, analytical dilutions, and percent solids, where applicable.
FC	Fecal Coliforms: Sample(s) received past 40 CFR Part 136 specified holding time. Results reported as estimated values.
G1	The gasoline elution pattern for the sample is not typical.
G2	The sample appears to be a heavier hydrocarbon range than gasoline.
G3	The sample appears to be a lighter hydrocarbon range than gasoline.
G4	Detected hydrocarbons in the gasoline range appear to be weathered gasoline.
HP	Sample re-analysis performed outside of method specified holding time.
HR	Sample received outside of method specified holding time.
HS	Sample analyzed for volatile organics contained headspace.
HT	At the client's request, the sample was analyzed outside of method specified holding time.
H	Analysis performed outside of method specified holding time.
J	Analyte detected below the Minimum Reporting Limit (MRL) and above the Method Detection Limit (MDL). The J flag result is an estimated value and the user should be aware that this data is of limited reliability.
MI	Surrogate or Matrix Spike recovery is out of control limits due to matrix interference. Sample results may be biased.
N	See Case Narrative on page 2 of report.
Q	Closing continuing calibration verification (CCV) or laboratory control sample (LCS) exceeded high recovery limits, but associated samples are non-detect and the sample results are not affected. Data meets EPA/NELAP requirements.
R	Relative percent difference (RPD) is outside of the accepted recovery limits.
R1	Relative percent difference (RPD) is outside of the accepted recovery limits. However, analyses are not controlled on RPD values for sample concentrations that are less than the reporting limit.
R3	The relative percent difference (RPD) and/or percent recovery for the duplicate (DUP) or matrix spike (MS)/matrix spike duplicate (MSD) cannot be accurately calculated due to the concentration of analyte already present in the sample.
R4	Duplicate analysis failed due to result being at or near method reporting limit.
S	Surrogate and/or matrix spike recovery is outside of the accepted recovery limits. Sample results may be biased.
S1	Surrogate or matrix spike recovery is outside of control limits due to dilution necessary for analysis.
SC	Sub-contracted to another laboratory for analysis.
SP	Sample(s) were not collected per EPA Method 5035A protocols. The results are considered minimum values.
T	Toxicity Characteristic Leaching Procedure – Sample submitted contained < 0.5% solids. If the waste contains <0.5% dry solids, the liquid portion of the waste, after filtration, is defined as the TCLP extract.
#	Value exceeds regulatory level for TCLP contaminant.
X1	The motor oil elution pattern for the sample is not typical.
X2	The sample appears to be a heavier hydrocarbon range than motor oil.
X3	The sample appears to be a lighter hydrocarbon range than motor oil.
*	Value exceeds Maximum Contaminant Level or is outside the acceptable range.

NRC SOP QA-1104/AD-3100  
Revision 3  
Effective Date: 6/3/16

**CLIENT:** Medford School District  
**Work Order:** 1607444  
**Project:** 16-48 Roosevelt Lead Study

**ANALYTICAL QC SUMMARY REPORT**

**BatchID: 35878**

Sample ID <b>MB-35878</b>	SampType: <b>MBLK</b>	TestCode: <b>ICPMS_200.8</b>	Units: <b>mg/L</b>	Prep Date: <b>7/20/2016</b>	RunNo: <b>88593</b>						
Client ID: <b>ZZZZZ</b>	Batch ID: <b>35878</b>	TestNo: <b>EPA 200.8</b>	<b>(EPA 200.8)</b>	Analysis Date: <b>7/20/2016</b>	SeqNo: <b>1328430</b>						
Analyte	Result	MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Copper	ND	0.000515									
Lead	ND	0.000103									

Sample ID <b>LCS-35878</b>	SampType: <b>LCS</b>	TestCode: <b>ICPMS_200.8</b>	Units: <b>mg/L</b>	Prep Date: <b>7/20/2016</b>	RunNo: <b>88593</b>						
Client ID: <b>ZZZZZ</b>	Batch ID: <b>35878</b>	TestNo: <b>EPA 200.8</b>	<b>(EPA 200.8)</b>	Analysis Date: <b>7/20/2016</b>	SeqNo: <b>1328431</b>						
Analyte	Result	MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Copper	0.09344	0.000520	0.1	0.00002097	93.4	85	115				
Lead	0.09561	0.000104	0.1	0	95.6	85	115				

Sample ID <b>1607444-06AMS</b>	SampType: <b>MS</b>	TestCode: <b>ICPMS_200.8</b>	Units: <b>mg/L</b>	Prep Date: <b>7/20/2016</b>	RunNo: <b>88593</b>						
Client ID: <b>Bottle #11401</b>	Batch ID: <b>35878</b>	TestNo: <b>EPA 200.8</b>	<b>(EPA 200.8)</b>	Analysis Date: <b>7/20/2016</b>	SeqNo: <b>1328449</b>						
Analyte	Result	MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	0.2340	0.000104	0.1	0.1302	104	70	130				

Sample ID <b>1607444-06AMS</b>	SampType: <b>MS</b>	TestCode: <b>ICPMS_200.8</b>	Units: <b>mg/L</b>	Prep Date: <b>7/20/2016</b>	RunNo: <b>88649</b>						
Client ID: <b>Bottle #11401</b>	Batch ID: <b>35878</b>	TestNo: <b>EPA 200.8</b>	<b>(EPA 200.8)</b>	Analysis Date: <b>7/21/2016</b>	SeqNo: <b>1329353</b>						
Analyte	Result	MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Copper	2.529	0.00520	0.1	2.416	113	70	130				

Sample ID <b>1607444-06AMSD</b>	SampType: <b>MSD</b>	TestCode: <b>ICPMS_200.8</b>	Units: <b>mg/L</b>	Prep Date: <b>7/20/2016</b>	RunNo: <b>88593</b>						
Client ID: <b>Bottle #11401</b>	Batch ID: <b>35878</b>	TestNo: <b>EPA 200.8</b>	<b>(EPA 200.8)</b>	Analysis Date: <b>7/20/2016</b>	SeqNo: <b>1328450</b>						
Analyte	Result	MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	0.2347	0.000104	0.1	0.1302	105	70	130	0.234	0.311	20	

**Qualifiers:** E Value above quantitation range      H Holding times for preparation or analysis exceeded      J Analyte detected below quantitation limits  
 ND Not Detected at the Minimum Reporting Limit      R RPD outside accepted recovery limits      S Spike Recovery outside accepted recovery limits

**CLIENT:** Medford School District  
**Work Order:** 1607444  
**Project:** 16-48 Roosevelt Lead Study

**ANALYTICAL QC SUMMARY REPORT**

**BatchID: 35878**

Sample ID	<b>1607444-06AMSD</b>	SampType:	<b>MSD</b>	TestCode:	<b>ICPMS_200.8</b>	Units:	<b>mg/L</b>	Prep Date:	<b>7/20/2016</b>	RunNo:	<b>88649</b>											
Client ID:	<b>Bottle #11401</b>	Batch ID:	<b>35878</b>	TestNo:	<b>EPA 200.8</b>		<b>(EPA 200.8)</b>	Analysis Date:	<b>7/21/2016</b>	SeqNo:	<b>1329354</b>											
Analyte		Result		MRL		SPK value		SPK Ref Val		%REC		LowLimit		HighLimit		RPD Ref Val		%RPD		RPDLimit		Qual
Copper		2.500		0.00520		0.1		2.416		83.8		70		130		2.529		1.16		20		

**Qualifiers:** E Value above quantitation range  
 ND Not Detected at the Minimum Reporting Limit

H Holding times for preparation or analysis exceeded  
 R RPD outside accepted recovery limits

J Analyte detected below quantitation limits  
 S Spike Recovery outside accepted recovery limits

**CLIENT:** Medford School District  
**Work Order:** 1607444  
**Project:** 16-48 Roosevelt Lead Study

**ANALYTICAL QC SUMMARY REPORT**

**BatchID: 35879**

Sample ID <b>MB-35879</b>	SampType: <b>MBLK</b>	TestCode: <b>ICPMS_200.8</b>	Units: <b>mg/L</b>	Prep Date: <b>7/20/2016</b>	RunNo: <b>88649</b>						
Client ID: <b>ZZZZZ</b>	Batch ID: <b>35879</b>	TestNo: <b>EPA 200.8</b>	<b>(EPA 200.8)</b>	Analysis Date: <b>7/21/2016</b>	SeqNo: <b>1329317</b>						
Analyte	Result	MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Copper	ND	0.000515									
Lead	ND	0.000103									

Sample ID <b>LCS-35879</b>	SampType: <b>LCS</b>	TestCode: <b>ICPMS_200.8</b>	Units: <b>mg/L</b>	Prep Date: <b>7/20/2016</b>	RunNo: <b>88649</b>						
Client ID: <b>ZZZZZ</b>	Batch ID: <b>35879</b>	TestNo: <b>EPA 200.8</b>	<b>(EPA 200.8)</b>	Analysis Date: <b>7/21/2016</b>	SeqNo: <b>1329318</b>						
Analyte	Result	MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Copper	0.09677	0.000520	0.1	0	96.8	85	115				
Lead	0.09651	0.000104	0.1	0	96.5	85	115				

Sample ID <b>1607444-26AMS</b>	SampType: <b>MS</b>	TestCode: <b>ICPMS_200.8</b>	Units: <b>mg/L</b>	Prep Date: <b>7/20/2016</b>	RunNo: <b>88649</b>						
Client ID: <b>Bottle #11368</b>	Batch ID: <b>35879</b>	TestNo: <b>EPA 200.8</b>	<b>(EPA 200.8)</b>	Analysis Date: <b>7/21/2016</b>	SeqNo: <b>1329339</b>						
Analyte	Result	MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	0.1532	0.000104	0.1	0.05282	100	70	130				
------	--------	----------	-----	---------	-----	----	-----	--	--	--	--

Sample ID <b>1607444-26AMSD</b>	SampType: <b>MSD</b>	TestCode: <b>ICPMS_200.8</b>	Units: <b>mg/L</b>	Prep Date: <b>7/20/2016</b>	RunNo: <b>88649</b>						
Client ID: <b>Bottle #11368</b>	Batch ID: <b>35879</b>	TestNo: <b>EPA 200.8</b>	<b>(EPA 200.8)</b>	Analysis Date: <b>7/21/2016</b>	SeqNo: <b>1329340</b>						
Analyte	Result	MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	0.1566	0.000104	0.1	0.05282	104	70	130	0.1532	2.22	20	
------	--------	----------	-----	---------	-----	----	-----	--------	------	----	--

**Qualifiers:** E Value above quantitation range      H Holding times for preparation or analysis exceeded      J Analyte detected below quantitation limits  
 ND Not Detected at the Minimum Reporting Limit      R RPD outside accepted recovery limits      S Spike Recovery outside accepted recovery limits

**CLIENT:** Medford School District  
**Work Order:** 1607444  
**Project:** 16-48 Roosevelt Lead Study

**ANALYTICAL QC SUMMARY REPORT**

**BatchID: 35880**

Sample ID <b>MB-35880</b>	SampType: <b>MBLK</b>	TestCode: <b>ICPMS_200.8</b>	Units: <b>mg/L</b>	Prep Date: <b>7/20/2016</b>	RunNo: <b>88593</b>						
Client ID: <b>ZZZZZ</b>	Batch ID: <b>35880</b>	TestNo: <b>EPA 200.8</b>	<b>(EPA 200.8)</b>	Analysis Date: <b>7/20/2016</b>	SeqNo: <b>1328397</b>						
Analyte	Result	MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Copper	ND	0.000500									
Lead	ND	0.000100									

Sample ID <b>LCS-35880</b>	SampType: <b>LCS</b>	TestCode: <b>ICPMS_200.8</b>	Units: <b>mg/L</b>	Prep Date: <b>7/20/2016</b>	RunNo: <b>88593</b>						
Client ID: <b>ZZZZZ</b>	Batch ID: <b>35880</b>	TestNo: <b>EPA 200.8</b>	<b>(EPA 200.8)</b>	Analysis Date: <b>7/20/2016</b>	SeqNo: <b>1328398</b>						
Analyte	Result	MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Copper	0.09697	0.000500	0.1	0.000018	97.0	85	115				
Lead	0.09474	0.000100	0.1	0	94.7	85	115				

Sample ID <b>1607798-02AMS</b>	SampType: <b>MS</b>	TestCode: <b>ICPMS_200.8</b>	Units: <b>mg/L</b>	Prep Date: <b>7/20/2016</b>	RunNo: <b>88593</b>						
Client ID: <b>ZZZZZ</b>	Batch ID: <b>35880</b>	TestNo: <b>EPA 200.8</b>	<b>(EPA 200.8)</b>	Analysis Date: <b>7/20/2016</b>	SeqNo: <b>1328407</b>						
Analyte	Result	MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Copper	0.2811	0.000500	0.1	0.1786	103	70	130				
Lead	0.1043	0.000100	0.1	0.007381	96.9	70	130				

Sample ID <b>1607798-02AMSD</b>	SampType: <b>MSD</b>	TestCode: <b>ICPMS_200.8</b>	Units: <b>mg/L</b>	Prep Date: <b>7/20/2016</b>	RunNo: <b>88593</b>						
Client ID: <b>ZZZZZ</b>	Batch ID: <b>35880</b>	TestNo: <b>EPA 200.8</b>	<b>(EPA 200.8)</b>	Analysis Date: <b>7/20/2016</b>	SeqNo: <b>1328408</b>						
Analyte	Result	MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Copper	0.2772	0.000500	0.1	0.1786	98.6	70	130	0.2811	1.40	20	
Lead	0.1031	0.000100	0.1	0.007381	95.7	70	130	0.1043	1.16	20	

**Qualifiers:** E Value above quantitation range      H Holding times for preparation or analysis exceeded      J Analyte detected below quantitation limits  
 ND Not Detected at the Minimum Reporting Limit      R RPD outside accepted recovery limits      S Spike Recovery outside accepted recovery limits

**CLIENT:** Medford School District  
**Work Order:** 1607444  
**Project:** 16-48 Roosevelt Lead Study

**ANALYTICAL QC SUMMARY REPORT**

**BatchID: 35885**

Sample ID <b>MB-35885</b>	SampType: <b>MBLK</b>	TestCode: <b>ICPMS_200.8</b>	Units: <b>mg/L</b>	Prep Date: <b>7/21/2016</b>	RunNo: <b>88658</b>						
Client ID: <b>ZZZZZ</b>	Batch ID: <b>35885</b>	TestNo: <b>EPA 200.8</b>	( <b>EPA 200.8</b> )	Analysis Date: <b>7/22/2016</b>	SeqNo: <b>1329997</b>						
Analyte	Result	MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Copper	ND	0.000515									
Lead	ND	0.000103									

Sample ID <b>LCS-35885</b>	SampType: <b>LCS</b>	TestCode: <b>ICPMS_200.8</b>	Units: <b>mg/L</b>	Prep Date: <b>7/21/2016</b>	RunNo: <b>88658</b>						
Client ID: <b>ZZZZZ</b>	Batch ID: <b>35885</b>	TestNo: <b>EPA 200.8</b>	( <b>EPA 200.8</b> )	Analysis Date: <b>7/22/2016</b>	SeqNo: <b>1329998</b>						
Analyte	Result	MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Copper	0.09882	0.000520	0.1	0	98.8	85	115				
Lead	0.09674	0.000104	0.1	0	96.7	85	115				

Sample ID <b>1607444-47AMS</b>	SampType: <b>MS</b>	TestCode: <b>ICPMS_200.8</b>	Units: <b>mg/L</b>	Prep Date: <b>7/21/2016</b>	RunNo: <b>88658</b>						
Client ID: <b>Bottle #11395</b>	Batch ID: <b>35885</b>	TestNo: <b>EPA 200.8</b>	( <b>EPA 200.8</b> )	Analysis Date: <b>7/22/2016</b>	SeqNo: <b>1330037</b>						
Analyte	Result	MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Copper	1.473	0.00520	0.1	1.384	88.3	70	130				

Sample ID <b>1607444-47AMS</b>	SampType: <b>MS</b>	TestCode: <b>ICPMS_200.8</b>	Units: <b>mg/L</b>	Prep Date: <b>7/21/2016</b>	RunNo: <b>88658</b>						
Client ID: <b>Bottle #11395</b>	Batch ID: <b>35885</b>	TestNo: <b>EPA 200.8</b>	( <b>EPA 200.8</b> )	Analysis Date: <b>7/22/2016</b>	SeqNo: <b>1330038</b>						
Analyte	Result	MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	0.1081	0.000104	0.1	0.01031	97.7	70	130				

Sample ID <b>1607444-47AMSD</b>	SampType: <b>MSD</b>	TestCode: <b>ICPMS_200.8</b>	Units: <b>mg/L</b>	Prep Date: <b>7/21/2016</b>	RunNo: <b>88658</b>						
Client ID: <b>Bottle #11395</b>	Batch ID: <b>35885</b>	TestNo: <b>EPA 200.8</b>	( <b>EPA 200.8</b> )	Analysis Date: <b>7/22/2016</b>	SeqNo: <b>1330039</b>						
Analyte	Result	MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Copper	1.461	0.00520	0.1	1.384	76.9	70	130	1.541	5.33	20	

**Qualifiers:** E Value above quantitation range      H Holding times for preparation or analysis exceeded      J Analyte detected below quantitation limits  
 ND Not Detected at the Minimum Reporting Limit      R RPD outside accepted recovery limits      S Spike Recovery outside accepted recovery limits

**CLIENT:** Medford School District  
**Work Order:** 1607444  
**Project:** 16-48 Roosevelt Lead Study

**ANALYTICAL QC SUMMARY REPORT**

**BatchID: 35885**

Sample ID	<b>1607444-47AMSD</b>	SampType:	<b>MSD</b>	TestCode:	<b>ICPMS_200.8</b>	Units:	<b>mg/L</b>	Prep Date:	<b>7/21/2016</b>	RunNo:	<b>88658</b>											
Client ID:	<b>Bottle #11395</b>	Batch ID:	<b>35885</b>	TestNo:	<b>EPA 200.8</b>		<b>(EPA 200.8)</b>	Analysis Date:	<b>7/22/2016</b>	SeqNo:	<b>1330040</b>											
Analyte		Result		MRL		SPK value		SPK Ref Val		%REC		LowLimit		HighLimit		RPD Ref Val		%RPD		RPDLimit		Qual
Lead		0.1049		0.000104		0.1		0.01031		94.6		70		130		0.1081		2.93		20		

**Qualifiers:** E Value above quantitation range      H Holding times for preparation or analysis exceeded      J Analyte detected below quantitation limits  
 ND Not Detected at the Minimum Reporting Limit      R RPD outside accepted recovery limits      S Spike Recovery outside accepted recovery limits

**CLIENT:** Medford School District  
**Work Order:** 1607444  
**Project:** 16-48 Roosevelt Lead Study

**ANALYTICAL QC SUMMARY REPORT**

**BatchID: 35888**

Sample ID <b>MB-35888</b>	SampType: <b>MBLK</b>	TestCode: <b>ICPMS_200.8</b>	Units: <b>mg/L</b>	Prep Date: <b>7/21/2016</b>	RunNo: <b>88658</b>						
Client ID: <b>ZZZZZ</b>	Batch ID: <b>35888</b>	TestNo: <b>EPA 200.8</b>	<b>(EPA 200.8)</b>	Analysis Date: <b>7/22/2016</b>	SeqNo: <b>1329904</b>						
Analyte	Result	MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Copper	ND	0.000500									
Lead	ND	0.000100									

Sample ID <b>LCS-35888</b>	SampType: <b>LCS</b>	TestCode: <b>ICPMS_200.8</b>	Units: <b>mg/L</b>	Prep Date: <b>7/21/2016</b>	RunNo: <b>88658</b>						
Client ID: <b>ZZZZZ</b>	Batch ID: <b>35888</b>	TestNo: <b>EPA 200.8</b>	<b>(EPA 200.8)</b>	Analysis Date: <b>7/22/2016</b>	SeqNo: <b>1329905</b>						
Analyte	Result	MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Copper	0.09565	0.000500	0.1	0.00004246	95.6	85	115				
Lead	0.09240	0.000100	0.1	0	92.4	85	115				

Sample ID <b>1607523-20AMS</b>	SampType: <b>MS</b>	TestCode: <b>ICPMS_200.8</b>	Units: <b>mg/L</b>	Prep Date: <b>7/21/2016</b>	RunNo: <b>88658</b>						
Client ID: <b>ZZZZZ</b>	Batch ID: <b>35888</b>	TestNo: <b>EPA 200.8</b>	<b>(EPA 200.8)</b>	Analysis Date: <b>7/22/2016</b>	SeqNo: <b>1329926</b>						
Analyte	Result	MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	0.1434	0.000100	0.1	0.05212	91.3	70	130				
------	--------	----------	-----	---------	------	----	-----	--	--	--	--

Sample ID <b>1607523-20AMS</b>	SampType: <b>MS</b>	TestCode: <b>ICPMS_200.8</b>	Units: <b>mg/L</b>	Prep Date: <b>7/21/2016</b>	RunNo: <b>88658</b>						
Client ID: <b>ZZZZZ</b>	Batch ID: <b>35888</b>	TestNo: <b>EPA 200.8</b>	<b>(EPA 200.8)</b>	Analysis Date: <b>7/22/2016</b>	SeqNo: <b>1329935</b>						
Analyte	Result	MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Copper	2.000	0.00500	0.1	1.93	70.0	70	130				
--------	-------	---------	-----	------	------	----	-----	--	--	--	--

Sample ID <b>1607523-20AMSD</b>	SampType: <b>MS</b>	TestCode: <b>ICPMS_200.8</b>	Units: <b>mg/L</b>	Prep Date: <b>7/21/2016</b>	RunNo: <b>88658</b>						
Client ID: <b>ZZZZZ</b>	Batch ID: <b>35888</b>	TestNo: <b>EPA 200.8</b>	<b>(EPA 200.8)</b>	Analysis Date: <b>7/22/2016</b>	SeqNo: <b>1329936</b>						
Analyte	Result	MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Copper	2.047	0.00500	0.1	1.93	117	70	130	2	2.32	0	
--------	-------	---------	-----	------	-----	----	-----	---	------	---	--

**Qualifiers:** E Value above quantitation range      H Holding times for preparation or analysis exceeded      J Analyte detected below quantitation limits  
 ND Not Detected at the Minimum Reporting Limit      R RPD outside accepted recovery limits      S Spike Recovery outside accepted recovery limits

**CLIENT:** Medford School District  
**Work Order:** 1607444  
**Project:** 16-48 Roosevelt Lead Study

**ANALYTICAL QC SUMMARY REPORT**

**BatchID: 35888**

Sample ID	<b>1607523-20AMSD</b>	SampType:	<b>MSD</b>	TestCode:	<b>ICPMS_200.8</b>	Units:	<b>mg/L</b>	Prep Date:	<b>7/21/2016</b>	RunNo:	<b>88658</b>											
Client ID:	<b>ZZZZZ</b>	Batch ID:	<b>35888</b>	TestNo:	<b>EPA 200.8</b>		<b>(EPA 200.8)</b>	Analysis Date:	<b>7/22/2016</b>	SeqNo:	<b>1329927</b>											
Analyte		Result		MRL		SPK value		SPK Ref Val		%REC		LowLimit		HighLimit		RPD Ref Val		%RPD		RPDLimit		Qual
Lead		0.1492		0.000100		0.1		0.05212		97.1		70		130		0.1434		3.96		20		

**Qualifiers:** E Value above quantitation range  
 ND Not Detected at the Minimum Reporting Limit

H Holding times for preparation or analysis exceeded  
 R RPD outside accepted recovery limits

J Analyte detected below quantitation limits  
 S Spike Recovery outside accepted recovery limits

**CLIENT:** Medford School District  
**Work Order:** 1607444  
**Project:** 16-48 Roosevelt Lead Study

**ANALYTICAL QC SUMMARY REPORT**

**BatchID: 35902**

Sample ID <b>MB-35902</b>	SampType: <b>MBLK</b>	TestCode: <b>ICPMS_200.8</b>	Units: <b>mg/L</b>	Prep Date: <b>7/21/2016</b>	RunNo: <b>88716</b>						
Client ID: <b>ZZZZZ</b>	Batch ID: <b>35902</b>	TestNo: <b>EPA 200.8</b>	<b>(EPA 200.8)</b>	Analysis Date: <b>7/25/2016</b>	SeqNo: <b>1331503</b>						
Analyte	Result	MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Copper	ND	0.000515									
Lead	ND	0.000103									

Sample ID <b>LCS-35902</b>	SampType: <b>LCS</b>	TestCode: <b>ICPMS_200.8</b>	Units: <b>mg/L</b>	Prep Date: <b>7/21/2016</b>	RunNo: <b>88716</b>						
Client ID: <b>ZZZZZ</b>	Batch ID: <b>35902</b>	TestNo: <b>EPA 200.8</b>	<b>(EPA 200.8)</b>	Analysis Date: <b>7/25/2016</b>	SeqNo: <b>1331504</b>						
Analyte	Result	MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Copper	0.09600	0.000520	0.1	0.00004464	96.0	85	115				
Lead	0.09510	0.000104	0.1	0	95.1	85	115				

Sample ID <b>1607444-25AMS</b>	SampType: <b>MS</b>	TestCode: <b>ICPMS_200.8</b>	Units: <b>mg/L</b>	Prep Date: <b>7/21/2016</b>	RunNo: <b>88716</b>						
Client ID: <b>Bottle #11267</b>	Batch ID: <b>35902</b>	TestNo: <b>EPA 200.8</b>	<b>(EPA 200.8)</b>	Analysis Date: <b>7/25/2016</b>	SeqNo: <b>1331527</b>						
Analyte	Result	MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Copper	1.387	0.00104	0.1	1.28	107	70	130				
--------	-------	---------	-----	------	-----	----	-----	--	--	--	--

Sample ID <b>1607444-25AMSD</b>	SampType: <b>MSD</b>	TestCode: <b>ICPMS_200.8</b>	Units: <b>mg/L</b>	Prep Date: <b>7/21/2016</b>	RunNo: <b>88716</b>						
Client ID: <b>Bottle #11267</b>	Batch ID: <b>35902</b>	TestNo: <b>EPA 200.8</b>	<b>(EPA 200.8)</b>	Analysis Date: <b>7/25/2016</b>	SeqNo: <b>1331528</b>						
Analyte	Result	MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Copper	1.368	0.00104	0.1	1.28	87.5	70	130	1.387	1.39	20	
--------	-------	---------	-----	------	------	----	-----	-------	------	----	--

**Qualifiers:** E Value above quantitation range      H Holding times for preparation or analysis exceeded      J Analyte detected below quantitation limits  
 ND Not Detected at the Minimum Reporting Limit      R RPD outside accepted recovery limits      S Spike Recovery outside accepted recovery limits



Environmental Testing Laboratory  
 245 South Grape Street • Medford, OR 97501  
 (541) 770-5678 Fax (541) 770-2901

*Roosevelt*  
**Chain of Custody Record**

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

**Section A**  
 Required Client Information

Company: Medford School District 549C  
 Address: 815 S. Oakdale,  
 Medford, Or 97501  
 Email: rick.rose@medford.k12.or.us  
 Phone: 541.842.1138 Fax 541.842.1160  
 Collected By (Print): *Larry Anderson*  
 Email Report  Yes  No Mail Report  Yes  No  
 Fax Report  Yes  No

**Section B**  
 Required Project Information

Project Name: 2016 Lead testing  
 Project Number: 16-48 / Roosevelt  
 Report To: rick.rose@medford.k12.or.us  
 Copy To: ron.havnear@medford.k12.or.us

**Section C**  
 Invoice Information

Attention: Accounting  
 Company Name: Medford School  
 Address: 815 S. Oakdale  
 Medford, Or 97501  
 P.O. # P112894

**Section D**  
 Rush Status (Subject to Scheduling)

Standard 10-14 Days  
 5 Business Days (50% surcharge)  
 3 Business Days (75% surcharge)  
 24 - 48 hours (100% surcharge)  
 Other \_\_\_\_\_  
 Authorized  Yes  No

**Section E**  
 Sample Information

Sample ID	Comp/Grab	Matrix*	Date Collected	Time Collected	No. of Containers	Analysis Requested	NRC Workorder # (Lab Use Only)	NRC Sample # (Lab Use Only)
Room 110 DF A	11373		7-12-16	2:24 PM	1		1607444	01
Room 110 DF B	11405			2:38	1			07
Room 110 DF C	11379			2:40	1			03
Richard Sliding Door infest Room 110 DF	11378			2:44	1			04
Richard Sliding Door infest Room 110 Sink	11380			2:45	1			05
Room 114 DF	11401			2:48	1			06
Room 113 DF	11393			2:51	1			07
Room 112 DF	11364			2:53	1			08
Room 111 DF	11398			2:56	1			09
Health Room Sink Left Basin	11385			2:58	1			10

**Section F**  
 Relinquish/Receive

Relinquish/Receive	Sign	Print	Date	Time
Relinquished By: <i>Larry Anderson</i>	<i>Larry Anderson</i>	<i>Larry Anderson</i>	7-12-16	3:25 PM
Relinquished By: <i>John Jensen</i>	<i>John Jensen</i>	<i>John Jensen</i>	7/21/16	3:38 PM
Relinquished By: <i>John Jensen</i>	<i>John Jensen</i>	<i>John Jensen</i>	7/21/16	4:09 PM
Relinquished By: <i>Paul Sawyer</i>	<i>Paul Sawyer</i>	<i>Paul Sawyer</i>	7/11/16	9:09

**Section G**  
 Lab Use Only

Temp: *AMBIENT*  
 4°C +/- 2°C: Yes  No   
 Received on Ice: Yes  No   
 Number of Bottles Received: *10*  
 pH Checked: *N/A*  
 COC Seals Intact: Yes  No  NA   
 Field Blank Included: Yes  No

Received Via  UPS  FedEx  Other  Hand  
 Payment:  Invoice  Cash  VISA, M/C  Check # \_\_\_\_\_ Amount \_\_\_\_\_



Environmental Testing Laboratory  
 245 South Grape Street • Medford, OR 97501  
 (541) 770-5678 Fax (541) 770-2901

# Chain of Custody Record

Roosevelt

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

<b>Section A</b>		<b>Section B</b>		<b>Section C</b>		<b>Section D</b>	
<b>Required Client Information</b>		<b>Required Project Information</b>		<b>Invoice Information</b>		<b>Rush Status (Subject to Scheduling)</b>	
Company: Medford School District 549C		Project Name: 2016 Lead testing		Attention: Accounting		Standard 10-14 Days	
Address: 815 S. Oakdale, Medford, Or, 97501		Project Number: 15-48 / Roosevelt		Company Name: Medford School		5 Business Days (50% surcharge)	
Email: rick.rose@medford.k12.or.us		Report To: rick.rose@medford.k12.or.us		Address: 815 S. Oakdale Medford, Or, 97501		3 Business Days (75% surcharge)	
Phone: 541.842.1138 Fax: 541.842.1160		Copy To: ron.havnicar@medford.k12.or.us		P.O. # P112894		24 - 48 hours (100% surcharge)	
Collected By (Print): Larry Anderson		Collected By (Sign): <i>Larry Anderson</i>		Authorized _____		Yes ___ No ___	
Email Report <input checked="" type="checkbox"/> Yes ___ No ___		Mail Report <input checked="" type="checkbox"/> Yes ___ No ___					
Fax Report <input type="checkbox"/> Yes ___ No ___							

Section E			Bottle #		Analysis Requested						
Sample Information	Sample ID	Comp/Grab	Matrix	Date Collected	Time Collected	No. of Containers					
Health Room Sink Right Fixture	11399			7-12-16	3:01 pm	1					
Room 140 DF A	11371				3:04	1					
Room 140 DF B	11375				3:07	1					
Room 141 DF	11394				3:09	1					
Room 142 DF	19752				3:12	1					
Room 143 DF	11376				3:14	1					
Room 130 DF	11264				3:17	1					

\*Matrix: DW - Drinking Water WW - Wastewater W - Water S - Soil/Solid SL - Sludge O - Oil WP - Wipe OT - Other

<b>Section F</b>		<b>Section G</b>	
<b>Relinquish/Receive</b>		<b>Lab Use Only</b>	
Relinquished By: <i>Larry Anderson</i>	Sign	Temp: <i>AMM</i>	Temp: <i>AMM</i>
Received By: <i>Larry Anderson</i>	Print	4°C +/- 2°C: <input checked="" type="checkbox"/> Yes ___ No ___	Received on Ice: <input checked="" type="checkbox"/> Yes ___ No ___
Relinquished By: <i>Larry Anderson</i>		Number of Bottles Received: <i>7</i>	pH Checked: <i>NA</i>
Received By: <i>Larry Anderson</i>		COC Seals Intact: <input checked="" type="checkbox"/> Yes ___ No ___	Field Blank Included: <input checked="" type="checkbox"/> Yes ___ No ___
Relinquished By: <i>Larry Anderson</i>			
Received By Laboratory: <i>W.D. Spitzer</i>			

Payment <input checked="" type="checkbox"/> Invoice	Cash <input type="checkbox"/>	Received Via
		UPS <input type="checkbox"/> FedEx <input checked="" type="checkbox"/> Other <input type="checkbox"/>
		Amount



Environmental Testing Laboratory  
 245 South Grape Street • Medford, OR 97501  
 (541) 770-5678 fax (541) 770-2901

Roosevelt

# Chain of Custody Record

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

<b>Section A</b> Required Client Information		<b>Section B</b> Required Project Information		<b>Section C</b> Invoice Information		<b>Section D</b> Rush Status (Subject to Scheduling)	
Company: Medford School District 549C		Project Name: 2016 Lead testing		Attention: Accounting		Standard 10-14 Days	
Address: 815 S. Oakdale, Medford, Or, 97501		Project Number: 16-48 / Roosevelt		Company Name: Medford School		5 Business Days (50% surcharge)	
Email: rick.rose@medford.k12.or.us		Report To: rick.rose@medford.k12.or.us		Address: 815 S. Oakdale Medford, Or, 97501		3 Business Days (75% surcharge)	
Phone: 541.842.1138 Fax: 541.842.1160		Copy To: ron.havnicar@medford.k12.or.us		P.O. # P112894		24 - 48 hours (100% surcharge)	
Collected By (Print): <u>Sofa Sessen</u>		Analysis Requested		Authorized		Yes ___ No ___	
Email Report <input checked="" type="checkbox"/> Yes ___ No ___							
Fax Report <input type="checkbox"/> Yes ___ No ___							

Sample ID	Completion	Matrix*	Date Collected	Time Collected	No. of Containers	Analysis Requested				NRC Workorder # (Lab Use Only)	NRC Sample # (Lab Use Only)
Playground DF	11369		7/12/16	3:18pm	1					1607444	18
Rm 604 Staff BK Rm Sink	11414			2:41pm	1						19
Rm 604 Staff BK Rm Toilet - Hot	11365			2:43pm	1						20
Kitchen Food Prep Sink	11412			2:57pm	1						21

\*Matrix: DW - Drinking Water WW - Wastewater W - Water S - Soil/Solid SL - Sludge O - Oil WP - Wipe OT - Other

<b>Section F</b> Relinquish/Receive		<b>Section G</b> Lab Use Only	
Relinquished By: <u>[Signature]</u>	Sign	Temp: <u>AWA/19</u>	Temp: <u>AWA/19</u>
Received By: <u>[Signature]</u>	Print	4°C +/- 2°C: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	Received on Ice: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
Relinquished By:		Number of Bottles Received: <u>4</u>	pH Checked: <u>WAD</u>
Received By:		COC Seals Intact: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	Field Blank Included: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
Relinquished By:		Received Via: <u>UPS</u>	UPS FedEX Other <input checked="" type="checkbox"/> Hand
Received By Laboratory: <u>[Signature]</u>	Date	Time	Amount
	7/12/16	4:09pm	

Payment:  Invoice  Cash  VISA, MC  Check # \_\_\_\_\_



Environmental Testing Laboratory  
 243 South Grape Street • Medford, OR 97501  
 (541) 770-5678 fax (541) 770-2901

*Roosevelt*  
**Chain of Custody Record**

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

<b>Section A</b> Required Client Information		<b>Section B</b> Required Project Information		<b>Section C</b> Invoice Information		<b>Section D</b> Rush Status (Subject to Scheduling)	
Company: Medford School District 549C		Project Name: 2016 Lead testing		Attention: Accounting		Standard 10-14 Days	
Address: 815 S. Oakdale, Medford, Or, 97501		Project Number: 16-48 / Roosevelt		Company Name: Medford School		5 Business Days (50% surcharge)	
Email: rick.rose@medford.k12.or.us		Report To: rick.rose@medford.k12.or.us		Address: 815 S. Oakdale		3 Business Days (75% surcharge)	
Phone: 541.842.1138 Fax: 541.842.1160		Copy To: ron.havniar@medford.k12.or.us		Medford, Or, 97501		24 - 48 hours (100% surcharge)	
Collected By (Print): <i>Bill Bartlett</i>		P.O. # P112894		Authorized		Yes ___ No ___	
Email Report <input checked="" type="checkbox"/> Yes ___ No ___							
Fax Report <input type="checkbox"/> Yes ___ No ___							

Sample Information	Sample ID	Matrix*	Date Collected	Time Collected	No. of Containers	Analysis Requested				NRC Workorder # (Lab Use Only)	NRC Sample # (Lab Use Only)	
	Rn 210 D.F. <i>18</i>		7-12-16	3:02 PM	1						1609444	77
	Rn 210 D.F. C			3:04 PM	1							73
	Rn 211 D.F.			3:06 PM	1							24
	Rn 212 D.F.			3:08 PM	1							25
	Rn 213 D.F.			3:18 PM	1							24
	Rn 219 D.F.			3:11 PM	1							27
	Znd Filter O.S. Rows R.R. D.F.			3:14 PM	1							28
	Znd Filter O.S. Rows R.R. D.F.			3:14 PM	1							29
	Rn 231 D.F.			3:16 PM	1							30

\*Matrix: DW - Drinking Water WW - Wastewater W - Water S - Soil/Solid SL - Sludge O - Oil WP - Wipe OT - Other

<b>Section F</b> Relinquish/Receive		<b>Section G</b> Lab Use Only	
Relinquished By: <i>Bill Bartlett</i>	Sign	Temp: <i>AMBER</i>	Temp: <i>AMBER</i>
Received By: <i>John Jensen</i>	Print	4°C +/- 2°C: Yes ___ No ___	Received on Ice: Yes ___ No ___
Relinquished By: <i>John Jensen</i>	Date	Number of Bottles Received: <i>10</i>	pH Checked: <i>NA</i>
Received By: <i>John Jensen</i>	Time	COC Seats Intact: Yes ___ No ___	Field Blank Included: Yes ___ No ___
Relinquished By: <i>John Jensen</i>			
Received By Laboratory: <i>John Jensen</i>			

Payment:  Invoice \_\_\_ Cash \_\_\_ VISA, M/C \_\_\_ Check # \_\_\_ Amount \_\_\_

Received Via:  UPS \_\_\_ FedEX \_\_\_ Other \_\_\_ Hand \_\_\_



Environmental Testing Laboratory  
 245 South Grape Street • Medford, OR 97501  
 (541) 770-5678 Fax (541) 770-2901

Roosevelt

# Chain of Custody Record

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

### Section A Required Client Information

Company: Medford School District 549C  
 Address: 815 S. Oakdale,  
 Medford, Or, 97501  
 Email: rick.rose@medford.k12.or.us  
 Phone: 541.842.1138 Fax: 541.842.1160  
 Collected By (Print): Bill Bartlett  
 Collected By (Sign): [Signature]  
 Email Report  Yes  No Mail Report  Yes  No  
 Fax Report  Yes  No

### Section B Required Project Information

Project Name: 2016 Lead testing  
 Project Number: 16-48 / Roosevelt  
 Report To: rick.rose@medford.k12.or.us  
 Copy To: ron.havniar@medford.k12.or.us  
 Attention: Accounting  
 Company Name: Medford School  
 Address: 815 S. Oakdale  
 P.O. # P112894

### Section C Invoice Information

Standard 10-14 Days  
 5 Business Days (50% surcharge)  
 3 Business Days (75% surcharge)  
 24 - 48 hours (100% surcharge)  
 Other \_\_\_\_\_  
 Authorized  Yes  No

### Section D Rush Status (Subject to Scheduling)

Standard 10-14 Days  
 5 Business Days (50% surcharge)  
 3 Business Days (75% surcharge)  
 24 - 48 hours (100% surcharge)  
 Other \_\_\_\_\_  
 Authorized  Yes  No

### Section E Sample Information

Sample ID	Client/Job	Matrix*	Date Collected	Time Collected	No. of Containers	Analysis Requested	NRC Workorder # (Lab Use Only)	NRC Sample # (Lab Use Only)
Rm 240 D.F.A			7-12-16	2:50 PM	1		1607444	31
Rm 240 D.F.B				2:51 PM	1			32
Rm 240 D.F.C				2:52 PM	1			33
Rm 241 D.F.				2:55 PM	1			34
Rm 242 D.F.				2:57 PM	1			35
Rm 245 D.F.				2:58 PM	1			36
Rm 210 D.F.A			5:01 PM		1			37

### Section F Relinquish/Receive

Relinquished By:	Sign	Print	Date	Time
Relinquished By:	<u>[Signature]</u>	Bill Bartlett	7-12-16	3:25 PM
Received By:	<u>[Signature]</u>	John Sesson	7/12/16	3:35 PM
Relinquished By:	<u>[Signature]</u>	John Sesson	7/12/16	4:09 PM
Received By:				
Relinquished By:				
Received By:				

### Section G Lab Use Only

Temp: 41.0  
 4°C +/- 2°C: Yes  No   
 Received on Ice: Yes  No   
 Number of Bottles Received: 7  
 pH Checked: N/A  
 COC Seals Intact: Yes  No  NA   
 Field Blank Included: Yes  No

Payment:  Invoice  Cash  VISA, MC  Check # \_\_\_\_\_ Amount \_\_\_\_\_  
 Received Via:  UPS  FedEx  Other  Hand



Environmental Testing Laboratory  
 245 South Grape Street • Medford, OR 97501  
 (541) 770-5078 fax (541) 770-2901

Roosevelt

# Chain of Custody Record

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Page \_\_\_ of \_\_\_

### Section A Required Client Information

Company: Medford School District 549C  
 Address: 815 S. Oakdale,  
 Medford, Or, 97501  
 Email: rick.rose@medford.k12.or.us  
 Phone: 541.842.1138 Fax: 541.842.1160  
 Collected By (Print): *John Jensen*  
 Email Report  Yes  No Mail Report  Yes  No  
 Fax Report  Yes  No

### Section B Required Project Information

Project Name: 2016 Lead testing  
 Project Number: 16-48 / Roosevelt  
 Report To: rick.rose@medford.k12.or.us  
 Copy To: ron.havniar@medford.k12.or.us  
 Attention: Accounting  
 Company Name: Medford School  
 Address: 815 S. Oakdale  
 Medford, Or, 97501  
 P.O. # P112894

### Section C Invoice Information

### Section D Rush Status (Subject to Scheduling)

Standard 10-14 Days  
 5 Business Days (50% surcharge)  
 3 Business Days (75% surcharge)  
 24 - 48 hours (100% surcharge)  
 Other \_\_\_\_\_  
 Authorized  Yes  No

### Section E Sample Information

Sample ID	Comments	Matrix*	Date Collected	Time Collected	No. of Containers	Analysis Requested	NRC Workorder # (Lab Use Only)	NRC Sample # (Lab Use Only)
Boys Lnts RR B120 DF (Liners)			7/13/16	2:27pm	1		1602444	38
Boys Lnts RR B120 DF (Liners)				2:28pm	1			39
Rn 120 DF				2:31pm	1			40
Rn 121 DF				2:32pm	1			41
Rn 122 DF				2:38pm	1			42
CAF DF (Upper)				2:54pm	1			43
CAF DF (Lower)				2:58pm	1			44
CAF DF Bottle Filter				2:53pm	1			45
Gyn DF (Upper)				3:01pm	1			46
Gyn DF (Lower)				3:09pm	1			47

\*Matrix: DW - Drinking Water WW - Wastewater W - Water S - Soil/Solid SL - Sludge O - Oil WP - Wipe OT - Other

### Section F Relinquish/Receive

Relinquish/Receive By:	Sign	Date	Time
Received By:	<i>John Jensen</i>	7/13/16	4:09pm
Relinquished By:			
Received By:			
Relinquished By:			
Received By:			
Relinquished By:			
Received By Laboratory:	<i>Tom Swager</i>	7/13/16	4:09

### Section G Lab Use Only

Temp: Ambient  
 4°C +/- 2°C: Yes  No   
 Received on Ice: Yes  No   
 Number of Bottles Received: 10  
 pH Checked:   
 COC Seals Intact: Yes  No   
 Field Blank Included: Yes  No

Received Via:  UPS  FedEx  Other  Hand  
 Payment:  Invoice  Cash  VISA  M/C  Check # \_\_\_\_\_ Amount \_\_\_\_\_