



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

March 20, 2020

Ron Havniar
Medford School District
815 S Oakdale Ave
Medford, OR 97501
TEL: 541-842-3646
FAX: 541-842-1160

RE: 18-56 Washington 2020 Lead Testing

Order No.: 20030599

Dear Ron Havniar:

Neilson Research Corporation received 4 sample(s) on 3/13/2020 for the analyses presented in the following report.

The results relate only to the parameters tested or to the sample as received by the laboratory. This report shall not be reproduced except in full, without the written approval of Neilson Research Corporation. If you have any questions regarding these test results, please feel free to call.

Sincerely,
Neilson Research Corporation

Tamra Schmedemann
Senior Project Manager
245 S Grape St
Medford, OR 97501



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Case Narrative

WO#: 20030599
Date: 3/20/2020

CLIENT: Medford School District
Project: 18-56 Washington 2020 Lead Testing

The analyses were performed according to the guidelines in the Neilson Research Corporation Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

Neilson Research Corporation certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 20030599
 Date Reported: 3/20/2020

Medford School District
 815 S Oakdale Ave
 Medford, OR 97501

Lab Order: 20030599
Received Date: 3/13/2020 8:21:00 AM
Reported Date: 3/20/2020 10:06:22 AM

Sample Information:

Lab ID: 20030599-01 Client Sample ID: 1st Floor Outside Boy's RR - DF (L)
 Collection Date: 3/13/2020 7:59:00 AM Collected By: Gary Severe
 Matrix: Drinking Water Sample Location: 1st Floor Outside Boy's RR - DF (L)

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.000581		0.000103	mg/L	1	3/17/2020	0.0150	A

Lab ID: 20030599-02 Client Sample ID: Room 1 - Drinking Fountain
 Collection Date: 3/13/2020 8:01:00 AM Collected By: Gary Severe
 Matrix: Drinking Water Sample Location: Room 1 - Drinking Fountain

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.000671		0.000103	mg/L	1	3/17/2020	0.0150	A

Lab ID: 20030599-03 Client Sample ID: Room 10 - Drinking Fountain
 Collection Date: 3/13/2020 8:08:00 AM Collected By: Gary Severe
 Matrix: Drinking Water Sample Location: Room 10 - Drinking Fountain

Trace Metals by EPA 200.8 ICP-MS								Analyst: SJS
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.000578		0.000103	mg/L	1	3/17/2020	0.0150	A

QUALIFIERS	* Value exceeds Maximum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcod
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	MI Recovery outside control limits due to Matrix Interference
	ND Not Detected at the Reporting Limit	PL Permit Limit
	R RPD outside accepted recovery limits	

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Analytical Report

WO#: 20030599
 Date Reported: 3/20/2020

Medford School District
 815 S Oakdale Ave
 Medford , OR 97501

Lab Order: 20030599
Received Date: 3/13/2020 8:21:00 AM
Reported Date: 3/20/2020 10:06:22 AM


Sample Information:

Lab ID: 20030599-04 Client Sample ID: Room 23 - Drinking Fountain
 Collection Date: 3/13/2020 8:05:00 AM Collected By: Gary Severe
 Matrix: Drinking Water Sample Location: Room 23 - Drinking Fountain

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.00294		0.000103	mg/L	1	3/17/2020	0.0150	A

QUALIFIERS	* Value exceeds Maximum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcod
	E Value above quantitation range	H Holding times for preparation or analysis exceeded
	J Analyte detected below quantitation limits	MI Recovery outside control limits due to Matrix Interference
	ND Not Detected at the Reporting Limit	PL Permit Limit
	R RPD outside accepted recovery limits	

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

QC SUMMARY REPORT

WO#: 20030599
 20-Mar-20

Client: Medford School District
Project: 18-56 Washington 2020 Lead Testing

TestCode: LEAD_DW

Sample ID: MB-3346	SampType: MBLK	TestCode: LEAD_DW	Units: mg/L	Prep Date: 3/16/2020	RunNo: 8374						
Client ID: PBW	Batch ID: 3346	TestNo: E200.8	E200.8	Analysis Date: 3/17/2020	SeqNo: 151615						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead ND 0.000103

Sample ID: LCS-3346	SampType: LCS	TestCode: LEAD_DW	Units: mg/L	Prep Date: 3/16/2020	RunNo: 8374						
Client ID: LCSW	Batch ID: 3346	TestNo: E200.8	E200.8	Analysis Date: 3/17/2020	SeqNo: 151616						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead 0.0994 0.000104 0.1000 0 99.4 85 115

Sample ID: 20030599-01AMS	SampType: MS	TestCode: LEAD_DW	Units: mg/L	Prep Date: 3/16/2020	RunNo: 8374						
Client ID: 1st Floor Outside Bo	Batch ID: 3346	TestNo: E200.8	E200.8	Analysis Date: 3/17/2020	SeqNo: 151625						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead 0.110 0.000104 0.1000 0.0005809 109 70 130

Sample ID: 20030599-01AMSD	SampType: MSD	TestCode: LEAD_DW	Units: mg/L	Prep Date: 3/16/2020	RunNo: 8374						
Client ID: 1st Floor Outside Bo	Batch ID: 3346	TestNo: E200.8	E200.8	Analysis Date: 3/17/2020	SeqNo: 151626						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead 0.0968 0.000104 0.1000 0.0005809 96.3 70 130 0.1097 12.5 20

Qualifiers: C1 Sample container temperature is out of limit as specified at testcode H Holding times for preparation or analysis exceeded MI Recovery outside control limits due to Matrix In
 ND Not Detected at the Reporting Limit PL Permit Limit RL Reporting Detection Limit

Original



Neilson Research Corporation
 245 S Grape St
 Medford, OR 97501
 TEL: (541) 770-5678 FAX: (541) 770-2901
 Website: www.nrclabs.com

Sample Log-In Check List

Client Name: **MedfordSchoolDist** Work Order Number: **20030599** RcptNo: **1**

Logged by:	Vincenza Gill	3/13/2020 8:21:00 AM	<i>Vincenza Gill</i>
Completed By:	Michelle Harsh	3/16/2020 1:40:00 PM	<i>Michelle Harsh</i>
Reviewed By:	Tamra Schmedemann	3/20/2020 9:57:54 AM	<i>Tamra Schmedemann</i>

Chain of Custody

1. Is Chain of Custody complete? Yes No Not Present
 2. How was the sample delivered? Client

Log In

3. Coolers are present? Yes No NA
 4. Shipping container/cooler in good condition? Yes No
 Custody seals intact on shipping container/cooler? Yes No Not Present
 No. Seal Date: Signed By:
 5. Was an attempt made to cool the samples? Yes No NA
 6. Were all samples received at a temperature of >0° C to 6.0°C Yes No NA
 7. Sample(s) in proper container(s)? Yes No
 8. Sufficient sample volume for indicated test(s)? Yes No
 9. Are samples (except VOA and ONG) properly preserved? Yes No
 10. Was preservative added to bottles? Yes No NA
 HNO3 pH < 2
 11. Is the headspace in the VOA vials less than 1/4 inch or 6 mm? Yes No No VOA Vials
 12. Were any sample containers received broken? Yes No
 13. Does paperwork match bottle labels? Yes No
 (Note discrepancies on chain of custody)
 14. Are matrices correctly identified on Chain of Custody? Yes No
 15. Is it clear what analyses were requested? Yes No
 16. Were all holding times able to be met? Yes No
 (If no, notify customer for authorization.)

Special Handling (if applicable)

17. Was client notified of all discrepancies with this order? Yes No NA

Person Notified:	<input type="text"/>	Date:	<input type="text"/>
By Whom:	<input type="text"/>	Via:	<input type="checkbox"/> eMail <input type="checkbox"/> Phone <input type="checkbox"/> Fax <input type="checkbox"/> In Person
Regarding:	<input type="text"/>		
Client Instructions:	<input type="text"/>		

18. Additional remarks:

Cooler Information

Cooler No	Temp °C	Condition	Seal Intact	Seal No	Seal Date	Signed By
-----------	---------	-----------	-------------	---------	-----------	-----------

