



# NEILSON RESEARCH CORPORATION

*Environmental Testing Laboratory*

7/25/2016

Rick Rose  
Medford School District  
815 S Oakdale Ave  
Medford, OR 97501

TEL: (541) 842-1138  
FAX 541-842-1160

RE: 16-64 Wilson Lead Study

Order No.: 1607258

Dear Rick Rose:

Neilson Research Corporation received 39 sample(s) on 7/7/2016 for the analyses presented in the following report.

The results relate only to the parameters tested or to the sample as received by the laboratory. This report shall not be reproduced except in full, without the written approval of Neilson Research Corporation. If you have any questions regarding these test results, please feel free to call.

Sincerely,  
Neilson Research Corporation

Alec C Smith  
Project Manager

# Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

## Analysis Report

ORELAP 100016  
EPA OR00028

**CLIENT:** Medford School District  
**Project:** 16-64 Wilson Lead Study  
**Lab Order:** 1607258

**Date:** 25-Jul-16

## CASE NARRATIVE

The analyses were performed according to the guidelines in the Neilson Research Corporation Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

Neilson Research Corporation certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

# Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

## Analysis Report

ORELAP 100016  
EPA OR00028

Medford School District  
815 S Oakdale Ave  
Medford, OR 97501

Lab Order: **1607258**  
NRC Sample ID: **1607258-01A**  
Collection Date: **7/7/2016 2:49:00 PM**  
Received Date: **7/7/2016 3:35:00 PM**  
Reported Date: **7/25/2016 2:55:10 PM**

### Sample Information:

16-64 Wilson Lead Study

Client Sample ID: Bottle #11456  
Collectors Name: Gary Severe  
Sample Location: Room 1 DF  
Source: City Water

## ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.00425		0.000103	mg/L	0.020 AL	7/20/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

# Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

## Analysis Report

ORELAP 100016  
EPA OR00028

Medford School District  
815 S Oakdale Ave  
Medford, OR 97501

Lab Order: **1607258**  
NRC Sample ID: **1607258-02A**  
Collection Date: **7/7/2016 2:50:00 PM**  
Received Date: **7/7/2016 3:35:00 PM**  
Reported Date: **7/25/2016 2:55:10 PM**

### Sample Information:

16-64 Wilson Lead Study

Client Sample ID: Bottle #11440  
Collectors Name: Gary Severe  
Sample Location: Room 2 DF  
Source: City Water

## ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.00236		0.000103	mg/L	0.020 AL	7/20/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

# Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

## Analysis Report

ORELAP 100016  
EPA OR00028

Medford School District  
815 S Oakdale Ave  
Medford, OR 97501

Lab Order: **1607258**  
NRC Sample ID: **1607258-03A**  
Collection Date: **7/7/2016 2:51:00 PM**  
Received Date: **7/7/2016 3:35:00 PM**  
Reported Date: **7/25/2016 2:55:10 PM**

### Sample Information:

16-64 Wilson Lead Study

Client Sample ID: Bottle #11466  
Collectors Name: Gary Severe  
Sample Location: Room 3 DF  
Source: City Water

## ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.00174		0.000103	mg/L	0.020 AL	7/20/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

# Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

## Analysis Report

ORELAP 100016  
EPA OR00028

Medford School District  
815 S Oakdale Ave  
Medford, OR 97501

Lab Order: **1607258**  
NRC Sample ID: **1607258-04A**  
Collection Date: **7/7/2016 2:53:00 PM**  
Received Date: **7/7/2016 3:35:00 PM**  
Reported Date: **7/25/2016 2:55:10 PM**

### Sample Information:

16-64 Wilson Lead Study

Client Sample ID: Bottle #11455  
Collectors Name: Gary Severe  
Sample Location: Room 4 DF  
Source: City Water

## ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	<b>0.00274</b>		0.000103	mg/L	0.020 AL	7/20/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

# Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

## Analysis Report

ORELAP 100016  
EPA OR00028

Medford School District  
815 S Oakdale Ave  
Medford, OR 97501

Lab Order: **1607258**  
NRC Sample ID: **1607258-05A**  
Collection Date: **7/7/2016 2:55:00 PM**  
Received Date: **7/7/2016 3:35:00 PM**  
Reported Date: **7/25/2016 2:55:10 PM**

### Sample Information:

16-64 Wilson Lead Study

Client Sample ID: Bottle #11478  
Collectors Name: Gary Severe  
Sample Location: Room 5 DF  
Source: City Water

## ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	<b>0.000549</b>		0.000103	mg/L	0.020 AL	7/20/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

# Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

## Analysis Report

ORELAP 100016  
EPA OR00028

Medford School District  
815 S Oakdale Ave  
Medford, OR 97501

Lab Order: **1607258**  
NRC Sample ID: **1607258-06A**  
Collection Date: **7/7/2016 2:57:00 PM**  
Received Date: **7/7/2016 3:35:00 PM**  
Reported Date: **7/25/2016 2:55:10 PM**

### Sample Information:

16-64 Wilson Lead Study

Client Sample ID: Bottle #11457  
Collectors Name: Gary Severe  
Sample Location: Room 6 DF  
Source: City Water

## ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	<b>0.00159</b>		0.000103	mg/L	0.020 AL	7/20/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

# Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

## Analysis Report

ORELAP 100016  
EPA OR00028

Medford School District  
815 S Oakdale Ave  
Medford, OR 97501

Lab Order: **1607258**  
NRC Sample ID: **1607258-07A**  
Collection Date: **7/7/2016 2:58:00 PM**  
Received Date: **7/7/2016 3:35:00 PM**  
Reported Date: **7/25/2016 2:55:10 PM**

### Sample Information:

16-64 Wilson Lead Study

Client Sample ID: Bottle #11442  
Collectors Name: Gary Severe  
Sample Location: Room 7 DF  
Source: City Water

## ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	<b>0.00100</b>		0.000103	mg/L	0.020 AL	7/20/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

# Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

## Analysis Report

ORELAP 100016  
EPA OR00028

Medford School District  
815 S Oakdale Ave  
Medford, OR 97501

Lab Order: **1607258**  
NRC Sample ID: **1607258-08A**  
Collection Date: **7/7/2016 2:59:00 PM**  
Received Date: **7/7/2016 3:35:00 PM**  
Reported Date: **7/25/2016 2:55:10 PM**

### Sample Information:

16-64 Wilson Lead Study

Client Sample ID: Bottle #11408  
Collectors Name: Gary Severe  
Sample Location: Room 8 DF  
Source: City Water

## ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	<b>0.00138</b>		0.000103	mg/L	0.020 AL	7/20/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

# Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

## Analysis Report

ORELAP 100016  
EPA OR00028

Medford School District  
815 S Oakdale Ave  
Medford, OR 97501

Lab Order: **1607258**  
NRC Sample ID: **1607258-09A**  
Collection Date: **7/7/2016 3:01:00 PM**  
Received Date: **7/7/2016 3:35:00 PM**  
Reported Date: **7/25/2016 2:55:10 PM**

### Sample Information:

16-64 Wilson Lead Study

Client Sample ID: Bottle #11458  
Collectors Name: Gary Severe  
Sample Location: Room 9 DF  
Source: City Water

## ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	<b>0.00180</b>		0.000103	mg/L	0.020 AL	7/20/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

# Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

## Analysis Report

ORELAP 100016  
EPA OR00028

Medford School District  
815 S Oakdale Ave  
Medford, OR 97501

Lab Order: **1607258**  
NRC Sample ID: **1607258-10A**  
Collection Date: **7/7/2016 3:02:00 PM**  
Received Date: **7/7/2016 3:35:00 PM**  
Reported Date: **7/25/2016 2:55:10 PM**

### Sample Information:

16-64 Wilson Lead Study

Client Sample ID: Bottle #11410  
Collectors Name: Gary Severe  
Sample Location: Room 10 DF  
Source: City Water

## ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.00570		0.000103	mg/L	0.020 AL	7/20/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

# Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

## Analysis Report

ORELAP 100016  
EPA OR00028

Medford School District  
815 S Oakdale Ave  
Medford, OR 97501

Lab Order: **1607258**  
NRC Sample ID: **1607258-11A**  
Collection Date: **7/7/2016 3:04:00 PM**  
Received Date: **7/7/2016 3:35:00 PM**  
Reported Date: **7/25/2016 2:55:10 PM**

### Sample Information:

16-64 Wilson Lead Study

Client Sample ID: Bottle #11430  
Collectors Name: Gary Severe  
Sample Location: Room 11 DF  
Source: City Water

## ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.000888		0.000103	mg/L	0.020 AL	7/20/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

# Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

## Analysis Report

ORELAP 100016  
EPA OR00028

Medford School District  
815 S Oakdale Ave  
Medford, OR 97501

Lab Order: **1607258**  
NRC Sample ID: **1607258-12A**  
Collection Date: **7/7/2016 3:05:00 PM**  
Received Date: **7/7/2016 3:35:00 PM**  
Reported Date: **7/25/2016 2:55:10 PM**

### Sample Information:

16-64 Wilson Lead Study

Client Sample ID: Bottle #11450  
Collectors Name: Gary Severe  
Sample Location: Room 12 DF  
Source: City Water

## ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	<b>0.00188</b>		0.000103	mg/L	0.020 AL	7/20/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

# Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

## Analysis Report

ORELAP 100016  
EPA OR00028

Medford School District  
815 S Oakdale Ave  
Medford, OR 97501

Lab Order: **1607258**  
NRC Sample ID: **1607258-13A**  
Collection Date: **7/7/2016 3:07:00 PM**  
Received Date: **7/7/2016 3:35:00 PM**  
Reported Date: **7/25/2016 2:55:10 PM**

### Sample Information:

16-64 Wilson Lead Study

Client Sample ID: Bottle #11465  
Collectors Name: Gary Severe  
Sample Location: Room 13 DF  
Source: City Water

## ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.00170		0.000103	mg/L	0.020 AL	7/20/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

# Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

## Analysis Report

ORELAP 100016  
EPA OR00028

Medford School District  
815 S Oakdale Ave  
Medford, OR 97501

Lab Order: **1607258**  
NRC Sample ID: **1607258-14A**  
Collection Date: **7/7/2016 3:08:00 PM**  
Received Date: **7/7/2016 3:35:00 PM**  
Reported Date: **7/25/2016 2:55:10 PM**

### Sample Information:

16-64 Wilson Lead Study

Client Sample ID: Bottle #11460  
Collectors Name: Gary Severe  
Sample Location: Room 14 DF  
Source: City Water

## ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.00177		0.000103	mg/L	0.020 AL	7/20/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

# Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

## Analysis Report

ORELAP 100016  
EPA OR00028

Medford School District  
815 S Oakdale Ave  
Medford, OR 97501

Lab Order: **1607258**  
NRC Sample ID: **1607258-15A**  
Collection Date: **7/7/2016 3:09:00 PM**  
Received Date: **7/7/2016 3:35:00 PM**  
Reported Date: **7/25/2016 2:55:10 PM**

### Sample Information:

16-64 Wilson Lead Study

Client Sample ID: Bottle #11449  
Collectors Name: Gary Severe  
Sample Location: Room 15 DF  
Source: City Water

## ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	<b>0.00343</b>		0.000103	mg/L	0.020 AL	7/20/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

# Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

## Analysis Report

ORELAP 100016  
EPA OR00028

Medford School District  
815 S Oakdale Ave  
Medford, OR 97501

Lab Order: **1607258**  
NRC Sample ID: **1607258-16A**  
Collection Date: **7/7/2016 2:43:00 PM**  
Received Date: **7/7/2016 3:35:00 PM**  
Reported Date: **7/25/2016 2:55:10 PM**

### Sample Information:

16-64 Wilson Lead Study

Client Sample ID: Bottle #11464  
Collectors Name: John Jessen  
Sample Location: Health Rm Sink  
Source: City Water

## ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	<b>0.00860</b>		0.000103	mg/L	0.020 AL	7/20/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

# Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

## Analysis Report

ORELAP 100016  
EPA OR00028

Medford School District  
815 S Oakdale Ave  
Medford, OR 97501

Lab Order: **1607258**  
NRC Sample ID: **1607258-17A**  
Collection Date: **7/7/2016 2:48:00 PM**  
Received Date: **7/7/2016 3:35:00 PM**  
Reported Date: **7/25/2016 2:55:10 PM**

### Sample Information:

16-64 Wilson Lead Study

Client Sample ID: Bottle #11418  
Collectors Name: John Jessen  
Sample Location: Staff Work Rm DF  
Source: City Water

## ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.00234		0.000103	mg/L	0.020 AL	7/20/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

# Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

## Analysis Report

ORELAP 100016  
EPA OR00028

Medford School District  
815 S Oakdale Ave  
Medford, OR 97501

Lab Order: **1607258**  
NRC Sample ID: **1607258-18A**  
Collection Date: **7/7/2016 2:45:00 PM**  
Received Date: **7/7/2016 3:35:00 PM**  
Reported Date: **7/25/2016 2:55:10 PM**

### Sample Information:

16-64 Wilson Lead Study

Client Sample ID: Bottle #11407  
Collectors Name: John Jessen  
Sample Location: Conf Rm by Main Office Sk  
Source: City Water

## ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.0121		0.000103	mg/L	0.020 AL	7/20/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

# Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

## Analysis Report

ORELAP 100016  
EPA OR00028

Medford School District  
815 S Oakdale Ave  
Medford, OR 97501

Lab Order: **1607258**  
NRC Sample ID: **1607258-19A**  
Collection Date: **7/7/2016 2:41:00 PM**  
Received Date: **7/7/2016 3:35:00 PM**  
Reported Date: **7/25/2016 2:55:10 PM**

### Sample Information:

16-64 Wilson Lead Study

Client Sample ID: Bottle #11400  
Collectors Name: John Jessen  
Sample Location: Staff Brk Rm Sink  
Source: City Water

## ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.00313		0.000103	mg/L	0.020 AL	7/20/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

# Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

## Analysis Report

ORELAP 100016  
EPA OR00028

Medford School District  
815 S Oakdale Ave  
Medford, OR 97501

Lab Order: **1607258**  
NRC Sample ID: **1607258-20A**  
Collection Date: **7/7/2016 2:59:00 PM**  
Received Date: **7/7/2016 3:35:00 PM**  
Reported Date: **7/25/2016 2:55:10 PM**

### Sample Information:

16-64 Wilson Lead Study

Client Sample ID: Bottle #11391  
Collectors Name: John Jessen  
Sample Location: Kitch. Food Prep Sink E Wall  
Source: City Water

## ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.000891		0.000103	mg/L	0.020 AL	7/20/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

# Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

## Analysis Report

ORELAP 100016  
EPA OR00028

Medford School District  
815 S Oakdale Ave  
Medford, OR 97501

Lab Order: **1607258**  
NRC Sample ID: **1607258-21A**  
Collection Date: **7/7/2016 3:01:00 PM**  
Received Date: **7/7/2016 3:35:00 PM**  
Reported Date: **7/25/2016 2:55:10 PM**

### Sample Information:

16-64 Wilson Lead Study

Client Sample ID: Bottle #11392  
Collectors Name: John Jessen  
Sample Location: Caf DF Upper  
Source: City Water

## ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.000550		0.000103	mg/L	0.020 AL	7/20/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

# Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

## Analysis Report

ORELAP 100016  
EPA OR00028

Medford School District  
815 S Oakdale Ave  
Medford, OR 97501

Lab Order: **1607258**  
NRC Sample ID: **1607258-22A**  
Collection Date: **7/7/2016 3:03:00 PM**  
Received Date: **7/7/2016 3:35:00 PM**  
Reported Date: **7/25/2016 2:55:10 PM**

### Sample Information:

16-64 Wilson Lead Study

Client Sample ID: Bottle #11411  
Collectors Name: John Jessen  
Sample Location: Caf DF Lower  
Source: City Water

## ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.00213		0.000103	mg/L	0.020 AL	7/20/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

# Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

## Analysis Report

ORELAP 100016  
EPA OR00028

Medford School District  
815 S Oakdale Ave  
Medford, OR 97501

Lab Order: **1607258**  
NRC Sample ID: **1607258-23A**  
Collection Date: **7/7/2016 3:03:00 PM**  
Received Date: **7/7/2016 3:35:00 PM**  
Reported Date: **7/25/2016 2:55:10 PM**

### Sample Information:

16-64 Wilson Lead Study

Client Sample ID: Bottle #11383  
Collectors Name: John Jessen  
Sample Location: Caf DF Bottle Filler  
Source: City Water

## ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.00275		0.000103	mg/L	0.020 AL	7/20/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

# Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

## Analysis Report

ORELAP 100016  
EPA OR00028

Medford School District  
815 S Oakdale Ave  
Medford, OR 97501

Lab Order: **1607258**  
NRC Sample ID: **1607258-24A**  
Collection Date: **7/7/2016 2:54:00 PM**  
Received Date: **7/7/2016 3:35:00 PM**  
Reported Date: **7/25/2016 2:55:10 PM**

### Sample Information:

16-64 Wilson Lead Study

Client Sample ID: Bottle #11443  
Collectors Name: John Jessen  
Sample Location: W Side Gym Outside DF L  
Source: City Water

## ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.00283		0.000103	mg/L	0.020 AL	7/20/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

# Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

## Analysis Report

ORELAP 100016  
EPA OR00028

Medford School District  
815 S Oakdale Ave  
Medford, OR 97501

Lab Order: **1607258**  
NRC Sample ID: **1607258-25A**  
Collection Date: **7/7/2016 2:55:00 PM**  
Received Date: **7/7/2016 3:35:00 PM**  
Reported Date: **7/25/2016 2:55:10 PM**

### Sample Information:

16-64 Wilson Lead Study

Client Sample ID: Bottle #11390  
Collectors Name: John Jessen  
Sample Location: W Side Gym Outside DF R  
Source: City Water

## ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.0175	CF	0.000103	mg/L	0.020 AL	7/20/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

# Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

## Analysis Report

ORELAP 100016  
EPA OR00028

Medford School District  
815 S Oakdale Ave  
Medford, OR 97501

Lab Order: **1607258**  
NRC Sample ID: **1607258-26A**  
Collection Date: **7/7/2016 2:51:00 PM**  
Received Date: **7/7/2016 3:35:00 PM**  
Reported Date: **7/25/2016 2:55:10 PM**

### Sample Information:

16-64 Wilson Lead Study

Client Sample ID: Bottle #11447  
Collectors Name: John Jessen  
Sample Location: EA Wing Outside Girls RR DF  
Source: City Water

## ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.00901		0.000103	mg/L	0.020 AL	7/20/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

# Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

## Analysis Report

ORELAP 100016  
EPA OR00028

Medford School District  
815 S Oakdale Ave  
Medford, OR 97501

Lab Order: **1607258**  
NRC Sample ID: **1607258-27A**  
Collection Date: **7/7/2016 3:00:00 PM**  
Received Date: **7/7/2016 3:35:00 PM**  
Reported Date: **7/25/2016 2:55:10 PM**

### Sample Information:

16-64 Wilson Lead Study

Client Sample ID: Bottle #11389  
Collectors Name: Roger Moulard  
Sample Location: Room 16 DF  
Source: City Water

## ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.00156		0.000103	mg/L	0.020 AL	7/20/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

# Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

## Analysis Report

ORELAP 100016  
EPA OR00028

Medford School District  
815 S Oakdale Ave  
Medford, OR 97501

Lab Order: **1607258**  
NRC Sample ID: **1607258-28A**  
Collection Date: **7/7/2016 2:38:00 PM**  
Received Date: **7/7/2016 3:35:00 PM**  
Reported Date: **7/25/2016 2:55:10 PM**

### Sample Information:

16-64 Wilson Lead Study

Client Sample ID: Bottle #11404  
Collectors Name: Roger Moulard  
Sample Location: Room 17 DF  
Source: City Water

## ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	<b>0.00198</b>		0.000103	mg/L	0.020 AL	7/20/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

# Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

## Analysis Report

ORELAP 100016  
EPA OR00028

Medford School District  
815 S Oakdale Ave  
Medford, OR 97501

Lab Order: **1607258**  
NRC Sample ID: **1607258-29A**  
Collection Date: **7/7/2016 2:41:00 PM**  
Received Date: **7/7/2016 3:35:00 PM**  
Reported Date: **7/25/2016 2:55:11 PM**

### Sample Information:

16-64 Wilson Lead Study

Client Sample ID: Bottle #11367  
Collectors Name: Roger Moulard  
Sample Location: Sm Kitchen Rm 18/19  
Source: City Water

## ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.0122		0.000103	mg/L	0.020 AL	7/20/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

# Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

## Analysis Report

ORELAP 100016  
EPA OR00028

Medford School District  
815 S Oakdale Ave  
Medford, OR 97501

Lab Order: **1607258**  
NRC Sample ID: **1607258-30A**  
Collection Date: **7/7/2016 2:43:00 PM**  
Received Date: **7/7/2016 3:35:00 PM**  
Reported Date: **7/25/2016 2:55:11 PM**

### Sample Information:

16-64 Wilson Lead Study

Client Sample ID: Bottle #11370  
Collectors Name: Roger Moulard  
Sample Location: Room 19 DF  
Source: City Water

## ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	<b>0.00242</b>		0.000103	mg/L	0.020 AL	7/20/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

# Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

## Analysis Report

ORELAP 100016  
EPA OR00028

Medford School District  
815 S Oakdale Ave  
Medford, OR 97501

Lab Order: **1607258**  
NRC Sample ID: **1607258-31A**  
Collection Date: **7/7/2016 2:44:00 PM**  
Received Date: **7/7/2016 3:35:00 PM**  
Reported Date: **7/25/2016 2:55:11 PM**

### Sample Information:

16-64 Wilson Lead Study

Client Sample ID: Bottle #11387  
Collectors Name: Roger Moulard  
Sample Location: Room 20 DF  
Source: City Water

## ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.000320		0.000103	mg/L	0.020 AL	7/20/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

# Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

## Analysis Report

ORELAP 100016  
EPA OR00028

Medford School District  
815 S Oakdale Ave  
Medford, OR 97501

Lab Order: **1607258**  
NRC Sample ID: **1607258-32A**  
Collection Date: **7/7/2016 2:45:00 PM**  
Received Date: **7/7/2016 3:35:00 PM**  
Reported Date: **7/25/2016 2:55:11 PM**

### Sample Information:

16-64 Wilson Lead Study

Client Sample ID: Bottle #11386  
Collectors Name: Roger Moulard  
Sample Location: Room 25 DF  
Source: City Water

## ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	<b>0.00350</b>		0.000103	mg/L	0.020 AL	7/20/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

# Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

## Analysis Report

ORELAP 100016  
EPA OR00028

Medford School District  
815 S Oakdale Ave  
Medford, OR 97501

Lab Order: **1607258**  
NRC Sample ID: **1607258-33A**  
Collection Date: **7/7/2016 2:47:00 PM**  
Received Date: **7/7/2016 3:35:00 PM**  
Reported Date: **7/25/2016 2:55:11 PM**

### Sample Information:

16-64 Wilson Lead Study

Client Sample ID: Bottle #11388  
Collectors Name: Roger Moulard  
Sample Location: Room 24 DF  
Source: City Water

## ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	<b>0.00105</b>		0.000103	mg/L	0.020 AL	7/20/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

# Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

## Analysis Report

ORELAP 100016  
EPA OR00028

Medford School District  
815 S Oakdale Ave  
Medford, OR 97501

Lab Order: **1607258**  
NRC Sample ID: **1607258-34A**  
Collection Date: **7/7/2016 2:49:00 PM**  
Received Date: **7/7/2016 3:35:00 PM**  
Reported Date: **7/25/2016 2:55:11 PM**

### Sample Information:

16-64 Wilson Lead Study

Client Sample ID: Bottle #11374  
Collectors Name: Roger Moulard  
Sample Location: Room 23 DF  
Source: City Water

## ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.00206		0.000103	mg/L	0.020 AL	7/20/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

# Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

## Analysis Report

ORELAP 100016  
EPA OR00028

Medford School District  
815 S Oakdale Ave  
Medford, OR 97501

Lab Order: **1607258**  
NRC Sample ID: **1607258-35A**  
Collection Date: **7/7/2016 2:51:00 PM**  
Received Date: **7/7/2016 3:35:00 PM**  
Reported Date: **7/25/2016 2:55:11 PM**

### Sample Information:

16-64 Wilson Lead Study

Client Sample ID: Bottle #11436  
Collectors Name: Roger Moulard  
Sample Location: Room 22 DF  
Source: City Water

## ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.00545		0.000103	mg/L	0.020 AL	7/20/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

# Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

## Analysis Report

ORELAP 100016  
EPA OR00028

Medford School District  
815 S Oakdale Ave  
Medford, OR 97501

Lab Order: **1607258**  
NRC Sample ID: **1607258-36A**  
Collection Date: **7/7/2016 3:03:00 PM**  
Received Date: **7/7/2016 3:35:00 PM**  
Reported Date: **7/25/2016 2:55:11 PM**

### Sample Information:

16-64 Wilson Lead Study

Client Sample ID: Bottle #11438  
Collectors Name: Roger Moulard  
Sample Location: Room 21 Sink  
Source: City Water

## ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.00615		0.000103	mg/L	0.020 AL	7/20/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

# Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

## Analysis Report

ORELAP 100016  
EPA OR00028

Medford School District  
815 S Oakdale Ave  
Medford, OR 97501

Lab Order: **1607258**  
NRC Sample ID: **1607258-37A**  
Collection Date: **7/7/2016 2:53:00 PM**  
Received Date: **7/7/2016 3:35:00 PM**  
Reported Date: **7/25/2016 2:55:11 PM**

### Sample Information:

16-64 Wilson Lead Study

Client Sample ID: Bottle #11459  
Collectors Name: Roger Moulard  
Sample Location: Room 26 DF  
Source: City Water

## ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.000206		0.000103	mg/L	0.020 AL	7/20/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

# Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

## Analysis Report

ORELAP 100016  
EPA OR00028

Medford School District  
815 S Oakdale Ave  
Medford, OR 97501

Lab Order: **1607258**  
NRC Sample ID: **1607258-38A**  
Collection Date: **7/7/2016 2:55:00 PM**  
Received Date: **7/7/2016 3:35:00 PM**  
Reported Date: **7/25/2016 2:55:11 PM**

### Sample Information:

16-64 Wilson Lead Study

Client Sample ID: Bottle #11372  
Collectors Name: Roger Moulard  
Sample Location: Room 27 DF  
Source: City Water

## ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.000139		0.000103	mg/L	0.020 AL	7/20/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

# Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

## Analysis Report

ORELAP 100016  
EPA OR00028

Medford School District  
815 S Oakdale Ave  
Medford, OR 97501

Lab Order: **1607258**  
NRC Sample ID: **1607258-39A**  
Collection Date: **7/7/2016 2:56:00 PM**  
Received Date: **7/7/2016 3:35:00 PM**  
Reported Date: **7/25/2016 2:55:11 PM**

### Sample Information:

16-64 Wilson Lead Study

Client Sample ID: Bottle #11377  
Collectors Name: Roger Moulard  
Sample Location: Room 28 DF  
Source: City Water

## ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.000139		0.000103	mg/L	0.020 AL	7/20/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

**Neilson Research Corporation**  
DATA FLAGS

B	Analyte detected in the associated method blank.
BA	BOD Alternative Calculation: The initial results performed by Standard Methods did not fall within parameters of the Standard Methods calculation. An alternate approved calculation was performed using the HACH method and the value reported is an estimated concentration.
C	Sample(s) does not meet NELAP/ORELAP sample acceptance criteria. See Case Narrative.
C1	Sample(s) does not meet NELAP/ORELAP sample acceptance criteria for temperature.
CF	Results confirmed by re-analysis.
CU	Cleanup performed as specified by method.
D1	The diesel elution pattern for the sample is not typical.
D2	The sample appears to be a heavier hydrocarbon range than diesel.
D3	The sample appears to be a lighter hydrocarbon range than diesel.
D4	Detected hydrocarbons do not have pattern and range consistent with typical petroleum products and may be due to biogenic interference.
D5	Detected hydrocarbons in the diesel range appear to be weathered diesel.
E	Estimated value.
ER	Elevated reporting limit due to matrix. Report limits (MDLs, MRLs & PQLs) are adjusted based on variations in sample preparation amounts, analytical dilutions, and percent solids, where applicable.
FC	Fecal Coliforms: Sample(s) received past 40 CFR Part 136 specified holding time. Results reported as estimated values.
G1	The gasoline elution pattern for the sample is not typical.
G2	The sample appears to be a heavier hydrocarbon range than gasoline.
G3	The sample appears to be a lighter hydrocarbon range than gasoline.
G4	Detected hydrocarbons in the gasoline range appear to be weathered gasoline.
HP	Sample re-analysis performed outside of method specified holding time.
HR	Sample received outside of method specified holding time.
HS	Sample analyzed for volatile organics contained headspace.
HT	At the client's request, the sample was analyzed outside of method specified holding time.
H	Analysis performed outside of method specified holding time.
J	Analyte detected below the Minimum Reporting Limit (MRL) and above the Method Detection Limit (MDL). The J flag result is an estimated value and the user should be aware that this data is of limited reliability.
MI	Surrogate or Matrix Spike recovery is out of control limits due to matrix interference. Sample results may be biased.
N	See Case Narrative on page 2 of report.
Q	Closing continuing calibration verification (CCV) or laboratory control sample (LCS) exceeded high recovery limits, but associated samples are non-detect and the sample results are not affected. Data meets EPA/NELAP requirements.
R	Relative percent difference (RPD) is outside of the accepted recovery limits.
R1	Relative percent difference (RPD) is outside of the accepted recovery limits. However, analyses are not controlled on RPD values for sample concentrations that are less than the reporting limit.
R3	The relative percent difference (RPD) and/or percent recovery for the duplicate (DUP) or matrix spike (MS)/matrix spike duplicate (MSD) cannot be accurately calculated due to the concentration of analyte already present in the sample.
R4	Duplicate analysis failed due to result being at or near method reporting limit.
S	Surrogate and/or matrix spike recovery is outside of the accepted recovery limits. Sample results may be biased.
S1	Surrogate or matrix spike recovery is outside of control limits due to dilution necessary for analysis.
SC	Sub-contracted to another laboratory for analysis.
SP	Sample(s) were not collected per EPA Method 5035A protocols. The results are considered minimum values.
T	Toxicity Characteristic Leaching Procedure – Sample submitted contained < 0.5% solids. If the waste contains <0.5% dry solids, the liquid portion of the waste, after filtration, is defined as the TCLP extract.
#	Value exceeds regulatory level for TCLP contaminant.
X1	The motor oil elution pattern for the sample is not typical.
X2	The sample appears to be a heavier hydrocarbon range than motor oil.
X3	The sample appears to be a lighter hydrocarbon range than motor oil.
*	Value exceeds Maximum Contaminant Level or is outside the acceptable range.

NRC SOP QA-1104/AD-3100  
Revision 3  
Effective Date: 6/3/16

**CLIENT:** Medford School District  
**Work Order:** 1607258  
**Project:** 16-64 Wilson Lead Study

**ANALYTICAL QC SUMMARY REPORT**

**BatchID: 35857**

Sample ID <b>MB-35857</b>	SampType: <b>MBLK</b>	TestCode: <b>ICPMS_200.8</b>	Units: <b>mg/L</b>	Prep Date: <b>7/18/2016</b>	RunNo: <b>88593</b>						
Client ID: <b>ZZZZZ</b>	Batch ID: <b>35857</b>	TestNo: <b>EPA 200.8</b>	<b>(EPA 200.8)</b>	Analysis Date: <b>7/20/2016</b>	SeqNo: <b>1328355</b>						
Analyte	Result	MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead ND 0.000103

Sample ID <b>LCS-35857</b>	SampType: <b>LCS</b>	TestCode: <b>ICPMS_200.8</b>	Units: <b>mg/L</b>	Prep Date: <b>7/18/2016</b>	RunNo: <b>88593</b>						
Client ID: <b>ZZZZZ</b>	Batch ID: <b>35857</b>	TestNo: <b>EPA 200.8</b>	<b>(EPA 200.8)</b>	Analysis Date: <b>7/20/2016</b>	SeqNo: <b>1328356</b>						
Analyte	Result	MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead 0.09461 0.000104 0.1 0 94.6 85 115

Sample ID <b>1607258-19AMS</b>	SampType: <b>MS</b>	TestCode: <b>ICPMS_200.8</b>	Units: <b>mg/L</b>	Prep Date: <b>7/18/2016</b>	RunNo: <b>88593</b>						
Client ID: <b>Bottle #11400</b>	Batch ID: <b>35857</b>	TestNo: <b>EPA 200.8</b>	<b>(EPA 200.8)</b>	Analysis Date: <b>7/20/2016</b>	SeqNo: <b>1328379</b>						
Analyte	Result	MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead 0.09368 0.000100 0.1 0.003131 90.5 70 130

Sample ID <b>1607258-19AMSD</b>	SampType: <b>MSD</b>	TestCode: <b>ICPMS_200.8</b>	Units: <b>mg/L</b>	Prep Date: <b>7/18/2016</b>	RunNo: <b>88593</b>						
Client ID: <b>Bottle #11400</b>	Batch ID: <b>35857</b>	TestNo: <b>EPA 200.8</b>	<b>(EPA 200.8)</b>	Analysis Date: <b>7/20/2016</b>	SeqNo: <b>1328380</b>						
Analyte	Result	MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead 0.09544 0.000100 0.1 0.003131 92.3 70 130 0.09368 1.86 20

**Qualifiers:** E Value above quantitation range H Holding times for preparation or analysis exceeded J Analyte detected below quantitation limits  
 ND Not Detected at the Minimum Reporting Limit R RPD outside accepted recovery limits S Spike Recovery outside accepted recovery limits

**CLIENT:** Medford School District  
**Work Order:** 1607258  
**Project:** 16-64 Wilson Lead Study

**ANALYTICAL QC SUMMARY REPORT**

**BatchID: 35870**

Sample ID <b>MB-35870</b>	SampType: <b>MBLK</b>	TestCode: <b>ICPMS_200.8</b>	Units: <b>mg/L</b>	Prep Date: <b>7/19/2016</b>	RunNo: <b>88593</b>						
Client ID: <b>ZZZZZ</b>	Batch ID: <b>35870</b>	TestNo: <b>EPA 200.8</b>	<b>(EPA 200.8)</b>	Analysis Date: <b>7/20/2016</b>	SeqNo: <b>1328383</b>						
Analyte	Result	MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead ND 0.000103

Sample ID <b>LCS-35870</b>	SampType: <b>LCS</b>	TestCode: <b>ICPMS_200.8</b>	Units: <b>mg/L</b>	Prep Date: <b>7/19/2016</b>	RunNo: <b>88593</b>						
Client ID: <b>ZZZZZ</b>	Batch ID: <b>35870</b>	TestNo: <b>EPA 200.8</b>	<b>(EPA 200.8)</b>	Analysis Date: <b>7/20/2016</b>	SeqNo: <b>1328384</b>						
Analyte	Result	MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead 0.09569 0.000104 0.1 0 95.7 85 115

Sample ID <b>1607258-39AMS</b>	SampType: <b>MS</b>	TestCode: <b>ICPMS_200.8</b>	Units: <b>mg/L</b>	Prep Date: <b>7/19/2016</b>	RunNo: <b>88593</b>						
Client ID: <b>Bottle #11377</b>	Batch ID: <b>35870</b>	TestNo: <b>EPA 200.8</b>	<b>(EPA 200.8)</b>	Analysis Date: <b>7/20/2016</b>	SeqNo: <b>1328462</b>						
Analyte	Result	MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead 0.09662 0.000104 0.1 0.0001388 96.5 70 130

Sample ID <b>1607258-39AMSD</b>	SampType: <b>MSD</b>	TestCode: <b>ICPMS_200.8</b>	Units: <b>mg/L</b>	Prep Date: <b>7/19/2016</b>	RunNo: <b>88593</b>						
Client ID: <b>Bottle #11377</b>	Batch ID: <b>35870</b>	TestNo: <b>EPA 200.8</b>	<b>(EPA 200.8)</b>	Analysis Date: <b>7/20/2016</b>	SeqNo: <b>1328463</b>						
Analyte	Result	MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead 0.09769 0.000104 0.1 0.0001388 97.5 70 130 0.09662 1.10 20

**Qualifiers:** E Value above quantitation range H Holding times for preparation or analysis exceeded J Analyte detected below quantitation limits  
 ND Not Detected at the Minimum Reporting Limit R RPD outside accepted recovery limits S Spike Recovery outside accepted recovery limits



Environmental Testing Laboratory  
 245 South Grape Street • Medford, OR 97501  
 (541) 770-5678 Fax (541) 770-2901

# Chain of Custody Record

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

**Section A**

**Required Client Information**

Company: Medford School District 549C  
 Address: 815 S. Oakdale,  
 Medford, Or, 97501  
 Email: rick.rose@medford.k12.or.us  
 Phone: 541.842.1138 Fax 541.842.1160  
 Collected By (Print): Gary Severe  
 Collected By (Sign): *[Signature]*  
 Email Report  Yes  No Mail Report  Yes  No  
 Fax Report  Yes  No

**Section B**

**Required Project Information**

Project Name: 2016 Lead testing  
 Project Number: 16-64 / Wilson  
 Report To: rick.rose@medford.k12.or.us  
 Copy To: ron.havtkear@medford.k12.or.us

**Section C**

**Invoice Information**

Attention: Accounting  
 Company Name: Medford School  
 Address: 815 S. Oakdale  
 Medford, Or, 97501  
 P.O. # P112894

**Section D**

**Rush Status (Subject to Scheduling)**

Standard 10-14 Days  
 5 Business Days (50% surcharge)  
 3 Business Days (75% surcharge)  
 24 - 48 hours (100% surcharge)  
 Other \_\_\_\_\_  
 Authorized  Yes  No

**Section E**

**Sample Information**

Sample ID	Geom/Equip	Matrix*	Date Collected	Time Collected	No. of Containers	Analysis Requested	NRC Workorder # (Lab Use Only)	NRC Sample # (Lab Use Only)
RM 1 DF	11456		7/7/16	2:49 PM	1		1607958	01
RM 2 DF	11440			2:50	1			02
RM 3 DF	11466			2:51	1			03
RM 4 DF	11455			2:53	1			04
RM 5 DF	11478			2:55	1			05
RM 6 DF	11457			2:57	1			06
RM 7 DF	11442			2:58	1			07
RM 8 DF	11428			2:59	1			08
RM 9 DF	11458			3:01	1			09
RM 10 DF	11410			3:02	1			10

\*Matrix: DW - Drinking Water WW - Wastewater W - Water S - Soil/Solid SL - Sludge O - Oil WP - Wipe OT - Other

**Section F**

**Relinquish/Receive**

Relinquished By: *[Signature]* Sign: *[Signature]*  
 Received By: *[Signature]* Sign: *[Signature]*  
 Relinquished By: *[Signature]* Sign: *[Signature]*  
 Received By: *[Signature]* Sign: *[Signature]*  
 Relinquished By: *[Signature]* Sign: *[Signature]*  
 Received By: *[Signature]* Sign: *[Signature]*

**Section G**

**Lab Use Only**

Temp: Ambient  
 4°C +/- 2°C: Yes  No   
 Received on Ice: Yes  No   
 Number of Bottles Received: 38  
 pH Checked: NA  
 COC Seals Intact: Yes  No   
 Field Blank Included: Yes  No

Received Via:  UPS  FedEx  Other   
 Payment:  Invoice  Cash  VISA  M/C  Check # \_\_\_\_\_ Amount \_\_\_\_\_



Environmental Testing Laboratory  
 245 South Grape Street Medford, OR 97501  
 (541) 770-5678 FAX (541) 770-2901

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

# Chain of Custody Record

**Section A**  
 Required Client Information

Company: Medford School District 549C  
 Address: 815 S. Oakdale,  
 Medford, Or, 97501  
 Email: rick.rose@medford.k12.or.us  
 Phone: 541.842.1138 Fax: 541.842.1160  
 Collected By (Print): Gary Severe  
 Collected By (Sign): *[Signature]*  
 Email Report  Yes  No  
 Fax Report  Yes  No

**Section B**  
 Required Project Information

Project Name: 2016 Lead testing  
 Project Number: 16-64 / Wilson  
 Report To: rick.rose@medford.k12.or.us  
 Copy To: ron.havniar@medford.k12.or.us  
 P.O. # P112894

**Section C**  
 Invoice Information

Attention: Accounting  
 Company Name: Medford School  
 Address: 815 S. Oakdale  
 Medford, Or, 97501

**Section D**  
 Rush Status (Subject to Scheduling)

Standard 10-14 Days  
 5 Business Days (50% surcharge)  
 3 Business Days (75% surcharge)  
 24 - 48 hours (100% surcharge)  
 Other \_\_\_\_\_  
 Authorized  Yes  No

**Section E**  
 Sample Information

Sample ID	Completion	Matrix	Date Collected	Time Collected	No. of Containers	Analysis Requested	NRC Workorder # (Lab Use Only)	NRC Sample # (Lab Use Only)
RW 11 DF	11430		7/7/16	3:04 PM	1		1607958	13
RW 12 DF	11450			3:05	1			13
RW 13 DF	11465			3:07	1			13
RW 14 DF	11460			3:08	1			14
RW 15 DF	11449			3:09	1			15

**Section F**  
 Requisition/Receive

Matrix: DW - Drinking Water WW - Wastewater W - Water S - Soil/Solid SL - Sludge O - Oil WP - Wipe OT - Other

Requisitioned By: *[Signature]* Sign: Gary Severe  
 Received By: *[Signature]* Sign: Gary Severe  
 Requisitioned By: *[Signature]* Sign: Gary Severe  
 Received By: *[Signature]* Sign: Gary Severe  
 Requisitioned By: \_\_\_\_\_  
 Received By: \_\_\_\_\_  
 Requisitioned By: \_\_\_\_\_  
 Received By: \_\_\_\_\_

**Section G**  
 Lab Use Only

Temp: \_\_\_\_\_  
 4°C +/- 2°C: Yes  No   
 Received on Ice: Yes  No   
 Number of Bottles Received: \_\_\_\_\_  
 pH Checked: \_\_\_\_\_  
 COC Seals Intact: Yes  No  NA   
 Field Blank Included: Yes  No

Received Via: UPS  FedEX  Other  Hand   
 Payment: Invoice  Cash  VISA, M/C  Check # \_\_\_\_\_ Amount \_\_\_\_\_

# Chain of Custody Record

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

**Section A**  
Required Client Information

Company: Medford School District 549C  
 Address: 815 S. Oakdale,  
 Medford, Or, 97501  
 Email: rick.rose@medford.k12.or.us  
 Phone: 541.842.1138 Fax: 541.842.1160  
 Collected By (Print): Schlosser  
 Collected By (Sign): [Signature]  
 Email Report  Yes  No Mail Report  Yes  No  
 Fax Report  Yes  No

**Section B**  
Required Project Information

Project Name: 2016 Lead Testing  
 Project Number: 16-64 / Wilson  
 Report To: rick.rose@medford.k12.or.us  
 Copy To: ron.havniar@medford.k12.or.us

**Section C**  
Invoice Information

Attention: Accounting  
 Company Name: Medford School  
 Address: 815 S. Oakdale,  
 Medford, Or, 97501  
 P.O. # P112894

**Section D**  
Rush Status (Subject to Scheduling)

Standard 10-14 Days  
 5 Business Days (50% surcharge)  
 3 Business Days (75% surcharge)  
 24 - 48 hours (100% surcharge)  
 Other \_\_\_\_\_  
 Authorized  Yes  No

**Section E**  
Sample Information

Sample ID	Compt/Grab	Matrix*	Date Collected	Time Collected	No. of Containers	Analysis Requested	NRC Workorder # (Lab Use Only)	NRC Sample # (Lab Use Only)
Heath Rm Sink	11464		7/7/16	2:43pm	1		16079688	16
Staff Work Rm DF	11418			2:48pm	1			17
Conf. Rm Near Main Off. Sink	11407			2:45pm	1			18
Staff Bk Rm Sink	11400			2:41pm	1			19
Kitchen Food Prep Sinks (E Wall)	11391			2:59pm	1			20
Off. DF (Upper)	11392			3:04pm	1			21
Off. DF (Lower)	11411			3:03pm	1			22
Off. DF (Battle Files)	11383			3:04pm	1			23
W. Side of Gym Outside DF (L)	11443			2:54pm	1			24
W. Side of Gym Outside DF (R)	11390			2:55pm	1			25

**Section F**  
Relinquish/Receive

Relinquished By: [Signature] Sign  
 Received By: [Signature] Sign  
 Relinquished By: \_\_\_\_\_  
 Received By: \_\_\_\_\_  
 Relinquished By: \_\_\_\_\_  
 Received By: \_\_\_\_\_  
 Relinquished By: \_\_\_\_\_  
 Received By: \_\_\_\_\_

**Section G**  
Lab Use Only

Temp: \_\_\_\_\_  
 4°C +/- 2°C: Yes  No   
 Received on Ice: Yes  No   
 Number of Bottles Received: \_\_\_\_\_  
 pH Checked: \_\_\_\_\_  
 COC Seals Intact: Yes  No  NA   
 Field Blank Included: Yes  No

Payment: \_\_\_\_\_ Invoice \_\_\_\_\_ Cash \_\_\_\_\_ VISA \_\_\_\_\_ M/C \_\_\_\_\_ Check # \_\_\_\_\_  
 Received Via: \_\_\_\_\_ UPS \_\_\_\_\_ FedEx \_\_\_\_\_ Other \_\_\_\_\_ Hand \_\_\_\_\_





Environmental Testing Laboratory  
 245 South Grape Street • Medford, OR 97501  
 (541) 770-5678 Fax (541) 770-2901

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

# Chain of Custody Record

### Section A Required Client Information

Company: Medford School District 549C  
 Address: 815 S. Oakdale,  
 Medford, Or, 97501  
 Email: rick.rose@medford.k12.or.us  
 Phone: 541.842.1138 Fax: 541.842.1160  
 Collected By (Print): Roger Monland  
 Collected By (Sign): *Roger Monland*  
 Email Report  Yes  No Mail Report  Yes  No  
 Fax Report  Yes  No

### Section B Required Project Information

Project Name: 2016 Lead Testing  
 Project Number: 16-64 / Wilson  
 Report To: rick.rose@medford.k12.or.us  
 Copy To: ron.havniar@medford.k12.or.us  
 Attention: Accounting  
 Company Name: Medford School  
 Address: 815 S. Oakdale  
 Medford, Or, 97501  
 P.O. # P112894

### Section C Invoice Information

### Section D Rush Status (Subject to Scheduling)

Standard 10-14 Days  
 5 Business Days (50% surcharge)  
 3 Business Days (75% surcharge)  
 24 - 48 hours (100% surcharge)  
 Other \_\_\_\_\_  
 Authorized  Yes  No

### Section E Sample Information

Sample ID	Comp/Grab	Matrix*	Date Collected	Time Collected	No. of Containers	Analysis Requested	NRG Workorder # <small>(Lab Use Only)</small>	NRG Sample # <small>(Lab Use Only)</small>
RM 16 DF	11382		7/7/16	3:00 PM	1		1607958	21
RM 17 DF	11404			2:38 PM	1			22
Small kitchen LM 18/19	11367			2:41 PM	1			23
RM 19 DF	11370			2:43 PM	1			24
20	11387			2:44 AM	1			25
25	11386			2:45 PM	1			26
24	11388			2:47 AM	1			27
27	11374			2:49 PM	1			28
22	11436			2:51 PM	1			29
21 Sink	11438			2:53 AM	1			30

\*Matrix: DW - Drinking Water WW - Wastewater W - Water S - Soil/Solid SL - Sludge O - Oil WP - Wipe OT - Other

### Section F Relinquish/Receive

Relinquished By:	Sign	Print	Date	Time
Relinquished By:	<i>Roger Monland</i>	Roger Monland	7-7-16	3:07 PM
Received By:	<i>John Sessa</i>	John Sessa	7/7/16	3:07 PM
Relinquished By:	<i>John Sessa</i>	John Sessa	7/7/16	3:33 PM
Received By:				
Relinquished By:				
Received By:				
Relinquished By:				
Received By:				
Relinquished By:				
Received By:				

### Section G Lab Use Only

Temp: \_\_\_\_\_  
 4°C +/- 2°C: Yes  No   
 Received on Ice: Yes  No   
 Number of Bottles Received: \_\_\_\_\_  
 PH Checked: \_\_\_\_\_  
 COC Seals Intact: Yes  No  NA   
 Field Blank Included: Yes  No

Received Via  UPS  FedEx  Other  Hand  
 Payment:  Invoice  Cash  VISA  M/C  Check # \_\_\_\_\_ Amount \_\_\_\_\_

