



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

March 27, 2020

Ron Havniear
Medford School District
815 S Oakdale Ave
Medford, OR 97501
TEL: 541-842-3646
FAX: 541-842-1160

RE: 18-06 Hedrick 2020 Lead Testing

Order No.: 20030680

Dear Ron Havniear:

Neilson Research Corporation received 170 sample(s) on 3/16/2020 for the analyses presented in the following report.

The results relate only to the parameters tested or to the sample as received by the laboratory. This report shall not be reproduced except in full, without the written approval of Neilson Research Corporation. If you have any questions regarding these test results, please feel free to call.

Sincerely,
Neilson Research Corporation

Tamra Schmedemann
Senior Project Manager
245 S Grape St
Medford, OR 97501

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Case Narrative

WO#: 20030680
Date: 3/27/2020

CLIENT: Medford School District

Project: 18-06 Hedrick 2020 Lead Testing

The analyses were performed according to the guidelines in the Neilson Research Corporation Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

Neilson Research Corporation certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 20030680

Date Reported: 3/27/2020

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: 20030680
Received Date: 3/16/2020 8:55:00 AM
Reported Date: 3/27/2020 11:46:39 AM

Sample Information:

Lab ID: 20030680-001 **Client Sample ID:** Weight Rm (O/S S ENT)-DF
Collection Date: 3/14/2020 7:50:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Weight Rm (O/S S ENT)-DF

Trace Metals by EPA 200.8 ICP-MS						Analyst; KMC		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.000674		0.000103	mg/L	1	3/18/2020	0.0150	A

Lab ID: 20030680-002 **Client Sample ID:** Weight Rm (O/S S ENT) Unisex RR-Sink L
Collection Date: 3/14/2020 8:00:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Weight Rm (O/S S ENT) Unisex RR-Sink L

Trace Metals by EPA 200.8 ICP-MS						Analyst; KMC		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.00243		0.000103	mg/L	1	3/18/2020	0.0150	A

Lab ID: 20030680-003 **Client Sample ID:** Weight Rm (O/S S ENT) Unisex RR-Sink R
Collection Date: 3/14/2020 8:00:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Weight Rm (O/S S ENT) Unisex RR-Sink R

Trace Metals by EPA 200.8 ICP-MS						Analyst; KMC		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.00437		0.000103	mg/L	1	3/18/2020	0.0150	A

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

Results are out of the EPA limits

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 20030680

Date Reported: 3/27/2020

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: 20030680
Received Date: 3/16/2020 8:55:00 AM
Reported Date: 3/27/2020 11:46:39 AM

Sample Information:

Lab ID: 20030680-004 **Client Sample ID:** Hose Bib Supplying Water Horse
Collection Date: 3/14/2020 8:02:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Hose Bib Supplying Water Horse

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.0143		0.000100	mg/L	1	3/20/2020	0.0150	A

Lab ID: 20030680-005 **Client Sample ID:** Boy's Locker Rm-Sink (L-Locker Area)
Collection Date: 3/14/2020 8:17:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Boy's Locker Rm-Sink (L-Locker Area)

Trace Metals by EPA 200.8 ICP-MS							Analyst: KMC	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.00367		0.000103	mg/L	1	3/18/2020	0.0150	A

Lab ID: 20030680-006 **Client Sample ID:** Boy's Locker Rm-Sink (R-Locker Area)
Collection Date: 3/14/2020 8:17:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Boy's Locker Rm-Sink (R-Locker Area)

Trace Metals by EPA 200.8 ICP-MS							Analyst: KMC	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.00237		0.000103	mg/L	1	3/18/2020	0.0150	A

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

Results are out of the EPA limits

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 20030680

Date Reported: 3/27/2020

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: 20030680
Received Date: 3/16/2020 8:55:00 AM
Reported Date: 3/27/2020 11:46:39 AM

Sample Information:

Lab ID: 20030680-007 **Client Sample ID:** Boy's Locker Rm-Sink (Urinal Area)
Collection Date: 3/14/2020 8:15:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Boy's Locker Rm-Sink (Urinal Area)

Trace Metals by EPA 200.8 ICP-MS							Analyst; KMC	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.00705		0.000103	mg/L	1	3/18/2020	0.0150	A

Lab ID: 20030680-008 **Client Sample ID:** Boy's Locker Rm Coach-Sink
Collection Date: 3/14/2020 8:13:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Boy's Locker Rm Coach-Sink

Trace Metals by EPA 200.8 ICP-MS							Analyst; SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.0110		0.000100	mg/L	1	3/20/2020	0.0150	A

Lab ID: 20030680-009 **Client Sample ID:** Boy's Locker Rm Coach RR-Sink
Collection Date: 3/14/2020 8:13:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Boy's Locker Rm Coach RR-Sink

Trace Metals by EPA 200.8 ICP-MS							Analyst; KMC	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.00252		0.000103	mg/L	1	3/18/2020	0.0150	A

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

Results are out of the EPA limits

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 20030680

Date Reported: 3/27/2020

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: 20030680
Received Date: 3/16/2020 8:55:00 AM
Reported Date: 3/27/2020 11:46:39 AM

Sample Information:

Lab ID: 20030680-010 **Client Sample ID:** Girl's Locker Room-DF (L)
Collection Date: 3/14/2020 8:03:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Girl's Locker Room-DF (L)

Trace Metals by EPA 200.8 ICP-MS							Analyst; KMC	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.000495		0.000103	mg/L	1	3/18/2020	0.0150	A

Lab ID: 20030680-011 **Client Sample ID:** Girl's Locker Room-DF (R)
Collection Date: 3/14/2020 8:05:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Girl's Locker Room-DF (R)

Trace Metals by EPA 200.8 ICP-MS							Analyst; KMC	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.000583		0.000103	mg/L	1	3/18/2020	0.0150	A

Lab ID: 20030680-012 **Client Sample ID:** Girl's Locker Rm-Sink (L-Locker Area)
Collection Date: 3/14/2020 8:05:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Girl's Locker Rm-Sink (L-Locker Area)

Trace Metals by EPA 200.8 ICP-MS							Analyst; SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.00348		0.000100	mg/L	1	3/20/2020	0.0150	A

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

Results are out of the EPA limits

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 20030680

Date Reported: 3/27/2020

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: 20030680
Received Date: 3/16/2020 8:55:00 AM
Reported Date: 3/27/2020 11:46:39 AM

Sample Information:

Lab ID: 20030680-013 **Client Sample ID:** Girl's Locker Rm-Sink (R-Locker Area)
Collection Date: 3/14/2020 8:06:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Girl's Locker Rm-Sink (R-Locker Area)

Trace Metals by EPA 200.8 ICP-MS							Analyst: KMC	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.00320		0.000103	mg/L	1	3/18/2020	0.0150	A

Lab ID: 20030680-014 **Client Sample ID:** Girl's Locker Rm-Sink (Urinal Area-L)
Collection Date: 3/14/2020 8:09:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Girl's Locker Rm-Sink (Urinal Area-L)

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.241	*	0.00100	mg/L	10	3/20/2020	0.0150	A

Lab ID: 20030680-015 **Client Sample ID:** Girl's Locker Rm-Sink (Urinal Area-C)
Collection Date: 3/14/2020 8:09:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Girl's Locker Rm-Sink (Urinal Area-C)

Trace Metals by EPA 200.8 ICP-MS							Analyst: KMC	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.00171		0.000103	mg/L	1	3/18/2020	0.0150	A

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

Results are out of the EPA limits

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 20030680

Date Reported: 3/27/2020

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: 20030680
Received Date: 3/16/2020 8:55:00 AM
Reported Date: 3/27/2020 11:46:39 AM

Sample Information:

Lab ID: 20030680-016 **Client Sample ID:** Girl's Locker Rm-Sink (Urinal Area-R)
Collection Date: 3/14/2020 8:09:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Girl's Locker Rm-Sink (Urinal Area-R)

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.00904		0.000100	mg/L	1	3/20/2020	0.0150	A

Lab ID: 20030680-017 **Client Sample ID:** Girl's Locker Rm Coach-Sink
Collection Date: 3/14/2020 8:10:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Girl's Locker Rm Coach-Sink

Trace Metals by EPA 200.8 ICP-MS							Analyst: KMC	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.000810		0.000103	mg/L	1	3/18/2020	0.0150	A

Lab ID: 20030680-018 **Client Sample ID:** Next to Rm 117 Men's RR-Sink (L)
Collection Date: 3/14/2020 7:53:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Next to Rm 117 Men's RR-Sink (L)

Trace Metals by EPA 200.8 ICP-MS							Analyst: KMC	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.00188		0.000103	mg/L	1	3/18/2020	0.0150	A

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

Results are out of the EPA limits

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 20030680

Date Reported: 3/27/2020

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: 20030680
Received Date: 3/16/2020 8:55:00 AM
Reported Date: 3/27/2020 11:46:39 AM

Sample Information:

Lab ID: 20030680-019 **Client Sample ID:** Next to Rm 117 Men's RR-Sink (C)
Collection Date: 3/14/2020 7:53:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Next to Rm 117 Men's RR-Sink (C)

Trace Metals by EPA 200.8 ICP-MS							Analyst; KMC	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.00210		0.000103	mg/L	1	3/18/2020	0.0150	A

Lab ID: 20030680-020 **Client Sample ID:** Next to Rm 117 Men's RR-Sink (R)
Collection Date: 3/14/2020 7:55:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Next to Rm 117 Men's RR-Sink (R)

Trace Metals by EPA 200.8 ICP-MS							Analyst; KMC	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.000284		0.000103	mg/L	1	3/18/2020	0.0150	A

Lab ID: 20030680-021 **Client Sample ID:** Next to Rm 117 Women's RR-Sink (L)
Collection Date: 3/14/2020 8:02:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Next to Rm 117 Women's RR-Sink (L)

Trace Metals by EPA 200.8 ICP-MS							Analyst; KMC	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.00150		0.000103	mg/L	1	3/18/2020	0.0150	A

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

Results are out of the EPA limits

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 20030680

Date Reported: 3/27/2020

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: 20030680
Received Date: 3/16/2020 8:55:00 AM
Reported Date: 3/27/2020 11:46:39 AM

Sample Information:

Lab ID: 20030680-022 **Client Sample ID:** Next to Rm 117 Women's RR-Sink (C)
Collection Date: 3/14/2020 8:03:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Next to Rm 117 Women's RR-Sink (C)

Trace Metals by EPA 200.8 ICP-MS							Analyst; KMC	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.000369		0.000103	mg/L	1	3/18/2020	0.0150	A

Lab ID: 20030680-023 **Client Sample ID:** Next to Rm 117 Women's RR-Sink (R)
Collection Date: 3/14/2020 8:03:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Next to Rm 117 Women's RR-Sink (R)

Trace Metals by EPA 200.8 ICP-MS							Analyst; KMC	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.000370		0.000103	mg/L	1	3/18/2020	0.0150	A

Lab ID: 20030680-024 **Client Sample ID:** NE Gym Ent Unisex RR-Sink
Collection Date: 3/14/2020 8:06:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** NE Gym Ent Unisex RR-Sink

Trace Metals by EPA 200.8 ICP-MS							Analyst; KMC	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.000426		0.000103	mg/L	1	3/18/2020	0.0150	A

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

Results are out of the EPA limits

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 20030680

Date Reported: 3/27/2020

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: 20030680
Received Date: 3/16/2020 8:55:00 AM
Reported Date: 3/27/2020 11:46:39 AM

Sample Information:

Lab ID: 20030680-025 **Client Sample ID:** NE Gym Ent-DF (Upper)
Collection Date: 3/14/2020 8:07:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** NE Gym Ent-DF (Upper)

Trace Metals by EPA 200.8 ICP-MS							Analyst: KMC	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.000103	mg/L	1	3/18/2020	0.0150	A

Lab ID: 20030680-026 **Client Sample ID:** NE Gym Ent-DF (Lower)
Collection Date: 3/14/2020 8:08:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** NE Gym Ent-DF (Lower)

Trace Metals by EPA 200.8 ICP-MS							Analyst: KMC	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.000103	mg/L	1	3/18/2020	0.0150	A

Lab ID: 20030680-027 **Client Sample ID:** Inside Gym NW Corner-DF
Collection Date: 3/14/2020 8:13:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Inside Gym NW Corner-DF

Trace Metals by EPA 200.8 ICP-MS							Analyst: KMC	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.000138		0.000103	mg/L	1	3/18/2020	0.0150	A

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

Results are out of the EPA limits

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 20030680

Date Reported: 3/27/2020

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: 20030680
Received Date: 3/16/2020 8:55:00 AM
Reported Date: 3/27/2020 11:46:39 AM

Sample Information:

Lab ID: 20030680-028 **Client Sample ID:** Inside Gym SW Corner-DF
Collection Date: 3/14/2020 8:15:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Inside Gym SW Corner-DF

Trace Metals by EPA 200.8 ICP-MS						Analyst: KMC		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.000214		0.000103	mg/L	1	3/18/2020	0.0150	A

Lab ID: 20030680-029 **Client Sample ID:** Fitness Rm (108)-DF
Collection Date: 3/14/2020 8:19:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Fitness Rm (108)-DF

Trace Metals by EPA 200.8 ICP-MS						Analyst: KMC		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.000211		0.000103	mg/L	1	3/18/2020	0.0150	A

Lab ID: 20030680-030 **Client Sample ID:** Rm 109 (Band Rm)-DF
Collection Date: 3/14/2020 8:24:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Rm 109 (Band Rm)-DF

Trace Metals by EPA 200.8 ICP-MS						Analyst: KMC		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.000418		0.000103	mg/L	1	3/18/2020	0.0150	A

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

Results are out of the EPA limits

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 20030680

Date Reported: 3/27/2020

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: 20030680
Received Date: 3/16/2020 8:55:00 AM
Reported Date: 3/27/2020 11:46:39 AM

Sample Information:

Lab ID: 20030680-031 **Client Sample ID:** Rm 109 (Band Rm)-Sink
Collection Date: 3/14/2020 8:25:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Rm 109 (Band Rm)-Sink

Trace Metals by EPA 200.8 ICP-MS							Analyst: KMC	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.000594		0.000103	mg/L	1	3/18/2020	0.0150	A

Lab ID: 20030680-032 **Client Sample ID:** Rm 107-DF
Collection Date: 3/14/2020 8:28:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Rm 107-DF

Trace Metals by EPA 200.8 ICP-MS							Analyst: KMC	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.000214		0.000103	mg/L	1	3/18/2020	0.0150	A

Lab ID: 20030680-033 **Client Sample ID:** Rm 106-DF (W Wall)
Collection Date: 3/14/2020 8:34:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Rm 106-DF (W Wall)

Trace Metals by EPA 200.8 ICP-MS							Analyst: KMC	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.000246		0.000103	mg/L	1	3/18/2020	0.0150	A

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

Results are out of the EPA limits

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 20030680

Date Reported: 3/27/2020

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: 20030680
Received Date: 3/16/2020 8:55:00 AM
Reported Date: 3/27/2020 11:46:39 AM

Sample Information:

Lab ID: 20030680-034 **Client Sample ID:** Rm 106-Sink (W Wall)
Collection Date: 3/14/2020 8:35:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Rm 106-Sink (W Wall)

Trace Metals by EPA 200.8 ICP-MS						Analyst: KMC		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.00107		0.000103	mg/L	1	3/18/2020	0.0150	A

Lab ID: 20030680-035 **Client Sample ID:** Rm 106-Sink (S Wall)
Collection Date: 3/14/2020 8:36:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Rm 106-Sink (S Wall)

Trace Metals by EPA 200.8 ICP-MS						Analyst: KMC		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.00143		0.000103	mg/L	1	3/18/2020	0.0150	A

Lab ID: 20030680-036 **Client Sample ID:** Rm 102-DF
Collection Date: 3/14/2020 8:41:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Rm 102-DF

Trace Metals by EPA 200.8 ICP-MS						Analyst: KMC		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.000159		0.000103	mg/L	1	3/18/2020	0.0150	A

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

Results are out of the EPA limits

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 20030680

Date Reported: 3/27/2020

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: 20030680
Received Date: 3/16/2020 8:55:00 AM
Reported Date: 3/27/2020 11:46:39 AM

Sample Information:

Lab ID: 20030680-037 **Client Sample ID:** Rm 102-Sink
Collection Date: 3/14/2020 8:39:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Rm 102-Sink

Trace Metals by EPA 200.8 ICP-MS						Analyst; KMC		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.00120		0.000103	mg/L	1	3/18/2020	0.0150	A

Lab ID: 20030680-038 **Client Sample ID:** Rm 103-DF
Collection Date: 3/14/2020 8:44:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Rm 103-DF

Trace Metals by EPA 200.8 ICP-MS						Analyst; KMC		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.00443		0.000103	mg/L	1	3/18/2020	0.0150	A

Lab ID: 20030680-039 **Client Sample ID:** Rm 103-Sink
Collection Date: 3/14/2020 8:45:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Rm 103-Sink

Trace Metals by EPA 200.8 ICP-MS						Analyst; KMC		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.00267		0.000103	mg/L	1	3/18/2020	0.0150	A

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

Results are out of the EPA limits

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 20030680

Date Reported: 3/27/2020

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: 20030680
Received Date: 3/16/2020 8:55:00 AM
Reported Date: 3/27/2020 11:46:39 AM

Sample Information:

Lab ID: 20030680-040 **Client Sample ID:** Rm 102A-Sink
Collection Date: 3/14/2020 8:43:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Rm 102A-Sink

Trace Metals by EPA 200.8 ICP-MS						Analyst; KMC		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.00410		0.000103	mg/L	1	3/18/2020	0.0150	A

Lab ID: 20030680-041 **Client Sample ID:** Rm 216-DF
Collection Date: 3/14/2020 7:56:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Rm 216-DF

Trace Metals by EPA 200.8 ICP-MS						Analyst; KMC		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.000164		0.000103	mg/L	1	3/18/2020	0.0150	A

Lab ID: 20030680-042 **Client Sample ID:** Rm 216-Sink
Collection Date: 3/14/2020 7:56:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Rm 216-Sink

Trace Metals by EPA 200.8 ICP-MS						Analyst; KMC		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.00116		0.000103	mg/L	1	3/18/2020	0.0150	A

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

Results are out of the EPA limits

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 20030680

Date Reported: 3/27/2020

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: 20030680
Received Date: 3/16/2020 8:55:00 AM
Reported Date: 3/27/2020 11:46:39 AM

Sample Information:

Lab ID: 20030680-043 **Client Sample ID:** Rm 215-DF
Collection Date: 3/14/2020 7:59:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Rm 215-DF

Trace Metals by EPA 200.8 ICP-MS						Analyst: KMC		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.000135		0.000103	mg/L	1	3/18/2020	0.0150	A

Lab ID: 20030680-044 **Client Sample ID:** Rm 215-Sink
Collection Date: 3/14/2020 7:59:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Rm 215-Sink

Trace Metals by EPA 200.8 ICP-MS						Analyst: KMC		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.000778		0.000103	mg/L	1	3/18/2020	0.0150	A

Lab ID: 20030680-045 **Client Sample ID:** Rm 206 A-Sink (Near Washer/Dryer)
Collection Date: 3/14/2020 8:05:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Rm 206 A-Sink (Near Washer/Dryer)

Trace Metals by EPA 200.8 ICP-MS						Analyst: KMC		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.00385		0.000103	mg/L	1	3/18/2020	0.0150	A

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

Results are out of the EPA limits

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 20030680

Date Reported: 3/27/2020

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: 20030680
Received Date: 3/16/2020 8:55:00 AM
Reported Date: 3/27/2020 11:46:39 AM

Sample Information:

Lab ID: 20030680-046 **Client Sample ID:** Rm 206 (Culinary)-Sink (N Wall-L)
Collection Date: 3/14/2020 8:05:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Rm 206 (Culinary)-Sink (N Wall-L)

Trace Metals by EPA 200.8 ICP-MS							Analyst: KMC	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.00137		0.000103	mg/L	1	3/18/2020	0.0150	A

Lab ID: 20030680-047 **Client Sample ID:** Rm 206 (Culinary)-Sink (N Wall-C)
Collection Date: 3/14/2020 8:05:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Rm 206 (Culinary)-Sink (N Wall-C)

Trace Metals by EPA 200.8 ICP-MS							Analyst: KMC	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.00113		0.000103	mg/L	1	3/18/2020	0.0150	A

Lab ID: 20030680-048 **Client Sample ID:** Rm 206 (Culinary)-Sink (N Wall-R)
Collection Date: 3/14/2020 8:05:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Rm 206 (Culinary)-Sink (N Wall-R)

Trace Metals by EPA 200.8 ICP-MS							Analyst: KMC	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.00177		0.000103	mg/L	1	3/18/2020	0.0150	A

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

Results are out of the EPA limits

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 20030680

Date Reported: 3/27/2020

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: 20030680
Received Date: 3/16/2020 8:55:00 AM
Reported Date: 3/27/2020 11:46:39 AM

Sample Information:

Lab ID: 20030680-049 **Client Sample ID:** Rm 206 (Culinary)-Sink (S Wall-L)
Collection Date: 3/14/2020 8:06:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Rm 206 (Culinary)-Sink (S Wall-L)

Trace Metals by EPA 200.8 ICP-MS							Analyst: KMC	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.00441		0.000103	mg/L	1	3/18/2020	0.0150	A

Lab ID: 20030680-050 **Client Sample ID:** Rm 206 (Culinary)-Sink (S Wall-C)
Collection Date: 3/14/2020 8:06:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Rm 206 (Culinary)-Sink (S Wall-C)

Trace Metals by EPA 200.8 ICP-MS							Analyst: KMC	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.00154		0.000103	mg/L	1	3/18/2020	0.0150	A

Lab ID: 20030680-051 **Client Sample ID:** Rm 206 (Culinary)-Sink (S Wall-R)
Collection Date: 3/14/2020 8:06:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Rm 206 (Culinary)-Sink (S Wall-R)

Trace Metals by EPA 200.8 ICP-MS							Analyst: KMC	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.000994		0.000103	mg/L	1	3/18/2020	0.0150	A

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

Results are out of the EPA limits

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 20030680

Date Reported: 3/27/2020

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: 20030680
Received Date: 3/16/2020 8:55:00 AM
Reported Date: 3/27/2020 11:46:39 AM

Sample Information:

Lab ID: 20030680-052 Client Sample ID: Rm 204-DF
Collection Date: 3/14/2020 8:15:00 AM Collected By:
Matrix: Drinking Water Sample Location: Rm 204-DF

Trace Metals by EPA 200.8 ICP-MS						Analyst: KMC		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.000385		0.000103	mg/L	1	3/19/2020	0.0150	A

Lab ID: 20030680-053 Client Sample ID: Rm 204-Sink
Collection Date: 3/14/2020 8:15:00 AM Collected By:
Matrix: Drinking Water Sample Location: Rm 204-Sink

Trace Metals by EPA 200.8 ICP-MS						Analyst: KMC		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.00113		0.000103	mg/L	1	3/19/2020	0.0150	A

Lab ID: 20030680-054 Client Sample ID: Rm 202-DF
Collection Date: 3/14/2020 8:16:00 AM Collected By:
Matrix: Drinking Water Sample Location: Rm 202-DF

Trace Metals by EPA 200.8 ICP-MS						Analyst: KMC		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.000313		0.000103	mg/L	1	3/19/2020	0.0150	A

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

Results are out of the EPA limits

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 20030680

Date Reported: 3/27/2020

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: 20030680
Received Date: 3/16/2020 8:55:00 AM
Reported Date: 3/27/2020 11:46:39 AM

Sample Information:

Lab ID: 20030680-055 **Client Sample ID:** Rm 202-Sink
Collection Date: 3/14/2020 8:16:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Rm 202-Sink

Trace Metals by EPA 200.8 ICP-MS						Analyst: KMC		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.00121		0.000103	mg/L	1	3/19/2020	0.0150	A

Lab ID: 20030680-056 **Client Sample ID:** Rm 303-DF
Collection Date: 3/14/2020 8:19:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Rm 303-DF

Trace Metals by EPA 200.8 ICP-MS						Analyst: KMC		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.000355		0.000103	mg/L	1	3/19/2020	0.0150	A

Lab ID: 20030680-057 **Client Sample ID:** Rm 303-Sink
Collection Date: 3/14/2020 8:19:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Rm 303-Sink

Trace Metals by EPA 200.8 ICP-MS						Analyst: KMC		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.00188		0.000103	mg/L	1	3/19/2020	0.0150	A

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

Results are out of the EPA limits

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 20030680

Date Reported: 3/27/2020

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: 20030680
Received Date: 3/16/2020 8:55:00 AM
Reported Date: 3/27/2020 11:46:39 AM

Sample Information:

Lab ID: 20030680-058 **Client Sample ID:** Across From Rm 303-DF
Collection Date: 3/14/2020 8:21:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Across From Rm 303-DF

Trace Metals by EPA 200.8 ICP-MS							Analyst: KMC	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.000298		0.000103	mg/L	1	3/19/2020	0.0150	A

Lab ID: 20030680-059 **Client Sample ID:** Across From Rm 303 Men's RR-Sink (L)
Collection Date: 3/14/2020 8:20:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Across From Rm 303 Men's RR-Sink (L)

Trace Metals by EPA 200.8 ICP-MS							Analyst: KMC	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.00250		0.000103	mg/L	1	3/19/2020	0.0150	A

Lab ID: 20030680-060 **Client Sample ID:** Across From Rm 303 Men's RR-Sink (R)
Collection Date: 3/14/2020 8:20:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Across From Rm 303 Men's RR-Sink (R)

Trace Metals by EPA 200.8 ICP-MS							Analyst: KMC	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.00143		0.000103	mg/L	1	3/19/2020	0.0150	A

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

Results are out of the EPA limits

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 20030680

Date Reported: 3/27/2020

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: 20030680
Received Date: 3/16/2020 8:55:00 AM
Reported Date: 3/27/2020 11:46:39 AM

Sample Information:

Lab ID: 20030680-061 **Client Sample ID:** Rm In-between 304/306 Storage Rm-Sink
Collection Date: 3/14/2020 8:25:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Rm In-between 304/306 Storage Rm-Sink

Trace Metals by EPA 200.8 ICP-MS							Analyst; KMC	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.00189		0.000103	mg/L	1	3/19/2020	0.0150	A

Lab ID: 20030680-062 **Client Sample ID:** Across From Rm 306 Women's RR-Sink (L)
Collection Date: 3/14/2020 8:26:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Across From Rm 306 Women's RR-Sink (L)

Trace Metals by EPA 200.8 ICP-MS							Analyst; KMC	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.000285		0.000103	mg/L	1	3/19/2020	0.0150	A

Lab ID: 20030680-063 **Client Sample ID:** Across From Rm 306 Women's RR-Sink (C)
Collection Date: 3/14/2020 8:26:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Across From Rm 306 Women's RR-Sink (C)

Trace Metals by EPA 200.8 ICP-MS							Analyst; KMC	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.00148		0.000103	mg/L	1	3/19/2020	0.0150	A

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

Results are out of the EPA limits

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 20030680

Date Reported: 3/27/2020

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: 20030680
Received Date: 3/16/2020 8:55:00 AM
Reported Date: 3/27/2020 11:46:39 AM

Sample Information:

Lab ID: 20030680-064 **Client Sample ID:** Across From Rm 306 Women's RR-Sink (R)
Collection Date: 3/14/2020 8:26:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Across From Rm 306 Women's RR-Sink (R)

Trace Metals by EPA 200.8 ICP-MS							Analyst; KMC	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.00130		0.000103	mg/L	1	3/19/2020	0.0150	A

Lab ID: 20030680-065 **Client Sample ID:** Health Rm-Sink
Collection Date: 3/14/2020 8:02:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Health Rm-Sink

Trace Metals by EPA 200.8 ICP-MS							Analyst; KMC	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.000698		0.000103	mg/L	1	3/19/2020	0.0150	A

Lab ID: 20030680-066 **Client Sample ID:** Health Rm Unisex RR-Sink
Collection Date: 3/14/2020 8:03:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Health Rm Unisex RR-Sink

Trace Metals by EPA 200.8 ICP-MS							Analyst; KMC	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.000174		0.000103	mg/L	1	3/19/2020	0.0150	A

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

Results are out of the EPA limits

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 20030680

Date Reported: 3/27/2020

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: 20030680
Received Date: 3/16/2020 8:55:00 AM
Reported Date: 3/27/2020 11:46:39 AM

Sample Information:

Lab ID: 20030680-067 **Client Sample ID:** Main Office-Kitchenette
Collection Date: 3/14/2020 8:05:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Main Office-Kitchenette

Trace Metals by EPA 200.8 ICP-MS							Analyst; KMC	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.000248		0.000103	mg/L	1	3/19/2020	0.0150	A

Lab ID: 20030680-068 **Client Sample ID:** By The Office-DF (Upper)
Collection Date: 3/14/2020 8:07:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** By The Office-DF (Upper)

Trace Metals by EPA 200.8 ICP-MS							Analyst; KMC	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.000103	mg/L	1	3/19/2020	0.0150	A

Lab ID: 20030680-069 **Client Sample ID:** By The Office-DF (Lower)
Collection Date: 3/14/2020 8:08:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** By The Office-DF (Lower)

Trace Metals by EPA 200.8 ICP-MS							Analyst; KMC	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.000103	mg/L	1	3/19/2020	0.0150	A

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

Results are out of the EPA limits

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 20030680

Date Reported: 3/27/2020

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: 20030680
Received Date: 3/16/2020 8:55:00 AM
Reported Date: 3/27/2020 11:46:39 AM

Sample Information:

Lab ID: 20030680-070 **Client Sample ID:** O/S Office Staff Men's RR-Sink (L)
Collection Date: 3/14/2020 8:11:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** O/S Office Staff Men's RR-Sink (L)

Trace Metals by EPA 200.8 ICP-MS							Analyst: KMC	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.00160		0.000103	mg/L	1	3/19/2020	0.0150	A

Lab ID: 20030680-071 **Client Sample ID:** O/S Office Staff Men's RR-Sink (R)
Collection Date: 3/14/2020 8:12:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** O/S Office Staff Men's RR-Sink (R)

Trace Metals by EPA 200.8 ICP-MS							Analyst: KMC	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.000230		0.000103	mg/L	1	3/19/2020	0.0150	A

Lab ID: 20030680-072 **Client Sample ID:** O/S Office Staff Women's RR-Sink (L)
Collection Date: 3/14/2020 8:13:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** O/S Office Staff Women's RR-Sink (L)

Trace Metals by EPA 200.8 ICP-MS							Analyst: KMC	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.000167		0.000103	mg/L	1	3/19/2020	0.0150	A

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

Results are out of the EPA limits

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 20030680
Date Reported: 3/27/2020

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: 20030680
Received Date: 3/16/2020 8:55:00 AM
Reported Date: 3/27/2020 11:46:39 AM

Sample Information:

Lab ID: 20030680-073 **Client Sample ID:** O/S Office Staff Women's RR-Sink (R)
Collection Date: 3/14/2020 8:14:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** O/S Office Staff Women's RR-Sink (R)

Trace Metals by EPA 200.8 ICP-MS						Analyst: KMC		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.00186		0.000103	mg/L	1	3/19/2020	0.0150	A

Lab ID: 20030680-074 **Client Sample ID:** Rm 309-DF
Collection Date: 3/14/2020 8:16:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Rm 309-DF

Trace Metals by EPA 200.8 ICP-MS						Analyst: KMC		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.000537		0.000103	mg/L	1	3/19/2020	0.0150	A

Lab ID: 20030680-075 **Client Sample ID:** Rm 309-Sink
Collection Date: 3/14/2020 8:17:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Rm 309-Sink

Trace Metals by EPA 200.8 ICP-MS						Analyst: KMC		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.00166		0.000103	mg/L	1	3/19/2020	0.0150	A

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

Results are out of the EPA limits

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 20030680

Date Reported: 3/27/2020

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: 20030680
Received Date: 3/16/2020 8:55:00 AM
Reported Date: 3/27/2020 11:46:39 AM

Sample Information:

Lab ID: 20030680-076 **Client Sample ID:** Rm 310-DF
Collection Date: 3/14/2020 8:18:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Rm 310-DF

Trace Metals by EPA 200.8 ICP-MS						Analyst: KMC		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.000586		0.000103	mg/L	1	3/19/2020	0.0150	A

Lab ID: 20030680-077 **Client Sample ID:** Rm 310-Sink
Collection Date: 3/14/2020 8:19:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Rm 310-Sink

Trace Metals by EPA 200.8 ICP-MS						Analyst: KMC		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.00130		0.000103	mg/L	1	3/19/2020	0.0150	A

Lab ID: 20030680-078 **Client Sample ID:** Rm 311-DF
Collection Date: 3/14/2020 8:20:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Rm 311-DF

Trace Metals by EPA 200.8 ICP-MS						Analyst: KMC		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.000560		0.000103	mg/L	1	3/19/2020	0.0150	A

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

Results are out of the EPA limits

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 20030680

Date Reported: 3/27/2020

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: 20030680
Received Date: 3/16/2020 8:55:00 AM
Reported Date: 3/27/2020 11:46:39 AM

Sample Information:

Lab ID: 20030680-079 **Client Sample ID:** Rm 311-Sink
Collection Date: 3/14/2020 8:21:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Rm 311-Sink

Trace Metals by EPA 200.8 ICP-MS							Analyst: KMC	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.00142		0.000103	mg/L	1	3/19/2020	0.0150	A

Lab ID: 20030680-080 **Client Sample ID:** Rm 314-DF
Collection Date: 3/14/2020 8:22:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Rm 314-DF

Trace Metals by EPA 200.8 ICP-MS							Analyst: KMC	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.0910	*	0.000103	mg/L	1	3/19/2020	0.0150	A

Lab ID: 20030680-081 **Client Sample ID:** Rm 314-Sink
Collection Date: 3/14/2020 8:23:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Rm 314-Sink

Trace Metals by EPA 200.8 ICP-MS							Analyst: KMC	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.175	*	0.000103	mg/L	1	3/19/2020	0.0150	A

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

Results are out of the EPA limits

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 20030680
Date Reported: 3/27/2020

Medford School District
815 S Oakdale Ave
Medford , OR 97501

Lab Order: 20030680
Received Date: 3/16/2020 8:55:00 AM
Reported Date: 3/27/2020 11:46:39 AM

Sample Information:

Lab ID: 20030680-082 **Client Sample ID:** Rm 314 Unisex RR-Sink
Collection Date: 3/14/2020 8:24:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Rm 314 Unisex RR-Sink

Trace Metals by EPA 200.8 ICP-MS						Analyst; KMC		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.000215		0.000103	mg/L	1	3/19/2020	0.0150	A

Lab ID: 20030680-083 **Client Sample ID:** Rm 315-DF
Collection Date: 3/14/2020 8:26:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Rm 315-DF

Trace Metals by EPA 200.8 ICP-MS						Analyst; KMC		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.000231		0.000103	mg/L	1	3/19/2020	0.0150	A

Lab ID: 20030680-084 **Client Sample ID:** Rm 315-Sink
Collection Date: 3/14/2020 8:27:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Rm 315-Sink

Trace Metals by EPA 200.8 ICP-MS						Analyst; KMC		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.000924		0.000103	mg/L	1	3/19/2020	0.0150	A

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

Results are out of the EPA limits

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 20030680

Date Reported: 3/27/2020

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: 20030680
Received Date: 3/16/2020 8:55:00 AM
Reported Date: 3/27/2020 11:46:39 AM

Sample Information:

Lab ID: 20030680-085 **Client Sample ID:** Rm 316 Staff Work Rm-DF (N Wall)
Collection Date: 3/14/2020 8:29:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Rm 316 Staff Work Rm-DF (N Wall)

Trace Metals by EPA 200.8 ICP-MS						Analyst: KMC		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.00460		0.000103	mg/L	1	3/18/2020	0.0150	A

Lab ID: 20030680-086 **Client Sample ID:** Rm 316 Staff Work Rm-Sink (N Wall)
Collection Date: 3/14/2020 8:30:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Rm 316 Staff Work Rm-Sink (N Wall)

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.00274		0.000103	mg/L	1	3/25/2020	0.0150	A

Lab ID: 20030680-087 **Client Sample ID:** Rm 316 Staff Work Rm-DF (W Wall)
Collection Date: 3/14/2020 8:31:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Rm 316 Staff Work Rm-DF (W Wall)

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.000362		0.000103	mg/L	1	3/25/2020	0.0150	A

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

Results are out of the EPA limits

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 20030680

Date Reported: 3/27/2020

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: 20030680
Received Date: 3/16/2020 8:55:00 AM
Reported Date: 3/27/2020 11:46:39 AM

Sample Information:

Lab ID: 20030680-088 **Client Sample ID:** Rm 316 Staff Work Rm-Sink (W Wall)
Collection Date: 3/14/2020 8:32:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Rm 316 Staff Work Rm-Sink (W Wall)

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.00180		0.000103	mg/L	1	3/25/2020	0.0150	A

Lab ID: 20030680-089 **Client Sample ID:** Rm 317-DF
Collection Date: 3/14/2020 8:33:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Rm 317-DF

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.000286		0.000103	mg/L	1	3/25/2020	0.0150	A

Lab ID: 20030680-090 **Client Sample ID:** Rm 317-Sink
Collection Date: 3/14/2020 8:34:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Rm 317-Sink

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.00148		0.000103	mg/L	1	3/25/2020	0.0150	A

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

Results are out of the EPA limits

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 20030680

Date Reported: 3/27/2020

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: 20030680
Received Date: 3/16/2020 8:55:00 AM
Reported Date: 3/27/2020 11:46:39 AM

Sample Information:

Lab ID: 20030680-091 **Client Sample ID:** Rm 322-DF
Collection Date: 3/14/2020 7:52:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Rm 322-DF

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.000155		0.000103	mg/L	1	3/25/2020	0.0150	A

Lab ID: 20030680-092 **Client Sample ID:** Rm 322-Sink
Collection Date: 3/14/2020 7:52:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Rm 322-Sink

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.000377		0.000103	mg/L	1	3/25/2020	0.0150	A

Lab ID: 20030680-093 **Client Sample ID:** Rm 323-DF
Collection Date: 3/14/2020 7:55:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Rm 323-DF

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.000187		0.000103	mg/L	1	3/25/2020	0.0150	A

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

Results are out of the EPA limits

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 20030680

Date Reported: 3/27/2020

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: 20030680
Received Date: 3/16/2020 8:55:00 AM
Reported Date: 3/27/2020 11:46:39 AM

Sample Information:

Lab ID: 20030680-094 **Client Sample ID:** Rm 323-Sink
Collection Date: 3/14/2020 7:55:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Rm 323-Sink

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.000267		0.000103	mg/L	1	3/25/2020	0.0150	A

Lab ID: 20030680-095 **Client Sample ID:** Rm 325-DF
Collection Date: 3/14/2020 8:01:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Rm 325-DF

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.000266		0.000103	mg/L	1	3/25/2020	0.0150	A

Lab ID: 20030680-096 **Client Sample ID:** Rm 325-Sink
Collection Date: 3/14/2020 8:01:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Rm 325-Sink

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.000867		0.000103	mg/L	1	3/25/2020	0.0150	A

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

Results are out of the EPA limits

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 20030680

Date Reported: 3/27/2020

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: 20030680
Received Date: 3/16/2020 8:55:00 AM
Reported Date: 3/27/2020 11:46:39 AM

Sample Information:

Lab ID: 20030680-097 **Client Sample ID:** Rm 324-DF
Collection Date: 3/14/2020 7:58:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Rm 324-DF

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.000118		0.000103	mg/L	1	3/25/2020	0.0150	A

Lab ID: 20030680-098 **Client Sample ID:** Rm 324-Sink
Collection Date: 3/14/2020 7:58:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Rm 324-Sink

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.000357		0.000103	mg/L	1	3/25/2020	0.0150	A

Lab ID: 20030680-099 **Client Sample ID:** Strge Rm Between (Science) 326/328-Sink
Collection Date: 3/14/2020 8:04:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Strge Rm Between (Science) 326/328-Sink

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.00717		0.000103	mg/L	1	3/25/2020	0.0150	A

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

Results are out of the EPA limits

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 20030680

Date Reported: 3/27/2020

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: 20030680
Received Date: 3/16/2020 8:55:00 AM
Reported Date: 3/27/2020 11:46:39 AM

Sample Information:

Lab ID: 20030680-100 **Client Sample ID:** Rm 327-DF
Collection Date: 3/14/2020 8:07:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Rm 327-DF

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.000112		0.000103	mg/L	1	3/25/2020	0.0150	A

Lab ID: 20030680-101 **Client Sample ID:** Rm 327-Sink
Collection Date: 3/14/2020 8:07:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Rm 327-Sink

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.000281		0.000103	mg/L	1	3/25/2020	0.0150	A

Lab ID: 20030680-102 **Client Sample ID:** Rm 329-DF
Collection Date: 3/14/2020 8:10:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Rm 329-DF

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.000118		0.000103	mg/L	1	3/25/2020	0.0150	A

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

Results are out of the EPA limits

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 20030680

Date Reported: 3/27/2020

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: 20030680
Received Date: 3/16/2020 8:55:00 AM
Reported Date: 3/27/2020 11:46:39 AM

Sample Information:

Lab ID: 20030680-103 **Client Sample ID:** Rm 329-Sink
Collection Date: 3/14/2020 8:10:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Rm 329-Sink

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.000907		0.000103	mg/L	1	3/25/2020	0.0150	A

Lab ID: 20030680-104 **Client Sample ID:** Rm 331-DF
Collection Date: 3/14/2020 8:14:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Rm 331-DF

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	ND		0.000103	mg/L	1	3/25/2020	0.0150	A

Lab ID: 20030680-105 **Client Sample ID:** Rm 331-Sink
Collection Date: 3/14/2020 8:14:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Rm 331-Sink

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.000593		0.000103	mg/L	1	3/25/2020	0.0150	A

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

Results are out of the EPA limits

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 20030680

Date Reported: 3/27/2020

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: 20030680
Received Date: 3/16/2020 8:55:00 AM
Reported Date: 3/27/2020 11:46:39 AM

Sample Information:

Lab ID: 20030680-106 **Client Sample ID:** Across From Rm 331 Women's RR-Sink (L)
Collection Date: 3/14/2020 8:18:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Across From Rm 331 Women's RR-Sink (L)

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.000900		0.000103	mg/L	1	3/25/2020	0.0150	A

Lab ID: 20030680-107 **Client Sample ID:** Across From Rm 331 Women's RR-Sink (C)
Collection Date: 3/14/2020 8:18:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Across From Rm 331 Women's RR-Sink (C)

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.00270		0.000103	mg/L	1	3/25/2020	0.0150	A

Lab ID: 20030680-108 **Client Sample ID:** Across From Rm 331 Women's RR-Sink (R)
Collection Date: 3/14/2020 8:18:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Across From Rm 331 Women's RR-Sink (R)

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.000778		0.000103	mg/L	1	3/25/2020	0.0150	A

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

Results are out of the EPA limits

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 20030680

Date Reported: 3/27/2020

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: 20030680
Received Date: 3/16/2020 8:55:00 AM
Reported Date: 3/27/2020 11:46:39 AM

Sample Information:

Lab ID: 20030680-109 **Client Sample ID:** Across From Rm 334 Men's RR-Sink (L)
Collection Date: 3/14/2020 8:21:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Across From Rm 334 Men's RR-Sink (L)

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.00122		0.000103	mg/L	1	3/25/2020	0.0150	A

Lab ID: 20030680-110 **Client Sample ID:** Across From Rm 334 Men's RR-Sink (C)
Collection Date: 3/14/2020 8:21:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Across From Rm 334 Men's RR-Sink (C)

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.00211		0.000103	mg/L	1	3/25/2020	0.0150	A

Lab ID: 20030680-111 **Client Sample ID:** Across From Rm 334 Men's RR-Sink (R)
Collection Date: 3/14/2020 8:21:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Across From Rm 334 Men's RR-Sink (R)

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.00258		0.000103	mg/L	1	3/25/2020	0.0150	A

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

Results are out of the EPA limits

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 20030680

Date Reported: 3/27/2020

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: 20030680
Received Date: 3/16/2020 8:55:00 AM
Reported Date: 3/27/2020 11:46:39 AM

Sample Information:

Lab ID: 20030680-112 **Client Sample ID:** In Hallway Between Rms 331/334-DF
Collection Date: 3/14/2020 8:25:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** In Hallway Between Rms 331/334-DF

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.000370		0.000103	mg/L	1	3/25/2020	0.0150	A

Lab ID: 20030680-113 **Client Sample ID:** Rm 334-DF
Collection Date: 3/14/2020 8:29:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Rm 334-DF

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.000118		0.000103	mg/L	1	3/25/2020	0.0150	A

Lab ID: 20030680-114 **Client Sample ID:** Rm 334-Sink
Collection Date: 3/14/2020 8:29:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Rm 334-Sink

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.000614		0.000103	mg/L	1	3/25/2020	0.0150	A

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

Results are out of the EPA limits

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 20030680

Date Reported: 3/27/2020

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: 20030680
Received Date: 3/16/2020 8:55:00 AM
Reported Date: 3/27/2020 11:46:39 AM

Sample Information:

Lab ID: 20030680-115 Client Sample ID: Rm 336-DF
Collection Date: 3/14/2020 8:32:00 AM Collected By:
Matrix: Drinking Water Sample Location: Rm 336-DF

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.000167		0.000103	mg/L	1	3/25/2020	0.0150	A

Lab ID: 20030680-116 Client Sample ID: Rm 336-Sink
Collection Date: 3/14/2020 8:32:00 AM Collected By:
Matrix: Drinking Water Sample Location: Rm 336-Sink

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.000452		0.000103	mg/L	1	3/25/2020	0.0150	A

Lab ID: 20030680-117 Client Sample ID: Rm 337 Storage Rm-Sink
Collection Date: 3/14/2020 8:34:00 AM Collected By:
Matrix: Drinking Water Sample Location: Rm 337 Storage Rm-Sink

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.000475		0.000103	mg/L	1	3/25/2020	0.0150	A

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

Results are out of the EPA limits

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 20030680

Date Reported: 3/27/2020

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: 20030680
Received Date: 3/16/2020 8:55:00 AM
Reported Date: 3/27/2020 11:46:39 AM

Sample Information:

Lab ID: 20030680-118 **Client Sample ID:** Rm 338-DF
Collection Date: 3/14/2020 8:37:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Rm 338-DF

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.000346		0.000103	mg/L	1	3/25/2020	0.0150	A

Lab ID: 20030680-119 **Client Sample ID:** Rm 338-Sink
Collection Date: 3/14/2020 8:37:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Rm 338-Sink

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.000714		0.000103	mg/L	1	3/25/2020	0.0150	A

Lab ID: 20030680-120 **Client Sample ID:** Wrestling Rm-DF
Collection Date: 3/14/2020 8:40:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Wrestling Rm-DF

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.000603		0.000103	mg/L	1	3/25/2020	0.0150	A

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

Results are out of the EPA limits

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 20030680

Date Reported: 3/27/2020

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: 20030680
Received Date: 3/16/2020 8:55:00 AM
Reported Date: 3/27/2020 11:46:39 AM

Sample Information:

Lab ID: 20030680-121 **Client Sample ID:** Media Center Work Rm-DF
Collection Date: 3/14/2020 7:56:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Media Center Work Rm-DF

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.000202		0.000103	mg/L	1	3/25/2020	0.0150	A

Lab ID: 20030680-122 **Client Sample ID:** Media Center Work Rm-Sink
Collection Date: 3/14/2020 7:57:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Media Center Work Rm-Sink

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.00629		0.000103	mg/L	1	3/25/2020	0.0150	A

Lab ID: 20030680-123 **Client Sample ID:** Media Center Office-DF
Collection Date: 3/14/2020 8:00:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Media Center Office-DF

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.000301		0.000103	mg/L	1	3/25/2020	0.0150	A

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

Results are out of the EPA limits

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 20030680

Date Reported: 3/27/2020

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: 20030680
Received Date: 3/16/2020 8:55:00 AM
Reported Date: 3/27/2020 11:46:39 AM

Sample Information:

Lab ID: 20030680-124 **Client Sample ID:** Media Center Office-Sink
Collection Date: 3/14/2020 8:01:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Media Center Office-Sink

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.000780		0.000103	mg/L	1	3/25/2020	0.0150	A

Lab ID: 20030680-125 **Client Sample ID:** Rm 401-DF
Collection Date: 3/14/2020 8:04:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Rm 401-DF

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.000400		0.000103	mg/L	1	3/25/2020	0.0150	A

Lab ID: 20030680-126 **Client Sample ID:** Rm 401-Sink
Collection Date: 3/14/2020 8:05:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Rm 401-Sink

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.00135		0.000103	mg/L	1	3/25/2020	0.0150	A

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

Results are out of the EPA limits

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 20030680

Date Reported: 3/27/2020

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: 20030680
Received Date: 3/16/2020 8:55:00 AM
Reported Date: 3/27/2020 11:46:39 AM

Sample Information:

Lab ID: 20030680-127 **Client Sample ID:** Rm 402-DF
Collection Date: 3/14/2020 8:07:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Rm 402-DF

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.000402		0.000103	mg/L	1	3/25/2020	0.0150	A

Lab ID: 20030680-128 **Client Sample ID:** Rm 402-Sink
Collection Date: 3/14/2020 8:08:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Rm 402-Sink

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.00115		0.000103	mg/L	1	3/25/2020	0.0150	A

Lab ID: 20030680-129 **Client Sample ID:** Rm 404-DF
Collection Date: 3/14/2020 8:12:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Rm 404-DF

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.000444		0.000103	mg/L	1	3/25/2020	0.0150	A

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

Results are out of the EPA limits

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 20030680

Date Reported: 3/27/2020

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: 20030680
Received Date: 3/16/2020 8:55:00 AM
Reported Date: 3/27/2020 11:46:39 AM

Sample Information:

Lab ID: 20030680-130 **Client Sample ID:** Rm 404-Sink
Collection Date: 3/14/2020 8:13:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Rm 404-Sink

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.00125		0.000103	mg/L	1	3/25/2020	0.0150	A

Lab ID: 20030680-131 **Client Sample ID:** In-between Rm 408/404 Men's RR-Sink (L)
Collection Date: 3/14/2020 8:15:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** In-between Rm 408/404 Men's RR-Sink (L)

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.00188		0.000103	mg/L	1	3/25/2020	0.0150	A

Lab ID: 20030680-132 **Client Sample ID:** In-between Rm 408/404 Men's RR-Sink (C)
Collection Date: 3/14/2020 8:16:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** In-between Rm 408/404 Men's RR-Sink (C)

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.00214		0.000103	mg/L	1	3/25/2020	0.0150	A

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

Results are out of the EPA limits

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 20030680

Date Reported: 3/27/2020

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: 20030680
Received Date: 3/16/2020 8:55:00 AM
Reported Date: 3/27/2020 11:46:39 AM

Sample Information:

Lab ID: 20030680-133 **Client Sample ID:** In-between Rm 408/404 Men's RR-Sink (R)
Collection Date: 3/14/2020 8:17:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** In-between Rm 408/404 Men's RR-Sink (R)

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.000401		0.000103	mg/L	1	3/25/2020	0.0150	A

Lab ID: 20030680-134 **Client Sample ID:** Between Rm 408/404 Women's RR-Sink (L)
Collection Date: 3/14/2020 8:19:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Between Rm 408/404 Women's RR-Sink (L)

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.000787		0.000103	mg/L	1	3/25/2020	0.0150	A

Lab ID: 20030680-135 **Client Sample ID:** Between Rm 408/404 Women's RR-Sink (C)
Collection Date: 3/14/2020 8:19:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Between Rm 408/404 Women's RR-Sink (C)

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.000612		0.000103	mg/L	1	3/25/2020	0.0150	A

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

Results are out of the EPA limits

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 20030680

Date Reported: 3/27/2020

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: 20030680
Received Date: 3/16/2020 8:55:00 AM
Reported Date: 3/27/2020 11:46:39 AM

Sample Information:

Lab ID: 20030680-136 **Client Sample ID:** Between Rm 408/404 Women's RR-Sink (R)
Collection Date: 3/14/2020 8:20:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Between Rm 408/404 Women's RR-Sink (R)

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.00226		0.000103	mg/L	1	3/25/2020	0.0150	A

Lab ID: 20030680-137 **Client Sample ID:** Rm 408-DF
Collection Date: 3/14/2020 8:23:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Rm 408-DF

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.000701		0.000103	mg/L	1	3/25/2020	0.0150	A

Lab ID: 20030680-138 **Client Sample ID:** Rm 408-Sink
Collection Date: 3/14/2020 8:24:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Rm 408-Sink

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.00175		0.000103	mg/L	1	3/25/2020	0.0150	A

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

Results are out of the EPA limits

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 20030680

Date Reported: 3/27/2020

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: 20030680
Received Date: 3/16/2020 8:55:00 AM
Reported Date: 3/27/2020 11:46:39 AM

Sample Information:

Lab ID: 20030680-139 **Client Sample ID:** Rm 411-DF
Collection Date: 3/14/2020 8:25:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Rm 411-DF

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.000369		0.000103	mg/L	1	3/25/2020	0.0150	A

Lab ID: 20030680-140 **Client Sample ID:** Rm 411-Sink
Collection Date: 3/14/2020 8:26:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Rm 411-Sink

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.00265		0.000103	mg/L	1	3/25/2020	0.0150	A

Lab ID: 20030680-141 **Client Sample ID:** Rm 410-DF
Collection Date: 3/14/2020 8:28:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Rm 410-DF

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.000653		0.000103	mg/L	1	3/25/2020	0.0150	A

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

Results are out of the EPA limits

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 20030680
Date Reported: 3/27/2020

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: 20030680
Received Date: 3/16/2020 8:55:00 AM
Reported Date: 3/27/2020 11:46:39 AM

Sample Information:

Lab ID: 20030680-142 **Client Sample ID:** Rm 410-Sink
Collection Date: 3/14/2020 8:29:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Rm 410-Sink

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.00103		0.000103	mg/L	1	3/25/2020	0.0150	A

Lab ID: 20030680-143 **Client Sample ID:** Rm 409-DF (E Wall)
Collection Date: 3/14/2020 8:34:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Rm 409-DF (E Wall)

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.00115		0.000103	mg/L	1	3/25/2020	0.0150	A

Lab ID: 20030680-144 **Client Sample ID:** Storage Rm In-between 409/403-Sink
Collection Date: 3/14/2020 8:35:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Storage Rm In-between 409/403-Sink

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.00138		0.000103	mg/L	1	3/25/2020	0.0150	A

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

Results are out of the EPA limits

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 20030680

Date Reported: 3/27/2020

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: 20030680
Received Date: 3/16/2020 8:55:00 AM
Reported Date: 3/27/2020 11:46:39 AM

Sample Information:

Lab ID: 20030680-145 **Client Sample ID:** Rm 119 (Store)-Sink (Utility)
Collection Date: 3/14/2020 7:58:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Rm 119 (Store)-Sink (Utility)

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.00157		0.000103	mg/L	1	3/25/2020	0.0150	A

Lab ID: 20030680-146 **Client Sample ID:** Rm 122-Sink (S Wall-L)
Collection Date: 3/14/2020 8:16:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Rm 122-Sink (S Wall-L)

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.0100		0.000103	mg/L	1	3/25/2020	0.0150	A

Lab ID: 20030680-147 **Client Sample ID:** Rm 122-Sink (S Wall-C)
Collection Date: 3/14/2020 8:16:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Rm 122-Sink (S Wall-C)

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.000394		0.000103	mg/L	1	3/25/2020	0.0150	A

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

Results are out of the EPA limits

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 20030680

Date Reported: 3/27/2020

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: 20030680
Received Date: 3/16/2020 8:55:00 AM
Reported Date: 3/27/2020 11:46:39 AM

Sample Information:

Lab ID: 20030680-148 **Client Sample ID:** Rm 122-Sink (S Wall-R)
Collection Date: 3/14/2020 8:17:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Rm 122-Sink (S Wall-R)

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.000401		0.000103	mg/L	1	3/25/2020	0.0150	A

Lab ID: 20030680-149 **Client Sample ID:** Rm 122-Sink (E Wall-Back Corner)
Collection Date: 3/14/2020 8:17:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Rm 122-Sink (E Wall-Back Corner)

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.00111		0.000103	mg/L	1	3/25/2020	0.0150	A

Lab ID: 20030680-150 **Client Sample ID:** Rm 125-Sink (N Wall-L)
Collection Date: 3/14/2020 8:40:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Rm 125-Sink (N Wall-L)

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.00334		0.000103	mg/L	1	3/25/2020	0.0150	A

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

Results are out of the EPA limits

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 20030680

Date Reported: 3/27/2020

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: 20030680
Received Date: 3/16/2020 8:55:00 AM
Reported Date: 3/27/2020 11:46:39 AM

Sample Information:

Lab ID: 20030680-151 **Client Sample ID:** Rm 125-Sink (N Wall-R)
Collection Date: 3/14/2020 8:40:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Rm 125-Sink (N Wall-R)

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.00150		0.000103	mg/L	1	3/25/2020	0.0150	A

Lab ID: 20030680-152 **Client Sample ID:** Rm 125-Sink (S Wall-L)
Collection Date: 3/14/2020 8:40:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Rm 125-Sink (S Wall-L)

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.000334		0.000103	mg/L	1	3/25/2020	0.0150	A

Lab ID: 20030680-153 **Client Sample ID:** Rm 125-Sink (S Wall-R)
Collection Date: 3/14/2020 8:40:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Rm 125-Sink (S Wall-R)

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.00534		0.000103	mg/L	1	3/25/2020	0.0150	A

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

Results are out of the EPA limits

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 20030680

Date Reported: 3/27/2020

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: 20030680
Received Date: 3/16/2020 8:55:00 AM
Reported Date: 3/27/2020 11:46:39 AM

Sample Information:

Lab ID: 20030680-154 Client Sample ID: Custodial Office Unisex RR-Sink
Collection Date: 3/14/2020 8:42:00 AM Collected By:
Matrix: Drinking Water Sample Location: Custodial Office Unisex RR-Sink

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.000687		0.000103	mg/L	1	3/25/2020	0.0150	A

Lab ID: 20030680-155 Client Sample ID: Rm 121-DF
Collection Date: 3/14/2020 8:31:00 AM Collected By:
Matrix: Drinking Water Sample Location: Rm 121-DF

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.000310		0.000103	mg/L	1	3/25/2020	0.0150	A

Lab ID: 20030680-156 Client Sample ID: Rm 121-Sink
Collection Date: 3/14/2020 8:31:00 AM Collected By:
Matrix: Drinking Water Sample Location: Rm 121-Sink

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.00401		0.000103	mg/L	1	3/25/2020	0.0150	A

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

Results are out of the EPA limits

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 20030680

Date Reported: 3/27/2020

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: 20030680
Received Date: 3/16/2020 8:55:00 AM
Reported Date: 3/27/2020 11:46:39 AM

Sample Information:

Lab ID: 20030680-157 **Client Sample ID:** Rm 124 (Staff Break Rm) Men's RR-Sink (L)
Collection Date: 3/14/2020 8:34:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Rm 124 (Staff Break Rm) Men's RR-Sink (L)

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.00196		0.000103	mg/L	1	3/25/2020	0.0150	A

Lab ID: 20030680-158 **Client Sample ID:** Rm 124 (Staff Break Rm) Men's RR-Sink (R)
Collection Date: 3/14/2020 8:35:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Rm 124 (Staff Break Rm) Men's RR-Sink (R)

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.00130		0.000103	mg/L	1	3/25/2020	0.0150	A

Lab ID: 20030680-159 **Client Sample ID:** Rm 124 (Staff Brk Rm) Women's RR-Sink (L)
Collection Date: 3/14/2020 8:35:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Rm 124 (Staff Brk Rm) Women's RR-Sink (L)

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.000674		0.000103	mg/L	1	3/25/2020	0.0150	A

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

Results are out of the EPA limits

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 20030680

Date Reported: 3/27/2020

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: 20030680
Received Date: 3/16/2020 8:55:00 AM
Reported Date: 3/27/2020 11:46:39 AM

Sample Information:

Lab ID: 20030680-160 **Client Sample ID:** Rm 124 (Staff Brk Rm) Women's RR-Sink (R)
Collection Date: 3/14/2020 8:35:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Rm 124 (Staff Brk Rm) Women's RR-Sink (R)

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.000418		0.000103	mg/L	1	3/25/2020	0.0150	A

Lab ID: 20030680-161 **Client Sample ID:** Rm 124 (Staff Break Rm)-Sink
Collection Date: 3/14/2020 8:33:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Rm 124 (Staff Break Rm)-Sink

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.000125		0.000103	mg/L	1	3/25/2020	0.0150	A

Lab ID: 20030680-162 **Client Sample ID:** Kitch Hand Wash-Sink (Near Serving Line)
Collection Date: 3/14/2020 8:26:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Kitch Hand Wash-Sink (Near Serving Line)

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.000461		0.000103	mg/L	1	3/25/2020	0.0150	A

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

Results are out of the EPA limits

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 20030680

Date Reported: 3/27/2020

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: 20030680
Received Date: 3/16/2020 8:55:00 AM
Reported Date: 3/27/2020 11:46:39 AM

Sample Information:

Lab ID: 20030680-163 **Client Sample ID:** Kitch Hand Wash-Sink (Serves Ct Yard)
Collection Date: 3/14/2020 8:27:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Kitch Hand Wash-Sink (Serves Ct Yard)

Trace Metals by EPA 200.8 ICP-MS							Analyst; SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.000377		0.000103	mg/L	1	3/25/2020	0.0150	A

Lab ID: 20030680-164 **Client Sample ID:** Kitch Pre-Rinse/Dishwasher-Sink (Single)
Collection Date: 3/14/2020 8:27:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Kitch Pre-Rinse/Dishwasher-Sink (Single)

Trace Metals by EPA 200.8 ICP-MS							Analyst; SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.00249		0.000103	mg/L	1	3/25/2020	0.0150	A

Lab ID: 20030680-165 **Client Sample ID:** Kitch Pre-Rinse/Dishwasher-Sink (Double)
Collection Date: 3/14/2020 8:28:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Kitch Pre-Rinse/Dishwasher-Sink (Double)

Trace Metals by EPA 200.8 ICP-MS							Analyst; SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.00616		0.000103	mg/L	1	3/25/2020	0.0150	A

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

Results are out of the EPA limits

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 20030680

Date Reported: 3/27/2020

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: 20030680
Received Date: 3/16/2020 8:55:00 AM
Reported Date: 3/27/2020 11:46:39 AM

Sample Information:

Lab ID: 20030680-166 **Client Sample ID:** Kitch Food Prep-Sink (Double)
Collection Date: 3/14/2020 8:29:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Kitch Food Prep-Sink (Double)

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.000616		0.000103	mg/L	1	3/20/2020	0.0150	A

Lab ID: 20030680-167 **Client Sample ID:** Rm 120-DF
Collection Date: 3/14/2020 8:03:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Rm 120-DF

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.000599		0.000103	mg/L	1	3/20/2020	0.0150	A

Lab ID: 20030680-168 **Client Sample ID:** Rm 120-Sink
Collection Date: 3/14/2020 8:05:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Rm 120-Sink

Trace Metals by EPA 200.8 ICP-MS						Analyst: SJS		
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.000600		0.000103	mg/L	1	3/20/2020	0.0150	A

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

Results are out of the EPA limits

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

Analytical Report

WO#: 20030680

Date Reported: 3/27/2020

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: 20030680
Received Date: 3/16/2020 8:55:00 AM
Reported Date: 3/27/2020 11:46:39 AM

Sample Information:

Lab ID: 20030680-169 **Client Sample ID:** Rm 118-Ice Machine
Collection Date: 3/14/2020 8:04:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Rm 118-Ice Machine

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.000780		0.000100	mg/L	1	3/20/2020	0.0150	A

Lab ID: 20030680-170 **Client Sample ID:** Hallway E Side of Gym Near Rm 118-DF
Collection Date: 3/14/2020 8:10:00 AM **Collected By:**
Matrix: Drinking Water **Sample Location:** Hallway E Side of Gym Near Rm 118-DF

Trace Metals by EPA 200.8 ICP-MS							Analyst: SJS	
Analyses	Result	Qual	MRL	Units	DF	Date Analyzed	MCL	NELAP Status
Lead	0.00597		0.000103	mg/L	1	3/20/2020	0.0150	A

QUALIFIERS	*	Value exceeds Maximum Contaminant Level.	C1	Sample container temperature is out of limit as specified at testcode
	E	Value above quantitation range	H	Holding times for preparation or analysis exceeded
	J	Analyte detected below quantitation limits	MI	Recovery outside control limits due to Matrix Interference
	ND	Not Detected at the Reporting Limit	PL	Permit Limit
	R	RPD outside accepted recovery limits		

Results are out of the EPA limits

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

QC SUMMARY REPORT

WO#: 20030680

27-Mar-20

Client: Medford School District
Project: 18-06 Hedrick 2020 Lead Testing

TestCode: LEAD_DW

Sample ID: MB-3363	SampType: MBLK	TestCode: LEAD_DW	Units: mg/L	Prep Date: 3/18/2020	RunNo: 8415						
Client ID: PBW	Batch ID: 3363	TestNo: E200.8	E200.8	Analysis Date: 3/18/2020	SeqNo: 152815						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead ND 0.000103

Sample ID: LCS-3363	SampType: LCS	TestCode: LEAD_DW	Units: mg/L	Prep Date: 3/18/2020	RunNo: 8415						
Client ID: LCSW	Batch ID: 3363	TestNo: E200.8	E200.8	Analysis Date: 3/18/2020	SeqNo: 152816						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead 0.102 0.000104 0.1000 0 102 85 115

Sample ID: 20030680-024AMS	SampType: MS	TestCode: LEAD_DW	Units: mg/L	Prep Date: 3/18/2020	RunNo: 8415						
Client ID: NE Gym Ent Unisex	Batch ID: 3363	TestNo: E200.8	E200.8	Analysis Date: 3/18/2020	SeqNo: 152839						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead 0.0988 0.000104 0.1000 0.0004264 98.4 70 130

Sample ID: 20030680-024AMSD	SampType: MSD	TestCode: LEAD_DW	Units: mg/L	Prep Date: 3/18/2020	RunNo: 8415						
Client ID: NE Gym Ent Unisex	Batch ID: 3363	TestNo: E200.8	E200.8	Analysis Date: 3/18/2020	SeqNo: 152840						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead 0.101 0.000104 0.1000 0.0004264 101 70 130 0.09884 2.38 20

Qualifiers:

* Value exceeds Maximum Contaminant Level.
H Holding times for preparation or analysis exceeded
PL Permit Limit

C1 Sample container temperature is out of limit as specified at testcode
MI Recovery outside control limits due to Matrix Interference
RL Reporting Detection Limit

E Value above quantitation range
ND Not Detected at the Reporting Limit

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

QC SUMMARY REPORT

WO#: 20030680

27-Mar-20

Client: Medford School District
Project: 18-06 Hedrick 2020 Lead Testing

TestCode: LEAD_DW

Sample ID: MB-3364	SampType: MBLK	TestCode: LEAD_DW	Units: mg/L	Prep Date: 3/18/2020	RunNo: 8415
Client ID: PBW	Batch ID: 3364	TestNo: E200.8	E200.8	Analysis Date: 3/18/2020	SeqNo: 152843
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead ND 0.000103

Sample ID: LCS-3364	SampType: LCS	TestCode: LEAD_DW	Units: mg/L	Prep Date: 3/18/2020	RunNo: 8415
Client ID: LCSW	Batch ID: 3364	TestNo: E200.8	E200.8	Analysis Date: 3/18/2020	SeqNo: 152844
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead 0.102 0.000104 0.1000 0 102 85 115

Sample ID: 20030680-044AMS	SampType: MS	TestCode: LEAD_DW	Units: mg/L	Prep Date: 3/18/2020	RunNo: 8415
Client ID: Rm 215-Sink	Batch ID: 3364	TestNo: E200.8	E200.8	Analysis Date: 3/18/2020	SeqNo: 152868
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead 0.104 0.000104 0.1000 0.000777 103 70 130

Sample ID: 20030680-044AMSD	SampType: MSD	TestCode: LEAD_DW	Units: mg/L	Prep Date: 3/18/2020	RunNo: 8415
Client ID: Rm 215-Sink	Batch ID: 3364	TestNo: E200.8	E200.8	Analysis Date: 3/18/2020	SeqNo: 152869
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead 0.104 0.000104 0.1000 0.000777 103 70 130 0.1035 0.613 20

Qualifiers:

* Value exceeds Maximum Contaminant Level.
H Holding times for preparation or analysis exceeded
PL Permit Limit

C1 Sample container temperature is out of limit as specified at testcode
MI Recovery outside control limits due to Matrix Interference
RL Reporting Detection Limit

E Value above quantitation range
ND Not Detected at the Reporting Limit

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

QC SUMMARY REPORT

WO#: 20030680

27-Mar-20

Client: Medford School District
Project: 18-06 Hedrick 2020 Lead Testing

TestCode: LEAD_DW

Sample ID: MB-3365	SampType: MBLK	TestCode: LEAD_DW	Units: mg/L	Prep Date: 3/18/2020	RunNo: 8415
Client ID: PBW	Batch ID: 3365	TestNo: E200.8	E200.8	Analysis Date: 3/18/2020	SeqNo: 152872
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead ND 0.000103

Sample ID: LCS-3365	SampType: LCS	TestCode: LEAD_DW	Units: mg/L	Prep Date: 3/18/2020	RunNo: 8415
Client ID: LCSW	Batch ID: 3365	TestNo: E200.8	E200.8	Analysis Date: 3/18/2020	SeqNo: 152873
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead 0.108 0.000104 0.1000 0 108 85 115

Sample ID: 20030680-064AMS	SampType: MS	TestCode: LEAD_DW	Units: mg/L	Prep Date: 3/18/2020	RunNo: 8415
Client ID: Across From Rm 30	Batch ID: 3365	TestNo: E200.8	E200.8	Analysis Date: 3/19/2020	SeqNo: 152896
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead 0.108 0.000104 0.1000 0.001303 107 70 130

Sample ID: 20030680-064AMSD	SampType: MSD	TestCode: LEAD_DW	Units: mg/L	Prep Date: 3/18/2020	RunNo: 8415
Client ID: Across From Rm 30	Batch ID: 3365	TestNo: E200.8	E200.8	Analysis Date: 3/19/2020	SeqNo: 152897
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead 0.110 0.000104 0.1000 0.001303 108 70 130 0.1080 1.49 20

Qualifiers: * Value exceeds Maximum Contaminant Level.
H Holding times for preparation or analysis exceeded
PL Permit Limit
C1 Sample container temperature is out of limit as specified at testcode
MI Recovery outside control limits due to Matrix Interference
RL Reporting Detection Limit
E Value above quantitation range
ND Not Detected at the Reporting Limit

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

QC SUMMARY REPORT

WO#: 20030680

27-Mar-20

Client: Medford School District
Project: 18-06 Hedrick 2020 Lead Testing

TestCode: LEAD_DW

Sample ID: MB-3366	SampType: MBLK	TestCode: LEAD_DW	Units: mg/L	Prep Date: 3/18/2020	RunNo: 8415
Client ID: PBW	Batch ID: 3366	TestNo: E200.8	E200.8	Analysis Date: 3/19/2020	SeqNo: 152900
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead ND 0.000103

Sample ID: LCS-3366	SampType: LCS	TestCode: LEAD_DW	Units: mg/L	Prep Date: 3/18/2020	RunNo: 8415
Client ID: LCSW	Batch ID: 3366	TestNo: E200.8	E200.8	Analysis Date: 3/19/2020	SeqNo: 152901
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead 0.105 0.000104 0.1000 0 105 85 115

Sample ID: 20030680-084AMS	SampType: MS	TestCode: LEAD_DW	Units: mg/L	Prep Date: 3/18/2020	RunNo: 8415
Client ID: Rm 315-Sink	Batch ID: 3366	TestNo: E200.8	E200.8	Analysis Date: 3/19/2020	SeqNo: 152924
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead 0.110 0.000104 0.1000 0.0009239 109 70 130

Sample ID: 20030680-084AMSD	SampType: MSD	TestCode: LEAD_DW	Units: mg/L	Prep Date: 3/18/2020	RunNo: 8415
Client ID: Rm 315-Sink	Batch ID: 3366	TestNo: E200.8	E200.8	Analysis Date: 3/19/2020	SeqNo: 152925
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead 0.0979 0.000104 0.1000 0.0009239 97.0 70 130 0.1098 11.4 20

Qualifiers:

* Value exceeds Maximum Contaminant Level.
H Holding times for preparation or analysis exceeded
PL Permit Limit

C1 Sample container temperature is out of limit as specified at testcode
MI Recovery outside control limits due to Matrix Interference
RL Reporting Detection Limit

E Value above quantitation range
ND Not Detected at the Reporting Limit

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

QC SUMMARY REPORT

WO#: 20030680

27-Mar-20

Client: Medford School District
Project: 18-06 Hedrick 2020 Lead Testing

TestCode: LEAD_DW

Sample ID: MB-3372	SampType: MBLK	TestCode: LEAD_DW	Units: mg/L	Prep Date: 3/19/2020	RunNo: 8470
Client ID: PBW	Batch ID: 3372	TestNo: E200.8	E200.8	Analysis Date: 3/20/2020	SeqNo: 153496
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead ND 0.000100

Sample ID: LCS-3372	SampType: LCS	TestCode: LEAD_DW	Units: mg/L	Prep Date: 3/19/2020	RunNo: 8470
Client ID: LCSW	Batch ID: 3372	TestNo: E200.8	E200.8	Analysis Date: 3/20/2020	SeqNo: 153497
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead 0.105 0.000100 0.1000 0 105 85 115

Sample ID: 20030789-01AMS	SampType: MS	TestCode: LEAD_DW	Units: mg/L	Prep Date: 3/19/2020	RunNo: 8470
Client ID: BatchQC	Batch ID: 3372	TestNo: E200.8	E200.8	Analysis Date: 3/20/2020	SeqNo: 153499
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead 0.102 0.000100 0.1000 0.00002500 102 70 130

Sample ID: 20030789-01AMSD	SampType: MSD	TestCode: LEAD_DW	Units: mg/L	Prep Date: 3/19/2020	RunNo: 8470
Client ID: BatchQC	Batch ID: 3372	TestNo: E200.8	E200.8	Analysis Date: 3/20/2020	SeqNo: 153500
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead 0.103 0.000100 0.1000 0.00002500 103 70 130 0.1016 1.68 20

Qualifiers:

* Value exceeds Maximum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode	E Value above quantitation range
H Holding times for preparation or analysis exceeded	MI Recovery outside control limits due to Matrix Interference	ND Not Detected at the Reporting Limit
PL Permit Limit	RL Reporting Detection Limit	

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

QC SUMMARY REPORT

WO#: 20030680

27-Mar-20

Client: Medford School District
Project: 18-06 Hedrick 2020 Lead Testing

TestCode: LEAD_DW

Sample ID: MB-3379	SampType: MBLK	TestCode: LEAD_DW	Units: mg/L	Prep Date: 3/19/2020	RunNo: 8470
Client ID: PBW	Batch ID: 3379	TestNo: E200.8	E200.8	Analysis Date: 3/20/2020	SeqNo: 153524
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead ND 0.000103

Sample ID: LCS-3379	SampType: LCS	TestCode: LEAD_DW	Units: mg/L	Prep Date: 3/19/2020	RunNo: 8470
Client ID: LCSW	Batch ID: 3379	TestNo: E200.8	E200.8	Analysis Date: 3/20/2020	SeqNo: 153525
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead 0.115 0.000104 0.1000 0 115 85 115

Sample ID: 20030680-170AMS	SampType: MS	TestCode: LEAD_DW	Units: mg/L	Prep Date: 3/19/2020	RunNo: 8470
Client ID: Hallway E Side of G	Batch ID: 3379	TestNo: E200.8	E200.8	Analysis Date: 3/20/2020	SeqNo: 153532
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead 0.119 0.000104 0.1000 0.005966 113 70 130

Sample ID: 20030680-170AMSD	SampType: MSD	TestCode: LEAD_DW	Units: mg/L	Prep Date: 3/19/2020	RunNo: 8470
Client ID: Hallway E Side of G	Batch ID: 3379	TestNo: E200.8	E200.8	Analysis Date: 3/20/2020	SeqNo: 153533
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead 0.114 0.000104 0.1000 0.005966 108 70 130 0.1190 3.94 20

Qualifiers: * Value exceeds Maximum Contaminant Level.
H Holding times for preparation or analysis exceeded
PL Permit Limit
C1 Sample container temperature is out of limit as specified at testcode
MI Recovery outside control limits due to Matrix Interference
RL Reporting Detection Limit
E Value above quantitation range
ND Not Detected at the Reporting Limit

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

QC SUMMARY REPORT

WO#: 20030680

27-Mar-20

Client: Medford School District
Project: 18-06 Hedrick 2020 Lead Testing

TestCode: LEAD_DW

Sample ID: MB-3379	SampType: MBLK	TestCode: LEAD_DW	Units: mg/L	Prep Date: 3/19/2020	RunNo: 8524
Client ID: PBW	Batch ID: 3379	TestNo: E200.8	E200.8	Analysis Date: 3/24/2020	SeqNo: 154560
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead ND 0.000103

Sample ID: LCS-3379	SampType: LCS	TestCode: LEAD_DW	Units: mg/L	Prep Date: 3/19/2020	RunNo: 8524
Client ID: LCSW	Batch ID: 3379	TestNo: E200.8	E200.8	Analysis Date: 3/24/2020	SeqNo: 154561
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead 0.109 0.000104 0.1000 0 109 85 115

Sample ID: MB-3375	SampType: MBLK	TestCode: LEAD_DW	Units: mg/L	Prep Date: 3/19/2020	RunNo: 9566
Client ID: PBW	Batch ID: 3375	TestNo: E200.8	E200.8	Analysis Date: 3/25/2020	SeqNo: 156484
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead ND 0.000103

Sample ID: LCS-3375	SampType: LCS	TestCode: LEAD_DW	Units: mg/L	Prep Date: 3/19/2020	RunNo: 9566
Client ID: LCSW	Batch ID: 3375	TestNo: E200.8	E200.8	Analysis Date: 3/25/2020	SeqNo: 156485
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual

Lead 0.111 0.000104 0.1000 0 111 85 115

Qualifiers:

* Value exceeds Maximum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode	E Value above quantitation range
H Holding times for preparation or analysis exceeded	MI Recovery outside control limits due to Matrix Interference	ND Not Detected at the Reporting Limit
PL Permit Limit	RL Reporting Detection Limit	

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

QC SUMMARY REPORT

WO#: 20030680

27-Mar-20

Client: Medford School District
Project: 18-06 Hedrick 2020 Lead Testing

TestCode: LEAD_DW

Sample ID: 20030680-105AMS	SampType: MS	TestCode: LEAD_DW	Units: mg/L	Prep Date: 3/19/2020	RunNo: 9566						
Client ID: Rm 331-Sink	Batch ID: 3375	TestNo: E200.8	E200.8	Analysis Date: 3/25/2020	SeqNo: 156508						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	0.123	0.000103	0.1000	0.0005933	123	70	130				
------	-------	----------	--------	-----------	-----	----	-----	--	--	--	--

Sample ID: 20030680-105AMSD	SampType: MSD	TestCode: LEAD_DW	Units: mg/L	Prep Date: 3/19/2020	RunNo: 9566						
Client ID: Rm 331-Sink	Batch ID: 3375	TestNo: E200.8	E200.8	Analysis Date: 3/25/2020	SeqNo: 156509						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	0.114	0.000103	0.1000	0.0005933	113	70	130	0.1232	8.11	20	
------	-------	----------	--------	-----------	-----	----	-----	--------	------	----	--

Sample ID: MB-3376	SampType: MBLK	TestCode: LEAD_DW	Units: mg/L	Prep Date: 3/19/2020	RunNo: 9566						
Client ID: PBW	Batch ID: 3376	TestNo: E200.8	E200.8	Analysis Date: 3/25/2020	SeqNo: 156512						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	ND	0.000103									
------	----	----------	--	--	--	--	--	--	--	--	--

Sample ID: LCS-3376	SampType: LCS	TestCode: LEAD_DW	Units: mg/L	Prep Date: 3/19/2020	RunNo: 9566						
Client ID: LCSW	Batch ID: 3376	TestNo: E200.8	E200.8	Analysis Date: 3/25/2020	SeqNo: 156513						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	0.102	0.000104	0.1000	0	102	85	115				
------	-------	----------	--------	---	-----	----	-----	--	--	--	--

Qualifiers:

* Value exceeds Maximum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode	E Value above quantitation range
H Holding times for preparation or analysis exceeded	MI Recovery outside control limits due to Matrix Interference	ND Not Detected at the Reporting Limit
PL Permit Limit	RL Reporting Detection Limit	

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

QC SUMMARY REPORT

WO#: 20030680

27-Mar-20

Client: Medford School District
Project: 18-06 Hedrick 2020 Lead Testing

TestCode: LEAD_DW

Sample ID: 20030680-125AMS	SampType: MS	TestCode: LEAD_DW	Units: mg/L	Prep Date: 3/19/2020	RunNo: 9566						
Client ID: Rm 401-DF	Batch ID: 3376	TestNo: E200.8	E200.8	Analysis Date: 3/25/2020	SeqNo: 156536						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	0.106	0.000103	0.1000	0.0003996	106	70	130				
------	-------	----------	--------	-----------	-----	----	-----	--	--	--	--

Sample ID: 20030680-125AMSD	SampType: MSD	TestCode: LEAD_DW	Units: mg/L	Prep Date: 3/19/2020	RunNo: 9566						
Client ID: Rm 401-DF	Batch ID: 3376	TestNo: E200.8	E200.8	Analysis Date: 3/25/2020	SeqNo: 156537						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	0.107	0.000103	0.1000	0.0003996	107	70	130	0.1063	0.745	20	
------	-------	----------	--------	-----------	-----	----	-----	--------	-------	----	--

Sample ID: MB-3377	SampType: MBLK	TestCode: LEAD_DW	Units: mg/L	Prep Date: 3/19/2020	RunNo: 9566						
Client ID: PBW	Batch ID: 3377	TestNo: E200.8	E200.8	Analysis Date: 3/25/2020	SeqNo: 156547						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	ND	0.000103									
------	----	----------	--	--	--	--	--	--	--	--	--

Sample ID: LCS-3377	SampType: LCS	TestCode: LEAD_DW	Units: mg/L	Prep Date: 3/19/2020	RunNo: 9566						
Client ID: LCSW	Batch ID: 3377	TestNo: E200.8	E200.8	Analysis Date: 3/25/2020	SeqNo: 156548						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	0.109	0.000104	0.1000	0	109	85	115				
------	-------	----------	--------	---	-----	----	-----	--	--	--	--

Qualifiers:

* Value exceeds Maximum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode	E Value above quantitation range
H Holding times for preparation or analysis exceeded	MI Recovery outside control limits due to Matrix Interference	ND Not Detected at the Reporting Limit
PL Permit Limit	RL Reporting Detection Limit	

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

QC SUMMARY REPORT

WO#: 20030680

27-Mar-20

Client: Medford School District
Project: 18-06 Hedrick 2020 Lead Testing

TestCode: LEAD_DW

Sample ID: 20030680-145AMS	SampType: MS	TestCode: LEAD_DW	Units: mg/L	Prep Date: 3/19/2020	RunNo: 9566						
Client ID: Rm 119 (Store)-Sink	Batch ID: 3377	TestNo: E200.8	E200.8	Analysis Date: 3/25/2020	SeqNo: 156571						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	0.110	0.000103	0.1000	0.001571	108	70	130				
------	-------	----------	--------	----------	-----	----	-----	--	--	--	--

Sample ID: 20030680-145AMSD	SampType: MSD	TestCode: LEAD_DW	Units: mg/L	Prep Date: 3/19/2020	RunNo: 9566						
Client ID: Rm 119 (Store)-Sink	Batch ID: 3377	TestNo: E200.8	E200.8	Analysis Date: 3/25/2020	SeqNo: 156572						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	0.113	0.000103	0.1000	0.001571	111	70	130	0.1098	2.44	20	
------	-------	----------	--------	----------	-----	----	-----	--------	------	----	--

Sample ID: MB-3378	SampType: MBLK	TestCode: LEAD_DW	Units: mg/L	Prep Date: 3/19/2020	RunNo: 9566						
Client ID: PBW	Batch ID: 3378	TestNo: E200.8	E200.8	Analysis Date: 3/25/2020	SeqNo: 156575						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	ND	0.000103									
------	----	----------	--	--	--	--	--	--	--	--	--

Sample ID: LCS-3378	SampType: LCS	TestCode: LEAD_DW	Units: mg/L	Prep Date: 3/19/2020	RunNo: 9566						
Client ID: LCSW	Batch ID: 3378	TestNo: E200.8	E200.8	Analysis Date: 3/25/2020	SeqNo: 156576						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead	0.108	0.000104	0.1000	0	108	85	115				
------	-------	----------	--------	---	-----	----	-----	--	--	--	--

Qualifiers:

* Value exceeds Maximum Contaminant Level.	C1 Sample container temperature is out of limit as specified at testcode	E Value above quantitation range
H Holding times for preparation or analysis exceeded	MI Recovery outside control limits due to Matrix Interference	ND Not Detected at the Reporting Limit
PL Permit Limit	RL Reporting Detection Limit	

Original



Neilson Research Corporation
245 S Grape St
Medford, OR 97501
TEL: (541) 770-5678 FAX: (541) 770-2901
Website: www.nrclabs.com

QC SUMMARY REPORT

WO#: 20030680

27-Mar-20

Client: Medford School District

Project: 18-06 Hedrick 2020 Lead Testing

TestCode: LEAD_DW

Sample ID: 20030680-165AMS	SampType: MS	TestCode: LEAD_DW	Units: mg/L	Prep Date: 3/19/2020	RunNo: 9566						
Client ID: Kitch Pre-Rinse/Dish	Batch ID: 3378	TestNo: E200.8	E200.8	Analysis Date: 3/25/2020	SeqNo: 156599						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	0.119	0.000103	0.1000	0.006156	112	70	130				

Sample ID: 20030680-165AMSD	SampType: MSD	TestCode: LEAD_DW	Units: mg/L	Prep Date: 3/19/2020	RunNo: 9566						
Client ID: Kitch Pre-Rinse/Dish	Batch ID: 3378	TestNo: E200.8	E200.8	Analysis Date: 3/25/2020	SeqNo: 156600						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	0.118	0.000103	0.1000	0.006156	112	70	130	0.1185	0.643	20	

Qualifiers:

* Value exceeds Maximum Contaminant Level.
H Holding times for preparation or analysis exceeded
PL Permit Limit

C1 Sample container temperature is out of limit as specified at testcode
MI Recovery outside control limits due to Matrix Interference
RL Reporting Detection Limit

E Value above quantitation range
ND Not Detected at the Reporting Limit

Original

Sample Log-In Check List

Client Name: **MedfordSchoolDist**

Work Order Number: **20030680**

RcptNo: **1**

Logged by: **Sarah Spence** **3/16/2020 8:55:00 AM**

Sarah Spence

Completed By: **Katherine Crooks** **3/17/2020 3:54:00 PM**

Katherine Crooks

Reviewed By: **Naomi Orr** **3/27/2020 8:45:48 AM**

Naomi Orr

Chain of Custody

1. Is Chain of Custody complete? Yes ☒ No ☐ Not Present ☐
2. How was the sample delivered? Client

Log In

3. Coolers are present? Yes ☐ No ☐ NA ☒
4. Shipping container/cooler in good condition? Yes ☒ No ☐
Custody seals intact on shipping container/cooler? Yes ☐ No ☐ Not Present ☒
No. Seal Date: Signed By:
5. Was an attempt made to cool the samples? Yes ☐ No ☐ NA ☒
6. Were all samples received at a temperature of >0° C to 6.0°C Yes ☐ No ☐ NA ☒
7. Sample(s) in proper container(s)? Yes ☒ No ☐
8. Sufficient sample volume for indicated test(s)? Yes ☒ No ☐
9. Are samples (except VOA and ONG) properly preserved? Yes ☒ No ☐
10. Was preservative added to bottles? Yes ☒ No ☐ NA ☐
11. Is the headspace in the VOA vials less than 1/4 inch or 6 mm? Yes ☐ No ☐ HNO3 pH<2
No VOA Vials ☒
12. Were any sample containers received broken? Yes ☐ No ☒
13. Does paperwork match bottle labels? Yes ☒ No ☐
(Note discrepancies on chain of custody)
14. Are matrices correctly identified on Chain of Custody? Yes ☒ No ☐
15. Is it clear what analyses were requested? Yes ☒ No ☐
16. Were all holding times able to be met? Yes ☒ No ☐
(If no, notify customer for authorization.)

Special Handling (if applicable)

17. Was client notified of all discrepancies with this order? Yes ☐ No ☐ NA ☒

Person Notified: Date:
By Whom: Via: ☐ eMail ☐ Phone ☐ Fax ☐ In Person
Regarding:
Client Instructions:

18. Additional remarks:

Cooler Information

Cooler No	Temp °C	Condition	Seal Intact	Seal No	Seal Date	Signed By
-----------	---------	-----------	-------------	---------	-----------	-----------



Environmental Testing Laboratory
245 South Grape Street * Medford, OR 97501
(541) 770-5678 fax (541) 770-2901

Chain of Custody Record

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Section A

Required Client Information

Company:	MSD 549C
Address:	815 South Oakdale Avenue Medford, OR 97501
Email:	ron.havnear@medford.k12.or.us
Phone:	541-840-4315 Fax:
Collected By (Print):	
Collected By (Sign):	
Email Report ☐ Yes ☐ No	Mail Report ☐ Yes ☐ No
Fax Report ☐ Yes ☐ No	

Section B

Required Project Information

Project Name:	2020 Lead Testing
Project Number:	18-06 Hedrick
Report	ron.havnear@medford.k12.or.us
Copy T andy.chasteen@medford.k12.or.us	

Section C

Invoice Information

Attention:	Accounting
Company Name:	Medford School District
Address:	815 South Oakdale Avenue Medford, OR 97501
P.O. #	61172

Section D

Rush Status (Subject to Scheduling)

Standard 10-14 Days	☐
5 Business Days (50% surcharge)	☐
3 Business Days (75% surcharge)	☐
24 - 48 hours (100% surcharge)	☐
Other	☐

Authorized ☐ Yes ☐ No

Analysis Requested

3/14/20

Section E

Sample Information

Sample ID	Bottle	Matrix*	Date Collected	Time Collect	No. of Containers
Weight Room (Outside South Entrance) - Drinking Fountain		DW	3/18/2020	7:57	1
Weight Room (Outside South Entrance) Unisex Restroom - Si		DW	3/18/2020	8:00	1
Weight Room (Outside South Entrance) Unisex Restroom - Si		DW	3/18/2020	8:00	1
Hose Bib Supplying Water Horse		DW	3/18/2020	8:02	1
Boy's Locker Room - Sink (Left - Locker Area)		DW	3/18/2020	8:17	1
Boy's Locker Room - Sink (Right - Locker Area)		DW	3/18/2020	8:17	1
Boy's Locker Room - Sink (Urinal Area)		DW	3/18/2020	8:15	1
Boy's Locker Room Coach - Sink		DW	3/18/2020	8:13	1
Boy's Locker Room Coach Restroom - Sink		DW	3/18/2020	8:13	1
Girl's Locker Room - Drinking Fountain (Left)		DW	3/18/2020	8:03	1
Girl's Locker Room - Drinking Fountain (Right)		DW	3/18/2020	8:05	1
Girl's Locker Room - Sink (Left - Locker Area)		DW	3/18/2020	8:05	1
Girl's Locker Room - Sink (Right - Locker Area)		DW	3/18/2020	8:06	1
Girl's Locker Room - Sink (Urinal Area - Left)		DW	3/18/2020	8:09	1
Girl's Locker Room - Sink (Urinal Area - Center)		DW	3/18/2020	8:09	1
Girl's Locker Room - Sink (Urinal Area - Right)		DW	3/18/2020	8:09	1
Girl's Locker Room Coach - Sink		DW	3/18/2020	8:10	1

NRC Workorder # 20030680

Remarks/Field Data

NRC Sample # (Lab Use Only)

01A
02A
03A
04A
05A
06A
07A
08A
09A
10A
11A
12A
13A
14A
15A
16A
17A



**RESEARCH
CORPORATION**

Environmental Testing Laboratory
South Grape Street * Medford, OR 97504
(541) 770-5678 fax (541) 770-2901

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Section A

Section A
Required Client Information

Company:	MSD 549C			
Address:	815 South Oakdale Avenue			
	Medford, OR 97501			
Email:	<u>ron.havnear@medford.k12.or.us</u>			
Phone:	541-840-4315	Fax:		
Collected By (Print):				
Collected By (Sign):				
Email Report	___ Yes ___ No	Mail Report	___ Yes ___ No	
Fax Report	___ Yes ___ No			

Section B

Required Project Information

Project Name:	2020 Lead Testing	Attention: Accounting
Project Number:	18-06 Hedrick	Company Name: Medford School District
Report	ron.havnear@medford.k12.or.us	Address: 815 South Oakdale Avenue
Copy To	andy.chasteen@medford.k12.or.us	Medford, OR 97501
		P.O. # 61172

Section C

Invoice Information

Attention: Accounting	Standard 10-14 Days
Company Name: Medford School District	5 Business Days (50% surcharge)
Address: 815 South Oakdale Avenue	3 Business Days (75% surcharge)
Medford, OR 97501	24 - 48 hours (100% surcharge)
P.O. # 61172	Other

Section D

Section D
Rush Status (Subject to Scheduling)

Standard 10-14 Days
5 Business Days (50% surcharge)
3 Business Days (75% surcharge)
24 - 48 hours (100% surcharge)
Other

Authorized _____ Yes _____ No _____

Section E

Sample Information

Sample ID	Bottle	Matrix*	Date Collected	Time Collect
Next To Room 117 Men's Restroom - Sink (Left)	57930	DW	3/18/2020	7:53
Next To Room 117 Men's Restroom - Sink (Center)	57936	DW	3/18/2020	7:53
Next To Room 117 Men's Restroom - Sink (Right)	57915	DW	3/18/2020	7:55
Next To Room 117 Women's Restroom - Sink (Left)	57899	DW	3/18/2020	8:02
Next To Room 117 Women's Restroom - Sink (Center)	57902	DW	3/18/2020	8:03
Next To Room 117 Women's Restroom - Sink (Right)	57897	DW	3/18/2020	8:03
North East Gym Entrance Unisex Restroom - Sink	57903	DW	3/18/2020	8:06
North East Gym Entrance - Drinking Fountain (Upper)	57931	DW	3/18/2020	8:07
North East Gym Entrance - Drinking Fountain (Lower)	57633	DW	3/18/2020	8:08
Inside Gym North West Corner - Drinking Fountain	57913	DW	3/18/2020	8:13
Inside Gym South West Corner - Drinking Fountain	57900	DW	3/18/2020	8:18
Fitness Room (108) - Drinking Fountain	57926	DW	3/18/2020	8:19
Room 109 (Band Room) - Drinking Fountain	914	DW	3/18/2020	8:24
Room 109 (Band Room) - Sink	875	DW	3/18/2020	8:25
Room 107 - Drinking Fountain	896	DW	3/18/2020	8:28
Room 106 - Drinking Fountain (West Wall)	904	DW	3/18/2020	8:31
Room 106 - Sink (West Wall)	890	DW	3/18/2020	8:35
Room 106 - Sink (South Wall)	632	DW	3/18/2020	8:36
Room 102 - Drinking Fountain	873	DW	3/18/2020	8:41
Room 102 - Sink	891	DW	3/18/2020	8:39
Room 103 - Drinking Fountain	888	DW	3/18/2020	8:44
Room 103 - Sink	636	DW	3/18/2020	8:45
Room 102A SINK	916		3/18/2020	8:43

3/14/20

Analysis Requested

[illegible]



Environmental Testing Laboratory
245 South Grape Street * Medford, OR 97501
(541) 770-5678 fax (541) 770-2901

Chain of Custody Record

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

24

Page 1 of 3

Section A Required Client Information		Section B Required Project Information		Section C Invoice Information		Section D Rush Status (Subject to Scheduling)	
Company:	MSD 549C	Project Name:	2020 Lead Testing	Attention:	Accounting	Standard 10-14 Days	
Address:	815 South Oakdale Avenue Medford, OR 97501	Project Number:	18-06 Hedrick	Company Name	Medford School District	5 Business Days (50% surcharge)	
Email:	ron.havniear@medford.k12.or.us	Report	ron.havniear@medford.k12.or.us	Address:	815 South Oakdale Avenue Medford, OR 97501	3 Business Days (75% surcharge)	
Phone:	541-840-4315 Fax:	Copy	T andy.chasteen@medford.k12.or.us	P.O. #	61172	24 - 48 hours (100% surcharge)	
Collected By (Print):	Roger Moulard	Authorized Yes No					
Collected By (Sign):							
Email Report Yes No	No Mail Report Yes No						
Fax Report Yes No							

Section E Sample Information				Analysis Requested		NRC Workorder # 20030680	
Sample ID	Bottle	Matrix*	Date Collected	Time Collected	Remarks/Field Data	NRC Sample # (Lab Use Only)	
Room 216 - Drinking Fountain		DW	3/18/2020	7:56		414	
Room 216 - Sink		DW	3/18/2020	7:56		424	
Room 215 - Drinking Fountain		DW	3/18/2020	7:59		434	
Room 215 - Sink		DW	3/18/2020	7:59		444	
Room 206 A - Sink (Near Washer/Dryer)		DW	3/18/2020	8:05		454	
Room 206 (Culinary) - Sink (North Wall - Left)		DW	3/18/2020	8:05		464	
Room 206 (Culinary) - Sink (North Wall - Center)		DW	3/18/2020	8:05		474	
Room 206 (Culinary) - Sink (North Wall - Right)		DW	3/18/2020	8:05		484	
Room 206 (Culinary) - Sink (South Wall - Left)		DW	3/18/2020	8:06		494	
Room 206 (Culinary) - Sink (South Wall - Center)		DW	3/18/2020	8:06		504	
Room 206 (Culinary) - Sink (South Wall - Right)		DW	3/18/2020	8:05		514	
Room 204 - Drinking Fountain		DW	3/18/2020	8:15		524	
Room 204 - Sink		DW	3/18/2020	8:15		534	
Room 202 - Drinking Fountain		DW	3/18/2020	8:16		544	
Room 202 - Sink		DW	3/18/2020	8:16		554	
Room 303 - Drinking Fountain		DW	3/18/2020	8:19		564	
Room 303 - Sink		DW	3/18/2020	8:19		574	
Across From Room 303 - Drinking Fountain		DW	3/18/2020	8:21		584	
Across From Room 303 Men's Restroom - Sink (Left)		DW	3/18/2020	8:20		594	
Across From Room 303 Men's Restroom - Sink (Right)		DW	3/18/2020	8:20		604	
Room In-between 304/306 Storage Room - Sink		DW	3/18/2020	8:25		614	
Across From Room 306 Women's Restroom - Sink (Left)		DW	3/18/2020	8:26		624	
Across From Room 306 Women's Restroom - Sink (Center)		DW	3/18/2020	8:26		634	
Across From Room 306 Women's Restroom - Sink (Right)		DW	3/18/2020	8:26		644	



Chain of Custody Record

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Section A Required Client Information		Section B Required Project Information		Section C Invoice Information		Section D Rush Status (Subject to Scheduling)																									
Company:	MSD 549C	Project Name:	2020 Lead Testing	Attention:	Accounting	☐ Standard 10-14 Days ☐ 5 Business Days (50% surcharge) ☐ 3 Business Days (75% surcharge) ☐ 24 - 48 hours (100% surcharge) ☐ Other _____																									
Address:	815 South Oakdale Avenue Medford, OR 97501	Project Number:	18-06 Hedrick	Company Name: Medford School District																											
Email:	ron.havniar@medford.k12.or.us	Report	ron.havniar@medford.k12.or.us	Address: 815 South Oakdale Avenue																											
Phone:	541-840-4315 Fax:	Copy T andy.chasteen@medford.k12.or.us		Medford, OR 97501																											
Collected By (Print):	Maxton Taylor	P.O. #	61172			Authorized ☐ Yes ☐ No																									
Collected By (Sign):	<i>Maxton Taylor</i>	<table border="1"> <tr> <th colspan="6">Analysis Requested</th> </tr> <tr> <td></td><td></td><td></td><td></td><td></td><td></td> </tr> <tr> <td></td><td></td><td></td><td></td><td></td><td></td> </tr> <tr> <td></td><td></td><td></td><td></td><td></td><td></td> </tr> </table>						Analysis Requested																							
Analysis Requested																															
Email Report	☐ Yes ☐ No Mail Report ☒ Yes ☐ No																														
Fax Report	☐ Yes ☐ No																														

Section E Sample Information				No. of Conts		NRC Workorder # (Lab Use Only)		NRC Sample # (Lab Use Only)	
Sample ID	Bottle	Matrix*	Date Collected	Time Collect			Remarks/Field Data		
Health Room - Sink		DW	3/18/2020	8:02 AM					654
Health Room Unisex Restroom - Sink		DW	3/18/2020	8:03 AM					664
Main Office - Kitchenette		DW	3/18/2020	8:05 AM					674
By The Office - Drinking Fountain (Upper)		DW	3/18/2020	8:07 AM					684
By The Office - Drinking Fountain (Lower)		DW	3/18/2020	8:08 AM					694
Outside Office Staff Men's Restroom - Sink (Left)		DW	3/18/2020	8:11 AM					704
Outside Office Staff Men's Restroom - Sink (Right)		DW	3/18/2020	8:12 AM					714
Outside Office Staff Women's Restroom - Sink (Left)		DW	3/18/2020	8:13 AM					724
Outside Office Staff Women's Restroom - Sink (Right)		DW	3/18/2020	8:14 AM					734
Room 309 - Drinking Fountain		DW	3/18/2020	8:16 AM					744
Room 309 - Sink		DW	3/18/2020	8:17 AM					754
Room 310 - Drinking Fountain		DW	3/18/2020	8:18 AM					764
Room 310 - Sink		DW	3/18/2020	8:19 AM					774
Room 311 - Drinking Fountain		DW	3/18/2020	8:20 AM					784
Room 311 - Sink		DW	3/18/2020	8:21 AM					794
Room 314 - Drinking Fountain		DW	3/18/2020	8:22 AM					804
Room 314 - Sink		DW	3/18/2020	8:23 AM					814
Room 314 Unisex Restroom - Sink		DW	3/18/2020	8:24 AM					824
Room 315 - Drinking Fountain		DW	3/18/2020	8:26 AM					834
Room 315 - Sink		DW	3/18/2020	8:27 AM					844
Room 316 Staff Work Room - Drinking Fountain (North Wall)		DW	3/18/2020	8:29 AM					854
Room 316 Staff Work Room - Sink (North Wall)		DW	3/18/2020	8:30 AM					864
Room 316 Staff Work Room - Drinking Fountain (West Wall)		DW	3/18/2020	8:31 AM					874
Room 316 Staff Work Room - Sink (West Wall)		DW	3/18/2020	3:32 AM					884



Chain of Custody Record

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Page 1 of 3

Environmental Testing Laboratory
245 South Grape Street * Medford, OR 97501
(541) 770-5678 fax (541) 770-2901

Section A		Section B		Section C		Section D	
Required Client Information		Required Project Information		Invoice Information		Rush Status (Subject to Scheduling)	
Company:	MSD 549C	Project Name:	2020 Lead Testing	Attention:	Accounting	Standard 10-14 Days	
Address:	815 South Oakdale Avenue	Project Number:	18-06 Hedrick	Company Name:	Medford School District	5 Business Days (50% surcharge)	
	Medford, OR 97501	Report	ron.havnier@medford.k12.or.us	Address:	815 South Oakdale Avenue	3 Business Days (75% surcharge)	
Email:	ron.havnier@medford.k12.or.us	Copy T	andy.chasteen@medford.k12.or.us		Medford, OR 97501	24 - 48 hours (100% surcharge)	
Phone:	541-840-4315			P.O. #	61172	Other _____	
Fax:							
Collected By (Print):		Authorized _____ Yes _____ No _____					

[illegible]



This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Page 1 of 3

Environmental Testing Laboratory
245 South Grape Street * Medford, OR 97501
(541) 770-5678 fax (541) 770-2901

Section A Required Client Information				Section B Required Project Information				Section C Invoice Information				Section D Rush Status (Subject to Scheduling)			
Company:	MSD 549C			Project Name:	2020 Lead Testing			Attention:	Accounting			Standard 10-14 Days			
Address:	815 South Oakdale Avenue Medford, OR 97501			Project Number:	18-06 Hedrick			Company Name:	Medford School District			5 Business Days (50% surcharge)			
Email:	ron.havnear@medford.k12.or.us			Report To:	ron.havnear@medford.k12.or.us			Address:	815 South Oakdale Avenue Medford, OR 97501			3 Business Days (75% surcharge)			
Phone:	541-840-4315 Fax:			Copy To:	andy.chasteen@medford.k12.or.us								24 - 48 hours (100% surcharge)		
Collected By (Print): Gary Spence								P.O. # 61172				Other			
Collected By (Sign): Gary Spence												Authorized Yes No			
Email Report Yes No Mail Report Yes No															
Fax Report Yes No															
Section E Sample Information												NRC Workorder # 20030680		NRC Sample # (Lab Use Only)	
Sample ID				B#		Matrix		Date Collected		Time Collected		Remarks/Field Data		NRC Sample # (Lab Use Only)	
Media Center Work Room - Drinking Fountain						DW		3/18/2020		7:56 AM				121 A	
Media Center Work Room - Sink						DW		3/18/2020		7:57				122 A	
Media Center Office - Drinking Fountain						DW		3/18/2020		8:00				123 A	
Media Center Office - Sink						DW		3/18/2020		8:01				124 A	
Room 401 - Drinking Fountain						DW		3/18/2020		8:04				125 A	
Room 401 - Sink						DW		3/18/2020		8:05				126 A	
Room 402 - Drinking Fountain						DW		3/18/2020		8:07				127 A	
Room 402 - Sink						DW		3/18/2020		8:08				128 A	
Room 404 - Drinking Fountain						DW		3/18/2020		8:12				129 A	
Room 404 - Sink						DW		3/18/2020		8:13				130 A	
In-between Room 408/404 Men's Restroom - Sink (Left)						DW		3/18/2020		8:15				131 A	
In-between Room 408/404 Men's Restroom - Sink (Center)						DW		3/18/2020		8:16				132 A	
In-between Room 408/404 Men's Restroom - Sink (Right)						DW		3/18/2020		8:17				133 A	
In-between Room 408/404 Women's Restroom - Sink (Left)						DW		3/18/2020		8:19				134 A	
In-between Room 408/404 Women's Restroom - Sink (Center)						DW		3/18/2020		8:19				135 A	
In-between Room 408/404 Women's Restroom - Sink (Right)						DW		3/18/2020		8:20				136 A	
Room 408 - Drinking Fountain						DW		3/18/2020		8:23				137 A	
Room 408 - Sink						DW		3/18/2020		8:24				138 A	
Room 411 - Drinking Fountain						DW		3/18/2020		8:25				139 A	
Room 411 - Sink						DW		3/18/2020		8:26				140 A	
Room 410 - Drinking Fountain						DW		3/18/2020		8:28				141 A	
Room 410 - Sink						DW		3/18/2020		8:29				142 A	
Room 409 - Drinking Fountain (East Wall)						DW		3/18/2020		8:34				143 A	
Storage Room In-between 409/403 - Sink						DW		3/18/2020		8:35				144 A	



Chain of Custody Record

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Section D

Section D
Rush Status (Subject to Scheduling)

3/14/20

02/11/15

Sample ID	Bottle Matrix*	Date Collected	Time Collect	No of							Remarks/Field Data	NRC Sample # (Lab Use Only)
Room 119 (Store) - Sink (Utility)	58079	DW	3/18/2020	7:58 AM	1							145A
Room 122 - Sink (South Wall - Left)	57884	DW	3/18/2020	8:16 AM	1							146A
Room 122 - Sink (South Wall - Center)	58366	DW	3/18/2020	8:16	1							147A
Room 122 - Sink (South Wall - Right)	58022	DW	3/18/2020	8:17	1							148A
Room 122 - Sink (East Wall - Back Corner)	52403	DW	3/18/2020	8:17	1							149A
Room 125 - Sink (North Wall - Left)		DW	3/18/2020	8:40 AM	1							150A
Room 125 - Sink (North Wall - Right)		DW	3/18/2020	8:40	1							151A
Room 125 - Sink (South Wall - Left)		DW	3/18/2020	8:40	1							152A
Room 125 - Sink (South Wall - Right)		DW	3/18/2020	8:40	1							153A
Custodial Office Unisex Restroom - Sink		DW	3/18/2020	8:42 AM	1							154A
Room 121 - Drinking Fountain	8131	DW	3/18/2020	8:51	1							155A
Room 121 - Sink	8131	DW	3/18/2020	8:51	1							156A
Room 124 (Staff Break Room) Men's Restroom - Sink (Left)		DW	3/18/2020	8:54	1							157A
Room 124 (Staff Break Room) Men's Restroom - Sink (Right)		DW	3/18/2020	8:55	1							158A
Room 124 (Staff Break Room) Women's Restroom - Sink (L)		DW	3/18/2020	8:55	1							159A
Room 124 (Staff Break Room) Women's Restroom - Sink (R)		DW	3/18/2020	8:55	1							160A
Room 124 (Staff Break Room) - Sink		DW	3/18/2020	8:53	1							161A
Kitchen Hand Wash - Sink (Near Serving Line)	54358	DW	3/18/2020	8:26 AM	1							162A
Kitchen Hand Wash - Sink (In Back Area That Serves Courtyard)	58073	DW	3/18/2020	8:27	1							163A
Kitchen Pre-Rinse/Dishwasher - Sink (Single)	52401	DW	3/18/2020	8:27	1							164A
Kitchen Pre-Rinse/Dishwasher - Sink (Double)	52400	DW	3/18/2020	8:28	1							165A
Kitchen Food Prep - Sink (Double)		DW	3/18/2020	8:29	1							166A
Room 120 - Drinking Fountain	58071	DW	3/18/2020	8:33 AM	1							167A
Room 120 - Sink	52404	DW	3/18/2020	8:05	1							168A

- hr/>
- B Analyte detected in the associated method blank.
 - BA BOD Alternative Calculation: The initial results performed by Standard Methods did not fall within parameters of the Standard Methods calculation. An alternate approved calculation was performed using the HACH method and the value reported is an estimated concentration.
 - C Sample(s) does not meet NELAP/ORELAP sample acceptance criteria. See Case Narrative.
 - C1 Sample(s) does not meet NELAP/ORELAP sample acceptance criteria for temperature.
 - CF Results confirmed by re-analysis.
 - CU Cleanup performed as specified by method.
 - D1 The diesel elution pattern for the sample is not typical.
 - D2 The sample appears to be a heavier hydrocarbon range than diesel.
 - D3 The sample appears to be a lighter hydrocarbon range than diesel.
 - D4 Detected hydrocarbons do not have pattern and range consistent with typical petroleum products and may be due to biogenic interference.
 - D5 Detected hydrocarbons in the diesel range appear to be weathered diesel.
 - E Estimated value.
 - ER Elevated reporting limit due to matrix. Report limits (MDLs, MRLs & PQLs) are adjusted based on variations in sample preparation amounts, analytical dilutions, and percent solids, where applicable.
 - FC Fecal Coliforms: Sample(s) received past 40 CFR Part 136 specified holding time. Results reported as estimated values.
 - G1 The gasoline elution pattern for the sample is not typical.
 - G2 The sample appears to be a heavier hydrocarbon range than gasoline.
 - G3 The sample appears to be a lighter hydrocarbon range than gasoline.
 - G4 Detected hydrocarbons in the gasoline range appear to be weathered gasoline.
 - HP Sample re-analysis performed outside of method specified holding time.
 - HR Sample received outside of method specified holding time.
 - HS Sample analyzed for volatile organics contained headspace.
 - HT ☐ At the client's request, the sample was analyzed outside of method specified holding time.
 - H Analysis performed outside of method specified holding time.
 - J Analyte detected below the Minimum Reporting Limit (MRL) and above the Method Detection Limit (MDL). The J flag result is an estimated value and the user should be aware that this data is of limited reliability.
 - L Dissolved metals were not filtered within 15 minutes of collection per 40 CFR Part 136.
 - MI Surrogate, Duplicate Sample (DUP) or Matrix Spikes recoveries are out of control limits due to matrix interference. Sample results may be biased.
 - N See Case Narrative on page 2 of report.
 - NLR No Legionella Recovered.
 - PLR Presence of Legionella Recovered.
 - Q Initial calibration verification (ICV), continuing calibration verification (CCV) or laboratory control sample (LCS) exceeded high recovery limits, but associated samples are non-detect and the sample results are not affected. Data meets EPA/NELAP requirements.
 - R Relative percent difference (RPD) is outside of the accepted recovery limits.
 - R1 Relative percent difference (RPD) is outside of the accepted recovery limits. However, analyses are not controlled on RPD values for sample concentrations that are less than the reporting limit.
 - R3 The relative percent difference (RPD) and/or percent recovery for the duplicate (DUP) or matrix spike (MS)/matrix spike duplicate (MSD) cannot be accurately calculated due to the concentration of analyte already present in the sample.
 - R4 Duplicate analysis failed due to result being at or near the method reporting limit.
 - S Surrogate and/or matrix spike recovery is outside of the accepted recovery limits. Sample results may be biased.
 - S1 Surrogate or matrix spike recovery is outside of control limits due to dilution necessary for analysis.
 - SC Sub-contracted to another laboratory for analysis.
 - SP Sample(s) were not collected per EPA Method 5035A protocols. The results are considered minimum values.
 - # Value exceeds regulatory level for TCLP contaminant.
 - X1 The motor oil elution pattern for the sample is not typical.
 - X2 The sample appears to be a heavier hydrocarbon range than motor oil.
 - X3 The sample appears to be a lighter hydrocarbon range than motor oil.
 - * Value exceeds Maximum Contaminant Level or is outside the acceptable range.