



NEILSON RESEARCH CORPORATION

Environmental Testing Laboratory

8/3/2016

Rick Rose
Medford School District
815 S Oakdale Ave
Medford, OR 97501

TEL: (541) 842-1138

FAX 541-842-1160

RE: 16-06 Hedrick Lead Study

Order No.: 1607890

Dear Rick Rose:

Neilson Research Corporation received 67 sample(s) on 7/20/2016 for the analyses presented in the following report.

The results relate only to the parameters tested or to the sample as received by the laboratory. This report shall not be reproduced except in full, without the written approval of Neilson Research Corporation. If you have any questions regarding these test results, please feel free to call.

Sincerely,
Neilson Research Corporation

Alec C Smith
Project Manager

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

CLIENT: Medford School District
Project: 16-06 Hedrick Lead Study
Lab Order: 1607890

Date: 03-Aug-16

CASE NARRATIVE

The analyses were performed according to the guidelines in the Neilson Research Corporation Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

Neilson Research Corporation certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: **1607890**
NRC Sample ID: **1607890-01A**
Collection Date: **7/20/2016 1:55:00 PM**
Received Date: **7/20/2016 3:42:00 PM**
Reported Date: **8/3/2016 7:32:39 AM**

Sample Information:

16-06 Hedrick Lead Study

Client Sample ID: Bottle #12975
Collectors Name: Gary Severe
Sample Location: Room 310 DF
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.00114		0.000103	mg/L	0.020 AL	7/26/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: **1607890**
NRC Sample ID: **1607890-02A**
Collection Date: **7/20/2016 1:56:00 PM**
Received Date: **7/20/2016 3:42:00 PM**
Reported Date: **8/3/2016 7:32:39 AM**

Sample Information:

16-06 Hedrick Lead Study

Client Sample ID: Bottle #12951
Collectors Name: Gary Severe
Sample Location: Room 311 DF
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.000736		0.000103	mg/L	0.020 AL	7/26/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: **1607890**
NRC Sample ID: **1607890-03A**
Collection Date: **7/20/2016 1:58:00 PM**
Received Date: **7/20/2016 3:42:00 PM**
Reported Date: **8/3/2016 7:32:39 AM**

Sample Information:

16-06 Hedrick Lead Study

Client Sample ID: Bottle #12918
Collectors Name: Gary Severe
Sample Location: Room 314 DF
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.000198		0.000103	mg/L	0.020 AL	7/26/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: **1607890**
NRC Sample ID: **1607890-04A**
Collection Date: **7/20/2016 1:59:00 PM**
Received Date: **7/20/2016 3:42:00 PM**
Reported Date: **8/3/2016 7:32:39 AM**

Sample Information:

16-06 Hedrick Lead Study

Client Sample ID: Bottle #12974
Collectors Name: Gary Severe
Sample Location: Room 315 DF
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.000587		0.000103	mg/L	0.020 AL	7/26/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: **1607890**
NRC Sample ID: **1607890-05A**
Collection Date: **7/20/2016 1:41:00 PM**
Received Date: **7/20/2016 3:42:00 PM**
Reported Date: **8/3/2016 7:32:39 AM**

Sample Information:

16-06 Hedrick Lead Study

Client Sample ID: Bottle #12966
Collectors Name: Gary Severe
Sample Location: Room 404 DF
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.000688		0.000103	mg/L	0.020 AL	7/26/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: **1607890**
NRC Sample ID: **1607890-06A**
Collection Date: **7/20/2016 1:42:00 PM**
Received Date: **7/20/2016 3:42:00 PM**
Reported Date: **8/3/2016 7:32:39 AM**

Sample Information:

16-06 Hedrick Lead Study

Client Sample ID: Bottle #12956
Collectors Name: Gary Severe
Sample Location: Room 408 DF
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.000957		0.000103	mg/L	0.020 AL	7/26/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: **1607890**
NRC Sample ID: **1607890-07A**
Collection Date: **7/20/2016 1:43:00 PM**
Received Date: **7/20/2016 3:42:00 PM**
Reported Date: **8/3/2016 7:32:39 AM**

Sample Information:

16-06 Hedrick Lead Study

Client Sample ID: Bottle #12961
Collectors Name: Gary Severe
Sample Location: Room 411 DF
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.000430		0.000103	mg/L	0.020 AL	7/26/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: **1607890**
NRC Sample ID: **1607890-08A**
Collection Date: **7/20/2016 1:45:00 PM**
Received Date: **7/20/2016 3:42:00 PM**
Reported Date: **8/3/2016 7:32:39 AM**

Sample Information:

16-06 Hedrick Lead Study

Client Sample ID: Bottle #12954
Collectors Name: Gary Severe
Sample Location: Room 410 DF
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.000771		0.000103	mg/L	0.020 AL	7/26/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: **1607890**
NRC Sample ID: **1607890-09A**
Collection Date: **7/20/2016 1:46:00 PM**
Received Date: **7/20/2016 3:42:00 PM**
Reported Date: **8/3/2016 7:32:39 AM**

Sample Information:

16-06 Hedrick Lead Study

Client Sample ID: Bottle #12963
Collectors Name: Gary Severe
Sample Location: Room 409 DF
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.00197		0.000103	mg/L	0.020 AL	7/26/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: **1607890**
NRC Sample ID: **1607890-10A**
Collection Date: **7/20/2016 1:48:00 PM**
Received Date: **7/20/2016 3:42:00 PM**
Reported Date: **8/3/2016 7:32:39 AM**

Sample Information:

16-06 Hedrick Lead Study

Client Sample ID: Bottle #12931
Collectors Name: Gary Severe
Sample Location: Room 204 DF
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.00125		0.000103	mg/L	0.020 AL	7/26/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: **1607890**
NRC Sample ID: **1607890-11A**
Collection Date: **7/20/2016 1:50:00 PM**
Received Date: **7/20/2016 3:42:00 PM**
Reported Date: **8/3/2016 7:32:39 AM**

Sample Information:

16-06 Hedrick Lead Study

Client Sample ID: Bottle #12960
Collectors Name: Gary Severe
Sample Location: Room 202 DF
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.00109		0.000103	mg/L	0.020 AL	7/26/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: **1607890**
NRC Sample ID: **1607890-12A**
Collection Date: **7/20/2016 1:51:00 PM**
Received Date: **7/20/2016 3:42:00 PM**
Reported Date: **8/3/2016 7:32:39 AM**

Sample Information:

16-06 Hedrick Lead Study

Client Sample ID: Bottle #12962
Collectors Name: Gary Severe
Sample Location: Room 303 DF
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.000789		0.000103	mg/L	0.020 AL	7/26/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: **1607890**
NRC Sample ID: **1607890-13A**
Collection Date: **7/20/2016 1:52:00 PM**
Received Date: **7/20/2016 3:42:00 PM**
Reported Date: **8/3/2016 7:32:39 AM**

Sample Information:

16-06 Hedrick Lead Study

Client Sample ID: Bottle #12926
Collectors Name: Gary Severe
Sample Location: Across from Rm 303 DF
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.000426		0.000103	mg/L	0.020 AL	7/26/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: **1607890**
NRC Sample ID: **1607890-14A**
Collection Date: **7/20/2016 1:54:00 PM**
Received Date: **7/20/2016 3:42:00 PM**
Reported Date: **8/3/2016 7:32:39 AM**

Sample Information:

16-06 Hedrick Lead Study

Client Sample ID: Bottle #12941
Collectors Name: Gary Severe
Sample Location: Room 309 DF
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.00217		0.000103	mg/L	0.020 AL	7/26/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR0028

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: **1607890**
NRC Sample ID: **1607890-15A**
Collection Date: **7/20/2016 2:36:00 PM**
Received Date: **7/20/2016 3:42:00 PM**
Reported Date: **8/3/2016 7:32:39 AM**

Sample Information:

16-06 Hedrick Lead Study

Client Sample ID: Bottle #12977
Collectors Name: John Jessen
Sample Location: Rm 316 DF N Wall
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.00152		0.000103	mg/L	0.020 AL	7/26/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: **1607890**
NRC Sample ID: **1607890-16A**
Collection Date: **7/20/2016 2:35:00 PM**
Received Date: **7/20/2016 3:42:00 PM**
Reported Date: **8/3/2016 7:32:39 AM**

Sample Information:

16-06 Hedrick Lead Study

Client Sample ID: Bottle #12930
Collectors Name: John Jessen
Sample Location: Room 316 Sink N Wall
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.00411		0.000103	mg/L	0.020 AL	7/26/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: **1607890**
NRC Sample ID: **1607890-17A**
Collection Date: **7/20/2016 2:34:00 PM**
Received Date: **7/20/2016 3:42:00 PM**
Reported Date: **8/3/2016 7:32:39 AM**

Sample Information:

16-06 Hedrick Lead Study

Client Sample ID: Bottle #12967
Collectors Name: John Jessen
Sample Location: Room 316 DF W Wall
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.000490		0.000103	mg/L	0.020 AL	7/26/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: **1607890**
NRC Sample ID: **1607890-18A**
Collection Date: **7/20/2016 2:39:00 PM**
Received Date: **7/20/2016 3:42:00 PM**
Reported Date: **8/3/2016 7:32:39 AM**

Sample Information:

16-06 Hedrick Lead Study

Client Sample ID: Bottle #12903
Collectors Name: John Jessen
Sample Location: Room 317 DF
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.000590		0.000103	mg/L	0.020 AL	7/28/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: **1607890**
NRC Sample ID: **1607890-19A**
Collection Date: **7/20/2016 2:44:00 PM**
Received Date: **7/20/2016 3:42:00 PM**
Reported Date: **8/3/2016 7:32:39 AM**

Sample Information:

16-06 Hedrick Lead Study

Client Sample ID: Bottle #12965
Collectors Name: John Jessen
Sample Location: Room 119 Utility Sink
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.00560		0.000103	mg/L	0.020 AL	7/28/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: **1607890**
NRC Sample ID: **1607890-20A**
Collection Date: **7/20/2016 2:48:00 PM**
Received Date: **7/20/2016 3:42:00 PM**
Reported Date: **8/3/2016 7:32:39 AM**

Sample Information:

16-06 Hedrick Lead Study

Client Sample ID: Bottle #12955
Collectors Name: John Jessen
Sample Location: Room 121 DF
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.000383		0.000103	mg/L	0.020 AL	7/28/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: **1607890**
NRC Sample ID: **1607890-21A**
Collection Date: **7/20/2016 2:49:00 PM**
Received Date: **7/20/2016 3:42:00 PM**
Reported Date: **8/3/2016 7:32:39 AM**

Sample Information:

16-06 Hedrick Lead Study

Client Sample ID: Bottle #12904
Collectors Name: John Jessen
Sample Location: Room 124 Sink
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.00130		0.000103	mg/L	0.020 AL	7/28/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR0028

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: **1607890**
NRC Sample ID: **1607890-22A**
Collection Date: **7/20/2016 3:08:00 PM**
Received Date: **7/20/2016 3:42:00 PM**
Reported Date: **8/3/2016 7:32:39 AM**

Sample Information:

16-06 Hedrick Lead Study

Client Sample ID: Bottle #12957
Collectors Name: John Jessen
Sample Location: Kitchen Food Prep Sink
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.000876		0.000103	mg/L	0.020 AL	7/28/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR0028

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: **1607890**
NRC Sample ID: **1607890-23A**
Collection Date: **7/20/2016 2:46:00 PM**
Received Date: **7/20/2016 3:42:00 PM**
Reported Date: **8/3/2016 7:32:39 AM**

Sample Information:

16-06 Hedrick Lead Study

Client Sample ID: Bottle #12901
Collectors Name: John Jessen
Sample Location: Room 120 DF
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.000805		0.000103	mg/L	0.020 AL	7/28/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: **1607890**
NRC Sample ID: **1607890-24A**
Collection Date: **7/20/2016 2:44:00 PM**
Received Date: **7/20/2016 3:42:00 PM**
Reported Date: **8/3/2016 7:32:39 AM**

Sample Information:

16-06 Hedrick Lead Study

Client Sample ID: Bottle #12927
Collectors Name: John Jessen
Sample Location: Room 118 Ice Machine
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	ND		0.000103	mg/L	0.020 AL	7/28/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: **1607890**
NRC Sample ID: **1607890-25A**
Collection Date: **7/20/2016 2:46:00 PM**
Received Date: **7/20/2016 3:42:00 PM**
Reported Date: **8/3/2016 7:32:39 AM**

Sample Information:

16-06 Hedrick Lead Study

Client Sample ID: Bottle #12890
Collectors Name: John Jessen
Sample Location: E Side Gym Near H8 DF
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.000447		0.000103	mg/L	0.020 AL	7/28/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: **1607890**
NRC Sample ID: **1607890-26A**
Collection Date: **7/20/2016 2:49:00 PM**
Received Date: **7/20/2016 3:42:00 PM**
Reported Date: **8/3/2016 7:32:39 AM**

Sample Information:

16-06 Hedrick Lead Study

Client Sample ID: Bottle #12964
Collectors Name: John Jessen
Sample Location: NE Gym Entrance DF Upper
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.000635		0.000103	mg/L	0.020 AL	7/28/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: **1607890**
NRC Sample ID: **1607890-27A**
Collection Date: **7/20/2016 2:48:00 PM**
Received Date: **7/20/2016 3:42:00 PM**
Reported Date: **8/3/2016 7:32:39 AM**

Sample Information:

16-06 Hedrick Lead Study

Client Sample ID: Bottle #12973
Collectors Name: John Jessen
Sample Location: NE Gym Entrance DF Lower
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.000291		0.000103	mg/L	0.020 AL	7/28/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: **1607890**
NRC Sample ID: **1607890-28A**
Collection Date: **7/20/2016 2:54:00 PM**
Received Date: **7/20/2016 3:42:00 PM**
Reported Date: **8/3/2016 7:32:39 AM**

Sample Information:

16-06 Hedrick Lead Study

Client Sample ID: Bottle #12970
Collectors Name: John Jessen
Sample Location: Weight Rm SE Ent DF
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.00440		0.000103	mg/L	0.020 AL	7/28/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR0028

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: **1607890**
NRC Sample ID: **1607890-29A**
Collection Date: **7/20/2016 2:57:00 PM**
Received Date: **7/20/2016 3:42:00 PM**
Reported Date: **8/3/2016 7:32:39 AM**

Sample Information:

16-06 Hedrick Lead Study

Client Sample ID: Bottle #12902
Collectors Name: John Jessen
Sample Location: HB Feeding Water Horse
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.00282		0.000103	mg/L	0.020 AL	7/28/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: **1607890**
NRC Sample ID: **1607890-30A**
Collection Date: **7/20/2016 1:52:00 PM**
Received Date: **7/20/2016 3:42:00 PM**
Reported Date: **8/3/2016 7:32:39 AM**

Sample Information:

16-06 Hedrick Lead Study

Client Sample ID: Bottle #12866
Collectors Name: Bill Bartlett
Sample Location: Room 331 DF
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.000218		0.000103	mg/L	0.020 AL	7/28/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR0028

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: **1607890**
NRC Sample ID: **1607890-31A**
Collection Date: **7/20/2016 1:54:00 PM**
Received Date: **7/20/2016 3:42:00 PM**
Reported Date: **8/3/2016 7:32:39 AM**

Sample Information:

16-06 Hedrick Lead Study

Client Sample ID: Bottle #12910
Collectors Name: Bill Bartlett
Sample Location: Hallway between 331-334 DF
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.000544		0.000103	mg/L	0.020 AL	7/28/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: **1607890**
NRC Sample ID: **1607890-32A**
Collection Date: **7/20/2016 1:57:00 PM**
Received Date: **7/20/2016 3:42:00 PM**
Reported Date: **8/3/2016 7:32:39 AM**

Sample Information:

16-06 Hedrick Lead Study

Client Sample ID: Bottle #12942
Collectors Name: Bill Bartlett
Sample Location: Room 334 DF
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.000357		0.000103	mg/L	0.020 AL	7/28/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR0028

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: **1607890**
NRC Sample ID: **1607890-33A**
Collection Date: **7/20/2016 1:58:00 PM**
Received Date: **7/20/2016 3:42:00 PM**
Reported Date: **8/3/2016 7:32:39 AM**

Sample Information:

16-06 Hedrick Lead Study

Client Sample ID: Bottle #12892
Collectors Name: Bill Bartlett
Sample Location: Room 336 DF
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.000284		0.000103	mg/L	0.020 AL	7/28/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: **1607890**
NRC Sample ID: **1607890-34A**
Collection Date: **7/20/2016 2:00:00 PM**
Received Date: **7/20/2016 3:42:00 PM**
Reported Date: **8/3/2016 7:32:39 AM**

Sample Information:

16-06 Hedrick Lead Study

Client Sample ID: Bottle #12881
Collectors Name: Bill Bartlett
Sample Location: Room 338 DF
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.000313		0.000103	mg/L	0.020 AL	7/28/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: **1607890**
NRC Sample ID: **1607890-35A**
Collection Date: **7/20/2016 1:33:00 PM**
Received Date: **7/20/2016 3:42:00 PM**
Reported Date: **8/3/2016 7:32:39 AM**

Sample Information:

16-06 Hedrick Lead Study

Client Sample ID: Bottle #12944
Collectors Name: Larry Anderson
Sample Location: Wrestling Rm DF
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.00164		0.000103	mg/L	0.020 AL	7/28/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: **1607890**
NRC Sample ID: **1607890-36A**
Collection Date: **7/20/2016 1:39:00 PM**
Received Date: **7/20/2016 3:42:00 PM**
Reported Date: **8/3/2016 7:32:39 AM**

Sample Information:

16-06 Hedrick Lead Study

Client Sample ID: Bottle #12952
Collectors Name: Larry Anderson
Sample Location: Room 216 DF
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.000673		0.000103	mg/L	0.020 AL	7/28/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: **1607890**
NRC Sample ID: **1607890-37A**
Collection Date: **7/20/2016 1:42:00 PM**
Received Date: **7/20/2016 3:42:00 PM**
Reported Date: **8/3/2016 7:32:39 AM**

Sample Information:

16-06 Hedrick Lead Study

Client Sample ID: Bottle #12919
Collectors Name: Larry Anderson
Sample Location: Room 215 DF
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.000225		0.000103	mg/L	0.020 AL	7/28/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: **1607890**
NRC Sample ID: **1607890-38A**
Collection Date: **7/20/2016 1:45:00 PM**
Received Date: **7/20/2016 3:42:00 PM**
Reported Date: **8/3/2016 7:32:39 AM**

Sample Information:

16-06 Hedrick Lead Study

Client Sample ID: Bottle #12872
Collectors Name: Larry Anderson
Sample Location: Media Cntr Wrk Rm DF
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.000227		0.000103	mg/L	0.020 AL	7/28/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: **1607890**
NRC Sample ID: **1607890-39A**
Collection Date: **7/20/2016 1:48:00 PM**
Received Date: **7/20/2016 3:42:00 PM**
Reported Date: **8/3/2016 7:32:39 AM**

Sample Information:

16-06 Hedrick Lead Study

Client Sample ID: Bottle #12906
Collectors Name: Larry Anderson
Sample Location: Media Center Office DF
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.000254		0.000103	mg/L	0.020 AL	7/28/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: **1607890**
NRC Sample ID: **1607890-40A**
Collection Date: **7/20/2016 1:52:00 PM**
Received Date: **7/20/2016 3:42:00 PM**
Reported Date: **8/3/2016 7:32:39 AM**

Sample Information:

16-06 Hedrick Lead Study

Client Sample ID: Bottle #12915
Collectors Name: Larry Anderson
Sample Location: Rm 206 Sink N Wall Left
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.00178		0.000103	mg/L	0.020 AL	7/28/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: **1607890**
NRC Sample ID: **1607890-41A**
Collection Date: **7/20/2016 1:53:00 PM**
Received Date: **7/20/2016 3:42:00 PM**
Reported Date: **8/3/2016 7:32:39 AM**

Sample Information:

16-06 Hedrick Lead Study

Client Sample ID: Bottle #12871
Collectors Name: Larry Anderson
Sample Location: Rm 206 Sink N Wall Center
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.00196		0.000103	mg/L	0.020 AL	7/28/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: **1607890**
NRC Sample ID: **1607890-42A**
Collection Date: **7/20/2016 1:55:00 PM**
Received Date: **7/20/2016 3:42:00 PM**
Reported Date: **8/3/2016 7:32:39 AM**

Sample Information:

16-06 Hedrick Lead Study

Client Sample ID: Bottle #12897
Collectors Name: Larry Anderson
Sample Location: Rm 206 Sink N Wall Right
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.00190		0.000103	mg/L	0.020 AL	7/28/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: **1607890**
NRC Sample ID: **1607890-43A**
Collection Date: **7/20/2016 1:56:00 PM**
Received Date: **7/20/2016 3:42:00 PM**
Reported Date: **8/3/2016 7:32:39 AM**

Sample Information:

16-06 Hedrick Lead Study

Client Sample ID: Bottle #12865
Collectors Name: Larry Anderson
Sample Location: Rm 206 Sink S Wall Left
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.00516		0.000103	mg/L	0.020 AL	7/28/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR0028

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: **1607890**
NRC Sample ID: **1607890-44A**
Collection Date: **7/20/2016 1:57:00 PM**
Received Date: **7/20/2016 3:42:00 PM**
Reported Date: **8/3/2016 7:32:39 AM**

Sample Information:

16-06 Hedrick Lead Study

Client Sample ID: Bottle #12886
Collectors Name: Larry Anderson
Sample Location: Rm 206 Sink S Wall Center
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.00185		0.000103	mg/L	0.020 AL	7/28/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR0028

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: **1607890**
NRC Sample ID: **1607890-45A**
Collection Date: **7/20/2016 1:58:00 PM**
Received Date: **7/20/2016 3:42:00 PM**
Reported Date: **8/3/2016 7:32:39 AM**

Sample Information:

16-06 Hedrick Lead Study

Client Sample ID: Bottle #12869
Collectors Name: Larry Anderson
Sample Location: Rm 206 Sink S Wall Right
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.00355		0.000103	mg/L	0.020 AL	7/28/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: **1607890**
NRC Sample ID: **1607890-46A**
Collection Date: **7/20/2016 2:01:00 PM**
Received Date: **7/20/2016 3:42:00 PM**
Reported Date: **8/3/2016 7:32:39 AM**

Sample Information:

16-06 Hedrick Lead Study

Client Sample ID: Bottle #12958
Collectors Name: Larry Anderson
Sample Location: Room 401 DF
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.000707		0.000103	mg/L	0.020 AL	7/28/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: **1607890**
NRC Sample ID: **1607890-47A**
Collection Date: **7/20/2016 2:05:00 PM**
Received Date: **7/20/2016 3:42:00 PM**
Reported Date: **8/3/2016 7:32:39 AM**

Sample Information:

16-06 Hedrick Lead Study

Client Sample ID: Bottle #12920
Collectors Name: Larry Anderson
Sample Location: Room 402 DF
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.00129		0.000103	mg/L	0.020 AL	7/28/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: **1607890**
NRC Sample ID: **1607890-48A**
Collection Date: **7/20/2016 1:38:00 PM**
Received Date: **7/20/2016 3:42:00 PM**
Reported Date: **8/3/2016 7:32:39 AM**

Sample Information:

16-06 Hedrick Lead Study

Client Sample ID: Bottle #12972
Collectors Name: Bill Bartlett
Sample Location: Health Rm Sink
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.000676		0.000103	mg/L	0.020 AL	7/28/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: **1607890**
NRC Sample ID: **1607890-49A**
Collection Date: **7/20/2016 1:39:00 PM**
Received Date: **7/20/2016 3:42:00 PM**
Reported Date: **8/3/2016 7:32:39 AM**

Sample Information:

16-06 Hedrick Lead Study

Client Sample ID: Bottle #12880
Collectors Name: Bill Bartlett
Sample Location: Main Office Kitchen Sink
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.000318		0.000103	mg/L	0.020 AL	7/28/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: **1607890**
NRC Sample ID: **1607890-50A**
Collection Date: **7/20/2016 1:40:00 PM**
Received Date: **7/20/2016 3:42:00 PM**
Reported Date: **8/3/2016 7:32:39 AM**

Sample Information:

16-06 Hedrick Lead Study

Client Sample ID: Bottle #12979
Collectors Name: Bill Bartlett
Sample Location: Near Office DF Upper
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.000111		0.000103	mg/L	0.020 AL	7/28/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: **1607890**
NRC Sample ID: **1607890-51A**
Collection Date: **7/20/2016 1:40:00 PM**
Received Date: **7/20/2016 3:42:00 PM**
Reported Date: **8/3/2016 7:32:39 AM**

Sample Information:

16-06 Hedrick Lead Study

Client Sample ID: Bottle #12933
Collectors Name: Bill Bartlett
Sample Location: Near Office DF Lower
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.000153		0.000103	mg/L	0.020 AL	7/28/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR0028

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: **1607890**
NRC Sample ID: **1607890-52A**
Collection Date: **7/20/2016 1:41:00 PM**
Received Date: **7/20/2016 3:42:00 PM**
Reported Date: **8/3/2016 7:32:39 AM**

Sample Information:

16-06 Hedrick Lead Study

Client Sample ID: Bottle #12978
Collectors Name: Bill Bartlett
Sample Location: Room 322 DF
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.000345		0.000103	mg/L	0.020 AL	7/28/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: **1607890**
NRC Sample ID: **1607890-53A**
Collection Date: **7/20/2016 1:43:00 PM**
Received Date: **7/20/2016 3:42:00 PM**
Reported Date: **8/3/2016 7:32:39 AM**

Sample Information:

16-06 Hedrick Lead Study

Client Sample ID: Bottle #12971
Collectors Name: Bill Bartlett
Sample Location: Room 323 DF
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.000254		0.000103	mg/L	0.020 AL	7/28/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: **1607890**
NRC Sample ID: **1607890-54A**
Collection Date: **7/20/2016 1:45:00 PM**
Received Date: **7/20/2016 3:42:00 PM**
Reported Date: **8/3/2016 7:32:39 AM**

Sample Information:

16-06 Hedrick Lead Study

Client Sample ID: Bottle #12893
Collectors Name: Bill Bartlett
Sample Location: Room 325 DF
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.000550		0.000103	mg/L	0.020 AL	7/28/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: **1607890**
NRC Sample ID: **1607890-55A**
Collection Date: **7/20/2016 1:48:00 PM**
Received Date: **7/20/2016 3:42:00 PM**
Reported Date: **8/3/2016 7:32:39 AM**

Sample Information:

16-06 Hedrick Lead Study

Client Sample ID: Bottle #12976
Collectors Name: Bill Bartlett
Sample Location: Room 324 DF
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.000308		0.000103	mg/L	0.020 AL	7/28/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR0028

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: **1607890**
NRC Sample ID: **1607890-56A**
Collection Date: **7/20/2016 1:49:00 PM**
Received Date: **7/20/2016 3:42:00 PM**
Reported Date: **8/3/2016 7:32:39 AM**

Sample Information:

16-06 Hedrick Lead Study

Client Sample ID: Bottle #12922
Collectors Name: Bill Bartlett
Sample Location: Room 327 DF
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.000220		0.000103	mg/L	0.020 AL	7/28/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: **1607890**
NRC Sample ID: **1607890-57A**
Collection Date: **7/20/2016 1:50:00 PM**
Received Date: **7/20/2016 3:42:00 PM**
Reported Date: **8/3/2016 7:32:39 AM**

Sample Information:

16-06 Hedrick Lead Study

Client Sample ID: Bottle #12969
Collectors Name: Bill Bartlett
Sample Location: Room 329 DF
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.000394		0.000103	mg/L	0.020 AL	7/28/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: **1607890**
NRC Sample ID: **1607890-58A**
Collection Date: **7/20/2016 2:22:00 PM**
Received Date: **7/20/2016 3:42:00 PM**
Reported Date: **8/3/2016 7:32:39 AM**

Sample Information:

16-06 Hedrick Lead Study

Client Sample ID: Bottle #12888
Collectors Name: Roger Moulard
Sample Location: Gym NW Corner DF
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.0114		0.000103	mg/L	0.020 AL	7/28/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: **1607890**
NRC Sample ID: **1607890-59A**
Collection Date: **7/20/2016 2:20:00 PM**
Received Date: **7/20/2016 3:42:00 PM**
Reported Date: **8/3/2016 7:32:39 AM**

Sample Information:

16-06 Hedrick Lead Study

Client Sample ID: Bottle #12895
Collectors Name: Roger Moulard
Sample Location: Gym SW Corner DF
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.00559		0.000103	mg/L	0.020 AL	7/28/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: **1607890**
NRC Sample ID: **1607890-60A**
Collection Date: **7/20/2016 2:25:00 PM**
Received Date: **7/20/2016 3:42:00 PM**
Reported Date: **8/3/2016 7:32:39 AM**

Sample Information:

16-06 Hedrick Lead Study

Client Sample ID: Bottle #12916
Collectors Name: Roger Moulard
Sample Location: Girls LR DF RT
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.0178	CF	0.000103	mg/L	0.020 AL	7/28/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: **1607890**
NRC Sample ID: **1607890-61A**
Collection Date: **7/20/2016 2:26:00 PM**
Received Date: **7/20/2016 3:42:00 PM**
Reported Date: **8/3/2016 7:32:39 AM**

Sample Information:

16-06 Hedrick Lead Study

Client Sample ID: Bottle #12968
Collectors Name: Roger Moulard
Sample Location: Girls LR DF LF
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.00365		0.000103	mg/L	0.020 AL	7/28/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR0028

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: **1607890**
NRC Sample ID: **1607890-62A**
Collection Date: **7/20/2016 2:30:00 PM**
Received Date: **7/20/2016 3:42:00 PM**
Reported Date: **8/3/2016 7:32:39 AM**

Sample Information:

16-06 Hedrick Lead Study

Client Sample ID: Bottle #12959
Collectors Name: Roger Moulard
Sample Location: Fitness Rm 108 DF
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.000684		0.000103	mg/L	0.020 AL	7/28/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: **1607890**
NRC Sample ID: **1607890-63A**
Collection Date: **7/20/2016 2:31:00 PM**
Received Date: **7/20/2016 3:42:00 PM**
Reported Date: **8/3/2016 7:32:39 AM**

Sample Information:

16-06 Hedrick Lead Study

Client Sample ID: Bottle #12932
Collectors Name: Roger Moulard
Sample Location: Band Rm 109 DF
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.000565		0.000103	mg/L	0.020 AL	7/28/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: **1607890**
NRC Sample ID: **1607890-64A**
Collection Date: **7/20/2016 2:33:00 PM**
Received Date: **7/20/2016 3:42:00 PM**
Reported Date: **8/3/2016 7:32:39 AM**

Sample Information:

16-06 Hedrick Lead Study

Client Sample ID: Bottle #12950
Collectors Name: Roger Moulard
Sample Location: Room 107 DF
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.000956		0.000103	mg/L	0.020 AL	7/28/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: **1607890**
NRC Sample ID: **1607890-65A**
Collection Date: **7/20/2016 2:34:00 PM**
Received Date: **7/20/2016 3:42:00 PM**
Reported Date: **8/3/2016 7:32:39 AM**

Sample Information:

16-06 Hedrick Lead Study

Client Sample ID: Bottle #12953
Collectors Name: Roger Moulard
Sample Location: Room 106 DF
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.000255		0.000103	mg/L	0.020 AL	7/28/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: **1607890**
NRC Sample ID: **1607890-66A**
Collection Date: **7/20/2016 2:36:00 PM**
Received Date: **7/20/2016 3:42:00 PM**
Reported Date: **8/3/2016 7:32:39 AM**

Sample Information:

16-06 Hedrick Lead Study

Client Sample ID: Bottle #12949
Collectors Name: Roger Moulard
Sample Location: Room 102 DF
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.000201		0.000103	mg/L	0.020 AL	7/28/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Medford School District
815 S Oakdale Ave
Medford, OR 97501

Lab Order: **1607890**
NRC Sample ID: **1607890-67A**
Collection Date: **7/20/2016 2:38:00 PM**
Received Date: **7/20/2016 3:42:00 PM**
Reported Date: **8/3/2016 7:32:39 AM**

Sample Information:

16-06 Hedrick Lead Study

Client Sample ID: Bottle #12917
Collectors Name: Roger Moulard
Sample Location: Room 103 DF
Source: City Water

ANALYTICAL RESULTS

Analyses	Method	NELAP Accredited	Result	Qual	MRL	Units	EPA Limit	Date Analyzed	Analyst
Lead	EPA 200.8	A	0.000877		0.000103	mg/L	0.020 AL	7/28/2016	OML

Notes: ND - Not Detected at the MRL

N.L. - No Limit

MRL - Minimum Reporting Limit

Neilson Research Corporation
DATA FLAGS

B	Analyte detected in the associated method blank.
BA	BOD Alternative Calculation: The initial results performed by Standard Methods did not fall within parameters of the Standard Methods calculation. An alternate approved calculation was performed using the HACH method and the value reported is an estimated concentration.
C	Sample(s) does not meet NELAP/ORELAP sample acceptance criteria. See Case Narrative.
C1	Sample(s) does not meet NELAP/ORELAP sample acceptance criteria for temperature.
CF	Results confirmed by re-analysis.
CU	Cleanup performed as specified by method.
D1	The diesel elution pattern for the sample is not typical.
D2	The sample appears to be a heavier hydrocarbon range than diesel.
D3	The sample appears to be a lighter hydrocarbon range than diesel.
D4	Detected hydrocarbons do not have pattern and range consistent with typical petroleum products and may be due to biogenic interference.
D5	Detected hydrocarbons in the diesel range appear to be weathered diesel.
E	Estimated value.
ER	Elevated reporting limit due to matrix. Report limits (MDLs, MRLs & PQLs) are adjusted based on variations in sample preparation amounts, analytical dilutions, and percent solids, where applicable.
FC	Fecal Coliforms: Sample(s) received past 40 CFR Part 136 specified holding time. Results reported as estimated values.
G1	The gasoline elution pattern for the sample is not typical.
G2	The sample appears to be a heavier hydrocarbon range than gasoline.
G3	The sample appears to be a lighter hydrocarbon range than gasoline.
G4	Detected hydrocarbons in the gasoline range appear to be weathered gasoline.
HP	Sample re-analysis performed outside of method specified holding time.
HR	Sample received outside of method specified holding time.
HS	Sample analyzed for volatile organics contained headspace.
HT	At the client's request, the sample was analyzed outside of method specified holding time.
H	Analysis performed outside of method specified holding time.
J	Analyte detected below the Minimum Reporting Limit (MRL) and above the Method Detection Limit (MDL). The J flag result is an estimated value and the user should be aware that this data is of limited reliability.
MI	Surrogate or Matrix Spike recovery is out of control limits due to matrix interference. Sample results may be biased.
N	See Case Narrative on page 2 of report.
Q	Closing continuing calibration verification (CCV) or laboratory control sample (LCS) exceeded high recovery limits, but associated samples are non-detect and the sample results are not affected. Data meets EPA/NELAP requirements.
R	Relative percent difference (RPD) is outside of the accepted recovery limits.
R1	Relative percent difference (RPD) is outside of the accepted recovery limits. However, analyses are not controlled on RPD values for sample concentrations that are less than the reporting limit.
R3	The relative percent difference (RPD) and/or percent recovery for the duplicate (DUP) or matrix spike (MS)/matrix spike duplicate (MSD) cannot be accurately calculated due to the concentration of analyte already present in the sample.
R4	Duplicate analysis failed due to result being at or near method reporting limit.
S	Surrogate and/or matrix spike recovery is outside of the accepted recovery limits. Sample results may be biased.
S1	Surrogate or matrix spike recovery is outside of control limits due to dilution necessary for analysis.
SC	Sub-contracted to another laboratory for analysis.
SP	Sample(s) were not collected per EPA Method 5035A protocols. The results are considered minimum values.
T	Toxicity Characteristic Leaching Procedure – Sample submitted contained < 0.5% solids. If the waste contains <0.5% dry solids, the liquid portion of the waste, after filtration, is defined as the TCLP extract.
#	Value exceeds regulatory level for TCLP contaminant.
X1	The motor oil elution pattern for the sample is not typical.
X2	The sample appears to be a heavier hydrocarbon range than motor oil.
X3	The sample appears to be a lighter hydrocarbon range than motor oil.
*	Value exceeds Maximum Contaminant Level or is outside the acceptable range.

NRC SOP QA-1104/AD-3100
Revision 3
Effective Date: 6/3/16

CLIENT: Medford School District
Work Order: 1607890
Project: 16-06 Hedrick Lead Study

ANALYTICAL QC SUMMARY REPORT

TestCode: ICPMS_200.8_SCHOOL

Sample ID MB-35950	SampType: MBLK	TestCode: ICPMS_200.8	Units: mg/L	Prep Date: 7/25/2016	RunNo: 88740						
Client ID: ZZZZZ	Batch ID: 35950	TestNo: EPA 200.8	(EPA 200.8)	Analysis Date: 7/26/2016	SeqNo: 1332330						
Analyte	Result	MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead ND 0.000103

Sample ID MB-35951	SampType: MBLK	TestCode: ICPMS_200.8	Units: mg/L	Prep Date: 7/25/2016	RunNo: 88754						
Client ID: ZZZZZ	Batch ID: 35951	TestNo: EPA 200.8	(EPA 200.8)	Analysis Date: 7/28/2016	SeqNo: 1333005						
Analyte	Result	MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead ND 0.000103

Sample ID MB-35954	SampType: MBLK	TestCode: ICPMS_200.8	Units: mg/L	Prep Date: 7/25/2016	RunNo: 88754						
Client ID: ZZZZZ	Batch ID: 35954	TestNo: EPA 200.8	(EPA 200.8)	Analysis Date: 7/28/2016	SeqNo: 1333033						
Analyte	Result	MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead ND 0.000103

Sample ID MB-35956	SampType: MBLK	TestCode: ICPMS_200.8	Units: mg/L	Prep Date: 7/25/2016	RunNo: 88754						
Client ID: ZZZZZ	Batch ID: 35956	TestNo: EPA 200.8	(EPA 200.8)	Analysis Date: 7/28/2016	SeqNo: 1333061						
Analyte	Result	MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead ND 0.000103

Sample ID LCS-35950	SampType: LCS	TestCode: ICPMS_200.8	Units: mg/L	Prep Date: 7/25/2016	RunNo: 88740						
Client ID: ZZZZZ	Batch ID: 35950	TestNo: EPA 200.8	(EPA 200.8)	Analysis Date: 7/26/2016	SeqNo: 1332331						
Analyte	Result	MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead 0.09751 0.000104 0.1 0 97.5 85 115

Qualifiers: E Value above quantitation range H Holding times for preparation or analysis exceeded J Analyte detected below quantitation limits
 ND Not Detected at the Minimum Reporting Limit R RPD outside accepted recovery limits S Spike Recovery outside accepted recovery limits

CLIENT: Medford School District
Work Order: 1607890
Project: 16-06 Hedrick Lead Study

ANALYTICAL QC SUMMARY REPORT

TestCode: ICPMS_200.8_SCHOOL

Sample ID	LCS-35951	SampType: LCS	TestCode: ICPMS_200.8	Units: mg/L	Prep Date: 7/25/2016	RunNo: 88754					
Client ID:	ZZZZZ	Batch ID: 35951	TestNo: EPA 200.8	(EPA 200.8)	Analysis Date: 7/28/2016	SeqNo: 1333006					
Analyte	Result	MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead 0.09339 0.000104 0.1 0 93.4 85 115

Sample ID	LCS-35954	SampType: LCS	TestCode: ICPMS_200.8	Units: mg/L	Prep Date: 7/25/2016	RunNo: 88754					
Client ID:	ZZZZZ	Batch ID: 35954	TestNo: EPA 200.8	(EPA 200.8)	Analysis Date: 7/28/2016	SeqNo: 1333034					
Analyte	Result	MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead 0.09384 0.000104 0.1 0 93.8 85 115

Sample ID	LCS-35956	SampType: LCS	TestCode: ICPMS_200.8	Units: mg/L	Prep Date: 7/25/2016	RunNo: 88754					
Client ID:	ZZZZZ	Batch ID: 35956	TestNo: EPA 200.8	(EPA 200.8)	Analysis Date: 7/28/2016	SeqNo: 1333062					
Analyte	Result	MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead 0.09357 0.000104 0.1 0 93.6 85 115

Sample ID	1607890-17AMS	SampType: MS	TestCode: ICPMS_200.8	Units: mg/L	Prep Date: 7/25/2016	RunNo: 88740					
Client ID:	Bottle #12967	Batch ID: 35950	TestNo: EPA 200.8	(EPA 200.8)	Analysis Date: 7/26/2016	SeqNo: 1332354					
Analyte	Result	MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead 0.09594 0.000104 0.1 0.0004898 95.5 70 130

Sample ID	1607890-37AMS	SampType: MS	TestCode: ICPMS_200.8	Units: mg/L	Prep Date: 7/25/2016	RunNo: 88754					
Client ID:	Bottle #12919	Batch ID: 35951	TestNo: EPA 200.8	(EPA 200.8)	Analysis Date: 7/28/2016	SeqNo: 1333029					
Analyte	Result	MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead 0.09228 0.000104 0.1 0.0002252 92.1 70 130

Qualifiers: E Value above quantitation range H Holding times for preparation or analysis exceeded J Analyte detected below quantitation limits
 ND Not Detected at the Minimum Reporting Limit R RPD outside accepted recovery limits S Spike Recovery outside accepted recovery limits

CLIENT: Medford School District
Work Order: 1607890
Project: 16-06 Hedrick Lead Study

ANALYTICAL QC SUMMARY REPORT

TestCode: ICPMS_200.8_SCHOOL

Sample ID	1607890-57AMS	SampType:	MS	TestCode:	ICPMS_200.8	Units:	mg/L	Prep Date:	7/25/2016	RunNo:	88754					
Client ID:	Bottle #12969	Batch ID:	35954	TestNo:	EPA 200.8		(EPA 200.8)	Analysis Date:	7/28/2016	SeqNo:	1333057					
Analyte		Result		MRL		SPK value		SPK Ref Val		%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead		0.09304		0.000104		0.1		0.0003937		92.6	70	130				
------	--	---------	--	----------	--	-----	--	-----------	--	------	----	-----	--	--	--	--

Sample ID	1607945-10AMS	SampType:	MS	TestCode:	ICPMS_200.8	Units:	mg/L	Prep Date:	7/25/2016	RunNo:	88754					
Client ID:	ZZZZZ	Batch ID:	35956	TestNo:	EPA 200.8		(EPA 200.8)	Analysis Date:	7/28/2016	SeqNo:	1333085					
Analyte		Result		MRL		SPK value		SPK Ref Val		%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead		0.09079		0.000104		0.1		0.0003881		90.4	70	130				
------	--	---------	--	----------	--	-----	--	-----------	--	------	----	-----	--	--	--	--

Sample ID	1607890-17AMSD	SampType:	MSD	TestCode:	ICPMS_200.8	Units:	mg/L	Prep Date:	7/25/2016	RunNo:	88740					
Client ID:	Bottle #12967	Batch ID:	35950	TestNo:	EPA 200.8		(EPA 200.8)	Analysis Date:	7/26/2016	SeqNo:	1332355					
Analyte		Result		MRL		SPK value		SPK Ref Val		%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead		0.09666		0.000104		0.1		0.0004898		96.2	70	130	0.09594	0.745	20	
------	--	---------	--	----------	--	-----	--	-----------	--	------	----	-----	---------	-------	----	--

Sample ID	1607890-37AMSD	SampType:	MSD	TestCode:	ICPMS_200.8	Units:	mg/L	Prep Date:	7/25/2016	RunNo:	88754					
Client ID:	Bottle #12919	Batch ID:	35951	TestNo:	EPA 200.8		(EPA 200.8)	Analysis Date:	7/28/2016	SeqNo:	1333030					
Analyte		Result		MRL		SPK value		SPK Ref Val		%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead		0.09344		0.000104		0.1		0.0002252		93.2	70	130	0.09228	1.25	20	
------	--	---------	--	----------	--	-----	--	-----------	--	------	----	-----	---------	------	----	--

Sample ID	1607890-57AMSD	SampType:	MSD	TestCode:	ICPMS_200.8	Units:	mg/L	Prep Date:	7/25/2016	RunNo:	88754					
Client ID:	Bottle #12969	Batch ID:	35954	TestNo:	EPA 200.8		(EPA 200.8)	Analysis Date:	7/28/2016	SeqNo:	1333058					
Analyte		Result		MRL		SPK value		SPK Ref Val		%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead		0.09357		0.000104		0.1		0.0003937		93.2	70	130	0.09304	0.568	20	
------	--	---------	--	----------	--	-----	--	-----------	--	------	----	-----	---------	-------	----	--

Qualifiers: E Value above quantitation range H Holding times for preparation or analysis exceeded J Analyte detected below quantitation limits
 ND Not Detected at the Minimum Reporting Limit R RPD outside accepted recovery limits S Spike Recovery outside accepted recovery limits

CLIENT: Medford School District
Work Order: 1607890
Project: 16-06 Hedrick Lead Study

ANALYTICAL QC SUMMARY REPORT

TestCode: ICPMS_200.8_SCHOOL

Sample ID 1607945-10AMSD	SampType: MSD	TestCode: ICPMS_200.8	Units: mg/L	Prep Date: 7/25/2016	RunNo: 88754						
Client ID: ZZZZZ	Batch ID: 35956	TestNo: EPA 200.8	(EPA 200.8)	Analysis Date: 7/28/2016	SeqNo: 1333086						
Analyte	Result	MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Lead	0.09100	0.000104	0.1	0.0003881	90.6	70	130	0.09079	0.229	20	

Qualifiers: E Value above quantitation range H Holding times for preparation or analysis exceeded J Analyte detected below quantitation limits
 ND Not Detected at the Minimum Reporting Limit R RPD outside accepted recovery limits S Spike Recovery outside accepted recovery limits



Environmental Testing Laboratory
 245 South Grape Street • Medford, OR 97501
 (541) 770-5678 fax (541) 770-2901

Chain of Custody Record

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Section A Required Client Information
 Company: Medford School District 549C
 Address: 815 S. Oakdale, Medford, Or. 97501
 Email: rick.rose@medford.k12.or.us
 Phone: 541.842.1138 Fax: 541.842.1160

Section B Required Project Information
 Project Name: 2016 Lead testing
 Project Number: 16-06 / Hedrick
 Report To: rick.rose@medford.k12.or.us
 Copy To: ron.havniar@medford.k12.or.us

Section C Invoice Information
 Attention: Accounting
 Company Name: Medford School
 Address: 815 S. Oakdale, Medford, Or. 97501
 P.O. # P112894

Section D Rush Status (Subject to Scheduling)
 Standard 10-14 Days
 5 Business Days (50% surcharge)
 3 Business Days (75% surcharge)
 24 - 48 hours (100% surcharge)
 Other _____
 Authorized Yes No

Section E Sample Information

Sample ID	Compsizab	Matrix*	Date Collected	Time Collected	No. of Containers	Analysis Requested
RM 310 DF	12975		7/20/16	155 PM	1	
RM 311 DF	12951			156	1	
RM 314 DF	12918			158	1	
RM 315 DF	12974			159	1	

Bottle #

Section F Matrix: DW - Drinking Water WW - Wastewater W - Water S - Soil/Solid SL - Sludge O - Oil WP - Wipe OT - Other

Section G Lab Use Only

NRC Workorder # 1607870

Remarks/Field Data

NRC Sample # (Lab Use Only)

Temp: AWW

4°C +/- 2°C: Yes No

Received on Ice: Yes No

Number of Bottles Received: 4

pH Checked: WW

COC Seals Intact: Yes No NA

Field Blank Included: Yes No

Section F Relinquish/Receive

Relinquish/Receive	Sign	Date	Time
Received By: <u>Gary Severe</u>	<u>Gary Severe</u>	7/20/16	2:09 PM
Relinquished By: <u>John Severe</u>	<u>John Severe</u>	7/20/16	3:40 PM
Received By: <u>Paul Severe</u>	<u>Paul Severe</u>	7/20/16	3:40

Section G Payment

Payment Invoice Cash VISA M/C Check #

Received Via UPS FedEx Other Hand



Environmental Testing Laboratory
 245 South Grape Street • Medford, OR 97501
 (541) 770-5678 fax (541) 770-2901

Chain of Custody Record

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Section A Required Client Information
 Company: Medford School District 549C
 Address: 815 S. Oakdale
 Medford, Or, 97501
 Email: rick.rose@medford.k12.or.us
 Phone: 541.842.1138 Fax: 541.842.1160

Section B Required Project Information
 Project Name: 2016 Lead testing
 Project Number: 16-06 / Hedrick
 Report To: rick.rose@medford.k12.or.us
 Copy To: ron.havntear@medford.k12.or.us

Section C Invoice Information
 Attention: Accounting
 Company Name: Medford School
 Address: 815 S. Oakdale
 Medford, Or, 97501
 P.O. # P112894

Section D Rush Status (Subject to Scheduling)
 Standard 10-14 Days
 5 Business Days (50% surcharge)
 3 Business Days (75% surcharge)
 24 - 48 hours (100% surcharge)
 Other _____
 Authorized Yes No

Section E Sample Information

Sample ID	Comp/Grab	Matrix*	Date Collected	Time Collected	No. of Containers	Analysis Requested	NRC Workorder # (Lab Use Only)	NRC Sample # (Lab Use Only)
RM 404 DF	12966		7/20/16	141 PM	1		1607810	15
RM 408 BF	12956			142	1			09
RM 411 DF	12961			143	1			07
RM 410 DF	12954			145	1			08
RM 409 DF	12963			146	1			09
RM 204 DF	12931			148	1			10
RM 202 DF	12960			150	1			11
RM 303 DF	12962			151	1			12
Access From RM 303 DF	12926			152	1			13
RM 309 DF	12941			154	1			14

*Matrix: DW - Drinking Water WW - Wastewater W - Water S - Soil/Solid SL - Sludge O - Oil WP - Wipe OT - Other

Collected By (Print): Gary Severe
 Collected By (Sign): [Signature]
 Email Report Yes No Mail Report Yes No
 Fax Report Yes No

Section F Relinquish/Receive

Relinquished By:	Sign	Print	Date	Time
Relinquished By:	<u>[Signature]</u>	<u>Gary Severe</u>	7/20/16	2:09 PM
Received By:	<u>[Signature]</u>	<u>Sgt. Jensen</u>	7/20/16	3:09 PM
Relinquished By:	<u>[Signature]</u>	<u>Sgt. Jensen</u>	7/20/16	3:48 PM
Received By:	<u>[Signature]</u>	<u>[Signature]</u>		
Relinquished By:	<u>[Signature]</u>	<u>[Signature]</u>		
Received By:	<u>[Signature]</u>	<u>[Signature]</u>		

Section G Lab Use Only

Temp: AMBIENT
 4°C +/- 2°C: Yes No
 Received on Ice: Yes No
 Number of Bottles Received: 10
 pH Checked: WT
 COC Seals Intact: Yes No NA
 Field Blank Included: Yes No

Payment Invoice Cash VISA, M/C Check # Amount

Received Via UPS FedEx Other Hand

Hedrick

Chain of Custody Record

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Section A
Required Client Information

Company: Medford School District 549C
 Address: 815 S. Oakdale, Medford, Or, 97501
 Email: rick.rose@medford.k12.or.us
 Phone: 541.842.1138 Fax: 541.842.1160
 Collected By (Print): *SEM SSEN*
 Email Report Yes No Mail Report Yes No
 Fax Report Yes No

Section B
Required Project Information

Project Name: 2016 Lead testing
 Project Number: 16-06 \ Hedrick
 Report To: rick.rose@medford.k12.or.us
 Copy To: ron.havnear@medford.k12.or.us

Section C
Invoice Information

Attention: Accounting
 Company Name: Medford School
 Address: 815 S. Oakdale Medford, Or, 97501
 P.O. # P112894

Section D
Rush Status (Subject to Scheduling)

Standard 10-14 Days
 5 Business Days (50% surcharge)
 3 Business Days (75% surcharge)
 24 - 48 hours (100% surcharge)
 Other _____
 Authorized Yes No

Section E
Sample Information

Sample ID	Comp/Grab	Matrix*	Date Collected	Time Collected	No. of Containers	Analysis Requested	NRC Workorder # (Lab Use Only)	NRC Sample # (Lab Use Only)
Rm 316 Staff Wk Rm DF (N Wall)			7/20/16	2:34pm			1607890	19
Rm 316 Staff Wk Rm Sink (N Wall)				2:35pm				19
Rm 316 Staff Wk Rm DF (W. Wall)				2:34pm				19
Rm 317 DF				2:34pm				19
Rm 119 Slee (Utility Sink)				2:44pm				20
Rm 121 DF				2:48pm				21
Rm 124 Staff Bk Rm Sink				2:47pm				22
Kitchen Food Rep Sink				3:06pm				23
Rm 120 DF				2:46pm				23
Rm 118 Ice Machine				2:44pm				24

Matrix: DW - Drinking Water WW - Wastewater W - Water S - Solid/Solid SL - Sludge O - Oil WP - Wipe OT - Other

Section F
Relinquish/Receive

Relinquish/Receive By:	Sign	Date	Time
Received By:	<i>[Signature]</i>	7/20/16	3:14pm
Relinquished By:			
Received By:			
Relinquished By:			
Received By:			
Relinquished By:			
Received By Laboratory:	<i>[Signature]</i>	7/20/16	3:42

Section G
Lab Use Only

Temp: *70.0*
 4°C +/- 2°C: Yes No
 Received on Ice: Yes No
 Number of Bottles Received: *10*
 pH Checked: *NA*
 COC Seals Intact: Yes No *NA*
 Field Blank Included: Yes No

Payment Invoice Cash VISA M/C Check # Amount
 Received Via UPS FedEx Other Hand



Environmental Testing Laboratory
 245 South Grape Street • Medford, OR 97501
 (541) 770-5578 fax (541) 770-2901

Heberick

Chain of Custody Record

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Section A Required Client Information

Company: Medford School District 549C
 Address: 815 S. Oakdale,
 Medford, Or. 97501
 Email: rick.rose@medford.k12.or.us
 Phone: 541.842.1138 Fax: 541.842.1160
 Collected By (Print): *John Jensen*
 Email Report Yes No
 Fax Report Yes No

Section B Required Project Information

Project Name: 2016 Lead testing
 Project Number: 16-06 / Hedrick
 Report To: rick.rose@medford.k12.or.us
 Copy To: ron.hvntear@medford.k12.or.us

Section C Invoice Information

Attention: Accounting
 Company Name: Medford School
 Address: 815 S. Oakdale
 Medford, Or. 97501
 P.O. # P112894

Section D Rush Status (Subject to Scheduling)

Standard 10-14 Days
 5 Business Days (50% surcharge)
 3 Business Days (75% surcharge)
 24 - 48 hours (100% surcharge)
 Other _____
 Authorized Yes No

Section E Sample Information

Sample ID	Matrix*	Date Collected	Time Collected	No. of Containers	Analysis Requested	NRC Workorder # (Lab Use Only)	NRC Sample # (Lab Use Only)
<i>Holloway E Side Gym Near AIG DF</i>		<i>7/20/16</i>	<i>3:46pm</i>	<i>1</i>		<i>1607890</i>	
<i>NE Gym Entrance DF (Upper)</i>			<i>2:49pm</i>	<i>1</i>			<i>25</i>
<i>NE Gym Entrance DF (Lower)</i>			<i>2:48pm</i>	<i>1</i>			<i>26</i>
<i>Weight Rm SE Ent. DF</i>			<i>2:51pm</i>	<i>1</i>			<i>27</i>
<i>H.R. Feeding Water Horse</i>			<i>2:57pm</i>	<i>1</i>			<i>28</i>
							<i>29</i>

Section F Rollinquinsh/Receive

Received By: *John Jensen*
 Received By: _____
 Received By: _____
 Received By: _____
 Received By Laboratory: *RED SQUAW*

Section G Lab Use Only

Temp: *44.0*
 Received on Ice: Yes No
 Number of Bottles Received: *5*
 pH Checked: *NA*
 COC Seals Intact: Yes No
 Field Blank Included: Yes No

Payment: Invoice Cash VISA, M/C Check # _____ Amount _____
 Received Via UPS FedEx Other Hand



Environmental Testing Laboratory
 245 South Grape Street • Medford, OR 97501
 (541) 770-5678 fax (541) 770-2901

Chain of Custody Record

Handwritten signature

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Section A
 Required Client Information

Company: Medford School District 549C
 Address: 815 S. Oakdale, Medford, Or, 97501
 Email: rick.rose@medford.k12.or.us
 Phone: 541.842.1138 Fax: 541.842.1160
 Collected By (Print): *Bill Bartsch*
 Collected By (Sign): *Bill Bartsch*
 Email Report Yes No Mail Report Yes No
 Fax Report Yes No

Section B
 Required Project Information

Project Name: 2016 Lead testing
 Project Number: 16-06 / Hedrick
 Report To: rick.rose@medford.k12.or.us
 Copy To: ron.havvlear@medford.k12.or.us
 P.O. # P112894

Section C
 Invoice Information

Attention: Accounting
 Company Name: Medford School
 Address: 815 S. Oakdale, Medford, Or, 97501

Section D
 Rush Status (Subject to Scheduling)

Standard 10-14 Days
 5 Business Days (50% surcharge)
 3 Business Days (75% surcharge)
 24 - 48 hours (100% surcharge)
 Other _____
 Authorized Yes No

Section E
 Sample Information

Sample ID	Bottle #	Comps/Grb	Matrix*	Date Collected	Time Collected	No. of Containers	Analysis Requested	NRC Workorder # (Lab Use Only)	NRC Sample # (Lab Use Only)
Rn, 331 D.F.		12,866		7-20-16	1:52 Pm	1		1607890	
Ev Hallway between 331-334 D.F.		12,910			1:54 Pm	1			
Rn 334 D.F.		12,942			1:57 Pm	1			
Rn 336 D.F.		12,892			1:58 Pm	1			
Rn 335 D.F.		12,881			2:00 Pm	1			

Section F
 Relinquish/Receive

Relinquish/Receive	Sign	Print	Date	Time
Relinquished By:	<i>Bill Bartsch</i>	<i>Bill Bartsch</i>	7-20-16	2:05 Pm
Received By:	<i>John Jensen</i>	<i>John Jensen</i>	7/20/16	2:09 Pm
Relinquished By:	<i>John Jensen</i>	<i>John Jensen</i>	7/20/16	3:18 Pm
Received By:	<i>John Jensen</i>	<i>John Jensen</i>		
Relinquished By:	<i>John Jensen</i>	<i>John Jensen</i>		
Received By Laboratory:	<i>John Jensen</i>	<i>John Jensen</i>	7/20/16	3:14 Pm

Section G
 Lab Use Only

Temp: *WATER*
 4°C +/- 2°C: Yes No
 Received on Ice: Yes No
 Number of Bottles Received: *5*
 PH Checked: *NA*
 COC Seals Intact: Yes No
 Field Blank Included: Yes No

Received Via UPS FedEx Other Hand
 Payment: Invoice Cash VISA, M/C Check # _____ Amount _____



Environmental Testing Laboratory
 245 South Grape Street • Medford, OR 97501
 (541) 770-5678 fax (541) 770-2901

Chain of Custody Record

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Section A Required Client Information **Section B** Required Project Information **Section C** Invoice Information **Section D** Rush Status (Subject to Scheduling)

Company: Medford School District 549C Project Name: 2016 Lead testing
 Address: 815 S. Oakdale, Medford, OR, 97501 Project Number: 16-06 / Hedrick
 Email: rick.rose@medford.k12.or.us Report To: rick.rose@medford.k12.or.us Address: 815 S. Oakdale
 Phone: 541.842.1138 Fax: 541.842.1160 Copy To: ron.havnhear@medford.k12.or.us Medford, Or, 97501
 Collected By (Print): Larry A. Anderson P.O. # P112894
 Collected By (Sign): [Signature]
 Email Report Yes No Mail Report Yes No
 Fax Report Yes No

Section E Sample Information **Section F** Requisition/Receive **Section G** Lab Use Only

Sample ID	Comp/Grab	Matrix*	Date Collected	Time Collected	No. of Containers	Analysis Requested	NRC Workorder # (Lab Use Only)	NRC Sample # (Lab Use Only)
Restroom Room DF	12944		7-20-16	1:33 PM	1		1607890	35
Rm 216 DF	12952			1:39	1			36
Rm 215 DF	12919			1:42	1			37
Media Center Work Rm DF	12872			1:45	1			38
Media Center Office DF	12906			1:48	1			39
Room 206 Coliving Sink North Wall Left	12915			1:52	1			40
Room 206 Coliving Sink North Wall Right	12871			1:53	1			41
Room 206 Coliving Sink North Wall Right	12897			1:55	1			42
Room 206 Coliving Sink South Wall Left	12865			1:56	1			43
Room 206 Coliving Sink South Wall Left	12886			1:57	1			44

Section F Requisition/Receive

Requisitioned By: [Signature] Sign: _____ Print: _____ Date: 7-20-16 Time: 2:08 PM

Received By: [Signature] Sign: _____ Print: Larry Anderson Date: 7/20/16 Time: 2:08 PM

Requisitioned By: [Signature] Sign: _____ Print: Sofia Jensen Date: 7/20/16 Time: 3:42 PM

Received By: [Signature] Sign: _____ Print: [Signature] Date: 7/20/16 Time: 3:42

Requisitioned By: _____ Sign: _____ Print: _____ Date: _____ Time: _____

Received By: _____ Sign: _____ Print: _____ Date: _____ Time: _____

Payment: Invoice Cash VISA M/C Check # _____ Amount _____

Received Via: UPS FedEx Other Hand



Environmental Testing Laboratory
 245 South Grange Street • Medford, OR 97501
 (541) 770-5678 fax (541) 770-2901

Chain of Custody Record

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Section A Required Client Information **Section B** Required Project Information **Section C** Invoice Information **Section D** Rush Status (Subject to Scheduling)

Company: Medford School District 549C	Project Name: 2016 Lead testing	Attention: Accounting	Standard 10-14 Days
Address: 815 S. Oakdale, Medford, Or, 97501	Project Number: 16-06 / Hedrick	Company Name: Medford School	5 Business Days (50% surcharge)
Email: rick.rose@medford.k12.or.us	Report To: rick.rose@medford.k12.or.us	Address: 815 S. Oakdale	3 Business Days (75% surcharge)
Phone: 541.842.1138 Fax: 541.842.1160	Copy To: ron.havniar@medford.k12.or.us	P.O. # P112894	24 - 48 hours (100% surcharge)
Collected By (Print): Larry Anderson			Other _____
Collected By (Sign): <i>Larry Anderson</i>			Authorized <input type="checkbox"/> Yes <input type="checkbox"/> No
Email Report <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Mail Report <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No			
Fax Report <input type="checkbox"/> Yes <input type="checkbox"/> No			

Section E Sample Information **Section F** Relinquish/Receive **Section G** Lab Use Only

Sample ID	Comp/Grab	Matrix*	Date Collected	Time Collected	No. of Containers	Analysis Requested	NRC Workorder # (Lab Use Only)	NRC Sample # (Lab Use Only)
Ron 401	DF		7-20-16	1:58 PM	1		1607892	415
Ron 402	DF		7-20-16	2:05	1			416
								417
								418
								419

*Matrix DW - Drinking Water WW - Wastewater W - Water S - Soil/Solid SL - Sludge O - Oil WP - Wipe OT - Other

Relinquished By: <i>Larry Anderson</i>	Sign	Print	Date	Time
Received By: <i>Larry Anderson</i>			7-20-16	2:08 PM
Relinquished By: <i>John Jensen</i>			7/20/16	3:48 PM
Received By: <i>John Jensen</i>			7/20/16	3:42
Relinquished By: _____				
Received By: _____				

Temp: 40.1 °C Yes No
 Received on Ice: _____ Yes No
 Number of Bottles Received: 3
 pH Checked: NA
 COC Seals Intact: Yes No
 Field Blank Included: Yes No

Received Via _____ UPS _____ FedEx _____ Other Hand
 Payment Invoice _____ Cash _____ VISA, M/C _____ Check # _____ Amount _____



Environmental Testing Laboratory
 245 South Grape Street • Medford, OR 97501
 (541) 770-5578 fax (541) 770-2901

Chain of Custody Record

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Section A Required Client Information

Company: Medford School District 549C
 Address: 815 S. Oakdale,
 Medford, Or. 97501
 Email: rick.rose@medford.k12.or.us
 Phone: 541.842.1138 Fax: 541.842.1160
 Collected By (Print): Bill Beavert
 Collected By (Sign): *Bill Beavert*
 Email Report Yes No Mail Report Yes No
 Fax Report Yes No

Section B Required Project Information

Project Name: 2016 Lead testing
 Project Number: 16-06 / Hedrick
 Report To: rick.rose@medford.k12.or.us
 Copy To: ron.havniar@medford.k12.or.us
 Attention: Accounting
 Company Name: Medford School
 Address: 815 S. Oakdale
 P.O. # P112894

Section C Invoice Information

Invoice Information
 P.O. # P112894

Section D Rush Status (Subject to Scheduling)

Rush Status (Subject to Scheduling)
 Standard 10-14 Days
 5 Business Days (50% surcharge)
 3 Business Days (75% surcharge)
 24 - 48 hours (100% surcharge)
 Other _____
 Authorized Yes No

Section E Sample Information

Sample ID	Compart	Matrix*	Date Collected	Time Collected	No. of Containers	Analysis Requested
Hedrick Room 314K	12972		7/20/16	1:38 PM	1	
Virginia office K12/chemical sink	12880			1:39 PM	1	
Bythe office D.F. upper	12974			1:40 PM	1	
Bythe office D.F. Lower	12933			1:40 PM	1	
Rm. 322 D.F.	12978			1:41 PM	1	
Rm. 323 D.F.	12971			1:43 PM	1	
Rm. 325 D.F.	12893			1:45 PM	1	
Rm. 324 D.F.	12976			1:48 PM	1	
Rm. 327 D.F.	12972			1:49 PM	1	
Rm. 329 D.F.	12969			1:50 PM	1	

Section F Relinquish/Receive

Relinquish/Receive	Sign	Print	Date	Time
Relinquished By: <i>Bill Beavert</i>	<i>Bill Beavert</i>	Bill Beavert	7/20/16	2:09 PM
Received By: <i>John Jenson</i>	<i>John Jenson</i>	John Jenson	7/20/16	2:09 PM
Relinquished By: <i>John Jenson</i>	<i>John Jenson</i>	John Jenson	7/20/16	3:40 PM
Received By: <i>Tom Quigg</i>	<i>Tom Quigg</i>	Tom Quigg	7/20/16	3:42

Section G Lab Use Only

NRC Workorder # 11007890
 (Lab Use Only)
 Remarks/Field Data
 NRC Sample # (Lab Use Only)
 Temp: *7.1/11.8/9.8*
 4°C +/- 2°C: Yes No
 Received on Ice: Yes No
 Number of Bottles Received: *10*
 pH Checked: *11/11*
 COC Seats Intact: Yes No
 Field Blank Included: Yes No
 Received Via UPS FedEx Other Hand
 Payment: Invoice Cash VISA M/C Check # _____ Amount _____



Environmental Testing Laboratory
 245 South Grape Street • Medford, OR 97501
 (541) 770-5678 fax (541) 770-2901

Chain of Custody Record

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Section A Required Client Information

Company: Medford School District 549C
 Address: 815 S. Oakdale,
 Medford, Or, 97501
 Email: rick.rose@medford.k12.or.us
 Phone: 541.842.1138 Fax 541.842.1160
 Collected By (Print): Roger McLeod
 Collected By (Sign): [Signature]
 Email Report Yes No
 Fax Report Yes No

Section B Required Project Information

Project Name: 2016 Lead testing
 Project Number: 16-06/Hedrick
 Report To: rick.rose@medford.k12.or.us
 Copy To: ron.havvlear@medford.k12.or.us
 Attention: Accounting
 Company Name: Medford School
 Address: 815 S. Oakdale
 Medford, Or, 97501
 P.O. # P112894

Section C Invoice Information

Invoice Information
 Attention: Accounting
 Company Name: Medford School
 Address: 815 S. Oakdale
 Medford, Or, 97501
 P.O. # P112894

Section D Rush Status (Subject to Scheduling)

Rush Status (Subject to Scheduling)
 Standard 10-14 Days
 5 Business Days (50% surcharge)
 3 Business Days (75% surcharge)
 24 - 48 hours (100% surcharge)
 Other _____
 Authorized Yes No

Section E Sample Information

Sample ID	Contrib	Matrix*	Time		No. of Containers	Analysis Requested				NRC Workorder # (Lab Use Only)	NRC Sample # (Lab Use Only)
			Date Collected	Time Collected							
In Gym NW Corner DF	12888		2:22 PM	7-20-16	1					1607890	58
" " SW " "	12895		2:25		1						59
Gills LR DF Rt	12916		2:25		1						60
" " " " LF	12968		2:26		1						61
Fitness RM 108 DF	12959		2:30		1						62
Basal RM 109 DF	12932		2:31		1						63
RM 107 DF	12950		2:33		1						64
106	12957		2:34		1						65
102	12949		2:36		1						66
103	12917		2:38		1						67

*Matrix: DW - Drinking Water WW - Wastewater W - Water S - Soil/Solid SL - Sludge O - Oil WP - Wipes OT - Other

Section F Relinquish/Receive

Relinquish/Receive	Sign	Print	Date	Time
Received By: <u>[Signature]</u>	<u>[Signature]</u>	<u>Roger McLeod</u>	7-20-16	2:55 PM
Relinquished By: <u>[Signature]</u>	<u>[Signature]</u>	<u>John Jessen</u>	7/20/16	2:55 PM
Received By: <u>[Signature]</u>	<u>[Signature]</u>	<u>John Jessen</u>	7/20/16	3:43 PM
Relinquished By: <u>[Signature]</u>	<u>[Signature]</u>	<u>John Jessen</u>	7/20/16	3:43 PM
Received By Laboratory: <u>[Signature]</u>	<u>[Signature]</u>	<u>Ten Spongy</u>	7/20/16	3:42

Section G Lab Use Only

Temp: AMM
 4°C +/- 2°C: Yes No
 Received on Ice: Yes No
 Number of Bottles Received: 10
 PH Checked: WTF
 COC Seals Intact: Yes No
 Field Blank Included: Yes No

Payment: Invoice Cash VISA, M/C Check # _____
 Received Via UPS FedEx Other Hand