

Hedrick Elementary School

Radon Tests - Hedrick Elementary School

#	Location/Type	Placement Description	Serial #	Dated Opened	Time Opened	Date Closed	Time Closed	Radon Test Results	Remarks
1	Main Office	E. Wall Counter	2918279	25-Oct-21	6:00 AM	27-Oct-21	6:28 AM	0.1	None.
2	Main Office - Duplicate	E. Wall Counter	2918294	25-Oct-21	6:00 AM	27-Oct-21	6:28 AM	0.1	None.
3	Health Room	N. Wall Bookcase	2913660	25-Oct-21	6:04 AM	27-Oct-21	6:29 AM	0.1	None.
4	Main Office - Room A	N. Wall Table - CONF 319A 2020 Floor Plan	2918255	25-Oct-21	6:05 AM	27-Oct-21	6:30 AM	0.1	None.
5	Main Office - Room J	W. Wall Counter - RM 319C 2020 Floor Plan	2918260	25-Oct-21	6:09 AM	27-Oct-21	6:32 AM	0.2	None.
6	Main Office - Room B	W. Wall - RM 319E 2020 Floor Plan	2913713	25-Oct-21	6:17 AM	27-Oct-21	6:33 AM	0.1	None.
7	Main Office - Room C	S. Wall - RM 319F 2020 Floor Plan	2918246	25-Oct-21	6:18 AM	27-Oct-21	6:34 AM	0.1	None.
8	Main Office - Room D	W. Wall Counter - RM 319G 2020 Floor Plan	2917602	25-Oct-21	6:19 AM	27-Oct-21	6:35 AM	0.1	None.
9	Main Office - Room E	W. Wall Table- RM 319H 2020 Floor Plan	2896292	25-Oct-21	6:21 AM	27-Oct-21	6:36 AM	0.1	None.
10	Main Office - Room F	W. Wall Counter - Principal Office - RM 319J 2020 Floor Plan	2913704	25-Oct-21	6:07 AM	27-Oct-21	6:31 AM	0.6	None.
11	Main Office - Room G	E. Wall Counter - RM 319K 2020 Floor Plan	2918263	25-Oct-21	6:22 AM	27-Oct-21	6:37 AM	0.1	None.
12	Main Office - Room H	W. Wall Counter - RM 319L 2020 Floor Plan	2918261	25-Oct-21	6:24 AM	27-Oct-21	6:38 AM	0.1	None.
13	Main Office - Room I	W. Wall Counter - SRO Office - RM 319M 2020 Floor Plan	2913749	25-Oct-21	6:26 AM	27-Oct-21	6:39 AM	0.1	None.
14	Room 325	W. Countertop	2913706	25-Oct-21	6:31 AM	27-Oct-21	6:40 AM	0.2	None.
15	Room 323	E. Countertop	2913342	25-Oct-21	6:33 AM	27-Oct-21	6:41 AM	0.1	None.
16	Room 322	W. Counter	2913711	25-Oct-21	6:35 AM	27-Oct-21	6:35 AM	0.3	None.
17	Staff Work Room		2913750	25-Oct-21	6:37 AM	27-Oct-21	6:45 AM	0.1	None.
18	Staff Work Room - Blank		2913659	25-Oct-21	6:37 AM	27-Oct-21	6:45 AM	0.1	None.
19	Room 317	N. Wall Counter	2896344	25-Oct-21	6:40 AM	27-Oct-21	6:46 AM	0.1	None.
20	Room 315	N. Wall Counter	2913689	25-Oct-21	6:42 AM	27-Oct-21	6:47 AM	0.1	None.
21	Room 314	S. Wall Counter	2917642	25-Oct-21	6:43 AM	27-Oct-21	6:48 AM	0.1	None.
22	Room 311	N. Wall Counter	2913755	25-Oct-21	6:45 AM	27-Oct-21	6:49 AM	0.3	None.
23	Room 310	N. Wall Counter	2913701	25-Oct-21	6:46 AM	27-Oct-21	6:50 AM	0.1	None.
24	Room 309	S. Wall Counter	2918269	25-Oct-21	6:47 AM	27-Oct-21	6:51 AM	0.3	None.
25	Room 306		2917641	25-Oct-21	6:04 AM	27-Oct-21	6:28 AM	0.1	None.
26	Room 304		2896373	25-Oct-21	6:08 AM	27-Oct-21	6:31 AM	0.1	None.
27	Room 304 - Duplicate	N.E. Wall Counter	2913687	25-Oct-21	6:08 AM	27-Oct-21	6:31 AM	0.1	None.
28	Room 303	W. Wall	2913690	25-Oct-21	6:13 AM	27-Oct-21	6:33 AM	0.4	None.
29	Room 202	E. Wall	2913754	25-Oct-21	6:17 AM	27-Oct-21	6:36 AM	0.3	None.
30	Room 204		2913381	25-Oct-21	6:20 AM	27-Oct-21	6:37 AM	0.1	None.
31	Room 204 - Blank		2916039	25-Oct-21	6:25 AM	27-Oct-21	6:37 AM	0.1	None.
32	Culinary Arts # 1		2896376	25-Oct-21	6:31 AM	27-Oct-21	6:39 AM	0.1	None.
33	Culinary Arts # 2		2896369	25-Oct-21	6:32 AM	27-Oct-21	6:39 AM	0.1	None.
34	Room 203		2916032	25-Oct-21	6:35 AM	27-Oct-21	6:42 AM	0.3	None.
35	Room 201	Desk	2918200	25-Oct-21	6:41 AM	27-Oct-21	6:43 AM	0.1	None.
36	Media Center # 1		2918306	25-Oct-21	6:49 AM	27-Oct-21	6:52 AM	0.1	None.
37	Media Center # 2	Bookcase	2918228	25-Oct-21	6:52 AM	27-Oct-21	6:54 AM	0.5	None.
38	Media Center # 3	S Wall	2913696	25-Oct-21	6:56 AM	27-Oct-21	6:58 AM	0.3	None.
39	Media Center - Video		2918295	25-Oct-21	6:59 AM	27-Oct-21	7:00 AM	0.1	None.
40	Media Center - Work Room		2917636	25-Oct-21	7:04 AM	27-Oct-21	7:05 AM	0.2	None.
41	Media Center - Office		2916048	25-Oct-21	7:08 AM	27-Oct-21	7:12 AM	0.1	None.
42	Media Center - Computer Room		2917649	25-Oct-21	7:10 AM	27-Oct-21	7:14 AM	0.1	None.
43	Room 215		2918303	25-Oct-21	7:14 AM	27-Oct-21	7:15 AM	0.2	None.
44	Room 215 - Duplicate		2918253	25-Oct-21	7:14 AM	27-Oct-21	7:15 AM	0.1	None.
45	Room 216		2913677	25-Oct-21	7:18 AM	27-Oct-21	7:20 AM	0.1	None.
46	Room 214		2917598	25-Oct-21	7:20 AM	27-Oct-21	7:21 AM	0.1	None.
47	Room 213		2913686	25-Oct-21	7:23 AM	27-Oct-21	7:24 AM	0.1	None.
48	Room 210		2917624	25-Oct-21	7:24 AM	27-Oct-21	7:25 AM	0.3	None.
49	Custodial Office		2913670	25-Oct-21	6:04 AM	27-Oct-21	6:28 AM	0.1	None.
50	Custodial Office - Duplicate		2896338	25-Oct-21	6:04 AM	27-Oct-21	6:28 AM	0.1	None.
51	Room 125		2917631	25-Oct-21	6:06 AM	27-Oct-21	6:30 AM	0.5	None.
52	Room 122		2913662	25-Oct-21	6:08 AM	27-Oct-21	Gone!	-	Missing.
53	Staff Break Room		2896350	25-Oct-21	6:11 AM	27-Oct-21	6:36 AM	0.3	None.
54	Staff Break Room - Duplicate		2913712	25-Oct-21	6:11 AM	27-Oct-21	6:36 AM	0.2	None.
55	Room 121		2918293	25-Oct-21	6:14 AM	27-Oct-21	6:39 AM	0.1	None.
56	Room 121 - Blank		2917639	25-Oct-21	6:16 AM	27-Oct-21	6:39 AM	0.1	None.
57	Room 120		2896291	25-Oct-21	6:20 AM	27-Oct-21	6:40 AM	0.2	None.
58	Cafeteria # 1	On Cubbie	2918259	25-Oct-21	6:22 AM	27-Oct-21	6:41 AM	0.1	None.
59	Cafeteria # 2	On Pepsi	2918247	25-Oct-21	6:22 AM	27-Oct-21	6:42 AM	0.4	None.
60	Cafeteria # 3	N Wall	2918249	25-Oct-21	6:24 AM	27-Oct-21	6:44 AM	0.1	None.
61	Room 109		2918276	25-Oct-21	6:30 AM	27-Oct-21	6:47 AM	0.1	None.
62	Room 109 - Blank		2896333	25-Oct-21	6:30 AM	27-Oct-21	6:47 AM	0.1	None.
63	Room 104		2918265	25-Oct-21	6:53 AM	27-Oct-21	7:04 AM	0.3	None.
64	Room 103		2913368	25-Oct-21	6:51 AM	27-Oct-21	7:01 AM	0.1	Found canister upside down with papers covering.
65	Room 103 - Duplicate		2896362	25-Oct-21	6:51 AM	27-Oct-21	7:01 AM	0.1	Found canister with papers covering.
66	Room 102 A		2896364	25-Oct-21	6:51 AM	27-Oct-21	6:59 AM	0.1	None.
67	Room 102 B		2918272	25-Oct-21	6:44 AM	27-Oct-21	6:58 AM	0.5	None.
68	Room 106 A		2918271	25-Oct-21	6:42 AM	27-Oct-21	6:55 AM	0.1	None.
69	Room 106 B		2913663	25-Oct-21	6:40 AM	27-Oct-21	6:53 AM	0.4	None.
70	Room 106 B - Duplicate		2918251	25-Oct-21	6:40 AM	27-Oct-21	6:53 AM	0.1	None.
71	Room 107		2917638	25-Oct-21	6:37 AM	27-Oct-21	6:50 AM	0.5	None.
72	Room 108		2913676	25-Oct-21	6:32 AM	27-Oct-21	6:49 AM	0.2	None.
73	Gymnasium # 1		2913672	25-Oct-21	6:02 AM	27-Oct-21	6:25 AM	0.4	None.
74	Gymnasium # 2		2913666	25-Oct-21	6:06 AM	27-Oct-21	6:27 AM	0.1	None.
75	Gymnasium # 3		2917629	25-Oct-21	6:10 AM	27-Oct-21	6:29 AM	0.1	None.
76	Gymnasium # 4		2917607	25-Oct-21	6:14 AM	27-Oct-21	6:30 AM	0.6	None.
77	Gymnasium # 5		2896335	25-Oct-21	6:19 AM	27-Oct-21	6:28 AM	0.1	None.
78	Gymnasium # 6		2896307	25-Oct-21	6:12 AM	27-Oct-21	6:26 AM	0.1	None.
79	Small Gymnasium # 1		2913671	25-Oct-21	6:33 AM	27-Oct-21	6:33 AM	0.5	None.
80	Small Gymnasium # 2		2918245	25-Oct-21	6:37 AM	27-Oct-21	6:37 AM	0.2	None.
81	Small Gymnasium # 3		2913736	25-Oct-21	6:40 AM	27-Oct-21	6:40 AM	0.4	None.
82	Weight Room		2918254	25-Oct-21	6:28 AM	27-Oct-21	6:35 AM	0.8	None.
83	Wrestling #1		2918275	25-Oct-21	6:45 AM	27-Oct-21	6:45 AM	0.5	None.
84	Wrestling #2		2918252	25-Oct-21	6:47 AM	27-Oct-21	6:47 AM	0.1	None.
#	Type	Description	Serial #	Dated Opened	Time Opened	Date Closed	Time Closed	Radon Test Results	Remarks
85	Spike # 1 (Room 421)		2756523					35.2	None.
86	Spike # 2 (Room 422)		2756347					33.8	None.
87	Spike # 3 (Room 423)		2756582					35.1	None.

*The E.P.A.'s recommended action level for radon is 4.0 pCi/L.

*This is not a health based number.

*Outdoor radon levels across the country average 0.4 pCi/L.

*If an RPD test result over 4.0 pCi/L differs by 28% or more, the data quality should be questioned.

*A trend in RPE values that are more than ± 30% should be investigated