

Site Radon Inspection Report

Date : 11/01/2021

Mr. Seth Barry
MEDFORD SCHOOL DISTRICT
815 South Oakdale Avenue
Medford, OR 97501-

Client: Hedrick Middle School
Test Location: 1501 East Jackson Street
Medford, OR 97504-

Individual Canister Results

Canister ID# : 2756347 Test Start : 10/25/2021 @ 06:14
Canister Type : Charcoal Canister 3 inch Test Stop : 10/27/2021 @ 06:20
Location : 1st FL=Rm 422 Received: 11/01/2021 @ 14:51
Radon Level : 33.8 pCi/L Analyzed: 11/02/2021 @ 12:07
Error for Measurement is: \pm 1.1 pCi/L

Canister ID# : 2756523 Test Start : 10/25/2021 @ 06:09
Canister Type : Charcoal Canister 3 inch Test Stop : 10/27/2021 @ 06:10
Location : 1st FL=Rm 421 Received: 11/01/2021 @ 14:51
Radon Level : 35.2 pCi/L Analyzed: 11/02/2021 @ 10:11
Error for Measurement is: \pm 1.1 pCi/L

Canister ID# : 2756582 Test Start : 10/25/2021 @ 06:12
Canister Type : Charcoal Canister 3 inch Test Stop : 10/27/2021 @ 06:15
Location : 1st FL=Rm 423 Received: 11/01/2021 @ 14:51
Radon Level : 35.1 pCi/L Analyzed: 11/02/2021 @ 11:02
Error for Measurement is: \pm 1.1 pCi/L

Canister ID# : 2896291 Test Start : 10/25/2021 @ 06:20
Canister Type : Charcoal Canister 3 inch Test Stop : 10/27/2021 @ 06:40
Location : Rm 120 Received: 11/01/2021 @ 14:51
Radon Level : 0.2 pCi/L Analyzed: 11/02/2021 @ 11:28
Error for Measurement is: \pm 0.6 pCi/L

Canister ID# : 2896292 Test Start : 10/25/2021 @ 06:21
Canister Type : Charcoal Canister 3 inch Test Stop : 10/27/2021 @ 06:36
Location : Rm 319-H RMH Received: 11/01/2021 @ 14:50
Radon Level : 0.1 pCi/L Analyzed: 11/02/2021 @ 12:38
Error for Measurement is: \pm 0.2 pCi/L

Canister ID# : 2896307 Test Start : 10/25/2021 @ 06:12
Canister Type : Charcoal Canister 3 inch Test Stop : 10/27/2021 @ 06:26
Location : Gym 6 Received: 11/01/2021 @ 14:51
Radon Level : 0.1 pCi/L Analyzed: 11/02/2021 @ 09:42
Error for Measurement is: \pm 0.4 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 11/01/2021

Mr. Seth Barry
MEDFORD SCHOOL DISTRICT
815 South Oakdale Avenue
Medford, OR 97501-

Client: Hedrick Middle School
Test Location: 1501 East Jackson Street
Medford, OR 97504-

Individual Canister Results

Canister ID# : 2896333 Test Start : 10/25/2021 @ 06:30
Canister Type : Charcoal Canister 3 inch Test Stop : 10/27/2021 @ 06:47
Location : Rm 109 BL Received: 11/01/2021 @ 14:51
Radon Level : 0.1 pCi/L Analyzed: 11/02/2021 @ 11:14
Error for Measurement is: \pm 0.8 pCi/L

Canister ID# : 2896335 Test Start : 10/25/2021 @ 06:19
Canister Type : Charcoal Canister 3 inch Test Stop : 10/27/2021 @ 06:28
Location : Gym 5 Received: 11/01/2021 @ 14:51
Radon Level : 0.1 pCi/L Analyzed: 11/02/2021 @ 10:46
Error for Measurement is: \pm 0.5 pCi/L

Canister ID# : 2896338 Test Start : 10/25/2021 @ 06:04
Canister Type : Charcoal Canister 3 inch Test Stop : 10/27/2021 @ 06:28
Location : Custodial Off. DP Received: 11/01/2021 @ 14:51
Radon Level : 0.1 pCi/L Analyzed: 11/02/2021 @ 11:30
Error for Measurement is: \pm 0.1 pCi/L

Canister ID# : 2896344 Test Start : 10/25/2021 @ 06:40
Canister Type : Charcoal Canister 3 inch Test Stop : 10/27/2021 @ 06:46
Location : Rm 317 Received: 11/01/2021 @ 14:50
Radon Level : 0.1 pCi/L Analyzed: 11/02/2021 @ 11:30
Error for Measurement is: \pm 0.9 pCi/L

Canister ID# : 2896350 Test Start : 10/25/2021 @ 06:11
Canister Type : Charcoal Canister 3 inch Test Stop : 10/27/2021 @ 06:36
Location : Staff Break Rm DP Received: 11/01/2021 @ 14:51
Radon Level : 0.3 pCi/L Analyzed: 11/02/2021 @ 10:27
Error for Measurement is: \pm 0.5 pCi/L

Canister ID# : 2896362 Test Start : 10/25/2021 @ 06:51
Canister Type : Charcoal Canister 3 inch Test Stop : 10/27/2021 @ 07:02
Location : Rm 103 DP Received: 11/01/2021 @ 14:51
Radon Level : 0.1 pCi/L Analyzed: 11/02/2021 @ 11:28
COVERED WITH PAPER



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 11/01/2021

Mr. Seth Barry
MEDFORD SCHOOL DISTRICT
815 South Oakdale Avenue
Medford, OR 97501-

Client: Hedrick Middle School
Test Location: 1501 East Jackson Street
Medford, OR 97504-

Individual Canister Results

Error for Measurement is: ± 0.6 pCi/L

Canister ID# : 2896364
Canister Type : Charcoal Canister 3 inch
Location : Rm 102-A
Radon Level : 0.1 pCi/L
Error for Measurement is: ± 0.4 pCi/L

Test Start : 10/25/2021 @ 06:49
Test Stop : 10/27/2021 @ 06:59
Received: 11/01/2021 @ 14:51
Analyzed: 11/02/2021 @ 11:34

Canister ID# : 2896369
Canister Type : Charcoal Canister 3 inch
Location : 2nd FL=Rm 206
Radon Level : 0.1 pCi/L
SOUTH COUNTER

Test Start : 10/25/2021 @ 06:32
Test Stop : 10/27/2021 @ 06:39
Received: 11/01/2021 @ 14:50
Analyzed: 11/02/2021 @ 12:07

Error for Measurement is: ± 0.2 pCi/L

Canister ID# : 2896373
Canister Type : Charcoal Canister 3 inch
Location : 3rd FL=Rm 304 DP
Radon Level : 0.1 pCi/L
Error for Measurement is: ± 0.5 pCi/L

Test Start : 10/25/2021 @ 06:08
Test Stop : 10/27/2021 @ 06:31
Received: 11/01/2021 @ 14:50
Analyzed: 11/02/2021 @ 11:04

Canister ID# : 2896376
Canister Type : Charcoal Canister 3 inch
Location : 2nd FL=Rm 206
Radon Level : 0.1 pCi/L
NORTH BY CUBBY

Test Start : 10/25/2021 @ 06:31
Test Stop : 10/27/2021 @ 06:39
Received: 11/01/2021 @ 14:50
Analyzed: 11/02/2021 @ 12:07

Error for Measurement is: ± 0.2 pCi/L

Canister ID# : 2913342
Canister Type : Charcoal Canister 3 inch
Location : Rm 323
Radon Level : 0.1 pCi/L
Error for Measurement is: ± 0.6 pCi/L

Test Start : 10/25/2021 @ 06:33
Test Stop : 10/27/2021 @ 06:41
Received: 11/01/2021 @ 14:50
Analyzed: 11/02/2021 @ 11:14



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 11/01/2021

Mr. Seth Barry
MEDFORD SCHOOL DISTRICT
815 South Oakdale Avenue
Medford, OR 97501-

Client: Hedrick Middle School
Test Location: 1501 East Jackson Street
Medford, OR 97504-

Individual Canister Results

Canister ID# : 2913368 Test Start : 10/25/2021 @ 06:51
Canister Type : Charcoal Canister 3 inch Test Stop : 10/27/2021 @ 07:02
Location : Rm 103 DP Received: 11/01/2021 @ 14:51
Radon Level : 0.1 pCi/L Analyzed: 11/02/2021 @ 10:57
FOUND UPSIDE DOWN

Error for Measurement is: \pm 0.7 pCi/L

Canister ID# : 2913381 Test Start : 10/25/2021 @ 06:20
Canister Type : Charcoal Canister 3 inch Test Stop : 10/27/2021 @ 06:37
Location : 2nd FL=Rm 204 Received: 11/01/2021 @ 14:50
Radon Level : 0.1 pCi/L Analyzed: 11/02/2021 @ 10:44
Error for Measurement is: \pm 0.4 pCi/L

Canister ID# : 2913659 Test Start : 10/25/2021 @ 06:37
Canister Type : Charcoal Canister 3 inch Test Stop : 10/27/2021 @ 06:45
Location : Staff Work Rm BL Received: 11/01/2021 @ 14:50
Radon Level : 0.1 pCi/L Analyzed: 11/02/2021 @ 11:14
Error for Measurement is: \pm 0.2 pCi/L

Canister ID# : 2913660 Test Start : 10/25/2021 @ 06:04
Canister Type : Charcoal Canister 3 inch Test Stop : 10/27/2021 @ 06:29
Location : Health Rm Received: 11/01/2021 @ 14:50
Radon Level : 0.1 pCi/L Analyzed: 11/02/2021 @ 10:30
Error for Measurement is: \pm 0.1 pCi/L

Canister ID# : 2913663 Test Start : 10/25/2021 @ 06:40
Canister Type : Charcoal Canister 3 inch Test Stop : 10/27/2021 @ 06:53
Location : Rm 106-B DP Received: 11/01/2021 @ 14:51
Radon Level : 0.4 pCi/L Analyzed: 11/02/2021 @ 11:34
Error for Measurement is: \pm 0.5 pCi/L

Canister ID# : 2913666 Test Start : 10/25/2021 @ 06:06
Canister Type : Charcoal Canister 3 inch Test Stop : 10/27/2021 @ 06:27
Location : Gym 2 Received: 11/01/2021 @ 14:51
Radon Level : 0.1 pCi/L Analyzed: 11/02/2021 @ 10:46



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 11/01/2021

Mr. Seth Barry
MEDFORD SCHOOL DISTRICT
815 South Oakdale Avenue
Medford, OR 97501-

Client: Hedrick Middle School
Test Location: 1501 East Jackson Street
Medford, OR 97504-

Individual Canister Results

Error for Measurement is: \pm 0.4 pCi/L

Canister ID# :	2913667	Test Start :	10/25/2021 @ 06:08
Canister Type :	Charcoal Canister 3 inch	Test Stop :	10/27/2021 @ 06:31
Location :	3rd FL=Rm 304 DP	Received:	11/01/2021 @ 14:50
Radon Level :	0.1 pCi/L	Analyzed:	11/02/2021 @ 12:05
Error for Measurement is: \pm	0.5 pCi/L		

Canister ID# :	2913670	Test Start :	10/25/2021 @ 06:04
Canister Type :	Charcoal Canister 3 inch	Test Stop :	10/27/2021 @ 06:28
Location :	Custodial Off. DP	Received:	11/01/2021 @ 14:51
Radon Level :	0.1 pCi/L	Analyzed:	11/02/2021 @ 11:28
Error for Measurement is: \pm	0.9 pCi/L		

Canister ID# :	2913671	Test Start :	10/25/2021 @ 06:33
Canister Type :	Charcoal Canister 3 inch	Test Stop :	10/27/2021 @ 06:33
Location :	2nd FL=Small Gym 1	Received:	11/01/2021 @ 14:51
Radon Level :	0.5 pCi/L	Analyzed:	11/02/2021 @ 11:02
Error for Measurement is: \pm	0.5 pCi/L		

Canister ID# :	2913672	Test Start :	10/25/2021 @ 06:02
Canister Type :	Charcoal Canister 3 inch	Test Stop :	10/27/2021 @ 06:25
Location :	Gym 1	Received:	11/01/2021 @ 14:51
Radon Level :	0.4 pCi/L	Analyzed:	11/02/2021 @ 10:46
Error for Measurement is: \pm	0.6 pCi/L		

Canister ID# :	2913676	Test Start :	10/25/2021 @ 06:32
Canister Type :	Charcoal Canister 3 inch	Test Stop :	10/27/2021 @ 06:49
Location :	Rm 108	Received:	11/01/2021 @ 14:51
Radon Level :	0.2 pCi/L	Analyzed:	11/02/2021 @ 11:15
Error for Measurement is: \pm	0.5 pCi/L		

Canister ID# :	2913677	Test Start :	10/25/2021 @ 07:18
Canister Type :	Charcoal Canister 3 inch	Test Stop :	10/27/2021 @ 07:20
Location :	2nd FL=Rm 216	Received:	11/01/2021 @ 14:51
Radon Level :	0.1 pCi/L	Analyzed:	11/02/2021 @ 11:47
Error for Measurement is: \pm	0.7 pCi/L		



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 11/01/2021

Mr. Seth Barry
MEDFORD SCHOOL DISTRICT
815 South Oakdale Avenue
Medford, OR 97501-

Client: Hedrick Middle School
Test Location: 1501 East Jackson Street
Medford, OR 97504-

Individual Canister Results

Canister ID# : 2913686 Test Start : 10/25/2021 @ 07:22
Canister Type : Charcoal Canister 3 inch Test Stop : 10/27/2021 @ 07:24
Location : 2nd FL=Rm 213 Received: 11/01/2021 @ 14:51
Radon Level : 0.1 pCi/L Analyzed: 11/02/2021 @ 10:13
Error for Measurement is: ± 0.2 pCi/L

Canister ID# : 2913689 Test Start : 10/25/2021 @ 06:42
Canister Type : Charcoal Canister 3 inch Test Stop : 10/27/2021 @ 06:47
Location : Rm 315 Received: 11/01/2021 @ 14:50
Radon Level : 0.1 pCi/L Analyzed: 11/02/2021 @ 11:14
Error for Measurement is: ± 0.1 pCi/L

Canister ID# : 2913690 Test Start : 10/25/2021 @ 06:13
Canister Type : Charcoal Canister 3 inch Test Stop : 10/27/2021 @ 06:33
Location : 3rd FL=Rm 303 Received: 11/01/2021 @ 14:50
Radon Level : 0.4 pCi/L Analyzed: 11/02/2021 @ 09:58
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2913696 Test Start : 10/25/2021 @ 06:56
Canister Type : Charcoal Canister 3 inch Test Stop : 10/27/2021 @ 06:58
Location : 2nd FL=Media S. Wall Received: 11/01/2021 @ 14:50
Radon Level : 0.3 pCi/L Analyzed: 11/02/2021 @ 10:13
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2913701 Test Start : 10/25/2021 @ 06:46
Canister Type : Charcoal Canister 3 inch Test Stop : 10/27/2021 @ 06:50
Location : Rm 310 Received: 11/01/2021 @ 14:50
Radon Level : 0.1 pCi/L Analyzed: 11/02/2021 @ 10:30
Error for Measurement is: ± 0.6 pCi/L

Canister ID# : 2913704 Test Start : 10/25/2021 @ 06:07
Canister Type : Charcoal Canister 3 inch Test Stop : 10/27/2021 @ 06:31
Location : Rm 319J RMJ Principal Received: 11/01/2021 @ 14:50
Radon Level : 0.6 pCi/L Analyzed: 11/02/2021 @ 11:47
Error for Measurement is: ± 0.6 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 11/01/2021

Mr. Seth Barry
MEDFORD SCHOOL DISTRICT
815 South Oakdale Avenue
Medford, OR 97501-

Client: Hedrick Middle School
Test Location: 1501 East Jackson Street
Medford, OR 97504-

Individual Canister Results

Canister ID# : 2913706 Test Start : 10/25/2021 @ 06:31
Canister Type : Charcoal Canister 3 inch Test Stop : 10/27/2021 @ 06:40
Location : Rm 325 Received: 11/01/2021 @ 14:50
Radon Level : 0.2 pCi/L Analyzed: 11/02/2021 @ 11:02
Error for Measurement is: \pm 0.6 pCi/L

Canister ID# : 2913711 Test Start : 10/25/2021 @ 06:35
Canister Type : Charcoal Canister 3 inch Test Stop : 10/27/2021 @ 06:42
Location : Rm 322 Received: 11/01/2021 @ 14:50
Radon Level : 0.3 pCi/L Analyzed: 11/02/2021 @ 10:30
Error for Measurement is: \pm 0.5 pCi/L

Canister ID# : 2913712 Test Start : 10/25/2021 @ 06:11
Canister Type : Charcoal Canister 3 inch Test Stop : 10/27/2021 @ 06:36
Location : Staff Break Rm DP Received: 11/01/2021 @ 14:51
Radon Level : 0.2 pCi/L Analyzed: 11/02/2021 @ 11:28
Error for Measurement is: \pm 0.6 pCi/L

Canister ID# : 2913713 Test Start : 10/25/2021 @ 06:17
Canister Type : Charcoal Canister 3 inch Test Stop : 10/27/2021 @ 06:33
Location : Conf. Rm 319-E Received: 11/01/2021 @ 14:50
Radon Level : 0.1 pCi/L Analyzed: 11/02/2021 @ 11:47
Error for Measurement is: \pm 0.2 pCi/L

Canister ID# : 2913736 Test Start : 10/25/2021 @ 06:40
Canister Type : Charcoal Canister 3 inch Test Stop : 10/27/2021 @ 06:40
Location : 2nd FL=Small Gym 3 Received: 11/01/2021 @ 14:51
Radon Level : 0.4 pCi/L Analyzed: 11/02/2021 @ 09:58
Error for Measurement is: \pm 0.5 pCi/L

Canister ID# : 2913749 Test Start : 10/25/2021 @ 06:26
Canister Type : Charcoal Canister 3 inch Test Stop : 10/27/2021 @ 06:39
Location : Rm 319-M RMM Received: 11/01/2021 @ 14:50
Radon Level : 0.1 pCi/L Analyzed: 11/02/2021 @ 11:47
Error for Measurement is: \pm 0.8 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 11/01/2021

Mr. Seth Barry
MEDFORD SCHOOL DISTRICT
815 South Oakdale Avenue
Medford, OR 97501-

Client: Hedrick Middle School
Test Location: 1501 East Jackson Street
Medford, OR 97504-

Individual Canister Results

Canister ID# : 2913750 Test Start : 10/25/2021 @ 06:37
Canister Type : Charcoal Canister 3 inch Test Stop : 10/27/2021 @ 06:45
Location : Staff Work Rm Received: 11/01/2021 @ 14:50
Radon Level : 0.1 pCi/L Analyzed: 11/02/2021 @ 11:47
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 2913754 Test Start : 10/25/2021 @ 06:17
Canister Type : Charcoal Canister 3 inch Test Stop : 10/27/2021 @ 06:36
Location : 2nd FL=Rm 202 Received: 11/01/2021 @ 14:50
Radon Level : 0.3 pCi/L Analyzed: 11/02/2021 @ 10:11
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2913755 Test Start : 10/25/2021 @ 06:45
Canister Type : Charcoal Canister 3 inch Test Stop : 10/27/2021 @ 06:49
Location : Rm 311 Received: 11/01/2021 @ 14:50
Radon Level : 0.3 pCi/L Analyzed: 11/02/2021 @ 11:15
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2916032 Test Start : 10/25/2021 @ 06:35
Canister Type : Charcoal Canister 3 inch Test Stop : 10/27/2021 @ 06:42
Location : 2nd FL=Rm 203 Received: 11/01/2021 @ 14:50
Radon Level : 0.3 pCi/L Analyzed: 11/02/2021 @ 12:07
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2916039 Test Start : 10/25/2021 @ 06:25
Canister Type : Charcoal Canister 3 inch Test Stop : 10/27/2021 @ 06:37
Location : 2nd FL=Rm 204 BL Received: 11/01/2021 @ 14:50
Radon Level : 0.1 pCi/L Analyzed: 11/02/2021 @ 10:11
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 2916048 Test Start : 10/25/2021 @ 07:08
Canister Type : Charcoal Canister 3 inch Test Stop : 10/27/2021 @ 07:12
Location : 2nd FL=Media Off. Received: 11/01/2021 @ 14:50
Radon Level : 0.4 pCi/L Analyzed: 11/02/2021 @ 12:05
Error for Measurement is: ± 0.5 pCi/L



Andreas C. George

Dante Galan

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 11/01/2021

Mr. Seth Barry
MEDFORD SCHOOL DISTRICT
815 South Oakdale Avenue
Medford, OR 97501-

Client: Hedrick Middle School
Test Location: 1501 East Jackson Street
Medford, OR 97504-

Individual Canister Results

Canister ID# : 2917598 Test Start : 10/25/2021 @ 07:20
Canister Type : Charcoal Canister 3 inch Test Stop : 10/27/2021 @ 07:21
Location : 2nd FL=Rm 214 Received: 11/01/2021 @ 14:51
Radon Level : 0.1 pCi/L Analyzed: 11/02/2021 @ 12:05
Error for Measurement is: \pm 0.4 pCi/L

Canister ID# : 2917602 Test Start : 10/25/2021 @ 06:19
Canister Type : Charcoal Canister 3 inch Test Stop : 10/27/2021 @ 06:35
Location : Rm 319-G RMG Received: 11/01/2021 @ 14:50
Radon Level : 0.1 pCi/L Analyzed: 11/02/2021 @ 10:57
Error for Measurement is: \pm 0.3 pCi/L

Canister ID# : 2917607 Test Start : 10/25/2021 @ 06:14
Canister Type : Charcoal Canister 3 inch Test Stop : 10/27/2021 @ 06:30
Location : Gym 4 Received: 11/01/2021 @ 14:51
Radon Level : 0.6 pCi/L Analyzed: 11/02/2021 @ 09:58
Error for Measurement is: \pm 0.5 pCi/L

Canister ID# : 2917624 Test Start : 10/25/2021 @ 07:24
Canister Type : Charcoal Canister 3 inch Test Stop : 10/27/2021 @ 07:25
Location : 2nd FL=Rm 210 Received: 11/01/2021 @ 14:51
Radon Level : 0.3 pCi/L Analyzed: 11/02/2021 @ 10:27
Error for Measurement is: \pm 0.4 pCi/L

Canister ID# : 2917629 Test Start : 10/25/2021 @ 06:10
Canister Type : Charcoal Canister 3 inch Test Stop : 10/27/2021 @ 06:29
Location : Gym 3 Received: 11/01/2021 @ 14:51
Radon Level : 0.1 pCi/L Analyzed: 11/02/2021 @ 10:44
Error for Measurement is: \pm 0.8 pCi/L

Canister ID# : 2917631 Test Start : 10/25/2021 @ 06:06
Canister Type : Charcoal Canister 3 inch Test Stop : 10/27/2021 @ 06:30
Location : Rm 125 Received: 11/01/2021 @ 14:51
Radon Level : 0.5 pCi/L Analyzed: 11/02/2021 @ 11:15
Error for Measurement is: \pm 0.5 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 11/01/2021

Mr. Seth Barry
MEDFORD SCHOOL DISTRICT
815 South Oakdale Avenue
Medford, OR 97501-

Client: Hedrick Middle School
Test Location: 1501 East Jackson Street
Medford, OR 97504-

Individual Canister Results

Canister ID# : 2917636 Test Start : 10/25/2021 @ 07:04
Canister Type : Charcoal Canister 3 inch Test Stop : 10/27/2021 @ 07:05
Location : 2nd FL=Media Work Rm Received: 11/01/2021 @ 14:50
Radon Level : 0.2 pCi/L Analyzed: 11/02/2021 @ 11:28
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 2917638 Test Start : 10/25/2021 @ 06:37
Canister Type : Charcoal Canister 3 inch Test Stop : 10/27/2021 @ 06:50
Location : Rm 107 Received: 11/01/2021 @ 14:51
Radon Level : 0.5 pCi/L Analyzed: 11/02/2021 @ 11:34
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2917639 Test Start : 10/25/2021 @ 06:16
Canister Type : Charcoal Canister 3 inch Test Stop : 10/27/2021 @ 06:39
Location : BLANK Received: 11/01/2021 @ 14:51
Radon Level : 0.1 pCi/L Analyzed: 11/02/2021 @ 11:34
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 2917641 Test Start : 10/25/2021 @ 06:04
Canister Type : Charcoal Canister 3 inch Test Stop : 10/27/2021 @ 06:28
Location : 3rd FL=Rm 306 Received: 11/01/2021 @ 14:50
Radon Level : 0.1 pCi/L Analyzed: 11/02/2021 @ 10:13
Error for Measurement is: ± 0.1 pCi/L

Canister ID# : 2917642 Test Start : 10/25/2021 @ 06:43
Canister Type : Charcoal Canister 3 inch Test Stop : 10/27/2021 @ 06:48
Location : Rm 314 Received: 11/01/2021 @ 14:50
Radon Level : 0.1 pCi/L Analyzed: 11/02/2021 @ 11:33
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2917649 Test Start : 10/25/2021 @ 07:10
Canister Type : Charcoal Canister 3 inch Test Stop : 10/27/2021 @ 07:14
Location : 2nd FL=Media Comp.Rm Received: 11/01/2021 @ 14:51
Radon Level : 0.1 pCi/L Analyzed: 11/02/2021 @ 10:27
Error for Measurement is: ± 0.3 pCi/L



Andreas C. George

Dante Galan

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 11/01/2021

Mr. Seth Barry
MEDFORD SCHOOL DISTRICT
815 South Oakdale Avenue
Medford, OR 97501-

Client: Hedrick Middle School
Test Location: 1501 East Jackson Street
Medford, OR 97504-

Individual Canister Results

Canister ID# : 2918200 Test Start : 10/25/2021 @ 06:41
Canister Type : Charcoal Canister 3 inch Test Stop : 10/27/2021 @ 06:43
Location : 2nd FL=Rm 201 Received: 11/01/2021 @ 14:50
Radon Level : 0.1 pCi/L Analyzed: 11/02/2021 @ 11:04
Error for Measurement is: ± 0.9 pCi/L

Canister ID# : 2918228 Test Start : 10/25/2021 @ 06:52
Canister Type : Charcoal Canister 3 inch Test Stop : 10/27/2021 @ 06:54
Location : 2nd FL=Media Bookcase Received: 11/01/2021 @ 14:50
Radon Level : 0.5 pCi/L Analyzed: 11/02/2021 @ 12:05
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2918245 Test Start : 10/25/2021 @ 06:37
Canister Type : Charcoal Canister 3 inch Test Stop : 10/27/2021 @ 06:37
Location : 2nd FL=Small Gym 2 Received: 11/01/2021 @ 14:51
Radon Level : 0.2 pCi/L Analyzed: 11/02/2021 @ 10:46
Error for Measurement is: ± 0.6 pCi/L

Canister ID# : 2918246 Test Start : 10/25/2021 @ 06:18
Canister Type : Charcoal Canister 3 inch Test Stop : 10/27/2021 @ 06:34
Location : Rm 319-F RMF Received: 11/01/2021 @ 14:50
Radon Level : 0.1 pCi/L Analyzed: 11/02/2021 @ 11:33
Error for Measurement is: ± 0.2 pCi/L

Canister ID# : 2918247 Test Start : 10/25/2021 @ 06:22
Canister Type : Charcoal Canister 3 inch Test Stop : 10/27/2021 @ 06:42
Location : Cafeteria on Pepsi Received: 11/01/2021 @ 14:51
Radon Level : 0.4 pCi/L Analyzed: 11/02/2021 @ 11:45
Error for Measurement is: ± 0.6 pCi/L

Canister ID# : 2918249 Test Start : 10/25/2021 @ 06:24
Canister Type : Charcoal Canister 3 inch Test Stop : 10/27/2021 @ 06:44
Location : Cafeteria N. Wall Received: 11/01/2021 @ 14:51
Radon Level : 0.1 pCi/L Analyzed: 11/02/2021 @ 11:30
Error for Measurement is: ± 0.7 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 11/01/2021

Mr. Seth Barry
MEDFORD SCHOOL DISTRICT
815 South Oakdale Avenue
Medford, OR 97501-

Client: Hedrick Middle School
Test Location: 1501 East Jackson Street
Medford, OR 97504-

Individual Canister Results

Canister ID# : 2918251 Test Start : 10/25/2021 @ 06:40
Canister Type : Charcoal Canister 3 inch Test Stop : 10/27/2021 @ 06:53
Location : Rm 106-B DP Received: 11/01/2021 @ 14:51
Radon Level : 0.1 pCi/L Analyzed: 11/02/2021 @ 11:47
Error for Measurement is: \pm 0.4 pCi/L

Canister ID# : 2918252 Test Start : 10/25/2021 @ 06:47
Canister Type : Charcoal Canister 3 inch Test Stop : 10/27/2021 @ 06:47
Location : 2nd FL=Wrestling Rm 2 Received: 11/01/2021 @ 14:51
Radon Level : 0.1 pCi/L Analyzed: 11/02/2021 @ 10:27
Error for Measurement is: \pm 0.2 pCi/L

Canister ID# : 2918253 Test Start : 10/25/2021 @ 07:14
Canister Type : Charcoal Canister 3 inch Test Stop : 10/27/2021 @ 07:15
Location : 2nd FL=Rm 215 DP Received: 11/01/2021 @ 14:51
Radon Level : 0.1 pCi/L Analyzed: 11/02/2021 @ 10:13
Error for Measurement is: \pm 0.4 pCi/L

Canister ID# : 2918254 Test Start : 10/25/2021 @ 06:28
Canister Type : Charcoal Canister 3 inch Test Stop : 10/27/2021 @ 06:35
Location : Weight Rm Received: 11/01/2021 @ 14:51
Radon Level : 0.8 pCi/L Analyzed: 11/02/2021 @ 09:58
Error for Measurement is: \pm 0.5 pCi/L

Canister ID# : 2918255 Test Start : 10/25/2021 @ 06:05
Canister Type : Charcoal Canister 3 inch Test Stop : 10/27/2021 @ 06:30
Location : Conf. Rm A Received: 11/01/2021 @ 14:50
Radon Level : 0.1 pCi/L Analyzed: 11/02/2021 @ 11:30
Error for Measurement is: \pm 0.2 pCi/L

Canister ID# : 2918259 Test Start : 10/25/2021 @ 06:22
Canister Type : Charcoal Canister 3 inch Test Stop : 10/27/2021 @ 06:41
Location : Cafeteria on Cubbie Received: 11/01/2021 @ 14:51
Radon Level : 0.1 pCi/L Analyzed: 11/02/2021 @ 11:45
Error for Measurement is: \pm 0.4 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 11/01/2021

Mr. Seth Barry
MEDFORD SCHOOL DISTRICT
815 South Oakdale Avenue
Medford, OR 97501-

Client: Hedrick Middle School
Test Location: 1501 East Jackson Street
Medford, OR 97504-

Individual Canister Results

Canister ID# : 2918260 Test Start : 10/25/2021 @ 06:09
Canister Type : Charcoal Canister 3 inch Test Stop : 10/27/2021 @ 06:32
Location : Rm 319C RMC Received: 11/01/2021 @ 14:50
Radon Level : 0.2 pCi/L Analyzed: 11/02/2021 @ 10:44
Error for Measurement is: ± 0.7 pCi/L

Canister ID# : 2918261 Test Start : 10/25/2021 @ 06:24
Canister Type : Charcoal Canister 3 inch Test Stop : 10/27/2021 @ 06:38
Location : Rm 319-L RML Received: 11/01/2021 @ 14:50
Radon Level : 0.1 pCi/L Analyzed: 11/02/2021 @ 11:33
Error for Measurement is: ± 3.6 pCi/L

Canister ID# : 2918263 Test Start : 10/25/2021 @ 06:22
Canister Type : Charcoal Canister 3 inch Test Stop : 10/27/2021 @ 06:37
Location : Rm 319-K RMK Received: 11/01/2021 @ 14:50
Radon Level : 0.1 pCi/L Analyzed: 11/02/2021 @ 10:30
Error for Measurement is: ± 0.4 pCi/L

Canister ID# : 2918265 Test Start : 10/25/2021 @ 06:53
Canister Type : Charcoal Canister 3 inch Test Stop : 10/27/2021 @ 07:03
Location : Rm 104 Received: 11/01/2021 @ 14:51
Radon Level : 0.3 pCi/L Analyzed: 11/02/2021 @ 11:45
Error for Measurement is: ± 0.6 pCi/L

Canister ID# : 2918269 Test Start : 10/25/2021 @ 06:47
Canister Type : Charcoal Canister 3 inch Test Stop : 10/27/2021 @ 06:51
Location : Rm 309 Received: 11/01/2021 @ 14:50
Radon Level : 0.3 pCi/L Analyzed: 11/02/2021 @ 11:28
Error for Measurement is: ± 0.5 pCi/L

Canister ID# : 2918271 Test Start : 10/25/2021 @ 06:42
Canister Type : Charcoal Canister 3 inch Test Stop : 10/27/2021 @ 06:55
Location : Rm 106-A Received: 11/01/2021 @ 14:51
Radon Level : 0.1 pCi/L Analyzed: 11/02/2021 @ 11:28
Error for Measurement is: ± 0.4 pCi/L



Andreas C. George

Dante Galan

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 11/01/2021

Mr. Seth Barry
MEDFORD SCHOOL DISTRICT
815 South Oakdale Avenue
Medford, OR 97501-

Client: Hedrick Middle School
Test Location: 1501 East Jackson Street
Medford, OR 97504-

Individual Canister Results

Canister ID# : 2918272 Test Start : 10/25/2021 @ 06:44
Canister Type : Charcoal Canister 3 inch Test Stop : 10/27/2021 @ 06:58
Location : Rm 102-B Received: 11/01/2021 @ 14:51
Radon Level : 0.5 pCi/L Analyzed: 11/02/2021 @ 11:47
Error for Measurement is: \pm 0.6 pCi/L

Canister ID# : 2918275 Test Start : 10/25/2021 @ 06:45
Canister Type : Charcoal Canister 3 inch Test Stop : 10/27/2021 @ 06:45
Location : 2nd FL=Wrestling Rm 1 Received: 11/01/2021 @ 14:51
Radon Level : 0.5 pCi/L Analyzed: 11/02/2021 @ 10:44
Error for Measurement is: \pm 0.6 pCi/L

Canister ID# : 2918276 Test Start : 10/25/2021 @ 06:30
Canister Type : Charcoal Canister 3 inch Test Stop : 10/27/2021 @ 06:47
Location : Rm 109 Received: 11/01/2021 @ 14:51
Radon Level : 0.1 pCi/L Analyzed: 11/02/2021 @ 11:47
Error for Measurement is: \pm 0.3 pCi/L

Canister ID# : 2918279 Test Start : 10/25/2021 @ 06:00
Canister Type : Charcoal Canister 3 inch Test Stop : 10/27/2021 @ 06:28
Location : Main Office DP Received: 11/01/2021 @ 14:50
Radon Level : 0.1 pCi/L Analyzed: 11/02/2021 @ 11:33
Error for Measurement is: \pm 0.8 pCi/L

Canister ID# : 2918293 Test Start : 10/25/2021 @ 06:14
Canister Type : Charcoal Canister 3 inch Test Stop : 10/27/2021 @ 06:39
Location : Rm 121 Received: 11/01/2021 @ 14:51
Radon Level : 0.1 pCi/L Analyzed: 11/02/2021 @ 11:45
Error for Measurement is: \pm 0.3 pCi/L

Canister ID# : 2918294 Test Start : 10/25/2021 @ 06:00
Canister Type : Charcoal Canister 3 inch Test Stop : 10/27/2021 @ 06:28
Location : Main Office DP Received: 11/01/2021 @ 14:50
Radon Level : 0.1 pCi/L Analyzed: 11/02/2021 @ 10:57
Error for Measurement is: \pm 0.1 pCi/L



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 11/01/2021

Mr. Seth Barry
MEDFORD SCHOOL DISTRICT
815 South Oakdale Avenue
Medford, OR 97501-

Client: Hedrick Middle School
Test Location: 1501 East Jackson Street
Medford, OR 97504-

Individual Canister Results

Canister ID# :	2918295	Test Start :	10/25/2021 @ 06:59
Canister Type :	Charcoal Canister 3 inch	Test Stop :	10/27/2021 @ 07:00
Location :	2nd FL=Media Videos	Received:	11/01/2021 @ 14:50
Radon Level :	0.1 pCi/L	Analyzed:	11/02/2021 @ 11:15
Error for Measurement is: ±	0.5 pCi/L		

Canister ID# :	2918303	Test Start :	10/25/2021 @ 07:14
Canister Type :	Charcoal Canister 3 inch	Test Stop :	10/27/2021 @ 07:15
Location :	2nd FL=Rm 215 DP	Received:	11/01/2021 @ 14:51
Radon Level :	0.2 pCi/L	Analyzed:	11/02/2021 @ 11:28
Error for Measurement is: ±	0.4 pCi/L		

Canister ID# :	2918306	Test Start :	10/25/2021 @ 06:49
Canister Type :	Charcoal Canister 3 inch	Test Stop :	10/27/2021 @ 06:52
Location :	2nd FL=Media Lib. Desk	Received:	11/01/2021 @ 14:50
Radon Level :	0.1 pCi/L	Analyzed:	11/02/2021 @ 10:11
Error for Measurement is: ±	0.4 pCi/L		

The results indicate that at least one testing device registered at or above the United States Environmental Protection Agency (EPA) action level of 4.0 picoCuries per liter of air (pCi/L). The EPA recommends mitigation if the average of two short-term tests taken in the lowest level of the building suitable for occupancy show radon levels that are equal to or greater than 4.0 pCi/L.

For information on how to reduce radon levels in your home, please review the EPA booklet: Consumer's Guide to Radon Reduction (www.epa.gov/radon/pdfs/consguid.pdf) and contact your state health department. The EPA maintains a radon information website, including copies of its publications, at www.epa.gov/iaq/radon.

For New Jersey clients: Please see the attached guidance document entitled Radon Testing and Mitigation: The Basics for further information.

For New York clients: If the radon level of one or more testing devices is equal to or exceeds 20 pCi/L please contact the New York State Department of Health, Bureau of Environmental Radiation Protection, for technical advice and assistance at 518-402-7556 or toll free 1-800-458-1158.



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201

Site Radon Inspection Report

Date : 11/01/2021

Mr. Seth Barry
MEDFORD SCHOOL DISTRICT
815 South Oakdale Avenue
Medford, OR 97501-

Client: Hedrick Middle School
Test Location: 1501 East Jackson Street
Medford, OR 97504-
Individual Canister Results

PLEDGE OF ASSURED QUALITY

All procedures used for generating this report are in complete accordance with the current EPA protocols for the analysis of radon in air (EPA 402-R-92-004). The analytical results relate only to the samples tested, in the condition received by the lab, and that calculations were based upon the information supplied by client. RTCA and its personnel do not assume responsibility or liability, collectively and individually, for analysis results when detectors have been improperly handled or placed by the consumer, nor does RTCA and its personnel accept responsibility for any financial or health consequences of subsequent action or lack of action, taken by the customer or its consultants based on RTCA-provided results.



Andreas C. George

Andreas C. George
Radon Measurement Specialist
NJ MES 11089

Dante Galan

Dante Galan
Laboratory Director

NRSB ARL0001
NYS ELAP ID: 10806
PADEP ID: 0346
NJDEP ID: NY933
NJ MEB 90036
FL DOH RB1609
IL RNL2000201